

APPENDIX A

NOTICE OF VIOLATION

Carolina Power and Light Company
Brunswick Steam Electric Plant

Docket Nos. 50-325, 50-324
License Nos. DPR-71, DPR-62

As a result of the inspection conducted on April 21-24, 1981, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violations were identified.

- A. Appendix B Technical Specification 4.2.3 (Surface Water Sampling) requires, in part, that automatic intermittent water samplers collect monthly samples from the intake and discharge canals.

Contrary to the above, as of April 24, 1981, automatic intermittent surface water sampling of the intake canal (Sampling Station 48) had never been implemented.

This is a Severity Level V Violation (Supplement VII.E)

- B. Appendix B Technical Specification 5.3 requires, in part, development of quality assurance procedures for monitoring, sample collection, and sample analysis.

Contrary to the above, the licensee failed to develop written quality assurance procedures for periodic calibration of dry gas meters associated with air particulate monitors located at the designated monitoring stations listed in Appendix B Technical Specification 4.2, Table 4.2-1.

This is a Severity Level V Violation (Supplement VII.E).

- C. Appendix B Technical Specification 4.2 states that any location from which milk samples can no longer be obtained may be dropped from the surveillance program. The subject specification requires that the NRC will be notified in writing within 30 days with an explanation of why milk can no longer be obtained from that location.

Contrary to the above, the licensee failed to meet the 30 day notification requirement following disclosure that weekly milk samples could no longer be obtained from Sampling Station 36 (Lewis Farm) during routine sampling on March 9, 1981.

This is a Severity Level V Violation (Supplement VII.E).

- D. Appendix B Environmental Technical Specification 5.3 requires that temporary changes to procedures which do not change the intent of the original procedure may be made, provided such changes are approved by two members of the management staff. Such changes will be documented, and subsequently reviewed by the Plant Nuclear Safety Committee and approved by the Plant Manager prior to implementation as permanent procedure changes.

Contrary to the above, as of April 24, 1981, the licensee failed to meet the approval requirements for temporary changes made to procedures RC-ER-12 (Determination of Gross Alpha and Beta in Water) and RC-ER-18 (Quality Control for Beta-Gamma Coincidence System).

This is a Severity Level V Violation (Supplement VJI.E).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within twenty-five days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

Date: JUN 10 1981