



MATERIAL TRANSMITTED HEREWITH
CONTAINS 2.790 INFORMATION
UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

Report No. 50-327/81-18

JUN 02 1981

Licensee: Tennessee Valley Authority
500A Chestnut Street
Chattanooga, TN 37401

Facility Name: Sequoyah Nuclear Plant

Docket No. 50-327

License No. DPR-77

Inspection at Soddy-Daisy, Tennessee

Date of Last Physical Security Inspection Visit: 1/26-30/81

Type of Inspection: Unannounced Physical Security

Inspector: *[Signature]*
C. D. Perny, Physical Security Inspector

6/1/81
Date Signed

Approved by: *[Signature]*
D. R. McGuire, Section Chief
Technical Inspection Branch
Engineering and Technical Inspection Division

6/1/81
Date Signed

SUMMARY

Inspected on May 12-15, 1981.

Areas Inspected: Included review of licensee action on previous inspection findings; security plan; physical barriers (protected and vital areas); lighting; access control (identification; authorization and badging); access control (search); access control (escorting); access control (vital areas); and alarm stations.

The inspection involved 42 inspector hours on site by one NRC inspector. Fifteen inspection hours were accomplished during offshift periods.

Results: The licensee was found to be in compliance with NRC requirements within the ten areas examined during the inspection except for the following two items:

1. Physical Barriers (Vital Area) - Failure to follow commitments in the Security Plan for securing openings in Vital Area barriers.
2. Access control (identification, authorization and badging) - Failure to follow procedures for vehicle gate control.

8108040284 810721
PDR ADOCK 05000327
G PDR

MATERIAL TRANSMITTED HEREWITH
CONTAINS 2.790 INFORMATION

S-F2 81 - 75
Copy 11 of 12 Copies
10 Pages
This Document is not to be
reproduced without specific
approval of IE:II