LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(2) LICENSEE CODE: T N S N P 1 | (3) LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 | (4) LICENSE TYPE: 4 1 1 1 1 | (5) CAT 58:

CONT

REPORT SOURCE: L (6) | DOCKET NUMBER: 0 5 0 0 0 3 2 7 (7) | EVENT DATE: 0 6 2 6 8 1 (8) | REPORT DATE: 0 7 2 4 8 1 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

Unit 1 in Mode 4 with RCS T avg ≈300°F and Pressure ≈1000 psig. The Service Bldg. Vent monitor (0-RM-90-132) was declared inoperable due to failure of sampling pump, which resulted in placing the unit into action statement 42 of LCO 3.3.3.10. Manual grab sampling was initiated at 1636 (CDT). There was no effect upon public health and safety. Previous occurrences - 1 (Reference: SQRO-50-327/80053).

SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
M B	E	F	P U M P X X	X	Z

(17) LER/RO REPORT NUMBER: EVENT YEAR	SEQUENTIAL REPORT NO.	OCCURRENCE CODE	REPORT TYPE	REVISION NO.
8 1	0 7 4	0 3	L	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER
A	Z	Z	Z	0 0 0 0	N	N	L	G 0 6 3

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The radiation monitor sample vacuum pump failed due to normal wear. The spare sample pump was valved in and the monitor placed back in service at 1530 (CDT) on 6/30/81. The defective pump was replaced on 7/15/81.

FACILITY STATUS (28): C | % POWER (29): 0 0 0 | OTHER STATUS (30): NA | METHOD OF DISCOVERY (31): A | DISCOVERY DESCRIPTION (32): Operator observation

ACTIVITY RELEASED (33): Z | ACTIVITY CONTENT OF RELEASE (34): Z | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES — NUMBER: 0 0 0 | TYPE (37): Z | DESCRIPTION (38): NA

PERSONNEL INJURIES — NUMBER: 0 0 0 | DESCRIPTION (39): NA

LOSS OF OR DAMAGE TO FACILITY (40) — TYPE: Z | DESCRIPTION (41): NA

PUBLICITY — ISSUED (42): N | DESCRIPTION (43): NA

8108040406 810724
PDR ADOCK 05000327
S PDR

NRC USE ONLY

Name of Preparer: D. P. Roberts/M. R. Harding Phone: (615) 842-8317