



Commonwealth Edison
 One First National Plaza, Chicago, Illinois
 Address Reply to: Post Office Box 767
 Chicago, Illinois 60690

July 22, 1981

Mr. James G. Keppler, Director
 Directorate of Inspection and
 Enforcement - Region III
 U.S. Nuclear Regulatory Commission
 799 Roosevelt Road
 Glen Ellyn, IL 60137



Subject: Dresden Station Units 2 and 3
 Quad Cities Station Units 1 and 2
 Zion Station Units 1 and 2
 Monthly Report of Status of I.E.
 Bulletin 79-14 Evaluations
 (through July 20, 1981)
 NRC Docket Nos. 50-237/249, 254/265
 and 295/304

Reference (a): J. G. Keppler letter to C. Reed
 dated August 18, 1980.

Dear Mr. Keppler:

In accordance with the request of Reference (a) the following monthly status report is provided for your use regarding the evaluations performed at Dresden, Quad Cities and Zion Stations in response to IE Bulletin 79-14. The content of this report now only addresses systems found to be inoperable, per discussions with Messrs. I. Yin and D. Daniellson of your office.

At Dresden and Quad Cities, there are no changes since the last status report for I.E. Bulletin 79-14 items.

At Zion Station, stress points in the Service Water package SW-5iA have been found to exceed the 2.4 Sh limit. The overstressed points, which were located in safety related portions of the system, have the following stress/allowable 2.4 Sh levels: Node 178-44805/36000 psi, and Node 210-37324/36000 psi.

*IE 11
S/0*

8108050117 810722
 PDR ADOCK 05000237
 Q PDR

JUL 31 1981

J. G. Keppler

- 2 -

July 22, 1981

Please address any questions you may have concerning this matter to this office.

Very truly yours,

Thomas J. Rausch

Thomas J. Rausch
Nuclear Licensing Administrator
Boiling Water Reactors

cc: Director, Div. of Reactor Operations Inspection
Region III Inspector - Dresden
Region III Inspector - Quad Cities
Region III Inspector - Zion

lm

2231N