

LICENSEE EVENT REPORT

CONTROL BLOCK _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	C	A	S	O	S	1	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	0	4	5							
7		8		9 LICENSEE CODE					14					15 LICENSE NUMBER					25					26 LICENSE TYPE					30					57 CAT 58				

0	1	L	6	0	5	0	0	0	2	0	6	7	0	6	1	8	8	1	B	0	6	3	0	8	1	9							
7		8		61 REPORT SOURCE					66 DOCKET NUMBER					69					74 EVENT DATE					75					80 REPORT DATE				

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 | SONGS-1 USED THE WESTINGHOUSE RECOMMENDATION FOR SATISFYING NUREG 0737, SECTION

0 3 | II.K.3.9 OF SETTING THE TIME CONSTANT TO "OFF" ON THE DERIVATIVE PORTION OF THE PORV

0 4 | CONTROLLER. THE RESULT WAS TO CAUSE THE PORV TO OPEN TWICE DURING THE NORMAL

0 5 | PRESSURE TRANSIENT FOLLOWING A REACTOR TRIP.

0 6 |

0 7 |

0 8 |

0	9	C	A	X	Z	I	N	S	T	R	U	C	Z																
7		8		9 SYSTEM CODE		10		11 CAUSE CODE		12		13 CAUSE SUBCODE		14		15 COMPONENT CODE		16		17		18		19		20		21	
17	8	1	0	1	3	9	9	X	0																				
7		8		9		10		11		13		14		15		16		17		18		19		20		21		22	
7		8		9		10		11		13		14		15		16		17		18		19		20		21		22	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 21

1 0 | TURNING THE TIME CONSTANT TO OFF ACCELERATES THE CONTROLLER RESPONSE

1 1 | THE PORV WAS TEMPORARILY PLACED IN MANUAL CONTROL. PERMANENT CORRECTIVE ACTION

1 2 | CURRENTLY PLANNED WILL TAKE THE PORV OFF THE CONTROLLER SUCH THAT IT WILL

1 3 | AUTOMATICALLY ACTUATE ONLY ON A FIXED PRESSURE SETPOINT.

1 4 |

1	1	C	0	3	6	NA	A	OPERATOR OBSERVATION																					
7		8		9		10		11		13		14		15		16		17		18		19		20		21		22	
1	6	Z	Z	NA	NA																								
7		8		9		10		11		13		14		15		16		17		18		19		20		21		22	
1	7	0	0	0	Z	NA																							
7		8		9		10		11		13		14		15		16		17		18		19		20		21		22	
1	8	0	0	0	NA																								
7		8		9		10		11		13		14		15		16		17		18		19		20		21		22	
1	9	Z	NA																										
7		8		9		10		11		13		14		15		16		17		18		19		20		21		22	
2	0	N	NA																										
7		8		9		10		11		13		14		15		16		17		18		19		20		21		22	

B108050146 B10727 J. M. CURRAN
 PDR ADDCK 05000206 ER PHONE 714-492-7700
 S PDR