

Docket No. 50-325

JUL 21 1981



Mr. J. A. Jones
Senior Executive Vice President
Carolina Power & Light Company
336 Fayetteville Street
Raleigh, North Carolina 27602

Dear Mr. Jones:

We have reviewed and evaluated your June 2, 1981, submittal which requested schedular relief for certain Inservice Inspection requirements for the Brunswick Steam Electric Plant, Unit No. 1 (the facility). We have concluded that the specific requirements were impractical to conduct during the Spring 1981 outage, because of high radiation levels in the examination areas, and should be deferred until the 1982 refueling outage when mechanized equipment will be available and hydrolazing will be possible.

Therefore, pursuant to paragraph 50.55 a(g)(6)(i) of 10 CFR Part 50, we grant relief from the specific schedule requirements that you have identified to be impractical, and impose the alternative schedule cited above. We have determined that this action will not endanger life or property as the common defense and security and is otherwise in the public interest giving due consideration to the burden upon Carolina Power & Light Company that could result if the requirements were imposed on the facility.

A copy of our Safety Evaluation is enclosed.

Sincerely,

V.L. Rooney for
Thomas A. Ippolito, Chief
Operating Reactors Branch #2
Division of Licensing

Enclosure: As Stated

cc w/enclosure
See next page

Distribution:

Docket File	D. Eisenhut	OELD	ACRS (10)
NRC PDR	T. Ippolito	I&E (3)	D. Chaney
Local PDR	S. Norris	NSIC	
ORB#2 Reading	J. Van Vliet	TERA	

OFFICE	DL:ORB#2	DL:ORB#2	DL:ORB#1	DL:ORB#2		
SURNAME	SNorris:pob	JVan Vliet	DCChaney	Tippolito		
	7/21/81	7/21/81	7/21/81	7/21/81		

8108060041 810721
PDR ADOCK 05000325
G PDR

OFFICIAL RECORD COPY