July 28, 1981

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-81-61

This preliminary notification constitutes EARLY notice of an event of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by IE staff as of this date.

FACILITY: Duke Power Company

Oconee 1

Docket No. 50-269 near Seneca, SC

SUBJECT: ODINE-131 UPTAKE IN WORKERS

Body burden analyses performed as of July 28 during the present unit 1 refueling outage indicate that 54 of 365 individuals have uptakes of iodine-131 in their thyroids. The maximum individual uptake was 50 nanocuries which is less than 6 percent of NRC exposure limits. The licensee attributes the uptake to absorption through the skin and has required workers to wear additional protective clothing to reduce further uptakes.

Media interest has occurred. Neither the NRC nor the licensee is planning a press release. The State of South Carolina has been informed.

Region II (Atlanta) received notification of this occurrence by telephone from the resident inspector at 3:30 a.m. on July 9. This information is current as of 4:00 p.m. on July 28.

Contact: J. R. Vray, RII 242-4198; C. M. Hosey, RII 242-5526

Distribution. Turnemittel	1 64	
Distribution: Transmittal I Chairman Palladino Commissioner Gilinsky	Commissioner Ahearne Commissioner Bradford	S. J. Chilk, SECY C. C. Kammerer, CA
Transmitted: MNBB	P. Bldg. 4:50 H. R. Denton, NRR	(For Distribution) IE:TAS(IE:HQ Dist.)
C. Michelson, AEOD J. J. Fouchard, PA N. M. Haller, MPA	R. H. Vollmer, NRR T. E. Murley, NRR R. Mattson, NRR	Landow(6 min/page) J. J. Cummings, OIA
H. K. Shapar, ELD Air Rights	D. Eisenhut, NRR S. H. Hanauer, NRR	MAIL IE:TAS
G. W. Kerr, SP Applicable Resident Site 5:03 Regional Offices Applicable Utility 4:54	J. G. Davis, NMSS R. Minogue, RES	Document Mgt. Br. (PDR) S. Ebbin, NSOC
	NSAC .	INPO
		Facsimile 404/952-6728

PRELIMINARY NOTIFICATION

1/0

8108070096 810728 PDR I&E PNO-II-81-061 PDR