

# LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | T | N | S | N | P | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

8 9      14 15      25 26      57 CAT 58

REPORT SOURCE L 6 | 0 | 5 | 0 | 0 | 0 | 3 | 2 | 7 | 7 | 0 | 7 | 1 | 9 | 8 | 1 | 8 | 0 | 7 | 3 | 1 | 8 | 1 | 9

60 61      68 69      74 75      80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 | Unit 1 in Mode 3 with RCS temperature and pressure at 537°F and 2235 psig. During

0 3 | performance of a linkage interlock test on the lower containment personnel access

0 4 | lock, the inner door was allowed to slam and bounce back. The latch-closed blocking

0 5 | the door ajar. The outer door was then opened violating containment integrity per

0 6 | technical specification 3.6.1.3. There was no effect upon public health or safety,

0 7 | Previous Occurrences - 2. (Reference: SQRO-50-327/80113 and 80116).

0 8 |

80

0 9 | S A 11 | E 12 | B 13 | P | E | N | E | T | R | 14 | A 15 | Z 16

9 10      11 12      13 18      19 20

17 | LER/RO REPORT NUMBER | 8 | 1 | — | 0 | 8 | 5 | 0 | 1 | — | 0

21 22      23 24      25 26      27 28      29 30      31 32

ACTION TAKEN E 18 | FUTURE ACTION Z 19 | EFFECT ON PLANT Z 20 | SHUTDOWN METHOD Z 21 | HOURS 0 0 0 0 | ATTACHMENT SUBMITTED N 23 | NRC 4 FORM SUB N 24 | PRIME COMP SUPPLIER L 25 | COMPONENT MANUFACTURER C 3 1 0

33 34      35 36      37 40      41 42      43 44      45 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

0 | Doors were properly closed within 5 seconds. Excessive slack in the door operating

1 | linkage allowed the door to bounce open enough to allow the latch to block it open,

2 | The linkage was adjusted to prevent the door from bouncing. An instruction has been

3 | prepared and is being implemented to periodically check and adjust the slack in the

4 | operating linkage. Maintaining this adjustment should prevent future occurrences.

5 | G 28 | 0 | 0 | 0 | 29 | NA | A 31 | Personnel Observation | 12

8 9      10 12      13 14      44 45      46 47      80

6 | Z 33 | Z 34 | NA | NA | NA | 35

8 9      10 11      44 45      80

7 | 0 | 0 | 0 | 37 | Z 38 | NA | 39

8 9      11 12      13 14      80

8 | 0 | 0 | 0 | 41 | NA | 41

8 9      11 12      80

9 | Z 42 | NA | 43

8 9      10 11      80

0 | N 44 | NA | 45

8 9      10 11      80

NRC USE ONLY