NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 LICENSEE CODE: N E C P R 1 (2) LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) LICENSE TYPE: 4 1 1 1 1 (4) CAT (5)

CON'T 01 REPORT SOURCE: L (6) DOCKET NUMBER: 0 5 0 0 0 2 9 8 (7) EVENT DATE: 0 6 2 5 8 1 (8) REPORT DATE: 0 7 2 2 8 1 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During routine surveillance testing, pressure switch NBI-PS-52A was found with a
03 trip point less conservative than allowed by Tech. Spec. Table 3.2.B, Page 1. There
04 was no significant occurrence as a result of this event. The redundant pressure
05 switches NBI-PIS-52B, PS-52C, and PIS-52D were all operable. There were no adverse
06 effects to public health and safety.
07
08

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
09	S F (11)	X (12)	Z (13)	I N S T R U (14)	S (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 1	—	0 1 8	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
E (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	(24)	N (25)	B 0 6 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 NBI-PS-52A is a Barksdale Model B2T pressure switch. The switch setpoint has demon-
11 strated a tendency to drift after a plant refueling outage. The switch was readjusted
12 at the time of occurrence ıd after further checks, demonstrated satisfactory per-
13 formance. Setpoints for the switches were subsequently reset to a value providing
14 more margin from the limit.

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
15	E (28)	0 9 8 (29)	NA	B (31)	Surveillance Testing

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
17	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
18	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
19	Z (42)	NA

PUBLICITY

	ISSUED	DESCRIPTION (45)
20	N (44)	NA

8108110106 810722
PDR ADOCK 05000298
S PDR

NRC USE ONLY

NAME OF PREPARER: Dennis Marker PHONE: 402-825-3811