



Commonwealth Edison

DEVIATION REPORT

DVR NO.	STA	UNIT	YEAR	NO.
	D-12	-2-	81-	75

PART 1 TITLE OF DEVIATION		OCCURRED	
Loss of Power Supply For process Monitors		07/06/81	0620
SYSTEM AFFECTED 1700		DATE	TIME
Process Radiation	PLANT CONDITIONS	TESTING	
MODE Run	PWR(MWT) 2121	LOAD(MWE) 680	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO

DESCRIPTION OF EVENT
 Received vent monitor down scale alarm on 902-3 PNL. Investigation revealed power supply for "B" Channel Isolation Condenser Vent Monitor, Reactor Bldg. Fuel Pool and Rx Bldg. Vent Monitor Reading 225V ("A" power supply at 595V).

DESCRIPTION OF CAUSE
 Loss of power supply cause unknown

OTHER APPLICABLE INFORMATION
 Logged in degraded equipment log.

EQUIPMENT FAILURE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	DR NO. -	WR NO. D14564	Bob Herbert	7/6/81
			RESPONSIBLE SUPERVISOR	DATE

PART 2 OPERATING ENGINEERS COMMENTS
 Power supply repaired in less than 8 hours

TYPE OF DEVIATION REPORTABLE OCCURRENCE	EVENT OF POTENTIAL PUBLIC INTEREST	TECH SPEC VIOLATION	NON-REPORTABLE OCCURRENCE	ANNUAL REPORTING	SAFETY-RELATED WR ISSUED
<input type="checkbox"/> 14 DAY <input type="checkbox"/> 10CFR21	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
<input checked="" type="checkbox"/> 30 DAY NOTIFICATION 6.6.B.2.b					

REPORTABLE OCCURRENCE NUMBER	ACTION ITEM NO.	PROMPT ON-SITE NOTIFICATION		
81-45/03L-0		C. E. Sargent	7/7/81	1700
		TITLE	DATE	TIME
		TITLE	DATE	TIME

24-HOUR NRC NOTIFICATION (Courtesy)	PROMPT OFF-SITE NOTIFICATION		
<input checked="" type="checkbox"/> TPH Mike Jordan 7/6/81 ≈1500	F. A. Palmer	7/8/81	9:04
REGION III DATE TIME	TITLE DATE TIME		
<input type="checkbox"/> TGM REGION III & DOL DATE TIME	TITLE DATE TIME		

RESPONSIBLE COMPANY OFFICER INFORMED OF 10CFR21 CONDITIONS AND THEIR REPORT TO NRC	TITLE	DATE	TIME
REVIEW AND COMPLETED	John W. Wujciga	7/6/81	
	OPERATING ENGINEER	DATE	

ACCEPTANCE BY STATION REVIEW AS REQUIRED

DATE

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION

J. Brunner 8/3/81
John Wujciga 7/3/81
Douglas J. Scott 8/4/81
 STATION SUPERINTENDENT DATE