

MONTHLY OPERATING INFORMATION DISTRIBUTION

Number of Copies

| | | |
|--|----|--|
| Director - - - - - | 10 | (Original of P Letter) |
| Office of Inspection and Enforcement U. S. Nuclear Regulatory Commission Washington, D.C. 20555 | | |
| Karl V. Seyfrit, Director - - - - - | 1 | (P Letter) |
| Region IV Office of Inspection and Enforcement Nuclear Regulatory Commission 611 Ryan Plaza Drive Suite 1000 Arlington, Texas 76012 | | |
| Director - - - - - | 2 | (P Letter) |
| Office of Management Information and Program Control U. S. Nuclear Regulatory Commission Washington, D.C. 20555 | | |
| Ted Cintula - - - - - | 1 | (P Letter) |
| U. S. Nuclear Regulatory Commission 12105 National Maryland Bank Building Washington, D.C. 20555 | | |
| Mr. Richard Phelps - - - - - | 1 | (P Letter) |
| FSV, GA, Site Representative General Atomic Company P. O. Box 426 Platteville, Colorado 80651 | | |
| NRC Resident Site Inspector - - - - - | 1 | (P Letter) |
| Senior Vice President, Room 770 - - - - - | 1 | (P Letter) |
| Vice President, Electrical Engineering and Planning, 39th Avenue - - - - - | 1 | (P Letter) |
| Vice President, Production Division, Belleview - - - - - | 1 | (P Letter) |
| Quality Assurance Manager - - - - - | 1 | (P Letter) |
| Site Engineering Coordinator - - - - - | 1 | (P Letter) |
| Nuclear Project Manager, Montbello - - - - - | 1 | (P Letter) |
| Gary Reeves, Public Relations, Room 950 - - - - - | 1 | (Original of Memo) |
| Bill Shinkle, Property Accounting, Holly Service Center - - - - - | 1 | (Original of Memo) |
| Supervisor, Licensing and Administrative Services, Nuclear Project Department, Montbello - - - - - | 1 | (P Letter) |
| Supervisor, Project Engineering, Nuclear Project Department, Montbello - - - - - | 1 | (P Letter) |
| Documents Control Technician, Montbello - - - - - | 2 | (2 P Letters) |
| Correspondence Coordinator, Nuclear Project Department, Montbello - - - - - | 1 | (P Letter) |
| Nuclear Production Manager - - - - - | 1 | (P Letter) |
| Operations Manager - - - - - | 1 | (P Letter) |
| Administrative Services Manager - - - - - | 1 | (P Letter) |
| PORC Committee - - - - - | 1 | (P Letter) |
| FSV NFSC Secretary - - - - - | 1 | (P Letter) |
| P Files - - - - - | 1 | (P Letter) |
| Record Storage - - - - - | 2 | (P Letter) |
| Technical Services Review - - - - - | 1 | (P Letter) |
| Technical Services Supervisor - - - - - | 1 | (P Letter) |
| Grey Book Notebook - - - - - | 1 | |
| Monthly Operations Folder - - - - - | 1 | |
| Monthly Operating Information Folder - - - - - | 1 | (P Letter) |
| Monthly Operating Information File - - - - - | 0 | (Original of Report and 1 Copy of P Letter) |
| Gas Cooled Reactor Associates - - - - - | 1 | (P Letter) |
| Attention: Mr. R. A. Evans 3344 North Torrey Pines Court Suite 300 LaJolla, California 92037 | | |
| Electric Power Research Institute - - - - - | 1 | (P Letter) |
| Attention: Mr. Melvin E. Lapidus 3412 Hillview Avenue P. O. Box 10412 Palo Alto, California 94303 | | |

OPERATING DATA REPORT

DOCKET NO. 50-267
 DATE 810803
 COMPLETED BY L. M. McBride
 TELEPHONE (303) 785-2224

OPERATING STATUS

1. Unit Name: Fort St. Vrain
2. Reporting Period: 810701 through 810731
3. Licensed Thermal Power (Mwt): 842
4. Nameplate Rating (Gross MWe): 342
5. Design Electrical Rating (Net MWe): 330
6. Maximum Dependable Capacity (Gross MWe): 342
7. Maximum Dependable Capacity (Net MWe): 330

NOTES

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
None

9. Power Level To Which Restricted, If Any (Net MWe): 231
10. Reasons for Restrictions, If Any: NRC restriction 70% pending resolution of temperature fluxuations.

| | This Month | Year to Date | Cumulative |
|---|-----------------|--------------------|--------------------|
| 11. Hours in Reporting Period | <u>744</u> | <u>5,087</u> | <u>18,298</u> |
| 12. Number of Hours Reactor Was Critical | <u>391.2</u> | <u>3,056.7</u> | <u>12,191.9</u> |
| 13. Reactor Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>0.0</u> |
| 14. Hours Generator On-Line | <u>130.0</u> | <u>2,261.5</u> | <u>7,954.8</u> |
| 15. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>0.0</u> |
| 16. Gross Thermal Energy Generated (MWH) | <u>56,828.1</u> | <u>1,159,414.9</u> | <u>3,867,507.7</u> |
| 17. Gross Electrical Energy Generated (MWH) | <u>10,443</u> | <u>410,888</u> | <u>1,282,682</u> |
| 18. Net Electrical Energy Generated (MWH) | <u>4,172</u> | <u>373,477</u> | <u>1,172,778</u> |
| 19. Unit Service Factor | <u>17.5</u> | <u>44.5</u> | <u>43.5</u> |
| 20. Unit Availability Factor | <u>17.5</u> | <u>44.5</u> | <u>43.5</u> |
| 21. Unit Capacity Factor (Using MDC Net) | <u>1.7</u> | <u>22.2</u> | <u>19.4</u> |
| 22. Unit Capacity Factor (Using DER Net) | <u>1.7</u> | <u>22.2</u> | <u>19.4</u> |
| 23. Unit Forced Outage Rate | <u>34.3</u> | <u>35.7</u> | <u>36.9</u> |

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): Maintenance/modification shutdown September 1, 1981 lasting 4 months.

25. If Shut Down at End of Report Period, Estimated Date of Startup: N/A

| 26. Units In Test Status (Prior to Commercial Operation): | Forecast | Achieved |
|---|------------|------------|
| INITIAL CRITICALITY | <u>N/A</u> | <u>N/A</u> |
| INITIAL ELECTRICITY | <u>N/A</u> | <u>N/A</u> |
| COMMERCIAL OPERATION | <u>N/A</u> | <u>N/A</u> |

AVERAGE DAILY UNIT POWER LEVEL

Docket No. 50-267

Unit Fort St. Vrain

Date 810803

Completed By L. M. McBride

Telephone (303) 785-2224

Month July, 1981

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

| | |
|----|------------|
| 1 | <u>0.0</u> |
| 2 | <u>0.0</u> |
| 3 | <u>0.0</u> |
| 4 | <u>0.0</u> |
| 5 | <u>0.0</u> |
| 6 | <u>0.0</u> |
| 7 | <u>0.0</u> |
| 8 | <u>0.0</u> |
| 9 | <u>0.0</u> |
| 10 | <u>0.0</u> |
| 11 | <u>0.0</u> |
| 12 | <u>0.0</u> |
| 13 | <u>0.0</u> |
| 14 | <u>0.0</u> |
| 15 | <u>0.0</u> |
| 16 | <u>0.0</u> |

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

| | |
|----|--------------|
| 17 | <u>0.0</u> |
| 18 | <u>0.0</u> |
| 19 | <u>0.0</u> |
| 20 | <u>0.0</u> |
| 21 | <u>0.0</u> |
| 22 | <u>0.0*</u> |
| 23 | <u>0.0*</u> |
| 24 | <u>2.88</u> |
| 25 | <u>0.0</u> |
| 26 | <u>0.0</u> |
| 27 | <u>61.96</u> |
| 28 | <u>71.92</u> |
| 29 | <u>70.33</u> |
| 30 | <u>74.71</u> |
| 31 | <u>79.54</u> |

*Generator on line but no net generation.

REFUELING INFORMATION

| | |
|--|---|
| 1. Name of Facility. | Fort St. Vrain Unit No. 1 |
| 2. Scheduled date for next refueling shutdown. | October 1, 1982 |
| 3. Scheduled date for restart following refueling. | December 1, 1982 |
| 4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? | No |
| If answer is yes, what, in general, will these be? | ----- |
| If answer is no, has the reload fuel design and core configuration been reviewed by your Plant Safety Review Committee to determine whether any unreviewed safety questions are associated with the core reload (Reference 10CFR Section 50.59)? | The Plant Operations Review Committee will review any questions associated with the reload. |
| If no such review has taken place, when is it scheduled? | May 1, 1931 |
| 5. Scheduled date(s) for submitting proposed licensing action and supporting information. | ----- |
| 6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures. | ----- |
| 7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool. | 1482 HTGR fuel elements 250 spent HTGR fuel elements |
| 8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies. | Capacity is limited in size to about one-third of core (approximately 500 HTGR elements). No change is planned. |

REFUELING INFORMATION (CONTINUED)

| | |
|---|--|
| 9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity. | 1986 under the Three Party Agreement (Contract AT (04-3)-633) between DOE, Public Service Company of Colorado (PSCo), and General Atomic Company.* |
|---|--|

*The 1986 date is based on the understanding that spent fuel discharged during the term of the Three Party Agreement will be shipped to the Idaho National Engineering Laboratory for storage by DOE at the Idaho Chemical Processing Plant (ICPP). The storage capacity has evidently been sized to accommodate fuel which is expected to be discharged during the eight year period covered by the Three Party Agreement.