

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 A L B R F 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 37 CAT 38

CON'T
0 1 REPORT SOURCE L 6 0 5 0 0 0 2 5 9 7 0 7 2 7 8 1 8 0 8 1 7 8 1 9
7 8 80 81 88 89 94 95 98 99

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 The 90-day report to NRC on secondary containment was not submitted by 7/9/81 as
0 3 required by T.S. 6.7.3.C.1.a. There was no danger to the health or safety of the
0 4 public, no resulting significant chain of events, and no previous similar events.
0 5
0 6
0 7
0 8

0 9
7 8 9
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
Z Z 11 A 12 X 13 Z Z Z Z Z Z 14 Z 15 Z 16
17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
X 18 G 9 Z 20 0 0 0 0 0 3 Y 23 N 24 Z 25 Z 9 9 9 26
33 34 35 36 37 40 41 42 43 44 47
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Due to U-1 outage and changeover of unit personnel, the 90-day report to NRC on
1 1 secondary containment deadline was not made. Report was written 7/28 for submittal
1 2 to NRC. Cognizant personnel have been instructed to be more aware of due dates. This
1 3 due date has been placed on plant services scheduled maintenance items list.
1 4

1 5 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
H 28 0 0 0 29 NA A 31 Reported by cognizant engineering.
7 8 9 10 11 12 13 44 45 46 80
1 6 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
Z 33 Z 34 NA 35 NA 36
7 8 9 10 11 12 13 44 45 80
1 7 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION PERSONNEL INJURIES NUMBER DESCRIPTION
0 0 0 37 Z 38 NA 40 NA 41
7 8 9 10 11 12 13 44 45 80
1 8 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION PUBLICITY ISSUED DESCRIPTION
Z 42 NA 43 NA 44 45
7 8 9 10 11 12 13 44 45 80
1 9 NRC USE ONLY
2 0 N 44 NA 45
7 8 9 10 11 12 13 44 45 80

8108200161 810817
PDR ADOCK 05000259
S PDR

Gene Holder

PHONE: (205) 729-6134

LER SUPPLEMENTAL INFORMATION

BFRO-50- 259 / 81043 Technical Specification Involved 6.7.3.C.1.a
Reported Under Technical Specification 6.7.2.b(3) *Date due NRC: 8/26/81
Date of Occurrence 7/27/81 Time of Occurrence 2400 Unit 1

Identification and Description of Occurrence:

The 90-day report to NRC on secondary containment was not submitted by the 7/9/81 deadline.

Conditions Prior to Occurrence:

Unit 1 in refueling outage.

Unit 2 at 97%.

Unit 3 at 97%.

Action specified in the Technical Specification Surveillance Requirements met due to inoperable equipment. Describe. _____

None

Apparent Cause of Occurrence:

Due to unit 1 outage and changeover of unit personnel, the 90-day report to NRC on secondary containment deadline was overlooked. This omission was discovered on 7/27.

Analysis of Occurrence:

There was no danger to the health or safety of the public, no release of activity, no damage to the plant or equipment, and no resulting significant chain of events.

Corrective Action:

The report was written on 7/28 and is being transmitted to NRC. Cognizant personnel have been instructed to be more aware of due dates. This report has been placed on plant services scheduled maintenance items list.

Failure Data: None

Retention: Period - Lifetime; Responsibility - Document Control Supervisor

*Revision: SA