

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M D C C N I 2 0 0 0 - 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 7 7 0 7 2 1 8 1 8 0 8 1 1 8 1 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 17

0 2 Between 2020 on July 21, and 0540 on July 22, during normal startup
0 3 operations, pressurizer level deviated slightly from the program level
0 4 by more than +/- 5% several times. The maximum period the level was
0 5 out of specification was 20 minutes. LER's 81-40 and 50-318/81-33
0 6 describe similar events.
0 7
0 8

0 9 SYSTEM CODE C B 11 CAUSE CODE X 12 CAUSE SUBCODE Z 13 COMPONENT CODE Z Z Z Z Z Z Z 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 LER/RO REPORT NUMBER 8 1 21 22 EVENT YEAR 8 1 23 24 SEQUENTIAL REPORT NO. 0 5 7 25 26 OCCURRENCE CODE 0 3 27 28 REPORT TYPE L 29 30 REVISION NO. 0 31 32

ACTION TAKEN Z 18 33 FUTURE ACTION Z 19 34 EFFECT ON PLANT Z 20 35 SHUTDOWN METHOD Z 21 36 HOURS 0 0 0 0 22 37 ATTACHMENT SUBMITTED N 23 40 NPRD-4 FORM SUB. N 24 42 PRIME COMP. SUPPLIER Z 25 43 COMPONENT MANUFACTURER Z 9 9 9 9 26 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 RCS temperature swings of 10 degrees are not uncommon during normal
1 1 startup operations. These temperature swings can result in deviations
1 2 greater than +/- 5% from the pressurizer program level. No corrective
1 3 action was deemed necessary.
1 4

1 5 FACILITY STATUS C 28 9 % POWER 0 0 2 29 10 11 OTHER STATUS NA 30 44 METHOD OF DISCOVERY A 31 45 DISCOVERY DESCRIPTION Operator Observation 32 46 80

1 6 ACTIVITY CONTENT Z 33 9 10 RELEASED OF RELEASE Z 34 11 AMOUNT OF ACTIVITY NA 35 44 LOCATION OF RELEASE NA 36 45 80

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 11 12 TYPE Z 38 13 DESCRIPTION NA 39 80

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 11 12 DESCRIPTION NA 41 13 80

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 9 10 DESCRIPTION NA 43 11 80

2 0 PUBLICITY ISSUED N 44 9 10 DESCRIPTION NA 45 11 80

8108200260 810811 PDR ADOCK 05000317 ARER M. A. Junge (301) 269-4969
S PDR