

LICENSEE EVENT REPORT

CONTROL BLOCK: [] [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
[0 1] [N C B E P 2] (2) [0 0 - 0 0 0 0 0 - 0 0] (3) [4 1 1 1 1] (4) [] [] (5)
7 8 9 14 15 25 26 30 57 CAT 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CONT
[0 1] REPORT SOURCE [L] (6) [0 5 0 - 0 3 2 4] (7) [0 7 1 4 8 1] (8) [0 8 1 1 8 1] (9)
7 8 60 61 68 69 74 75 80
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
[0 2] During plant operation while performing the No. 2 Diesel Generator Monthly Load Test,
[0 3] PT 12.2b, the diesel tripped and locked out due to jacket water temperature exceeding
[0 4] the trip setpoint of 200°F. This made the diesel unavailable to perform its design
[0 5] function. This event did not affect the health and safety of the public.
[0 6]
[0 7]
[0 8] Technical Specifications 3.8.1.1, 6.9.1.9b
7 8 9 80

[0 9] [E E] (11) [A] (12) [B] (13) [V A L V E X] (14) [B] (15) [Q] (16)
7 8 9 10 11 12 13 16 19 20
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
[17] [8 1] [] [0 6 6] [] [0 3] [L] [] [0]
21 22 23 24 26 27 28 29 30 31 32
LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
[H] (18) [H] (19) [Z] (20) [Z] (21) [0 0 0 0] [N] (23) [Y] (24) [N] (25) [G 0 8 0] (26)
33 34 35 36 37 40 41 42 43 44 47
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
[1 0] A failure to adequately monitor the diesel jacket water temperature after adjusting
[1 1] the jacket water temperature control valve manual bypass valve, DJW-V196, in order to
[1 2] raise the jacket water temperature, caused this event. Following this event, the
[1 3] diesel was restarted and the PT was satisfactorily completed. All auxiliary operators
[1 4] will be instructed by Shift Foreman to closely monitor diesel operating parameters
7 8 9 80
during diesel operation.

[1 5] [F] (28) [0 8 9] (29) [NA] (30) [B] (31) Periodic Test (32)
7 8 9 10 11 12 13 14 44 45 46 80
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
[1 6] [Z] (33) [Z] (34) [NA] (35) [NA] (36)
7 8 9 10 11 44 45 80
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

[1 7] [0 0 0] (37) [Z] (38) [NA] (39)
7 8 9 10 11 12 13 80
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

[1 8] [0 0 0] (40) [NA] (41)
7 8 9 10 11 12 80
PERSONNEL INJURIES NUMBER DESCRIPTION

[1 9] [Z] (42) [NA] (43)
7 8 9 10 80
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

[2 0] [N] (44) [NA] (45) 8108200320 610811 PDR ADOCK 05000324 PDR
7 8 9 10 68 69 80
ISSUED DESCRIPTION PUBLICLY ISSUED DESCRIPTION NRC USE ONLY

NAME OF PREPARER M. J. Pastva, Jr. PHONE (919) 457-9521