NRC FORM 366
(7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 CARS 1 (2) 001-0000-0001-00 (3) 4 1 1 1 1 (4) (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 REPORT SOURCE L (6) 05000313 12 (7) 071381 (8) 081381 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With the reactor at full power, performance of SP 201.03L, the fire door
03 surveillance procedure, revealed 37 apparently unacceptable fire doors.
04
05
06
07
08

09 SYSTEM CODE AB (11) CAUSE CODE X (12) CAUSE SUBCODE Z (13) COMPONENT CODE XXXXXX (14) COMP. SUBCODE Z (15) VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 81 — SEQUENTIAL REPORT NO. 038 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN B (18) FUTURE ACTION B (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0000 (22) ATTACHMENT SUBMITTED Y (23) NPRDS FORM SUB N (24) PRIME COMP. SUPPLIER A (25) COMPONENT MANUFACTURER C175 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 This was an initial inspection. Unless future inspections reveal further
11 degradation, it is assumed no generic problem exists. Twenty-three doors
12 were determined acceptable, 13 were/will be repaired (latches, hinges, holes,
13 improper gap), and an obstruction was removed from one. Until 11-4-81, when
14 repairs are complete, fire watches will be established.

15 FACILITY STATUS E (28) % POWER 100 (29) OTHER STATUS (30) N/A — METHOD OF DISCOVERY B (31) — DISCOVERY DESCRIPTION (32) Surveillance Test

16 ACTIVITY RELEASED Z (33) CONTENT OF RELEASE Z (34) — AMOUNT OF ACTIVITY (35) N/A — LOCATION OF RELEASE (36) N/A

17 PERSONNEL EXPOSURES NUMBER 000 (37) TYPE Z (38) DESCRIPTION (39) N/A

18 PERSONNEL INJURIES NUMBER 000 (40) DESCRIPTION (41) N/A

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION (43) N/A

20 PUBLICITY ISSUED Y (44) DESCRIPTION (45) Local newspapers and wire services

NRC USE ONLY

NAME OF PREPARER R. W. Colombo PHONE (916) 452-3211

8108210215 810813
PDR ADOCK 05000312
S PDR