12	CONTROL BLOCK: [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	T N S N P 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 57 CAT 50
CON'T	SOURCE L 6 0 5 10 0 0 3 12 17 7 0 7 2 1 8 1 8 0 8 1 7 8 1 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2	L At 1520 CDT on 7/. 1/81 with Unit 1 in Mode 3 (547°F and 2235 PSIG), the unit
03	operator observed auxiliary feedwater level control valve 1-LCV-3-164 to be
0 4	operating erratically. The valve was declared inoperable placing Unit 1 in
0 5	action statement "a" of LCO 3.7.1.2 until the valve was returned to service at
06	2130 CDT. There was no effect on public health or safety. No previous occurrences.
0 7	
0 8	80
0 9	SYSTEM CAUSE CODE SUBCODE SUBC
	LER/RO EVENT YEAR REPORT NO. 1) REPORT NUMBER 21 22 23 24 26 27 10 3 L 1 1 32 ACTION FUTURE CFFECT SHUTDOWN HOURS 22 SUBMITTED FORM SUB. PRIME COMP. TAKE! ACTION ON PLANT METHOD HOURS 22 SUBMITTED FORM SUB. SUPPLIER MANUFACTURER MANUFACT
[1]0]	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) The metering orifice on the valve positioner had apparently become clogged.
	After this orifice was cleared, the valve was verified to operate properly.
112	After completing all work on the valve, including the required post-maintenance
	test, the valve was declared operable at 2130 CDT.
114	1
1 5	FARTELLY SPOWER OTHER STATUS (30) METHOD OF DISCOVERY DESCRIPTION (32) D 28 0 0 0 29 NA A (45 46 80
1 6	ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (5) NA NA NA NA NA NA NA NA NA N
1 7	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39) O O O O O O O NA PERSONNEL INJURIES 13 80
18	NUMBER DESCRIPTION (41) NA
1191	LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION Z (42) NA
, 8	9 10 80
20	IN 44 NA SECRIPTION (45)
PDF S	08240080 81081/ 08000327 A M Wilkey/M. R. Harding Phone: (615) 842-8317