

AUG 19 1981

DCS-MS-016

Docket Nos. 50-266
and 50-301


DISTRIBUTION:

~~Docket File~~ Gray File
NRC PDR CTrammell
L PDR
NSIC
TERA
ORB#3 Rdg
DEisenhut
OELD
I&E-3
ACRS-10
JHeltemes
PMKreutzer-3
TColburn
RAClark

Mr. Sol Burstein
Executive Vice President
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, Wisconsin 53201

Dear Mr. Burstein:

SUBJECT: TMI TASK PLAN ITEMS II.K.3.9, II.K.3.10 AND II.K.3.12 FOR
POINT BEACH NUCLEAR PLANT UNITS 1 AND 2



Your letters of June 11, 1980, December 23, 1980 and January 19, 1981 indicate that you have taken the actions requested under item II.K.3.9 (PID Controller) of NUREG-0737. This has been verified by the Point Beach Resident Inspector. Therefore, this item is resolved for your facilities.

Your letters also indicate that no increase in the setpoint for the reactor trip on turbine trip is contemplated as this is part of the original plant design, and therefore, item II.K.3.10 is resolved for your facilities. In the future, should you request authorization to raise this setting, the information requested in item II.K.3.10 should be supplied.

Your letters further confirm that Point Beach Units 1 and 2 have an anticipatory reactor trip on turbine trip, in conformance with item II.K.3.12 of NUREG-0737. Therefore, this item is resolved for your facilities.

Sincerely,

Original signed by:

Charles M Trammell for
Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

cc: See next page

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL	ORB#3:DL		
SURNAME	PMKreutzer	TColburn/pn	CTrammell	RAClark		
DATE	8/19/81	8/19/81	8/19/81	8/19/81		
	8108280379	810819				
	PDR	ADUCK 05000266				

OFFICIAL RECORD COPY

USGPO: 1980-329-824

Wisconsin Electric Power Company

cc:

Mr. Bruce Churchill, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. William Guldemon
USNRC Resident Inspectors Office
6612 Nuclear Road
Two Rivers, Wisconsin 54241

Joseph Mann Library
1516 Sixteenth Street
Two Rivers, Wisconsin 54241

Mr. Glenn A. Reed, Manager
Nuclear Operations
Wisconsin Electric Power Company
Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, Wisconsin 54241

Mr. Gordon Blaha
Town Chairman
Town of Two Creeks
Route 3
Two Rivers, Wisconsin 54241

Ms. Kathleen M. Falk
General Counsel
Wisconsin's Environmental Decade
114 N. Carroll Street
Madison, Wisconsin 53703

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: Regional Radiation
Representative
230 S. Dearborn Street
Chicago, Illinois 60604

Chairman
Public Service Commission of Wisconsin
Hills Farms State Office Building
Madison, Wisconsin 53702



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

AUG 19 1981

NRC PDR

Docket Nos. 50-266
and 50-301

Mr. Sol Burstein
Executive Vice President
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, Wisconsin 53201

Dear Mr. Burstein:

SUBJECT: YMI TASK PLAN ITEMS II.K.3.9, II.K.3.10 AND II.K.3.12 FOR
POINT BEACH NUCLEAR PLANT UNITS 1 AND 2

Your letters of June 11, 1980, December 23, 1980 and January 19, 1981 indicate that you have taken the actions requested under item II.K.3.9 (PID Controller) of NUREG-0737. This has been verified by the Point Beach Resident Inspector. Therefore, this item is resolved for your facilities.

Your letters also indicate that no increase in the setpoint for the reactor trip on turbine trip is contemplated as this is part of the original plant design, and therefore, item II.K.3.10 is resolved for your facilities. In the future, should you request authorization to raise this setting, the information requested in item II.K.3.10 should be supplied.

Your letters further confirm that Point Beach Units 1 and 2 have an anticipatory reactor trip on turbine trip, in conformance with item II.K.3.12 of NUREG-0737. Therefore, this item is resolved for your facilities.

Sincerely,

for *Charles M. Trammel*
Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

cc: See next page

Wisconsin Electric Power Company

CC:

Mr. Bruce Churchill, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. William Guldemon
USNRC Resident Inspectors Office
6612 Nuclear Road
Two Rivers, Wisconsin 54241

Joseph Mann Library
1516 Sixteenth Street
Two Rivers, Wisconsin 54241

Mr. Glenn A. Reed, Manager
Nuclear Operations
Wisconsin Electric Power Company
Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, Wisconsin 54241

Mr. Gordon Blaha
Town Chairman
Town of Two Creeks
Route 3
Two Rivers, Wisconsin 54241

Ms. Kathleen M. Falk
General Counsel
Wisconsin's Environmental Decade
114 N. Carroll Street
Madison, Wisconsin 53703

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: Regional Radiation
Representative
230 S. Dearborn Street
Chicago, Illinois 60604

Chairman
Public Service Commission of Wisconsin
Hills Farms State Office Building
Madison, Wisconsin 53702

2 PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
AUG 19 1981

Docket Nos. 50-266
and 50-301

Mr. Sol Burstein
Executive Vice President
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, Wisconsin 53201

Dear Mr. Burstein.

SUBJECT: TMI TASK PLAN ITEMS II.K.3.9, II.K.3.10 AND II.K.3.12 FOR
POINT BEACH NUCLEAR PLANT UNITS 1 AND 2

Your letters of June 11, 1980, December 23, 1980 and January 19, 1981 indicate that you have taken the actions requested under item II.K.3.9 (PID Controller) of NUREG-0737. This has been verified by the Point Beach Resident Inspector. Therefore, this item is resolved for your facilities.

Your letters also indicate that no increase in the setpoint for the reactor trip on turbine trip is contemplated as this is part of the original plant design, and therefore, item II.K.3.10 is resolved for your facilities. In the future, should you request authorization to raise this setting, the information requested in item II.K.3.10 should be supplied.

Your letters further confirm that Point Beach Units 1 and 2 have an anticipatory reactor trip on turbine trip, in conformance with item II.K.3.12 of NUREG-0737. Therefore, this item is resolved for your facilities.

Sincerely,

for *Charles M. Trammell*
Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

cc: See next page

Wisconsin Electric Power Company

cc:

Mr. Bruce Churchill, Esquire
Shaw, Pittman, Potts and Trowbridge
1300 M Street, N. W.
Washington, D. C. 20036

Mr. William Guldemon
USNRC Resident Inspectors Office
6612 Nuclear Road
Two Rivers, Wisconsin 54241

Joseph Mann Library
1516 Sixteenth Street
Two Rivers, Wisconsin 54241

Mr. Glenn A. Reed, Manager
Nuclear Operations
Wisconsin Electric Power Company
Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, Wisconsin 54241

Mr. Gordon Blaha
Town Chairman
Town of Two Creeks
Route 3
Two Rivers, Wisconsin 54241

Ms. Kathleen M. Falk
General Counsel
Wisconsin's Environmental Decade
114 N. Carroll Street
Madison, Wisconsin 53703

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: Regional Radiation
Representative
230 S. Dearborn Street
Chicago, Illinois 60604

Chairman
Public Service Commission of Wisconsin
Hills Farms State Office Building
Madison, Wisconsin 53702



NSIC

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
AUG 19 1981

Docket Nos. 50-266
and 50-301

Mr. Sol Burstein
Executive Vice President
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, Wisconsin 53201

Dear Mr. Burstein:

SUBJECT: TMI TASK PLAN ITEMS II.K.3.9, II.K.3.10 AND II.K.3.12 FOR
POINT BEACH NUCLEAR PLANT UNITS 1 AND 2

Your letters of June 11, 1980, December 23, 1980 and January 19, 1981 indicate that you have taken the actions requested under item II.K.3.9 (PID Controller) of NUREG-0737. This has been verified by the Point Beach Resident Inspector. Therefore, this item is resolved for your facilities.

Your letters also indicate that no increase in the setpoint for the reactor trip on turbine trip is contemplated as this is part of the original plant design, and therefore, item II.K.3.10 is resolved for your facilities. In the future, should you request authorization to raise this setting, the information requested in item II.K.3.10 should be supplied.

Your letters further confirm that Point Beach Units 1 and 2 have an anticipatory reactor trip on turbine trip, in conformance with item II.K.3.12 of NUREG-0737. Therefore, this item is resolved for your facilities.

Sincerely,

for *Charles M. Trammell*
Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

cc: See next page

Wisconsin Electric Power Company

CC:

Mr. Bruce Churchill, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. William Guldemond
USNRC Resident Inspectors Office
6612 Nuclear Road
Two Rivers, Wisconsin 54241

Joseph Mann Library
1516 Sixteenth Street
Two Rivers, Wisconsin 54241

Mr. Glenn A. Reed, Manager
Nuclear Operations
Wisconsin Electric Power Company
Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, Wisconsin 54241

Mr. Gordon Blaha
Town Chairman
Town of Two Creeks
Route 3
Two Rivers, Wisconsin 54241

Ms. Kathleen M. Falk
General Counsel
Wisconsin's Environmental Decade
114 N. Carroll Street
Madison, Wisconsin 53703

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: Regional Radiation
Representative
230 S. Dearborn Street
Chicago, Illinois 60604

Chairman
Public Service Commission of Wisconsin
Hills Farms State Office Building
Madison, Wisconsin 53702

TERA



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

AUG 19 1981

Docket Nos. 50-266
and 50-301

Mr. Sol Burstein
Executive Vice President
Wisconsin Electric Power Company
231 West Michigan Street
Milwaukee, Wisconsin 53201

Dear Mr. Burstein:

SUBJECT: TMI TASK PLAN ITEMS II.K.3.9, II.K.3.10 AND II.K.3.12 FOR
POINT BEACH NUCLEAR PLANT UNITS 1 AND 2

Your letters of June 11, 1980, December 23, 1980 and January 19, 1981 indicate that you have taken the actions requested under item II.K.3.9 (PID Controller) of NUREG-0737. This has been verified by the Point Beach Resident Inspector. Therefore, this item is resolved for your facilities.

Your letters also indicate that no increase in the setpoint for the reactor trip on turbine trip is contemplated as this is part of the original plant design, and therefore, item II.K.3.10 is resolved for your facilities. In the future, should you request authorization to raise this setting, the information requested in item II.K.3.10 should be supplied.

Your letters further confirm that Point Beach Units 1 and 2 have an anticipatory reactor trip on turbine trip, in conformance with item II.K.3.12 of NUREG-0737. Therefore, this item is resolved for your facilities.

Sincerely,

for *Charles M. Trammell*
Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

cc: See next page

Wisconsin Electric Power Company

cc:

Mr. Bruce Churchill, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. William Guldmond
USNRC Resident Inspectors Office
6612 Nuclear Road
Two Rivers, Wisconsin 54241

Joseph Mann Library
1516 Sixteenth Street
Two Rivers, Wisconsin 54241

Mr. Glenn A. Reed, Manager
Nuclear Operations
Wisconsin Electric Power Company
Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, Wisconsin 54241

Mr. Gordon Blaha
Town Chairman
Town of Two Creeks
Route 3
Two Rivers, Wisconsin 54241

Ms. Kathleen M. Falk
General Counsel
Wisconsin's Environmental Decade
114 N. Carroll Street
Madison, Wisconsin 53703

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: Regional Radiation
Representative
230 S. Dearborn Street
Chicago, Illinois 60604

Chairman
Public Service Commission of Wisconsin
Hills Farms State Office Building
Madison, Wisconsin 53702