

## LICENSEE EVENT REPORT

CONTROL BLOCK 

1	2	3	4	5	6	7	8
---	---	---	---	---	---	---	---

 (S)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[0 1] M [1] PIA [L 1] [2] [0] [0] - [0] [0] [0] [0] - [0] [0] [3] [4] [1] [1] [1] [4] [5] [6]  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 32

CONT

[0 1] REPORT SOURCE [L 6] [0] [5] [0] [0] [0] [2] [5] [5] [7] [0] [1] [7] [2] [5] [8] [1] [8] [0] [1] [8] [2] [5] [8] [1] [7] [Q]  
7 8 9 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0 2] While performing plant startup checklist G CL 1, it was determined that the  
[0 3] LPSI pump suction valves (from SIRW tank) were closed; additionally, the  
[0 4] LPSI suction valves (from PCS) were open. The former pair of valves were  
[0 5] identified on G CL 1; however, the latter two were not. They were identified  
[0 6] as being mispositioned by the operator performing the CL. The two open  
[0 7] valves did not render the LPSI pumps inoperable, but could have increased  
[0 8] the potential for common-mode failure of LPSI pumps.

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE	REVISION NO.
[1 9]	[L 1] [2] [11]	[D 12]	[Z 13]	[Z 14]	[Z 15]	[Z 16]
7 8 9	9 10	11	12	13	14	15
17	LER PC REPORT NUMBER	EVENT YEAR	SEQUENTIAL REPORT NO.	OCCURRENCE CODE	REPORT TYPE	
21	[8 1]	[8 1]	[0 13] [1]	[10 13]	[L 14]	
22	23	24	25	26	27	28
29	30	31	32	33	34	35
33	34	35	36	37	38	39
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	ATTACHMENT SUBMITTED	NPRC FORM SUB
[L 18]	[Z 19]	[Z 20]	[Z 21]	[0 0] [0] [0]	[N 23]	[N 24]
33	34	35	36	37	38	39
40	41	42	43	44	45	46
47						

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[1 9] Misalignment occurred during the previous performance of a CL (CL 3.2) to  
[1 1] align the LPSI pumps for normal operation. CL 3.2 had incorrectly indentified  
[1 2] the valve positions. The error in CL 3.2 was introduced during a previous  
[1 3] revision and was clerical in nature. Admin controls for revision CLs  
[1 4] will be changed to require proofreading by originator of revision.

FACILITY STATUS	% POWER	OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION	LOCATION OF RELEASE
[1 5]	[G 28]	[0 0] [0] [29]	[NA]	[LA 31]	Observation by operator
7 8 9	10 11 12 13	14	45	46	47
ACTIVITY CONTENT	RELEASED / RELEASE	AMOUNT OF ACTIVITY			
[1 6]	[Z 33]	[Z 34]	[NA]		
7 8 9	10 11	12 13	44	45	46
47					

PERSONNEL EXPOSURES NUMBER	TYPE	DESCRIPTION	
[1 7]	[L 31] [2 32]	[Z 33]	NA
7 8 9	10 11 12 13	14	45

PERSONNEL INJURIES NUMBER	DESCRIPTION	
[1 8]	[L 31] [2 32]	NA
7 8 9	10 11 12	45

LOSS OF OR DAMAGE TO FACILITY TYPE	DESCRIPTION	
[1 9]	[L 42]	NA
7 8 9	10 11	45

PUBLICITY ISSUED DESCRIPTION		NRC USE ONLY
[1 10]	[L 44]	NA
7 8 9	10 11	45 46