Docket Nos.: STN 50-482, STN 50-483

and

Mr. J. K. Bryan Vice President Union Electric Company Post Office Box 149 St. Louis, Missouri 63166

Dear Gentlemen:

Subject: Design and Construction QA Program

Docket File RHartfield, MPA SEP 1 1981 LB#1 Rdg WJohnston DEisenhut OELD BJYoungblood OIE (3) MRushbrook RTedesco bcc: STN 50-486 RVollmer TERA NSIC TMurley NRC/PDR TIC RMattson L/PDR ACRS (16) Mr. Glenn L. Koester Vice President - Nuclear Kansas Gas and Electric Company 201 North Market Street Wichita, Kansas 67201

Dist.

Please find attached our request for additional information regarding Revision 3 of the SNUPPS QA Program for Design and Construction. Any questions you have may be directed to Dr. C. E. Edison, Licensing Project Manager, at NRC.

Sincerely,

Original signed by: B. J. Youngblood

B. J. Youngblood, Chief Licensing Branch No. 1 Division of Licensing

Attachment: As stated

cc: J. Spraul



## REQUEST FOR ADDITIONAL INFORMATION

## Callaway & Wolf Creek QA for Design & Construction

## 1. SNUPPS General -

Figures 17A.1-1 and 17A.1-2 indicate that TPO has been eliminated and the Bechtel Power Corporation has been formed. However, Figure 17A.1-3 and Section 17A.1.1.1 still refer to TPO. Figure 17A.1-6 shows MF&QCS supporting TPO, and there is no indication on the figures where the MF&QCS Department reports. Also, Figure 17A.1-10 refers to TPO quality policies, and Section 17A.1.1.2 discusses TPO. Clarify.

- Callaway The two new paragraphs at the top of page 17.1-5 assign quality assurance activities to "utility technical support personnel" and to the Manager, Nuclear Engineering. Discuss the involvement of Union Electric's Quality Assurance organization in these activities.
- 3. Callaway The changes on page 17.1-9 change the responsibilities for preoperational testing from the Plant Superintendent to the Manager, Nuclear Construction, and the corresponding QA program from operating (per FSAR) to design and construction (per Post-CP information). Discuss the involvement of the Plant Superintendent, his staff, and the Operations QA Group in the preoperational test program.
- 4. Callaway The new paragraph on page 17.1-28 assigns responsibilities to the site QA group leader. It appears this should be the Superintendent, Site QA. Clarify.
- 5. Wolf Creek Item f on page 17B-6 indicates the Daniel Construction Manager is responsible to "Disposition nonconforming items." What are the QA controls applicable to this activity?

Mr. Glenn L. Koester Vice President - Operations kansas Gas & Electric Company 201 North Market Street Wichita, Kansas 67201

cc: Mr. Nicholas A. Petrick
Executive Director, SNUPPS
5 Choke Cherry Road
Rockville, Maryland 20850

Gerald Charnoff, Esq. Shaw, Pittman, Potts, Trowbridge & Madden 1800 M Street, N. W. Washington, D. C. 20036

Mr. Donald T. McPnee Vice President Kansas City Power & Light Company 1330 Baltimore Avenue Kansas City, Missouri 64141

James T. Wiglesworth, Esc. 9800 Metcalf Suite 400 General Square Center Overland Park, Kansas 66212

Mr. William H. Griffin, Esq. Assistant Attorney General State of Kansas State House Topeka, Kansas 66612

Mr. John M. Wylie II Energy Reporter Kansas City Star 1729 Grand Kansas City, Missouri 64108

Mr. Gary Haden Wichita Eagle & Beacon Box A-20 Wichita, Kansas 67201 John Halzer, Esq.
Law Offices of Ralph Foster
Kansas Gas / Electric Company
P. O. Box 20%
Wichita, Kansas 67201

William H. Ward, Esq. MACEA 5130 Miss on Road Shawnee Mission, Kansas 66205 cc: Mr. Nicholas A. Petrick
Executive Director - SNUPPS
5 Choke Cherry Road
Rockville, Maryland 20850

Gerald Charnoff, Esq. Shaw, Pittman, Potts, Trowbridge & Madden 1800 M Street, N.W. Washington, D. C. 20036

Mr. J. E. Birk Assistant to the Ceneral Counsel Union Electric Company P. O. Box 149 St. Louis, Missouri 63166

Dr. Vern Starks Route 1, Box 863 Ketchikan, Alaska 99901

Professor Dennis J. Tuchler St. Louis University Law School 3700 Lindell Boulevard St. Louis, Missouri 63101 Ms. Treva Hern , Assistant General Counsel
Missouri Public Service Commission P. O. Box 360
Jefferson City, Missouri 65102