

CONTROL BLOCK:

--	--	--	--	--	--	--

 ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
---	---

REPORT SOURCE

1	6	0	5	0	0	0	3	1	1	7	0	8	0	3	8	1	8	0	8	2	6	8	1	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

DOCKET NUMBER

EVENT DATE

REPORT DATE

On August 3, 1981, No. 22 CSD breaker tripped from an unidentified cause. There were

03 no indicating flags showing on the relays. No. 21 CSD breaker was closed manually.

04 | Action statement 3.8.2.1.a was entered at 1533 hours, August 3, 1981.

0 5 _____

06 _____

07 _____

0	E	
---	---	--

C 9		SYSTEM CODE E B		CAUSE CODE X		CAUSE SUBCODE Z		COMPONENT CODE C K T B R K				COMP SUBCODE A		VALVE SUBCODE Z	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
LER RO REPORT NUMBER		EVENT YEAR		SHUTDOWN METHOD		SEQUENTIAL REPORT NO		OCCURRENCE CODE		REPORT TYPE		REVISION NO		ACTION TAKEN	
17		8 1		—		0 7 9		0 3		L		0		X	
23		24		25		26		27		28		29		30	
FUTURE ACTION		EFFECT ON PLANT		HOURS		ATTACHMENT SUBMITTED		NPRO-4 FORM SUB		PRIME COMP SUPPLIER		COMPONENT MANUFACTURER		31	
X		Z		0 0 0 0		Y		N		L		G 0 8 0		32	
33		34		35		36		37		38		39		40	

10 The cause of the breaker trip is still undetermined. It is being investigated.

1 1 The immediate corrective action was to manually close the No. 21 CSD breaker. At

1 2 | 1542 hours, August 3, 1981, action statement 3.8.2.1.a was terminated.

1	3	Previous similar occurrence: 81-71.
---	---	-------------------------------------

1 4

8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)

1 5 E (28) 0 7 5 (29) N/A A (31) Loss of vital bus. (32)

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 2 33 2 34 NA

7 8 9 10 11

AMOUNT OF ACTIVITY (35)

NA

LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES			
NUMBER	TYPE	DESCRIPTION	
1 7	0 0 0 (37) 2 (38)	NA	

		11	12	13	
		PERSONNEL INJURIES			
		NUMBER	DESCRIPTION		
1	H	0	0	40	NA

		7		8		9		10		11		12		
						LOSS OF OR DAMAGE TO FACILITY								
						TYPE						DESCRIPTION		
1	9	Z	(42)	NA										(43)

7 8 9 10
PUBLICITY
ISSUED DESCRIPTION (45)
2 0 N (44) NA
R 9 10
NRC USE ONLY

PHONE 609-935-5100

NRC USE ONLY