

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C M G S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 23 28 LICENSE TYPE 30 37 CAT 38

CON'T

01 1 5 0 5 0 0 0 3 6 9 7 0 8 1 4 8 1 8 0 8 3 1 5 1 9

REPORT SOURCE 50 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 On 8/17/81, it was discovered that during the Zero Power Physics Test Program,

03 the reactor was started up(changed from mode 3 to mode 2) on 8/14 and again on

04 8/16/81 with train "B" of the Control Area Ventilation(VC) System inoperable.

05 This violates TS 3.0.4 which is reportable per TS 6.9.1.12(f). Since the outside

06 air filters on train "B" of VC were functional throughout the incident as veri-

07 fied by subsequent testing, train "B" was actually functional and the health

08 and safety of the public were not affected.

09

10 S I G 11 A 12 A 13 F I L T E R 14 Z 15 Z 16

SYSTEM CODE 9 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP SUBCODE 14 VALVE SUBCODE 15

17 18 1 2 7 0 1 T 0

LER/RO REPORT NUMBER 21 22 SEQUENTIAL REPORT NO. 24 25 OCCURRENCE CODE 26 REPORT TYPE 27 REVISION NO. 28

X 18 H 19 Z 20 Z 21 0 0 0 0 Y 22 N 23 L 24 Z 25 9 9 9 9 26

ACTION TAKEN 29 FUTURE ACTION 30 EFFECT ON PLANT 31 SHUTDOWN METHOD 32 HOURS 33 ATTACHMENT SUBMITTED 34 NRC FORM SUB. 35 PRIME COMP SUPPLIER 36 COMPONENT MANUFACTURER 37

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The incidents were caused by Operations personnel misinterpreting the Technical

11 Specifications to mean that the inoperable VC train would not prevent a mode

12 change. All Operations personnel will be cautioned to read and interpret Tech-

13 nical Specifications carefully. Personnel will also be encouraged to evaluate

14 decisions independently and not be swayed by the opinions of others.

15

16 X 28 0 0 0 0 29 Mode 2 30 A 31 Personnel observation 32

FACILITY STATUS 33 % POW 34 OTHER STATUS 35 METHOD OF DISCOVERY 36 DISCOVERY DESCRIPTION 37

17 Z 32 Z 34 N/A 35 N/A 36

ACTIVITY CONTENT 38 RELEASED OR RELEASE 39 AMOUNT OF ACTIVITY 40 LOCATION OF RELEASE 41

18 0 0 0 37 Z 38 N/A 39

PERSONNEL EXPOSURES 42 NUMBER 43 TYPE 44 DESCRIPTION 45

19 0 0 0 40 N/A 41

PERSONNEL INJURIES 46 NUMBER 47 DESCRIPTION 48

20 0 0 0 42 N/A 43

LOSS OF OR DAMAGE TO FACILITY 49 TYPE 50 DESCRIPTION 51

21 Z 42 N/A 43

PUBLICITY 52 ISSUED 53 DESCRIPTION 54

22 N 44 N/A 45

NAME OF PREPARER Phillip B. Nardoci

PHONE: (704) 373-7432

NRC USE ONLY

810909570