

INSTALLATION & SERVICE ENGINEERING DIVISION

UNIT I PSI REPORT UPDATE

June 4, 1981

TABLE OF CONTENTS

<u>SECTION</u>	<u>VOLUME</u>	<u>DESCRIPTION</u>	<u>STATUS</u>
6.3	3	Receiving Inspection Report RIR-007	RR
10.2.1	4	GEL-1094 Page 1 Rev. 2	RR
		GEL-1095 Page 1 Rev. 2	RR
		1-NIR Page 6 Rev. 3	RR
10.3.1	4	IHP-PU Page 1 Rev. 4	RR
		IHP-PU Page 2 Rev. 1	RR
10.3.2	4	ILP-PU Page 1 Rev. 2	RR
		I_P-PU Page 2 Rev. 1	RR
10.3.3	4	IRH-PU1A Page 1 Rev. 3	RR
		IRH-PU1A Page 2 Rev. 3	RR
		IRH-PU1B Page 1 Rev. 3	RR
		IRH-PU1B Page 2 Rev. 3	RR
		IRH-PU1C Page 1 Rev. 2	RR
		IRH-PU1C Page 2 Rev. 1	RR
10.4.8	5	IRH-1023 Page 1 Rev. 2	RR
11.3	5	Noncomformity Report 1NCR-106	A
12.1.1	6	Calibration Data Sheet A100 Page 1	RR
		Calibration Data Sheet A102 Page 1	RR
		Calibration Data Sheet A102 Page 3	RR
		Calibration Data Sheet A104 Page 1	RR
		Calibration Data Sheet A104 Page 4	RR
		Calibration Data Sheet A107B Page 1	RR
		Calibration Data Sheet A107B Page 3	RR
		Calibration Data Sheet A107B Page 4	RR
		Calibration Data Sheet A110 Page 1	RR
		Calibration Data Sheet A112 Page 1	RR
		Calibration Data Sheet A114 Page 1	RR
		Calibration Data Sheet A116 Page 1	RR
		Calibration Data Sheet A116 Page 3	RR
		Calibration Data Sheet A121 Page 1	RR
		Calibration Data Sheet A125 Page 1	RR
		Calibration Data Sheet A125 Page 3	RR
		Calibration Data Sheet A128 Page 1	RR
		Calibration Data Sheet A128 Page 3	RR
		Calibration Data Sheet A136 Page 1	RR
		Calibration Data Sheet A136 Page 3	RR
		Calibration Data Sheet A136 Page 4	RR
		Calibration Data Sheet A138 Page 1	RR
		Calibration Data Sheet A138 Page 3	RR
		Calibration Data Sheet A140 Page 1	RR
		Calibration Data Sheet A140 Page 4	RR
		Calibration Data Sheet A143 Page 1	RR
		Calibration Data Sheet A143 Page 4	RR
		Calibration Data Sheet A143 Page 5	RR

8109150438 810901
PDR ADDCK 05000373
PDR

INSTALLATION & SERVICE ENGINEERING DIVISION

UNIT I PSI REPORT UPDATE

June 4, 1981

TABLE OF CONTENTS

<u>SECTION</u>	<u>VOLUME</u>	<u>DESCRIPTION</u>	<u>STATUS</u>
12.1.1	6	Calibration Data Sheet A145 Page 1	RR
		Calibration Data Sheet A147 Page 1	RR
		Calibration Data Sheet A149 Page 1	RR
		Calibration Data Sheet A151 Page 1	RR
		Calibration Data Sheet A151 Page 5	RR
		Calibration Data Sheet A153 Page 1	RR
		Calibration Data Sheet A153 Page 3	RR
		Calibration Data Sheet A155 Page 1	RR
		Calibration Data Sheet A157 Page 1	RR
		Calibration Data Sheet A157 Page 3	RR
		Calibration Data Sheet A157 Page 4	RR
		Calibration Data Sheet A162 Page 1	RR
		Calibration Data Sheet A165 Page 1	RR
		Calibration Data Sheet A169 Page 1	RR
		Calibration Data Sheet A169 Page 3	RR
		Calibration Data Sheet A172 Page 1	RR
		Calibration Data Sheet A172 Page 3	RR
		Calibration Data Sheet A172 Page 5	RR
		Calibration Data Sheet A176 Page 1	RR
		Calibration Data Sheet A176 Page 3	RR
		Calibration Data Sheet A178 Page 1	RR
		Calibration Data Sheet A181 Page 1	RR
		Calibration Data Sheet A186 Page 1	RR
		Calibration Data Sheet A188 Page 1	RR
		Calibration Data Sheet A188 Page 2	RR
		Calibration Data Sheet A188 Page 3	RR
		Calibration Data Sheet A191 Page 1	RR
		Calibration Data Sheet 84660	A
		Examination Data Sheet 84661	A
		Examination Data Sheet 84662	A
		Linearity Data Sheet 93029	A
		Calibration Data Sheet 93030	A
		Examination Data Sheet 93031	A
		Examination Data Sheet 93032	A
		Evaluation Sheet for 93032	A
		PSI Ref. No. RPV-13 Pages 1 through 7	A
12.2.1	8	Examination Data Sheet 40123	RR
12.2.1	9	Examination Data Sheet 77617	A
		Examination Data Sheet 77618	A
		Calibration Data Sheet 77619	A
		Examination Data Sheet 77620	A
		Evaluation Sheet for 77620	A
		Examination Data Sheet 77621	A

INSTALLATION & SERVICE ENGINEERING DIVISION

UNIT I PSI REPORT UPDATE

June 4, 1981

TABLE OF CONTENTS

<u>SECTION</u>	<u>VOLUME</u>	<u>DESCRIPTION</u>	<u>STATUS</u>
12.2.1	9	Evaluation Sheets for 77621 (2 sheets)	A
		Examination Data Sheet 77622	A
		Evaluation Sheet for 77622	A
		Examination Data Sheet 77623	A
		Evaluation Sheet for 77623	A
12.2.1	10	Examination Data Sheet 84512	RR
		Examination Data Sheet 84520 Page 1-3	A
12.2.1	11	Examination Data Sheet 91032 Page 4	RR
		Calibration Data Sheet 92283	A
		Examination Data Sheet 92284	A
		Calibration Data Sheet 92285	A
		Examination Data Sheet 92286	A
		Evaluation Sheet for 92286	A
		Examination Data Sheet 92287	A
		Evaluation Sheets for 92287 (2 sheets)	A
		Examination Data Sheet 92288 Pages 1-2	A
		Evaluation Sheet for 92288	A
		Calibration Data Sheet 92289	A
		Examination Data Sheet 92290	A
		Calibration Data Sheet 92291	A
		Examination Data Sheet 92292	A
		Calibration Data Sheet 92293	A
		Examination Data Sheet 92294	A
		Examination Data Sheet 92295	A
		Examination Data Sheet 92400	A
		Calibration Data Sheet 92401	A
		Examination Data Sheet 92402	A
		Calibration Data Sheet 92403	A
		Examination Data Sheet 92404	A
		Evaluation Sheet for 92404	A
		Examination Data Sheet 92409	A
		Examination Data Sheet 94030	RR



RECEIVING INSPECTION REPORT

RIR No. SIR-007

For Items List No. NA

Line No. NA

PART NO. 1

Project LaSalle #2 PSI Project No. LCS-PC173-2 Purchase Order No. 391NC172-X 3 L²W

Description Glycerine Product Specification & Rev. NA

PART NO. 2 CHARACTERISTICS TO BE INSPECTED:

Prepared by L Wheatley Date 4/10/80

- | | |
|-----------------------------|-----------|
| 1) <u>Quantity</u> | 5) _____ |
| 2) <u>Certification</u> | 7) _____ |
| 3) <u>Markings</u> | 8) _____ |
| 4) <u>Chemical Analysis</u> | 9) _____ |
| 5) _____ | 10) _____ |

PART NO. 3 RECEIVING INSPECTION

Markings Dist Glycerine USP 99.5%

Heat & Lot Or Serial No. DH0307C H041

Characteristics Inspected:		A - Accepted		R - Rejected	
1) <u>55 gal</u>	3) <u>A</u>	5) _____	7) _____	9) _____	
2) <u>A</u>	4) <u>A</u>	6) _____	8) _____	10) _____	

Remarks: (List Characteristic No. and reason for rejection)

Nonconformities:

Is Component or Appurtenance Code-Stamped Yes No Inspected By LQ Wheatley Date 4/10/80

PART NO. 4 RECEIVING VERIFICATION

	Yes	No	NA
Recorded markings meet the requirements of the Product Spec. _____	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Heat & lot numbers match the Material Certification _____	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Serial Numbers match the Data Reports (Code-stamped items only) _____	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Recorded characteristics meet the requirements of the Product Spec. _____	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Material Certifications and Test Reports meet the requirements of the Product Spec. _____	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Material Certifications and Test Reports accepted by QA/QC Supervisor (owner purchased items only) _____	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Date Reports acceptable (Code-stamped items only) _____	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Verified by LQ Wheatley Date 4/10/80

Reviewed by AI _____ Date _____

INSPECTION CHECKLIST

LASALLE COUNTY STATION UNIT #

IC NO. GEL-094 REV. 2

PAGE 1 of 1

REVIEWED AND APPROVED BY:

Q.C. SUPERVISOR DD Wootley DATE 4/30/81

SIZE	EXAM COMP ID NO	DWG. REV. NO.	ASME CAT	COMP FIG	PROCEDURE NO.	REV. NO.	EXAM TYPE	EDS NO.	CDS NO.	LSCS CAL STD. NO.	LDS NO.	Q.C. REVIEW SIGNATURE/DATE	AI INIT/DATE
00	01	02	03	04	05	06	07	08	09	10	11	12	13
N/A	GEL-1094-N8	0	B-F	N-F	2	7	PT	97098				<u>DD Wootley 4/30/81</u>	<u>WJC</u>
					1	6	UT-00	77436	77435	01-91-08	0036		
					1	6	UT-450	77438	77437	01-91-08	0038		

INSPECTION CHECKLIST

LASALLE COUNTY STATION UNIT 1

IC NO. GEL-1095 REV. 2

PAGE 1 of 1

REVIEWED AND APPROVED BY:

Q.C. SUPERVISOR R.D. Whentley DATE 4/30/81

SIZE	EXAM COMP ID NO	DMG. REV. NO. 02	ASME CAT 03	COMP FIG 04	PROCEDURE NO. 05	REV. NO. 06	EXAM TYPE 07	EDS NO. 08	CDS NO. 09	LSCS CAL STD. NO. 10	LDS NO. 11	Q.C. REVIEW SIGNATURE/DATE 12	AI INIT/DATE 13
N/A	GEL-1095-N7	0	B-F	N-F	2 1 1	7 6 6	PT UT-00 UT-45	77098 77436 77437	77435 77437	01-91-08 01-91-08	0036 0038	<u>R.D. Whentley</u> 4/30/81	<u>w.j. Caldwell</u> 4-30-81
N/A	GEL-1095-N18	0	B-F	N-F	2 1 1	7 6 6	PT UT-00 UT-45	77098 77436 77438	77435 77437	01-91-08 01-91-08	0036 0038	<u>R.D. Whentley</u> 4/30/81	<u>w.j.c</u> 4-30-81

INSPECTION CHECKLIST
LASALLE COUNTY STATION UNIT 1

IC NO. 1-NIR REV. 3

PAGE 6 of 7

REVIEWED AND APPROVED BY:

Q.C. SUPERVISOR L. D. Wheatley DATE 4/15/81

SIZE 00	EXAM COMP ID NO 01	DWG. REV. NO. 02	ASME CAT 03	COMP FIG 04	PROCEDURE NO. 05	REV. NO. 06	EXAM TYPE 07	EDS NO. 08	CDS NO. 09	LSCS CAL STD. NO. 10	LDS NO. 11	Q.C. REVIEW SIGNATURE/DATE 12	AI INIT/DATE 13
N/A	1-NIR-6C	0	B-D	NIR	13 13 16 16	0 0 0 0	Z1CW Z1CCW Z2CW Z2CCW	97005 45523 16020 16020	97000 45500 16017 16017	MP-1 MP-1 MP-1 MP-1	N/A N/A N/A N/A	L. D. Wheatley 4/15/81	ref 4-15-81
N/A	1-NIR-9A	0	B-D	NIR	13 13 17	0 0 0	Z1CW Z1CCW Z2	45520 45520 84661	45517 45519 84660	MP-1 MP-1 01-91-04	N/A N/A 84660	L. D. Wheatley 4/24/81	w g c 5-11-81
N/A	1-NIR-9B	0	B-D	NIR	13 13 17	0 0 0	Z1CW Z1CCW Z2	45521 45521 84662	45517 45519 84660	MP-1 MP-1 01-91-04	N/A N/A 84660	L. D. Wheatley 4/24/81	w g c 5-11-81
N/A	1-NIR-10	0	B-D	NIR	13 13 16 16	0 0 0 0	Z1CW Z1CCW Z2CW Z2CCW	97018 97018 16016 16016	97017 97017 16015 16015	MP-1 MP-1 MP-1 MP-1	N/A N/A N/A N/A	L. D. Wheatley 4/15/81	ref 4-15-81
N/A	1-NIR-16	0	B-D	NIR	13 13 16 16	0 0 0 0	Z1CW Z1CCW Z2CW Z2CCW	97001 45502 73007 73007	97000 45500 73005 73005	MP-1 MP-1 MP-1 MP-1	N/A N/A N/A N/A	L. D. Wheatley 4/15/81	ref 4-15-81

INSPECTION CHECKLIST

LASALLE COUNTY STATION UNIT 1

IC NO. IHP-PU REV. 4

PAGE 1 of 2

REVIEWED AND APPROVED BY:

Q.C. SUPERVISOR L.D. Wheatley DATE 4/30/81

SIZE 00	EXAM COMP ID NO 01	DWG. REV. NO. 02	ASME CAT 03	COMP FIG 04	PROCEDURE NO. 05	REV. NO. 06	EXAM TYPE 07	EDS NO. 08	CDS NO. 09	LSCS CAL STD. NO. 10	LDS NO. 11	Q.C. REVIEW SIGNATURE/DATE 12	AI INIT/DATE 13
14"	IHP-PU-1	0	C-F	E-F	2 1 1	6 6 6	PT UT-0° UT-45°	97054 93272 93274	93271 93273	01-70-04 01-70-04	0053 0054	L.D. Wheatley 4/30/81	wjc 4-30-81
6"	IHP-PU-2	0	C-F	P-E	2 1 1	6 6 6	PT UT-0° UT-45°	97054 93272 93274	93271 93273	01-70-04 01-70-04	0053 0054	L.D. Wheatley 4/30/81	wjc 4-30-81
14"	IHP-PU-3	0	C-F	PL-E	2 1 1	6 6 6	PT UT-0° UT-45°	97054 93272 93274	93271 93273	01-70-04 01-70-04	0053 0054	L.D. Wheatley 4/30/81	wjc 4-30-81
36"	IHP-PU-4	0	C-F	PL-SH	2	7	PT			N/A		Inaccessible See RI-17	
24"	IHP-PU-5	0	C-F	P-SH	2 1 1	6 5 5	PT UT-0° UT-45°	97054 77281 77284	77279 77282	01-24-02 01-24-02	0034 0028	L.D. Wheatley 4/30/81 Partial Exams due to Inaccessibility	wjc 4-30-81
24"	IHP-PU-6	0	C-F	P-F	2 1 1	7 5 5	PT UT-0° UT-45°	97054 77281 77284	77279 77282	01-24-02 01-24-02	0034 0028	Partial Exams due to Inaccessibility	
36"	IHP-PU-7A	0	C-F	PULS	2 1 1	7 6 6	PT UT-0° UT-45°					Inaccessible See RI-17	
36"	IHP-PU-7B	0	C-F	PULS	2 1 1	7 6 6	PT UT-0° UT-45°					Inaccessible See RI-17	

INSPECTION CHECKLIST
 LASALLE COUNTY STATION UNIT 1

IC NO. IHP-PU REV. 1
 PAGE 2 of 2

REVIEWED AND APPROVED BY:

Q.C. SUPERVISOR [Signature] DATE 4/30/81

SIZE	EXAM COMP ID NO	DMG. REV. NO. 02	ASME CAT 03	COMP FIG 04	PROCEDURE NO. 05	REV. NO. 06	EXAM TYPE 07	EDS NO. 08	CDS NO. 09	LSCS CAL STD. NO. 10	LDS NO. 11	Q.C. REVIEW SIGNATURE/DATE 12	AI INIT/DATE 13
00	01												
36"	IHP-PU-7C	0	C-F	PULS	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IHP-PU-8A	0	C-F	SH-SH	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IHP-FU-8B	0	C-F	SH-SH	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IHP-PU-8C	0	C-F	HD-SH	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
6"	IHP-PU-9	0	C-F	HD-SP	2	7	PT					Inaccessible See RI-17	

INSPECTION CHECKLIST
LASALLE COUNTY STATION UNIT 1

IC NO. ILP-PU REV 2

PAGE 1 of 2

REVIEWED AND APPROVED BY:

Q.C. SUPERVISOR L.D. Wheatley DATE 4/30/81

SIZE	EXAM COMP ID NO	DWG. REV. NO. 02	ASME CAT 03	COMP FIG 04	PROCEDURE NO. 05	REV. NO. 06	EXAM TYPE 07	EDS NO. 08	CDS NO. 09	LSCS CAL STD. NO. 10	LDS NO. 11	Q.C. REVIEW SIGNATURE/DATE 12	AI INIT/DATE 13
00	01												
14"	ILP-PU-1	0	C-F	P-F	2 1 1	6 6 6	PT UT-0° UT-45°	97054 77275 77278				L.D. Wheatley 4/30/81	w j c 4-30-81
6"	ILP-PU-2	0	C-F	P-E	2 1 1	6 5 6	PT UT-0° UT-45°	97054 94446 94453	77274 94445 94452	01-14-03 01-06-03 01-06-03	0027 0016 0016	L.D. Wheatley 4/30/81	w j c 4-30-81
6"	ILP-PU-2	0	C-F	P-E	2 1 1	6 6 6	PT UT-0° UT-45°	97054 77275 77278				L.D. Wheatley 4/30/81	w j c 4-30-81
14"	ILP-PU-3	0	C-F	PL-E	2 1 1	6 6 6	PT UT-0° UT-45°	97054 77275 77278				L.D. Wheatley 4/30/81	w j c 4-30-81
36"	ILP-PU-4	0	C-F	PL-SH	2	6	PT			N/A		Inaccessible See RI-17	
24"	ILP-PU-5	0	C-F	P-SH	2 1 1	6 6 6	PT UT-0° UT-45°	97054 77280 77285				L.D. Wheatley 4/30/81 Partial Exams due to Inaccessibility	w j c 4-30-81
24"	ILP-PU-6	0	C-F	P-F	2 1 1	6 6 6	PT UT-0° UT-45°	97054 77280 77285	77279 77282	01-24-02 01-24-02	0034 0028	L.D. Wheatley 4/30/81 Partial Exams due to Inaccessibility	w j c 4-30-81
36"	ILP-PU-7	0	C-F	SH-SH	2 1 1	6 5 5	PT UT-0° UT-45°					Inaccessible See RI-17	

INSPECTION CHECKLIST

LASALLE COUNTY STATION UNIT 1

IC NO. ILP-PU REV. 1

PAGE 2 of 2

REVIEWED AND APPROVED BY:

Q.C. SUPERVISOR DD Dally DATE 4/30/81

SIZE	EXAM COMP ID NO	DWG. REV. NO.	ASME CAT	COMP FIG	PROCEDURE NO.	REV. NO.	EXAM TYPE	EDS NO.	CDS NO.	LSCS CAL STD. NO.	LDS NO.	Q.C. REVIEW SIGNATURE/DATE	AI INIT/DATE
00	01	02	03	04	05	06	07	08	09	10	11	12	13
36"	ILP-PU-8	0	C-F	SH-HD	2 1 1	6 5 5	PT UT-00 UT-450					Inaccessible See RI-17	
6"	ILP-PU-9	0	C-F	HD-SP	2	6	PT			N/A		Inaccessible See RI-17	

INSPECTION CHECKLIST
LASALLE COUNTY STATION UNIT 1

IC NO. IRH-PU1A REV. 3

PAGE 1 of 2

REVIEWED AND APPROVED BY:

Q.C. SUPERVISOR L.D. Wheatley DATE 4/30/81

SIZE 00	EXAM COMP ID NO 01	DWG. REV. NO. 02	ASME CAT 03	COMP FIG 04	PROCEDURE NO. 05	REV. NO. 06	EXAM TYPE 07	EDS NO. 08	CDS NO. 09	LSCS CAL STD. NO. 10	LDS NO. 11	Q.C. REVIEW SIGNATURE/DATE 12	AI INIT/DATE 13
14"	IRH-PU1A-1	0	C-F	E-F	2 1 1	5 4 4	PT UT-0° UT-45°	91153 91155 91163	91154 91161	01-14-03 01-14-03	0010 0010	L.D. Wheatley 4/30/81	w j C 4-30-81
6"	IRH-PU1A-2	0	C-F	P-E	2 1 1	5 4 4	PT UT-0° UT-45°	91153 91157 91161	91156 91160	01-06-03 01-06-03	0010 91160	L.D. Wheatley 4/30/80	w j C 4-30-81
6"	IRH-PU1A-2	0	C-F	P-E	2 1 1	5 4 4	PT UT-0° UT-45°	91153 91155 91163	91154 91161	01-14-03 01-14-03	0010 0010	L.D. Wheatley 4/30/81	w j C 4-30-81
14"	IRH-PU1A-3	0	C-F	PL-E	2 1 1	5 4 4	PT UT-0° UT-45°	91153 91155 91163	91154 91161	01-14-03 01-14-03	0010 0010	L.D. Wheatley 4/30/81	w j C 4-30-81
36"	IRH-PU1A-4	0	C-F	PL-SH	2	7	PT					Inaccessible See RI-17	
24"	IRH-PU1A-5	0	C-F	P-SH	2 1 1	5 4 4	PT UT-0° UT-45°	91150 91152 91158	91151 91158	01-24-02 01-24-02	0010 0010	L.D. Wheatley 4/30/81 Partial Exams Due to Inaccessibility	w j C 4-30-81
24"	IRH-PU1A-6	0	C-F	P-F	2 1 1	5 4 4	PT UT-0° UT-45°	91150 91152 91159	91151 91158	01-24-02 01-24-02	0010 0010	L.D. Wheatley 4/30/81 Partial Exams Due to Inaccessibility	w j C 4-30-81
36"	IRH-PU1A-7A	0	C-F	PULS	2 1 1	7 6 6	PT UT-0° UT-45°					Inaccessible See RI-17	

GENERAL ELECTRIC

INSTALLATION & SERVICE ENGINEERING DIVISION

INSPECTION CHECKLIST

LASALLE COUNTY STATION UNIT 1

IC NO. IRH-PU1A REV. 3

PAGE 2 of 2

REVIEWED AND APPROVED BY:

[Signature]

Q.C. SUPERVISOR

DATE 4/30/81

SIZE	EXAM COMP ID NO	DWG. REV. NO. 02	ASME CAT 03	COMP FIG 04	PROCEDURE NO. 05	REV. NO. 06	EXAM TYPE 07	EDS NO. 08	CDS NO. 09	LSCS CAL STD. NO. 10	LDS NO. 11	Q.C. REVIEW SIGNATURE/DATE 12	AI INIT/DATE 13
00	01												
36"	IRH-PU1A-7B	0	C-F	PULS	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IRH-PU1A-7C	0	C-F	PULS	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IRH-PU1A-8A	0	C-F	SH-SH	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IRH-PU1A-8B	0	C-F	SH-SH	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IRH-PU1A-8C	0	C-F	SH-HD	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
6"	IRH-PU1A-9	0	C-F	HD-SP	2	7	PT					Inaccessible See RI-17	

INSPECTION CHECKLIST
LASALLE COUNTY STATION UNIT 1

IC NO. IRH-PU1B REV. 3

PAGE 1 of 2

REVIEWED AND APPROVED BY:

Q.C. SUPERVISOR L.D. D'Heathley DATE 4/30/81

SIZE	EXAM COMP ID NO	DWG. REV. NO. 02	ASME CAT 03	COMP FIG 04	PROCEDURE NO. 05	REV. NO. 06	EXAM TYPE 07	EDS NO. 08	CDS NO. 09	LSCS CAL STD. NO. 10	LDS NO. 11	Q.C. REVIEW SIGNATURE/DATE 12	AI INIT/DATE 13
14"	IRH-PU1B-1	0	C-F	E-F	2 1 1	5 4 4	PT UT-00 UT-450	5351 91135 91141	91134 91140	01-14-03 01-14-03	0010 0013	L.D. D'Heathley 4/30/81	wjc 4-30-81
6"	IRH-PU1B-2	0	C-F	P-E	2 1 1	5 4 4	PT UT-00 UT-450	91133 91137 91144	91136 91143	01-06-03 01-06-03	0010 0009	L.D. D'Heathley 4/30/81	wjc 4-30-81
6"	IRH-PU1B-2	0	C-F	P-E	2 1 1	5 4 4	PT UT-00 UT-450	91133 91135 91141	91134 91140	01-14-03 01-14-03	0013 0010	L.D. D'Heathley 4/30/81	wjc 4-30-81
14"	IRH-PU1B-3	0	C-F	PL-E	2 1 1	5 4 4	PT UT-00 UT-450	91133 91135 91142	91134 91140	01-14-03 01-14-03	0010 0010	L.D. D'Heathley 4/30/81	wjc 4-30-81
36"	IRH-PU1B-4	0	C-F	PL-SH	2	7	PT					Inaccessible See RI-17	
24"	IRH-PU1B-5	0	C-F	P-SH	2 1 1	5 4 4	PT UT-00 UT-450	91147 91146 91149	91145 91148	01-24-02 01-24-02	0010 0009	L.D. D'Heathley 4/30/81 Partial Exams Due to Inaccessibility	wjc 4-30-81
36"	IRH-PU1B-6	0	C-F	P-F	2 1 1	5 4 4	PT UT-00 UT-450	91133 91137 91149	91138 91148	01-24-02 01-24-02	0010 0009	L.D. D'Heathley 4/30/81 Partial Exams Due to Inaccessibility	wjc 4-30-81
36"	IRH-PU1B-7A	0	C-F	PULS	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	

INSPECTION CHECKLIST
LASALLE COUNTY STATION UNIT 1

IC NO. IRH-PU1B REV 3

PAGE 2 of 2

REVIEWED AND APPROVED BY:

Q.C. SUPERVISOR *[Signature]* DATE 4/30/81

SIZE	EXAM COMP ID NO	DWG. REV. NO.	ASME CAT	COMP FIG	PROCEDURE NO.	REV. NO.	EXAM TYPE	EDS NO.	CDS NO.	LSCS CAL STD. NO.	LDS NO.	Q.C. REVIEW SIGNATURE/DATE	AI INIT/DATE
00	01	02	03	04	05	06	07	08	09	10	11	12	13
36"	IRH-PU1B-7B	0	C-F	PULS	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IRH-PU1B-7C	0	C-F	PULS	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IRH-PU1B-8A	0	C-F	SH-SH	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IRH-PU1B-8B	0	C-F	SH-S	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IRH-PU1B-8C	0	C-F	SH-HD	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
6"	IRH-PU1B-9	0	C-F	HD-SP	2	7	PT					Inaccessible See RI-17	

INSPECTION CHECKLIST

LASALLE COUNTY STATION UNIT 1

IC NO. IRH-PUIC REV. 2

PAGE 1 of 2

REVIEWED AND APPROVED BY:

Q.C. SUPERVISOR L.W. Whalley DATE 4/30/81

SIZE	EXAM COMP ID NO	DWG. REV. NO. 02	ASME C-T C3	COMP FIG 04	PROCEDURE NO. 05	REV. NO. 06	EXAM TYPE 07	EDS NO. 08	CDS NO. 09	LSCS CAL STD. NO. 10	LDS NO. 11	Q.C. REVIEW SIGNATURE/DATE 12	AI INIT/DATE 13
14"	IRH-PUIC-1	1	C-F	E-F	2 1 1	6 6 6	PT UT-0° UT-45°	97056 77275 77277				L.W. Whalley 4/30/81	W J. Caldwell 4-30-81
6"	IRH-PUIC-2	1	C-F	P-E	2 1 1	6 5 6	PT UT-0° UT-45°	97056 94446 94453				L.W. Whalley 4/30/81	W J. Caldwell 4-30-81
14"	IRH-PUIC-2	1	C-F	P-E	2 1 1	6 6 6	PT UT-0° UT-45°	97056 77275 77277				L.W. Whalley 4/30/81	W J. Caldwell 4-30-81
14"	IRH-PUIC-3	1	C-F	PL-E	2 1 1	6 6 6	PT UT-0° UT-45°	97056 77275 77277				L.W. Whalley 4/30/81	W J. Caldwell 4-30-81
36"	IRH-PUIC-4		C-F	PL-SH	2	7	PT					Inaccessible See RI-17	
24"	IRH-PUIC-5	1	C-F	P-SH	2 1 1	6 6 6	PT UT-0° UT-45°	97056 77281 77283				L.W. Whalley 4/30/81 Partial Exams Due to Inaccessibility	W J. Caldwell 4-30-81
24"	IRH-PUIC-6	1	C-F	P-F	2 1 1	6 6 6	PT UT-0° UT-45°	97056 77281 77284				L.W. Whalley 4/30/81 Partial Exams Due to Inaccessibility	W J. Caldwell 4-30-81
36"	IRH-PUIC-7A	1	C-F	PULS	2 1 1	7 6 6	PT UT-0° UT-45°					Inaccessible See RI-17	

INSPECTION CHECKLIST
LASALLE COUNTY STATION UNIT 1

IC NO. IRH-PUIC REV. 1

PAGE 2 of 2

REVIEWED AND APPROVED BY:

Q.C. SUPERVISOR L. D. King DATE 4/30/61

SIZE	EXAM COMP ID NO	DMG. REV. NO. 02	ASME CAT 03	COMP FIG 04	PROCEDURE NO. 05	REV. NO. 06	EXAM TYPE 07	EDS NO. 08	CUS NO. 09	LSCS CAL STD. NO. 10	LDS NO. 11	Q.C. REVIEW SIGNATURE/DATE 12	AI INIT/DATE 13
36"	IRH-PUIC-7B	1	C-F	PULS	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IRH-PUIC-7C	1	C-F	PULS	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IRH-PUIC-8A	1	C-F	SH-SH	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IRH-PUIC-8B	1	C-F	SH-SH	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
36"	IRH-PUIC-8C	1	C-F	SH-HD	2 1 1	7 6 6	PT UT-00 UT-450					Inaccessible See RI-17	
9"	IRH-PUIC-9	1	C-F	HD-SP	2	7	PT					Inaccessible See RI-17	

INSPECTION CHECKLIST
LASALLE COUNTY STATION UNIT 1

IC NO. IRH-1023 REV. 2

PAGE 1 of 1

REVIEWED AND APPROVED BY:

Q.C. SUPERVISOR L D Wheatley DATE 3/29/81

SIZE	EXAM COMP ID NO	DWG. REV. NO.	ASME CAT	COMP FIG	PROCEDURE NO.	REV. NO.	EXAM TYPE	EDS NO.	CDS NO.	LSCS CAL STD. NO.	LDS NO.	Q.C. REVIEW SIGNATURE/DATE	AI INIT/DATE
00	01	02	03	04	05	06	07	08	09	10	11	12	13
18"	IRH-1023-2	0	C-F	E-P	2 1 1	7 6 6	PT UT-0° UT-45°	77617 92290 77622	92284 77619	01-18-01 01-18-01	0065 0064	L D Wheatley 4/30/81	wjc 5-11-81
18"	IRH-1023-4A	0	C-F	P-E	2 1 1	7 6 6	PT UT-0° UT-45°	77614 92290 77621	92284 77619	01-18-C. 01-18-01	0065 0064	L D Wheatley 4/13/81 #NCR-106	wjc 5-13-81
18"	IRH-1023-7	0	C-F	E-P	2 1 1	7 6 6	PT UT-0° UT-45°	77614 92290 77620	92284 77619	01-18-01 01-18-01	0065 0064	L D Wheatley 4/30/81	wjc 5-11-81
18"	IRH-1023-8	0	C-F	P-E	2 1 1	7 6 6	PT UT-0° UT-45°	77614 92284 92286	92283 92285	01-18-01 01-18-01	0064 0062	L D Wheatley 4/23/81	wjc 5-11-81
18"	IRH-1023-9	0	C-F	E-P	2 1 1	7 6 6	PT UT-0° UT-45°	77614 92284 92287	92283 92285	01-18-01 01-18-01	0064 0062	L D Wheatley 4/23/81	wjc 5-11-81
18"	IRH-1023-14	0	C-F	P-E	2 1 1	7 6 6	PT UT-0° UT-45°	77613 92290 77623	92284 77619	01-18-01 01-18-01	0065 0064	L D Wheatley 4/23/81	wjc 5-11-81
18"	IRH-1023-16	0	C-F	E-P	2 1 1	7 6 6	PT UT-0° UT-45°	77613 92284 92288	92283 92285	01-18-01 01-18-01	0065 0062	L D Wheatley 4/23/81	wjc 5-11-81

NONCONFORMITY REPORT

REVISION NO. 0

Project La Salle I PSI Report No. INCR-106

Initiated By L.W. Wheatley Date 4/2/81

Project No. LCS-PO173-1 Drawing No. IRH-1023

Item, Assembly Joint No. Weld IRH-1023-4A

Heat & Lot, Serial No. (if applicable) NA

Identity Record No. Nonconformity Noted (Traveler, RIR, Item List UT, RT Report, etc.) No. EDS 77616

Description of Nonconformity

Minimum wall violations caused during removal of PT indications. See enclosed EDS 77616 for details.

Proposed Resolution

RESOLUTION PER CECD ENGINEERING

Signature [Signature] Date 4/2/81


Comments

See EDS 92295, 92406, 92408 For re-examination after weld repair.

Resolution Approved By [Signature] Date 4/2/81

Reviewed with ANI By [Signature] Date 5-11-81

Completed [Signature] Date 5/11/81



REVISIONS		MORRISON CONSTRUCTION CO.	
NO.	DATE	BY	REVISION

1010 1/2 1/2 1/2 1/2 1/2 1/2 1/2 131 1/2 1/2 1/2 1/2 1/2 1/2 1/2 1100-1100-1100-1100-1100-1100-1100-1100 COMMONWEALTH EDISON CO. LA SALLE COUNTY ILLINOIS 62411 INSERVICE INSPECTION RESIDUAL HEAT REMOVAL SYSTEM	I-RH-1023 MORRISON CONSTRUCTION CO. ILLINOIS
--	--

FOR CONT SEE
I-RH-1024

LASALLE COUNTY NUCLEAR STATION
 U.T. CALIBRATION FORM

FORM # 77615
 DATE 3-27-81

EXAMINER CAH LEVEL II DATA TAKER NA LEVEL NA
 INSTRUMENT MODEL CL 202 SER# 801203
 TRANSDUCER SIZE .25 FREQ. NA MH₇ SERIAL NO. A28031
 CALIBRATION STD. CSC-1/CS Step Wedge MATERIAL CS
 COUPLANT Glycerine INITIAL CALIBRATION TIME 1243

(CALIBRATION DATA)

STANDARD THICKNESS	INSTRUMENT READING
1.486	1.486
1.253	1.254
.755	.755
.500	.501
.300	.302
.200	.202

CAL. VERIFICATION TIMES:

Final Cal. Check: 1535

- Gain
- Sweep
- Delay
- Filter
- Rep. Rate
- Dampening
- Reject
- Digital Range
- Calibrate
- Velocity

INSTRUMENT START	SETTINGS: FINISH
<u>2330</u>	<u>2330</u>

NDE Sup
SD Connolly 3/30/81
2902 Whitey 4/2/81 GE-QC

EXAMINATION DATA FORM

EXAM FORM # 77616

CAL. FORM # 77615


DATE 3-27-81

EXAMINER Chamber LEVEL II DATA TAKEN NA LEVEL NA

MATERIAL THICKNESS	1/ .687	2/ .618	3/ .596	4/ .671
PIT GAUGE READINGS	5/ .464			
REMAINING WALL THK.				

WELD NO. IRH-1023-4A NOMINAL PIPE THICKNESS 0.57
 NCR. NO. INCR-106 MINIMUM WALL 0.499

EXCAVATION LOCATED T.D.C



MATERIAL THICKNESS				
PIT GAUGE READINGS				
REMAINING WALL THK.				

WELD NO. _____ NOMINAL PIPE THICKNESS _____
 NCR. NO. _____ MINIMUM WALL _____

*NDF Says
 S. D. Sweeney
 3/30/81
 R. W. Whalley 4/2/81 GE-QC*

INSTALLATION & SERVICE ENGINEERING DIVISION

LASALLE COUNTY NUCLEAR STATION UNIT 1

A. PROCEDURE NO. PP-S751 REV. 7

B. EXAMINATION PERSONNEL:

NAME [Signature] LEVEL II

NAME [Signature] LEVEL II

C. PENETRANT MATERIALS:

- a. MANUFACTURER MAGNAFLUX-SPOTCHECK
- b. PRE-CLEANING SOLVENT TYPE SKC-S BATCH NO. 79C014
- c. PENETRANT TYPE SKL-HF /SKL-S BATCH NO. 79B109
- d. PENETRANT REMOVER TYPE SKC-S BATCH NO. 79C014
- e. DEVELOPER TYPE SKD-S BATCH NO. 79E033
- f. POST EXAMINATION CLEANER TYPE SKC-S BATCH NO. 79C014

D. PRE-EXAMINATION REQUIREMENTS:

a. TEMPERATURE:

- 1. PENETRANT MATERIALS BETWEEN 60° F & 125° F - YES NO
- 2. COMPONENT SURFACE BETWEEN 60° F & 125° F - YES NO

b. SURFACE PREPARATION:

- *1. GRINDING *2. FLAPPERING *3. NONE *4. OTHER

E. DATA: NOTE: All Exam components are ASME Sect. XI Category. C-F

LINE NO.	DATE	02 PRE-CLEAN EVAP. TIME	03 PEN. DWELL TIME	04 PEN. REM. EVAP. TIME	05 DEV. TIME	06 EXAMINATION COMPONENT I.D. NO.	07 MAT'L	08 SURF. PREP. #	RELEVANT INDICATION		ACCEPTABLE		RELEVANT INDICATION LOCATION/SIZE OR COMMENTS
									09 YES	10 NO	11 YES	12 NO	
1	4-28	5	10	5	15	IRH-1008-23	CS	2		X	X		
2	4-28	5	10	5	15	IRH-1023-4A	CS	2		X	X		INSPECT 5" EACH SIDE TDC-REPAIR AREA
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													

NOTE: FOR EACH EXAM COMPONENT ID NO., PLACE THE APPLICABLE NUMBER(S) (1,2,3 etc) IN ITS APPROPRIATE COLUMN.

REVIEWED BY: NCE SUPERVISOR [Signature] DATE 4/29/81
 QC SUPERVISOR [Signature] DATE 5/1/81
 AUTHORIZED INSPECTOR [Signature] DATE 5-11-81

INSTALLATION & SERVICE ENGINEERING DIVISION

A. Procedure No. MPUP-5751 REV. 6

B. Examination Personnel NAME John Williams LEVEL IT NAME ME Williams LEVEL IT

C. Instrument SERIAL NO. 1348 MAKE/MODEL: - BRANSON/303: SONIC/MK I KK/USL32 OTHER

D. Search Unit BEAM ANGLE/MODE: STRAIGHT BEAM/LONG WAVE 45°/TRANS WAVE 60°/TRANS WAVE
 TRANSDUCER SIZE/FREQ: 0.25" DIA/2.25 MHz 0.5" DIA/2.25 MHz 1.0" DIA/2.25 MHz
 SERIAL NO.: A22010 1.0" DIA/2.25 MHz 0.5"x0.5"/2.25 MHz
 TRANSDUCER TYPE: CERAMIC SINGLE ELEMENT CERAMIC DUAL ELEMENT OTHER
 WEDGE TYPE: STANDARD WEDGE SPECIAL WEDGE/TYPE
 CALCULATED BEAM ANGLE IN MATERIAL: $\theta_2 = 0^\circ$

E. Cable LENGTH 6 FT. TYPE: RG-58 RG-59 RG-57 RG-174 OTHER

F. Calibration Orientation: CALIBRATION REFERENCE REFLECTOR: PARALLEL TRANSVERSE TO PIPE AXIS
 FOR DUAL ELEMENT: SPLIT FOR MAXIMUM RESPONSE PARALLEL TRANSVERSE to hole center

G. Calibration Standard: LSCS CAL STD. NO. CF-15-01 THICKNESS .57" DIAMETER 15"
 MATERIAL: CARBON STAINLESS INCONEL OTHER


H. Couplant GLYCERINE ULTRAGEL OTHER

I. Comments

J. Dac Curve - Data

REFLECTOR	PEAK AMP	W1	Wm	W2	MP1	MPm	MPz	HOLE DEPTH
dB	dB	dB	dB	dB	dB	dB	dB	dB
WT of 1/8 Vee								
WT of 1/8 Vee	50?					.24		.24
WT of 1/8 Vee								
S.R. of 1/8 Vee	100?					.57		
	+6							

K. Dac Curve - Screen Representation



L. Instrument Settings/Checks

CONTROLS	SET	CHECK BOXES																		
		01	02	03	04	05	06	07	08	09	10									
GAIN	36	-																		
SCAN GAIN	44	-																		
SWEEP	15/6.70	-																		
DELAY	7.52	-																		
FILTER	AUTO	-																		
REP RATE	MED	-																		
PENING	OFF	-																		
REJECT	OFF	-																		
OTHER	NA	-																		

M. Calibration Time - Records

1981 DATE	01 ORIG. CAL TIME	02 CAL CHECK TIME	03 LAST E.D.S. #	04 LAST E.D.S. LINE #	05 VERIFICATION OF 25°F LIMIT (YES/NO)
4-29	1300	NA	NA	NA	YES
4-29	NA	1450	92406	1	YES

N. Reviewed By: NDE SUPERVISOR J.P. Connelly
 Q.C. SUPERVISOR [Signature]
 AUTHORIZED INSPECTOR W.D. [Signature]

DATE 4/30/81
 DATE 5/1/81
 DATE 5-11-81

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP-S751 REV. 6


EXAMINATION PERSONNEL:
 NAME [Signature] LEVEL II; NAME ME Williams LEVEL IT

SEARCH UNIT BEAM ANGLE: 0°: 45°: _____ 60°: _____ OTHER _____

COUPLANT: GLYCERINE: ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION



DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/W1	Lm/Wm	L2/W2	MP1	MPm	MP2	SCAN	STAT.	COMMENTS
1981 4-29	1	IRH-1023 4A	P-E		D .59	CL .63	E .68					A	Scan of Repair Area-5" Each Side of TDC

REVIEWED BY: AD Connelly DATE 4/30/81
 NDE SUPERVISOR _____ DATE 5/1/81
 QC SUPERVISOR L D Whentley DATE 5-11-81
 AUTHORIZED INSPECTOR w J Caldwell DATE _____

INSTALLATION & SERVICE ENGINEERING DIVISION

A. Procedure No. MPOP-5751 REV. 6

B. Examination Personnel NAME J. Williams LEVEL II NAME M.E. Williams LEVEL IT

Instrument SERIAL NO. 521 MAKE/MODEL: - BRANSON/303: SONIC/MK I; KX/USL32 OTHER

D. Search Unit BEAM ANGLE/MODE: STRAIGHT BEAM/LONG WAVE; 45°/TRANS WAVE; 60°/TRANS WAVE
 TRANSDUCER SIZE/FREQ: 0.25" DIA/2.25 MHz; 0.5" DIA/2.25 MHz; 1.0" DIA/2.25 MHz
 SERIAL NO.: 107944; 1.0" DIA/2.25 MHz; 0.5"x0.5"/2.25 MHz
 TRANSDUCER TYPE: CERAMIC SINGLE ELEMENT CERAMIC DUAL ELEMENT OTHER
 WEDGE TYPE: STANDARD WEDGE SPECIAL WEDGE/TYPE
 CALCULATED BEAM ANGLE IN MATERIAL: $\theta_2 = \underline{44.7}^\circ$

E. Cable LENGTH: 6 FT. TYPE: RG-58 RG-59 RG-57 RG-174 OTHER

F. Calibration Orientation: CALIBRATION REFERENCE REFLECTOR: PARALLEL TRANSVERSE TO PIPE AXIS
 FOR DUAL ELEMENT: SPLIT FOR MAXIMUM RESPONSE PARALLEL TRANSVERSE to hole center

G. Calibration Standard: LSCS CAL STD. NO. 01-18-01 THICKNESS .57" DIAMETER 1.8"
 MATERIAL: CARBON STAINLESS INCONEL OTHER


H. Couplant: GLYCERINE ULTRAGEL OTHER

I. Comments: +6 dB = 6/8 V TO 100% DAC

J. Dac Curve - Data

REFLECTOR	PEAK AMP	W1	Wm	W2	MP1	MPm	MPz	HOLE DEPTH
DB	DB	DB	DB	DB	DB	DB	DB	DB
WT of 4/8 Vee	80?		.57			.80		
WT of 5/8 Vee	65?		1.16			1.65		
WT of 1/2 Vee	40?		1.72			2.45		
S.R. of 6/8 Vee	100?		1.87			1.2	.27	

K. Dac Curve - Screen Representation



L. Instrument Settings/Checks

CONTROLS	SET	CHECK BOXES							
		01	02	03	04	05	06	07	08
GAIN	46	/							
SCAN GAIN	54	/							
SWEEP	25/883	/							
DELAY	7.54	/							
FILTER	AUTO	/							
REP RATE	MED	/							
PENING	OFF	/							
REJECT	OFF	/							
OTHER	NA	/							

M. Calibration Time - Records

1981 DATE	01 ORIG. CAL TIME	02 CAL CHECK TIME	03 LAST E.D.S. #	04 LAST E.D.S. LINE #	05 VERIFICATION OF 25% LIMIT (YES/NO)
4-29	1315	NA	NA	NA	YES
4-29	NA	1450	92408	2	YES

N. Reviewed by: NDE SUPERVISOR J. Connelly
 Q.C. SUPERVISOR J. Williams
 AUTHORIZED INSPECTOR M.E. Williams

DATE 4/30/81
 DATE 5/1/81
 DATE 5-11-81

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP-S751 REV. 6


EXAMINATION PERSONNEL:
 NAME [Signature] LEVEL IF; NAME M E Williams LEVEL IT

SEARCH UNIT BEAM ANGLE: 0°: _____ 45°: X 60°: _____ OTHER _____

COUPLANT: GLYCERINE: X ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION



DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/W1	Lm/Wm	L2/W2	MP1	MPm	MP2	SCAN	STAT.	COMMENTS
4-29 1981	1	IRN-1023 4A	P-E	50		INT .5			.85		5B	E	Scan of Repair Area 5" Each Side of FDC
4-29	2	4A	P-E	50		INT .65			1.65		5B	A	FDFT

REVIEWED BY: [Signature] DATE 4/30/81
 NDE SUPERVISOR
 QC SUPERVISOR [Signature] DATE 5/1/81
 AUTHORIZED INSPECTOR [Signature] DATE 5-11-81

LASALLE UNIT 21

$T_p =$.59


WELD IRH-1023-4A

$T_w =$.63

EDS 92408

$T_e =$.68

GENERAL  ELECTRIC



LINE	EVALUATION
1	ID geometry from weld root

EVALUATED BY L W Wheatley
Level III

DATE 5/1/81

REVIEWED BY W J Caldwell
ANII

DATE 5-11-81

UT CALIBRATION DATA SHEET

PAGE 1 DATA A101
 Cal Sheet No. A100

SITE LASALLE I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUN-5751 REV 2 CALIB BLOCK No. 019103
 DATE 10-23-79 COUPLANT H2O CAL STD TEMP 71°
 EXAMINER [Signature] ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 3 45°-6db
60°-7db
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1.0	2.25	5.0	10.0	15	BB
✓				1			
✓				2			
	✓			4			
	✓			8			
	✓			16			

FILTER

1 2 3 4

AMPLITUDE GATE

FLAW GATE LEVEL

119

BACK ECHO LEVEL

439

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA

SERIAL No. H11851 BEAM ANGLE 0

SIZE 1" Ø FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: [Signature]

REP RATE

551

SWEEP DELAY

300

REVIEWED BY [Signature] SNT-TC-1A LEVEL

w. J. Caldwell ANJI MSB
 3-27-81

Data A103

PAGE 1
Cal Sheet No. A102

UT CALIBRATION DATA SHEET

SITE LA SALLE I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUN-SX/REV 2 CALIB BLOCK No. 019103
 DATE 10/26/79 COUPLANT H₂O CAL STD TEMP 70°
 EXAMINER Paul Ramsey ASNT LEVEL II
 RECORDER ~~Flanagan~~ N/A ASNT LEVEL ~~II~~ N/A

EQUIPMENT DATA: INSTRUMENT MODEL No. K3E SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 3 45° = -6
60° = -7
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB			FREQUENCY					
OUT	IN		1.0	2.25	5.0	10.0	15	BB
✓		1	○	⊗	○	○	○	○
✓		2	○	⊗	○	○	○	○
	✓	4						
	✓	8						
	✓	16						

FILTER

1	2	3	4
○	○	⊗	○

AMPLITUDE GATE

FLAW GATE LEVEL

253

BACK ECHO LEVEL

397

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA

SERIAL No. H11851 BEAM ANGLE 0

SIZE 1" Ø FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: P Ramsey

REP RATE

504

SWEEP DELAY

328

R. E. Lind III

REVIEWED BY _____ SNT-TC-1A LEVEL

W. J. Caldwell ANII-MSB
3-27-81

CHANNEL 2 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" Ø FREQUENCY 2.25 MHz
 TRANSDUCER S/N H11851 IIV-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE RG179

HOLE DEPTH "T" INCHES	TRANSIT TIME µsec	MAX AMP
1/4	1.77	15.1
1/2	3.53	30.1
3/4	5.297	45.4

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	ΔTIME	FAR AMPLITUDE	ΔTIME
115:05				
18:49				
		N/A		
F				

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	_____ % FSH	50% FSH	_____ % FSH
90% "	_____ "	40% "	_____ "
80% "	<u>40</u> "	30% "	_____ "
70% "	_____ "	20% "	_____ "
60% "	_____ "		

SEE CHANNEL 10

CONTROL LINEARITY (MADE DAILY)			
80% FSH	-6db	_____	(32-48)
80% "	-12db	_____	(16-24)
40% "	+6db	_____	(64-96)
20% "	+12db	_____	(64-96)

SEE CHANNEL 10

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME
1/4										
1/2										
3/4										

N/A

CHANNEL 10 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" Ø FREQUENCY 2.25 MHz
 TRANSDUCER S/N H11851 IIV-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE RG179

HOLE DEPTH "T" INCHES	TRANSIT TIME µsec	MAX AMP
1/4	1.77	15.0
1/2	3.53	30.1
3/4	5.297	45.3
BE	7.06	57.2
		80

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	ΔTIME	FAR AMPLITUDE	ΔTIME
115:05				
18:49				
		N/A		
F				

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	<u>50</u> % FSH	50% FSH	<u>26</u> % FSH
90% "	<u>46</u> "	40% "	<u>21</u> "
80% "	<u>40</u> "	30% "	<u>16</u> "
70% "	<u>35</u> "	20% "	<u>11</u> "
60% "	<u>30</u> "		

CONTROL LINEARITY (MADE DAILY)			
80% FSH	-6db	<u>39</u>	(32-48)
80% "	-12db	<u>18</u>	(16-24)
40% "	+6db	<u>84</u>	(64-96)
20% "	+12db	<u>84</u>	(64-96)

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME
1/4										
1/2										
3/4										

N/A

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. A104

SITE LA SALLE I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUN-5751 REV 2 CALIB BLOCK No. 019103
 DATE 10-27-79 COUPLANT H₂O CAL STD TEMP 70°
 EXAMINER P. Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22537F
 TRANSDUCER PACKAGE No. 3

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB 45° = -6db 60° = -7db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1	2	4	8	16	BB
✓		1	○	○	○	○	○
✓		2	○	○	○	○	○
	✓	4	○	○	○	○	○
	✓	8	○	○	○	○	○
	✓	16	○	○	○	○	○

FILTER
 1 2 3 4
 ○ ○ ○

AMPLITUDE GATE

FLAW GATE LEVEL

(237)

BACK ECHO LEVEL

(397)

EQUIP DATA - ANGLE BEAM
 FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA

SERIAL No. 411851 BEAM ANGLE 0°

SIZE 1" φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: P. Ramsey

REP RATE

(504)

SWEEP DELAY

(328)

REVIEWED BY _____ SNT-TC-1A LEVEL

W. J. Caldwell ANII- HSB
 3-27-81

UT CALIBRATION DATA SHEET

PAGE 1
Cal Sheet No. A107B

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUN-5751 REV 2 CALIB BLOCK No. 09103¹⁰ 01-91-03
 DATE 10-28-79 COUPLANT H₂O CAL STD TEMP 71°
 EXAMINER R Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 3

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB 45°-6db, 60°-7db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1.0	2.25	5.0	10.0	15	BB
<input checked="" type="checkbox"/>				<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>							
	<input checked="" type="checkbox"/>						
	<input checked="" type="checkbox"/>						
	<input checked="" type="checkbox"/>						

FILTER

1 2 3 4

AMPLITUDE GATE

FLAW GATE LEVEL

261

BACK ECHO LEVEL

397

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.06

TRANSDUCER DATA

SERIAL No. H11857 BEAM ANGLE 0°

SIZE 1" φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: R Ramsey

REP RATE

504

SWEEP DELAY

328

REVIEWED BY R. E. Lind SNT-TC-1A LEVEL

W. J. Caldwell ANII-MSB
3-27-81

CHANNEL 2 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" Ø FREQUENCY 2.25 MHz
 TRANSDUCER S/N H11851 IIW-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE RG179

HOLE DEPTH	TRANSIT TIME	MAX AMP
"T" INCHES	µsec	
1/4	1.77	15.1
1/2	3.53	30.2
3/4	5.30	45.2

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	ΔTIME	FAR AMPLITUDE	ΔTIME
11:38				
15:23				
19:07				
20:51 PRR				
F				

N/A

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	_____ % FSH	50% FSH	_____ % FSH
90% "	_____ "	40% "	_____ "
80% "	<u>40</u> "	30% "	_____ "
70% "	_____ "	20% "	_____ "
60% "	<u>SEE CH 10</u>		

CONTROL LINEARITY (MADE DAILY)		
80% FSH	-6db	_____ (32-48)
80% "	-12db	_____ (16-24)
40% "	+6db	_____ (64-96)
20% "	+12db	_____ (64-96)
<u>SEE CH 10</u>		

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME
1/4										
1/2	<u>N/A</u>									
3/4	<u>N/A</u>									

CHANNEL 10 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" Ø FREQUENCY 2.25 MHz
 TRANSDUCER S/N H11851 IIW-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE RG179

HOLE DEPTH	TRANSIT TIME	MAX AMP
"T" INCHES	µsec	
1/4	1.77	15.1
1/2	3.53	30.2
3/4	5.30	45.2
BE	7.06	60.1

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	ΔTIME	FAR AMPLITUDE	ΔTIME
11:38				
15:23				
19:07				
F				

N/A

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	<u>50</u> % FSH	50% FSH	<u>26</u> % FSH
90% "	<u>48</u> "	40% "	<u>21</u> "
80% "	<u>41</u> "	30% "	<u>16</u> "
70% "	<u>36</u> "	20% "	<u>11</u> "
60% "	<u>30</u> "		

CONTROL LINEARITY (MADE DAILY)		
80% FSH	-6db	<u>38</u> (32-48)
80% "	-12db	<u>18</u> (16-24)
40% "	+6db	<u>84</u> (64-96)
20% "	+12db	<u>88</u> (64-96)

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME
1/4										
1/2	<u>N/A</u>									
3/4	<u>N/A</u>									

UT CALIBRATION DATA SHEET

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUN-5751 REV 2 CALIB BLOCK No. 019103
 DATE 10-30-79 COUPLANT H2O CAL STD TEMP 71°
 EXAMINER P Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KB1 SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 376

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)
45°-6db 45°-7db
60°-7db 60°-6db

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1.0	2.25	5.0	10.0	15	BB
✓				1			
✓				2			
	✓			4			
	✓			8			
	✓			16			

FILTER

1 2 3 4

AMPLITUDE GATE

FLAW GATE LEVEL

237

BACK ECHO LEVEL

397

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.06

TRANSDUCER DATA

SERIAL No. H11851 BEAM ANGLE 0°
 SIZE 1" φ FREQ 2.25
 SHOE No. N/A CABLE No. 2
 CHECK MADE BY: P Ramsey

REP RATE

538

SWEEP DELAY

328

REVIEWED BY P. S. Lind III

SNT-TC-1A LEVEL

w. J. Caldwell ANII-MSB
3-27-81

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. A112

SITE LaSalle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APQA-5751 REV 2 CALIB BLOCK No. 019103
 DATE 10-31-79 COUPLANT H₂O CAL STD TEMP 72°
 EXAMINER Ramsley ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBT SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 3 & 6

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB 45°-6db 60°-7db 65°-7db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION) 60°-6db

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1	2	3	4	8	16
✓		1	2.25	5.0	10.0	15	BB
✓		○	⊗	○	○	○	○
	✓	1	2	3	4	FILTER	
	✓	○	○	⊗	○		
	✓	16					

AMPLITUDE GATE

FLAW GATE LEVEL

237

BACK ECHO LEVEL

397

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.06

TRANSDUCER DATA

SERIAL No. H11851 BEAM ANGLE 0°

SIZE 1" φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: Ramsley

REP RATE

539

SWEEP DELAY

328

REVIEWED BY R.C. [Signature] SNT-TC-1A LEVEL

W. J. Caldwell ANII - HSB
 3-27-81

UT CALIBRATION DATA SHEET

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUV-5751 REV 2 CALIB BLOCK No. 019103
 DATE 11/1/79 COUPLANT H₂O CAL STD TEMP 70°
 EXAMINER Paul Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 326 3 45°-6db 45°-7db
60°-7db 60°-6db
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB			FREQUENCY					
OUT	IN		1.0	2.25	5.0	10.0	15	BB
✓		1	○	○	○	○	○	○
✓		2	○	○	○	○	○	○
	✓	4						
	✓	8						
	✓	16						

FILTER

1 2 3 4

○ ○ ○ ○

AMPLITUDE GATE

FLAW GATE LEVEL

044

BACK ECHO LEVEL

397

EQUIP DATA - ANGLE BEAM
FOR LINEARITY CHECKS

CODE BLOCK T 7.06

TRANSDUCER DATA

SERIAL No. 411851 BEAM ANGLE 0°

SIZE 1" Ø FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: Paul Ramsey

REP RATE

539

SWEEP DELAY

328

REVIEWED BY [Signature] SNT-TC-1A LEVEL

W-J. Caldwell ANII - HSB
3-27-81

UT CALIBRATION DATA SHEET

PAGE 1
Cal Sheet No. A116

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUN-575 REV 2 CALIB BLOCK No. 019103
 DATE 11-3-79 COUPLANT H2O CAL STD TEMP 69
 EXAMINER P. Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22581F
 TRANSDUCER PACKAGE No. 3

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB 45°-6db, 60°-7db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB			FREQUENCY					
OUT	IN		1.0	2.25	5.0	10.0	15	BB
<input checked="" type="checkbox"/>		1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>		2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input checked="" type="checkbox"/>	4	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input checked="" type="checkbox"/>	8	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input checked="" type="checkbox"/>	16	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

FILTER
 1 2 3 4

AMPLITUDE GATE

FLAW GATE LEVEL

(237)

BACK ECHO LEVEL

(397)

EQUIP DATA - ANGLE BEAM
FOR LINEARITY CHECKS

CODE BLOCK T 2.06

TRANSDUCER DATA

SERIAL No. H11851 BEAM ANGLE 0°

SIZE 1" φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: P. Ramsey

REP RATE

(540)

SWEEP DELAY

(328)

REVIEWED BY: [Signature] III

SNT-TC-1A LEVEL

W. J. Caldwell ANII - HSB
3-27-81

CHANNEL 2 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" Ø FREQUENCY 2.25 MHz
 TRANSDUCER S/N H11851 IIV-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE RG179

AMPLITUDE LINEARITY CHECK (MADE DAILY)

100% FSH	_____	% FSH	50% FSH	_____	% FSH
90% "	_____	"	40% "	_____	"
80% "	<u>40</u>	"	30% "	_____	"
70% "	_____	"	20% "	_____	"
60% "	_____	"	_____	_____	"

SEE CH 10

HOLE DEPTH	INCHES	TRANSIT TIME µsec	MAX AMP
1/4	<u>1.77</u>	<u>15.1</u>	<u>80</u>
1/2	<u>3.53</u>	<u>30.2</u>	<u>✓</u>
3/4	<u>5.30</u>	<u>45.5</u>	<u>✓</u>

CALIBRATION CHECKS

TIME	NEAR AMPLI-TUDE	ΔTIME	FAR AMPLI-TUDE	ΔTIME
<u>11:59</u>				
<u>18:59</u>				
<u>22:39</u>				
<u>0206</u>				
F				

N/A

CONTROL LINEARITY (MADE DAILY)

80% FSH	-6db	_____	(32-48)
80% "	-12db	_____	(16-24)
40% "	+6db	_____	(64-96)
20% "	+12db	_____	(64-96)

SEE CH 10

ANGLE BEAM SPREAD AT 1 X 45° OR 60°
(MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)

HOLE DEPTH	TRAILING RAY						LEADING RAY				
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC		
	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME	
1/4											
1/2											
3/4											

N/A

CHANNEL 10 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" Ø FREQUENCY 2.25 MHz
 TRANSDUCER S/N H11851 IIV-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100 TYPE RG179

AMPLITUDE LINEARITY CHECK (MADE DAILY)

100% FSH	<u>52</u>	% FSH	50% FSH	<u>26</u>	% FSH
90% "	<u>45</u>	"	40% "	<u>20</u>	"
80% "	<u>40</u>	"	30% "	<u>15</u>	"
70% "	<u>35</u>	"	20% "	<u>10</u>	"
60% "	<u>30</u>	"			"

HOLE DEPTH	INCHES	TRANSIT TIME µsec	MAX AMP
1/4	<u>1.77</u>	<u>15.1</u>	<u>N/A</u>
1/2	<u>3.53</u>	<u>30.2</u>	<u>✓</u>
3/4	<u>5.30</u>	<u>45.5</u>	<u>✓</u>
<u>BE</u>	<u>7.06</u>	<u>60.4</u>	<u>80</u>

CALIBRATION CHECKS

TIME	NEAR AMPLI-TUDE	ΔTIME	FAR AMPLI-TUDE	ΔTIME
<u>11:59</u>				
<u>18:59</u>				
<u>22:39</u>				
<u>0206</u>				
F				

N/A

CONTROL LINEARITY (MADE DAILY)

80% FSH	-6db	<u>38</u>	(32-48)
80% "	-12db	<u>18</u>	(16-24)
40% "	+6db	<u>34</u>	(64-96)
20% "	+12db	<u>86</u>	(64-96)

ANGLE BEAM SPREAD AT 1 X 45° OR 60°
(MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)

HOLE DEPTH	TRAILING RAY						LEADING RAY				
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC		
	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME	
1/4											
1/2											
3/4											

N/A

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. A121

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUN-57REV 2 CALIB BLOCK No. 019103
 DATE 11-9-79 COUPLANT H₂O CAL STD TEMP 69°
 EXAMINER P Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22857E
 TRANSDUCER PACKAGE No. 3

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB 45°-6db 60°-7db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB			FREQUENCY					
OUT	IN		1.0	2.25	5.0	10.0	15	88
<input checked="" type="checkbox"/>		1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>		2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input checked="" type="checkbox"/>	4	FILTER					
	<input checked="" type="checkbox"/>	8	1	2	3	4		
	<input checked="" type="checkbox"/>	16	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		

AMPLITUDE GATE

FLAW GATE LEVEL

(239)

BACK ECHO LEVEL

(342)

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.06

TRANSDUCER DATA

SERIAL No. H11951 BEAM ANGLE 0°

SIZE 1" φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: P Ramsey

REP RATE

(540)

SWEEP DELAY

(328)

REVIEWED BY R. E. King

SNT-TC-1A LEVEL

W. J. Caldwell ANII - HSB
 3-27-81

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. A125

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUR-575/REV 2 CALIB BLOCK No. 019103
 DATE 11-5-79 COUPLANT H₂O CAL STD TEMP 70°
 EXAMINER Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBT SERIAL No. 22587E
 TRANSDUCER PACKAGE No. 3

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB 45°-6db, 60°-7db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1.0	2.25	5.0	10.0	15	BB
<u>U</u>			<u>1</u>				
<u>U</u>			<u>2</u>				
	<u>L</u>		<u>4</u>				
	<u>L</u>		<u>8</u>				
	<u>L</u>		<u>16</u>				

FILTER

1 2 3 4

AMPLITUDE GATE

FLAW GATE LEVEL

234

BACK ECHO LEVEL

397

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.06

TRANSDUCER DATA

SERIAL No. H11851 BEAM ANGLE 0°

SIZE 1"φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: P Ramsey

REP RATE

540

SWEEP DELAY

328

REVIEWED BY [Signature] SNT-TC-1A LEVEL

W. J. Caldwell ANIS-MSB
 3-27-81

CHANNEL 2 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" Ø FREQUENCY 2.25 MHz
 TRANSDUCER S/N H11851 IIV-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE RG179

HOLE DEPTH "T"	INCHES	TRANSIT TIME µsec	MAX AMP
1/4	1.77	15.1	8
1/2	3.53	30.2	}
3/4	5.30	45.4	

CALIBRATION CHECKS				
TIME	NEAR AMPLI-TUDE	ΔTIME	FAR AMPLI-TUDE	ΔTIME
117.07				
20.52				
23.16				
F				

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	_____ % FSH	50% FSH	_____ % FSH
90% "	_____ " "	40% "	_____ " "
80% "	<u>40</u> " "	30% "	_____ " "
70% "	_____ " "	20% "	_____ " "
60% "	_____ " "		

See CH 10

CONTROL LINEARITY (MADE DAILY)			
80% FSH	-6db	_____	(32-48)
80% "	-12db	_____	(16-24)
40% "	+6db	_____	(64-96)
20% "	+12db	_____	(64-96)

See CH 10

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME
1/4										
1/2										
3/4										

CHANNEL 10 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" FREQUENCY 2.25 MHz
 TRANSDUCER S/N H11851 IIV-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE RG179

HOLE DEPTH "T"	INCHES	TRANSIT TIME µsec	MAX AMP
1/4	1.77	15.1	N/A
1/2	3.53	30.2	}
3/4	5.30	45.4	
<u>RF</u>	<u>7.06</u>	<u>60.2</u>	<u>80</u>

CALIBRATION CHECKS				
TIME	NEAR AMPLI-TUDE	ΔTIME	FAR AMPLI-TUDE	ΔTIME
117.07				
20.52				
23.16				
F				

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	<u>52</u> % FSH	50% FSH	<u>26</u> % FSH
90% "	<u>46</u> " "	40% "	<u>20</u> " "
80% "	<u>41</u> " "	30% "	<u>15</u> " "
70% "	<u>36</u> " "	20% "	<u>10</u> " "
60% "	<u>30</u> " "		

CONTROL LINEARITY (MADE DAILY)			
80% FSH	-6db	<u>38</u>	(32-48)
80% "	-12db	<u>18</u>	(16-24)
40% "	+6db	<u>82</u>	(64-96)
20% "	+12db	<u>86</u>	(64-96)

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME
1/4										
1/2										
3/4										

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. 4128

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUNS-757 REV 2 CALIB BLOCK No. 019103
 DATE 11-6-79 COUPLANT H2O CAL STD TEMP 70°
 EXAMINER Ramsay ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA INSTRUMENT MODEL No. KBI SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 3

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB 45°-6db, 60°-7db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY
OUT	IN	
<input checked="" type="checkbox"/>		1
<input checked="" type="checkbox"/>		2
	<input checked="" type="checkbox"/>	4
	<input checked="" type="checkbox"/>	8
	<input checked="" type="checkbox"/>	16

FREQUENCY: 1.0 2.25 5.0 10.0 15 BB

FILTER: 1 2 3 4

AMPLITUDE GATE

FLAW GATE LEVEL

238

BACK ECHO LEVEL

393

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.06

TRANSDUCER DATA

SERIAL No. H11851 BEAM ANGLE 0°

SIZE 1"φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY Ramsay

REP RATE

340

SWEEP DELAY

328

REVIEWED BY R. S. Kirk III

SNT-TC-1A LEVEL

W J Caldwell ANCI- HSB
 3-27-81

UT CALIBRATION DATA SHEET

PAGE 1
Cal Sheet No. A136

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUV-5751 REV 3 CALIB BLOCK No. 019103
 DATE 11-16-79 COUPLANT H₂O CAL STD TEMP 70°
 EXAMINER Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587 F
 TRANSDUCER PACKAGE No. 12513 45-5 13 45-5
60-5 60-5
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1	2	3	4	5	6
✓		1					
✓		2					
	✓	4					
	✓	8					
	✓	16					

FILTER

1 2 3 4

AMPLITUDE GATE

FLAW GATE LEVEL

237

BACK ECHO LEVEL

376

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.06

TRANSDUCER DATA D03914

SERIAL No. PRR-11857 BEAM ANGLE 0°

SIZE 1"φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: Ramsey

REP RATE

598

SWEEP DELAY

321

REVIEWED BY R. E. Caldwell III

REVIEWED BY _____ SNT-TC-1A LEVEL

W. J. Caldwell ANII- HSB
3-27-81

CHANNEL 2 0° 45° 60° OTHER
 TRANSDUCER SIZE 1"Ø FREQUENCY 2.25 MHz
 TRANSDUCER S/N D03914 IIV-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE R4179

HOLE DEPTH	TRANSIT TIME	MAX AMP
"T" INCHES	µsec	
1/4	1.77 15.1	80
1/2	3.53 30.1	S
3/4	5.30 45.4	

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	Δ TIME	FAR AMPLITUDE	Δ TIME
12:00				
03:59				
F				

N/A

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	_____ % FSH	50% FSH	_____ % FSH
90% "	_____ "	40% "	_____ "
80% "	<u>40</u> "	30% "	_____ "
70% "	_____ "	20% "	_____ "
60% "	_____ "		

SEE CH 10

CONTROL LINEARITY (MADE DAILY)		
80% FSH	-6db	_____ (32-48)
80% "	-12db	_____ (16-24)
40% "	+6db	_____ (64-96)
20% "	+12db	_____ (64-96)

SEE CH 10

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY					LEADING RAY				
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME
1/4										
1/2										
3/4										

N/A

CHANNEL 10 0° 45° 60° OTHER
 TRANSDUCER SIZE 1"Ø FREQUENCY 2.25 MHz
 TRANSDUCER S/N D03914 IIV-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE R4179

HOLE DEPTH	TRANSIT TIME	MAX AMP
"T" INCHES	µsec	
1/4	1.77 15.1	80
1/2	3.53 30.2	S
3/4	5.30 45.4	
BE	7.06 60.2	80

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	Δ TIME	FAR AMPLITUDE	Δ TIME
12:00				
03:59				
F				

N/A

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	<u>50</u> % FSH	50% FSH	<u>26</u> % FSH
90% "	<u>45</u> "	40% "	<u>20</u> "
80% "	<u>40</u> "	30% "	<u>15</u> "
70% "	<u>35</u> "	20% "	<u>10</u> "
60% "	<u>30</u> "		

CONTROL LINEARITY (MADE DAILY)		
80% FSH	-6db	<u>38</u> (32-48)
80% "	-12db	<u>18</u> (16-24)
40% "	+6db	<u>84</u> (64-96)
20% "	+12db	<u>56</u> (64-96)

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY					LEADING RAY				
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME
1/4										
1/2										
3/4										

N/A

CHANNEL 4 0° 45° 60° OTHER
 TRANSDUCER SIZE 1"φ FREQUENCY 2.25 MHZ
 TRANSDUCER S/N K23981 IIV-2 BEAM ANGLE 43°
 CABLE NO. 4 LENGTH 100' TYPE RG179

HOLE DEPTH	TRANSIT TIME	MAX AMP
"T"	INCHES	μsec
1/4	4.77	40.5
1/2	3.53	80.9
3/4	5.30	120.8

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	Δ TIME	FAR AMPLITUDE	Δ TIME
121:00				
03:59				
	N/A			
F				

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	_____ % FSH	50% FSH	_____ % FSH
90% "	_____ " "	40% "	_____ " "
80% "	<u>40</u> " "	30% "	_____ " "
70% "	_____ " "	20% "	_____ " "
60% "	SEE CH 10		

CONTROL LINEARITY (MADE DAILY)		
80% FSH	-6db _____	(32-48)
80% "	-12db _____	(16-24)
40% "	+6db _____	(64-96)
20% "	+12db _____	(64-96)
SEE CH 10		

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME
1/4	1.5	34.9	1.65	37.0	2.0	40.5	2.15	42.5	2.2	42.9
1/2	3.45	76.0	3.55	77.6	3.85	80.9	4.2	84.8	4.3	85.8
3/4	5.2	115.0	5.35	117.3	5.8	120.8	6.1	125.3	6.4	127.8

CHANNEL 5 0° 45° 60° OTHER
 TRANSDUCER SIZE 1"φ FREQUENCY 2.25 MHZ
 TRANSDUCER S/N K23982 IIV-2 BEAM ANGLE 59°
 CABLE NO. 5 LENGTH 100' TYPE RG179

HOLE DEPTH	TRANSIT TIME	MAX AMP
"T"	INCHES	μsec
1/4	1.77	55.5
1/2	3.53	110.6
3/4	5.30	167.8

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	Δ TIME	FAR AMPLITUDE	Δ TIME
121:00				
03:59				
	N/A			
F				

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	_____ FSH	50% FSH	_____ % FSH
90% "	_____ " "	40% "	_____ " "
80% "	<u>40</u> " "	30% "	_____ " "
70% "	_____ " "	20% "	_____ " "
60% "	SEE CH 10		

CONTROL LINEARITY (MADE DAILY)		
80% FSH	-6db _____	(32-48)
80% "	-12db _____	(16-24)
40% "	+6db _____	(64-96)
20% "	+12db _____	(64-96)
SEE CH 10		

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME
1/4	2.6	47.8	2.9	52.1	3.2	55.5	3.4	58.9	3.5	59.9
1/2	5.7	102.3	5.8	104.9	6.45	110.6	7.0	119.6	7.2	122.7
3/4	8.7	156.2	9.0	160.5	9.5	167.8	10.0	173.2	10.2	175.6

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. A138

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUV-5751 REV 3 CALIB BLOCK No. 019103
 DATE 11-17- COUPLANT H₂O CAL STD TEMP 71°
 EXAMINER PK Ramsey ASNT LEVEL II
 RECORDER _____ ASNT LEVEL _____

EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 12 & 13 12 13
45-5 45-5
60-5 60-5

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY				
OUT	IN	1.0	2.25	10.0	15	BB
✓						1
✓						2
	✓					4
	✓					8
	✓					16

FILTER

1 2 3 4

AMPLITUDE GATE

FLAW GATE LEVEL

238

BACK ECHO LEVEL

388

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA

SERIAL No. D03914 BEAM ANGLE 0°

SIZE 1"φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: PK Ramsey

REP RATE

597

SWEEP DELAY

321

REVIEWED BY PK Ramsey SNT-TC-1A LEVEL

W J Caldwell ANCI-753
 3-27-81

CHANNEL 2 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" d FREQUENCY 2.25 MHz
 TRANSDUCER S/N D03914 IIV-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE RG179

HOLE DEPTH	TRANSIT TIME	MAX AMP
"T" INCHES	μsec	
1/4	1.77	80
1/2	3.53	30.2
3/4	5.30	45.2

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	Δ TIME	FAR AMPLITUDE	Δ TIME
120:17				
00:24				
F				

N/A

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	% FSH	50% FSH	% FSH
90%"	"	40%"	"
80%"	40	30%"	"
70%"		20%"	"
60%"			

SEE CH 10

CONTROL LINEARITY (MADE DAILY)			
80% FSH	-6db		(32-48)
80%"	-12db		(16-24)
40%"	+6db		(64-96)
20%"	+12db		(64-96)

SEE CH 10

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME
1/4										
1/2										
3/4										

N/A

CHANNEL 10 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" FREQUENCY 2.25 MHz
 TRANSDUCER S/N D03914 IIV-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE RG-179

HOLE DEPTH	TRANSIT TIME	MAX AMP
"T" INCHES	μsec	
1/4	1.77	N/A
1/2	3.53	30.2
3/4	5.30	45.4
BE	7.06	60.2
		80

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	Δ TIME	FAR AMPLITUDE	Δ TIME
120:17				
00:24				
F				

N/A

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	% FSH	50% FSH	% FSH
90%"	52	40%"	26
80%"	46	30%"	21
70%"	FR 41	20%"	16
60%"	36		11
	3		

CONTROL LINEARITY (MADE DAILY)			
80% FSH	-6db	38	(32-48)
80%"	-12db	18	(16-24)
40%"	+6db	82	(64-96)
20%"	+12db	84	(64-96)

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME
1/4										
1/2										
3/4										

N/A

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. A140

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUV-5751 REV 3 CALIB BLOCK No. 019103
 DATE 11-18-79 COUPLANT H₂O CAL STD TEMP 70°
 EXAMINER P Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. K81 SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 12#13 12 13
45-5 45-5
60-5 60-5
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB			FREQUENCY					
OUT	IN		1.0	2.25	5.0	10.0	15	BB
✓		1	○	⊗	○	○	○	○
✓		2						
	✓	4						
	✓	8						
	✓	16						

FILTER

1 2 3 4

○ ○ ⊗ ○

AMPLITUDE GATE

FLAW GATE LEVEL

237

BACK ECHO LEVEL

387

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.06

TRANSDUCER DATA

SERIAL No. D03914 BEAM ANGLE 0°

SIZE 1"φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: P Ramsey

REP RATE

597

SWEEP DELAY

321

REVIEWED BY [Signature]

SNT-TC-1A LEVEL

w-j. Caldwell ANEI - HSB
3-27-81

UT CALIBRATION DATA SHEET

PAGE 1
 Cal Sheet No. A193 ^{PRE}

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUV-5751 REV 3 CALIB BLOCK No. 019103
 DATE 11-19-79 COUPLANT H2O CAL STD TEMP 71°
 EXAMINER P Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. K81 SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 12813 ¹² 45°-5db ¹³ 45°-5db
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB 60°-5db 60°-5db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1.0	2.25	5.0	10.0	15	BB
✓				1			
✓				2			
	✓			4			
	✓			8			
	✓			16			

FILTER

1	2	3	4
<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>

AMPLITUDE GATE

FLAW GATE LEVEL

(239)

BACK ECHO LEVEL

(389)

EQUIP DATA - ANGLE BEAM
 FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA

SERIAL No. D03914 BEAM ANGLE 0°
 SIZE 1"Ø FREQ 2.25
 SHOE No. N/A CABLE No. 2
 CHECK MADE BY: P Ramsey

REP RATE

(598)

SWEEP DELAY

(321)

REVIEWED BY P. G. [Signature]

SNT-TC-1A LEVEL

W. J. Caldwell ASES - HSB
 3-27-81

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. A145

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUV-5757 REV 3 CALIB BLOCK No. 019103
 DATE 11-29-79 COUPLANT 420 CAL STD TEMP 71°
 EXAMINER P. Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. K81 SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 12^d13 ¹² 45°-5db ¹³ 45°-5db
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB 60°-5db 60°-5db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1.0	2.25	5.0	10.0	15	BB
✓							
✓							
	✓						
	✓						
	✓						

FILTER

1	2	3	4
		✓	

AMPLITUDE GATE

FLAW GATE LEVEL

(239)

BACK ECHO LEVEL

(374)

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7062

TRANSDUCER DATA

SERIAL No. D03914 BEAM ANGLE 0°

SIZE 1" φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: P. Ramsey

REP RATE

(597)

SWEEP DELAY

(321)

REVIEWED BY [Signature] SNT-TC-1A LEVEL

W. J. Caldwell ANII - HSB
3-27-81

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. A147

SITE LA SALLE T PREOPERATIONAL INSERVICE
 PROCEDURE No. APUV-S751 REV 3 CALIB BLOCK No. 019103
 DATE 11-30-80 COUPLANT H₂O CAL STD TEMP 62°
 EXAMINER P. RAMSEY ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 12 & 13
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB ¹² 45°-5db ¹³ 45°-5db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION) 60°-5db 60°-5db

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1.0	2.25	5.0	10.0	15	BB
✓			1	○	○	○	○
✓			2	○	○	○	○
	✓		4				
	✓		8				
	✓		16				

FILTER

1 2 3 4

○ ○ ○ ○

AMPLITUDE GATE

FLAW GATE LEVEL

239

BACK ECHO LEVEL

374

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA

SERIAL No. 203914 BEAM ANGLE 0°

SIZE 1" φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: P. RAMSEY

REP RATE

597

SWEEP DELAY

321

REVIEWED BY P. Ramsey SNT-TC-1A LEVEL

w-g. Cahill ANII- HSB
3-27-81

UT CALIBRATION DATA SHEET

SITE La Salle I PRE OPERATIONAL IN SERVICE
 PROCEDURE No. APUJ-5751 REV 3 CALIB BLOCK No. 019103
 DATE 12-1-79 COUPLANT H₂O CAL STD TEMP 61°
 EXAMINER P. Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA INSTRUMENT MODEL No. NB1 SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 12413

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)
 45° - 5db 13 45° - 5db
 60° - 5db 60 - 5db

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1.0	2.25	5.0	10.0	15	BB
✓		○	⊗	○	○	○	○
✓							
	✓						
	✓						
	✓						
	✓						

FILTER
 1 2 3 4
 ○ ○ ⊗ ○

AMPLITUDE GATE

FLAW GATE LEVEL
 (239)

BACK ECHO LEVEL
 (374)

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA
 SERIAL No. D03914 BEAM ANGLE 0°
 SIZE 1" φ FREQ 2.25
 SHOE No. N/A CABLE No. 2
 CHECK MADE BY P. Ramsey

REP RATE SWEEP DELAY

(594) (321)

REVIEWED BY K. E. [Signature] SNT-TC-1A LEVEL

W. J. Caldwell ANEI - HSB
 3-30-81

UT CALIBRATION DATA SHEET

PAGE 1
Cal Sheet No. A151

SITE LA SALLE I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUV-S751 REV 3 CALIB BLOCK No. 019103
 DATE 12-2-79 COUPLANT H₂O CAL STD TEMP 61°
 EXAMINER P. RAMSEY ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 12 & 13
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

12 13
 45° - 5db 45° - 5db
 60° - 5db 60° - 5db

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1	2	3	4	5	6
✓		1	○	○	○	○	○
✓		2	○	○	○	○	○
	✓	4	○	○	○	○	○
	✓	8	○	○	○	○	○
	✓	16	○	○	○	○	○

FILTER
 1 2 3 4
 ○ ○ ○

AMPLITUDE GATE

FLAW GATE LEVEL

239

BACK ECHO LEVEL

374

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA

SERIAL No. D03914 BEAM ANGLE 0°

SIZE 1" Ø FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: P. Ramsey

REP RATE

597

SWEEP DELAY

321

REVIEWED BY [Signature] SNT-TC-1A LEVEL

w. j. Calhoun ANII- MSB
 3-30-81

TEST CALIBRATION DATA SHEET

PAGE 1
Cal Sheet No. A153

SITE LA SALLE I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUV-5751 REV 3 CALIB BLOCK No. 019103
 DATE 12-3-79 COUPLANT H2O CAL STD TEMP 62°
 EXAMINER Paul Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 12 & 13 ¹² 45°-5db ¹³ 45°-5db
60°-5db 60°-5db
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB			FREQUENCY					
OUT	IN		1.0	2.25	5.0	10.0	15	BB
✓		1	○	○	○	○	○	○
✓		2	○	○	○	○	○	○
	✓	4						
	✓	8						
	✓	16						

FILTER

1 2 3 4

○ ○ ○ ○

AMPLITUDE GATE

FLAW GATE LEVEL

238

BACK ECHO LEVEL

374

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA

SERIAL No. 203714 BEAM ANGLE 0°

SIZE 1" Ø FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: Paul Ramsey

REP RATE

597

SWEEP DELAY

321

REVIEWED BY [Signature] SNT-TC-1A LEVEL

w. j. Caldwell ANII - HSB
3-30-81

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. A155

SITE Fa Falls I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUN 3757 REV 3 CALIB BLOCK No. 019103
 DATE 12-4-79 COUPLANT H₂O CAL STD TEMP 64°
 EXAMINER P Ramsey ASNT LEVEL IT
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587E
 TRANSDUCER PACKAGE No. 11 45-5db
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB 60-5db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB			FREQUENCY					
OUT	IN		1.0	2.25	5.0	10.0	15	BB
✓		1	○	⊙	○	○	○	○
✓		2	○	○	○	○	○	○
	✓	4	○	○	○	○	○	○
	✓	8	○	○	⊙	○	○	○
	✓	16	○	○	○	○	○	○

FILTER
 1 2 3 4
 ○ ○ ⊙ ○

AMPLITUDE GATE

FLAW GATE LEVEL

(239)

BACK ECHO LEVEL

(374)

EQUIP DATA - ANGLE BEAM
 FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA

SERIAL No. 411851 BEAM ANGLE 0°

SIZE 1" φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: P Ramsey

REP RATE

(597)

SWEEP DELAY

(321)

REVIEWED BY P. E. [Signature]

SNT-TC-1A LEVEL

W. J. Caldwell ANII- HSB
 3-30-81

UT CALIBRATION DATA SHEET

PAGE 1
Cal Sheet No. A157

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUV-5751 REV 3 CALIB BLOCK No. 01910.3
 DATE 12/4/79 COUPLANT H₂O CAL STD TEMP 61°
 EXAMINER Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A

EQUIPMENT DATA: INSTRUMENT MODEL No. KBT SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 12#13

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES 12#13 dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)
¹² 25-5db ¹³ 45-5db
 60-5db 60-5db

INSTRUMENT SETTINGS

RF/VIDEO

dB			FREQUENCY					
OUT	IN		1.0	2.25	5.0	10.0	15	BB
✓		1	○	⊗	○	○	○	○
✓		2	○	○	○	○	○	○
	✓	4	○	○	○	○	○	○
	✓	8	○	○	⊗	○	○	○
	✓	16	○	○	○	○	○	○

FILTER
 1 2 3 4
 ○ ○ ⊗ ○

AMPLITUDE GATE

FLAW GATE LEVEL

(240)

BACK ECHO LEVEL

(374)

EQUIP DATA -- ANGLE BEAM
FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA

SERIAL No. H11851 BEAM ANGLE 0°

SIZE 1" φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: Ramsey

REP RATE

(592)

SWEEP DELAY

(321)

REVIEWED BY [Signature] SNT-TC-1A LEVEL

w. J. Caldwell ANII-MSB
3-30-81

CHANNEL 2 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" Ø FREQUENCY 2.25 MHZ
 TRANSDUCER S/N 003914 IHW-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE RG179

HOLE DEPTH "T"	INCHES	TRANSIT TIME µsec	MAX AMP
1/4	1.77	15.3	80
1/2	3.53	30.3)
3/4	5.30	45.6	

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	Δ TIME	FAR AMPLITUDE	Δ TIME
122:35				
03:57				
N/A				

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	_____ % FSH	50% FSH	_____ % FSH
90% "	_____ "	40% "	_____ "
80% "	<u>40</u> "	30% "	_____ "
70% "	_____ "	20% "	_____ "
60% "	SEE CH10		

CONTROL LINEARITY (MADE DAILY)		
80% FSH	-6db	_____ (32-48)
80% "	-12db	_____ (16-24)
40% "	+6db	_____ (64-96)
20% "	+12db	_____ (64-96)
SEE CH10		

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME
1/4										
1/2										
3/4	N/A									

CHANNEL 10 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" Ø FREQUENCY 2.25 MHZ
 TRANSDUCER S/N 003914 IHW-2 BEAM ANGLE 0
 CABLE NO. 2 LENGTH 100' TYPE RG179

HOLE DEPTH "T"	INCHES	TRANSIT TIME µsec	MAX AMP
1/4	1.77	15.1	N/A
1/2	3.53	30.2)
3/4	5.30	45.4	
BE	7.06	59.5	80

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	Δ TIME	FAR AMPLITUDE	Δ TIME
122:35				
03:57				
N/A				

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	<u>52</u> % FSH	50% FSH	<u>26</u> % FSH
90% "	<u>46</u> "	40% "	<u>21</u> "
80% "	<u>41</u> "	30% "	<u>16</u> "
70% "	<u>36</u> "	20% "	<u>10</u> "
60% "	<u>30</u> "		

CONTROL LINEARITY (MADE DAILY)		
80% FSH	-6db	<u>38</u> (32-48)
80% "	-12db	<u>18</u> (16-24)
40% "	+6db	<u>82</u> (64-96)
20% "	+12db	<u>85</u> (64-96)

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME
1/4										
1/2										
3/4	N/A									

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. A162

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUV-5751 REV 3 CALIB BLOCK No. 019103
 DATE 12-8-79 COUPLANT H₂O CAL STD TEMP 58°
 EXAMINER P Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A

EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 12 & 13 12 13 PAR

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION) 45-5db 45-5db
 60-5db 60-5db

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1.0	2.25	5.0	10.0	5	BB
✓							
✓			⊗				
	✓						
	✓						
	✓						
	✓						

FILTER

1 2 3 4

○ ○ ⊗ ○

AMPLITUDE GATE

FLAW GATE LEVEL

234

BACK ECHO LEVEL

374

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7062

TRANSDUCER DATA

SERIAL No. 003914 BEAM ANGLE 0°

SIZE 1"φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: P Ramsey

REP RATE

611

SWEEP DELAY

321

REVIEWED BY P Ramsey III

SNT-TC-1A LEVEL

w-g. Caldwell ANII - MSB
 3-30-81

UT CALIBRATION DATA SHEET

PAGE 1
Cal Sheet No. A165

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUV-5751 REV 3 CALIB BLOCK No. 019103
 DATE 12-9-79 COUPLANT H2O CAL STD TEMP 59°
 EXAMINER Ramsay ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 12 & 13 12 13

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)
45°-5db 45-5db
60°-5db 60-5db

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1.0	2.25	5.0	10.0	15	BB
✓			⊗	○	○	○	○
✓							
	✓						
	✓						
	✓						
	✓						

FILTER

1 2 3 4

○ ○ ⊗ ○

AMPLITUDE GATE

FLAW GATE LEVEL

739

BACK ECHO LEVEL

374

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA

SERIAL No. D03914 BEAM ANGLE 0°

SIZE 1"φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: Ramsay

REP RATE

611

SWEEP DELAY

321

REVIEWED BY [Signature] SNT-TC-1A LEVEL

W. J. Caldwell ANII - HSB
3-30-81

UT CALIBRATION DATA SHEET

PAGE 1
Cal Sheet No. A169

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APU-5751 REV 3 CALIB BLOCK No. 019103
 DATE 12-10-79 COUPLANT H₂O CAL STD TEMP 58°
 EXAMINER Paul Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KB1 SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 12 & 13 12 13
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB 45° - 5db 45 - 5db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION) 60° - 5db 60 - 5db

INSTRUMENT SETTINGS

RF/VIDEO

dB			FREQUENCY					
OUT	IN		1.0	2.25	5.0	10.0	15	BB
<input checked="" type="checkbox"/>		1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>		2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<input checked="" type="checkbox"/>	4	FILTER					
	<input checked="" type="checkbox"/>	8	1	2	3	4		
	<input checked="" type="checkbox"/>	16	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		

AMPLITUDE GATE

FLAW GATE LEVEL

(237)

BACK ECHO LEVEL

(374)

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA

SERIAL No. D03914 BEAM ANGLE 0°

SIZE 1" φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: P. Ramsey

REP RATE

(612)

SWEEP DELAY

(321)

[Signature]

REVIEWED BY _____ SNT-TC-1A LEVEL

w. J. Caldwell ANII - HSB
3-30-81

UT CALIBRATION DATA SHEET

PAGE 1
Cal Sheet No. A172

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APDU-5751 REV 3 CALIB BLOCK No. 019103
 DATE 12-11-79 COUPLANT H₂O CAL STD TEMP 61°
 EXAMINER P. Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A

EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587E
 TRANSDUCER PACKAGE No. 12F 13 ¹² 45-5db ¹³ 45-5db
60-5db 60-5db

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB			FREQUENCY					
OUT	IN		1.0	2.25	5.0	10.0	15	BB
✓		1	○	⊗	○	○	○	○
✓		2	○	○	○	○	○	○
	✓	4	○	○	○	○	○	○
	✓	8	○	○	⊗	○	○	○
	✓	16	○	○	○	○	○	○

FILTER
1 2 3 4
○ ○ ⊗ ○

AMPLITUDE GATE

FLAW GATE LEVEL

(237)

BACK ECHO LEVEL

(374)

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 7.062

TRANSDUCER DATA
 SERIAL No. D03914 BEAM ANGLE 0°
 SIZE 1" φ FREQ 2.25
 SHOE No. N/A CABLE No. 2
 CHECK MADE BY: P. Ramsey

REP RATE

(612)

SWEEP DELAY

(321)

REVIEWED BY P. S. Lind SNT-TC-1A LEVEL

W. J. Caldwell ANII-758
3-30-81

CHANNEL 2 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" ϕ FREQUENCY 2.25 MHz
 TRANSDUCER S/N D03914 IIV-2 BEAM ANGLE 0
 CABLE NO. 2 LENGTH 100' TYPE RG179

HOLE DEPTH	TRANSIT TIME	MAX AMP
"T" INCHES	μ sec	
1/4	1.77	15.0 80
1/2	3.53	30.1
3/4	5.30	45.4

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	Δ TIME	FAR AMPLITUDE	Δ TIME
120:21				
01:57				
05:42				
F				

N/A

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	% FSH	50% FSH	% FSH
90"		40"	
80"	40	30"	
70"		20"	
60"			

SEE CH 10

CONTROL LINEARITY (MADE DAILY)			
80% FSH	-6db		(32-48)
80"	-12db		(16-24)
40"	+6db		(64-96)
20"	+12db		(64-96)

SEE CH 10

ANGLE BEAM SPREAD AT $1 \times 45^\circ$ OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME
1/4										
1/2										
3/4										

N/A

CHANNEL 10 0° 45° 60° OTHER
 TRANSDUCER SIZE 1" ϕ FREQUENCY 2.25 MHz
 TRANSDUCER S/N D03914 IIV-2 BEAM ANGLE 0
 CABLE NO. 2 LENGTH 100' TYPE RG179

HOLE DEPTH	TRANSIT TIME	MAX AMP
"T" INCHES	μ sec	
1/4	1.77	15.1 N/A
1/2	3.53	30.2
3/4	5.30	45.4
BE 7.06	59.5	80

CALIBRATION CHECKS				
TIME	NEAR AMPLITUDE	Δ TIME	FAR AMPLITUDE	Δ TIME
120:21				
01:57				
05:42				
F				

N/A

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	% FSH	50% FSH	% FSH
90"	50	26	
80"	46	20	
70"	40	16	
60"	36	10	

CONTROL LINEARITY (MADE DAILY)			
80% FSH	-6db		(32-48)
30"	-12db	18	(16-24)
40"	+6db	82	(64-96)
20"	+12db	84	(64-96)

ANGLE BEAM SPREAD AT $1 \times 45^\circ$ OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME	W	Δ TIME
1/4										
1/2										
3/4										

N/A

UT CALIBRATION DATA SHEET

PAGE 1
Cal Sheet No. A176

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUN-5751 REV 3 CALIB BLOCK No. 019207
 DATE 12-12-79 COUPLANT H2O CAL STD TEMP 63°
 EXAMINER P Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587 F
 TRANSDUCER PACKAGE No. 11
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES 45° - 5db dB
60° - 5db
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1.0	2.25	5.0	10.0	15	BB
✓							
✓			⊗				
	✓						
	✓						
	✓						
	✓						

FILTER

1	2	3	4
○	○	⊗	○

AMPLITUDE GATE

FLAW GATE LEVEL

(237)

BACK ECHO LEVEL

(374)

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 8.06

TRANSDUCER DATA

SERIAL No. H11851 BEAM ANGLE 0°

SIZE 1" φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: P Ramsey

REP RATE

(611)

SWEEP DELAY

(321)

REVIEWED BY P. E. ... III

REVIEWED BY _____ SNT-TC-1A LEVEL

W. J. Caldwell ANII-MSB
3-30-81

CHANNEL 2 0° 45° 60° OTHER 0
 TRANSDUCER SIZE 1"φ FREQUENCY 2.25 MHZ
 TRANSDUCER S/N H11851 IIV-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE RG179

HOLE DEPTH "T" INCHES	TRANSIT TIME μsec	MAX AMP
1/4	2.11	18.2
1/2	4.22	36.5
3/4	6.33	54.3

CALIBRATION CHECKS				
TIME	NEAR AMPLI-TUDE	ΔTIME	FAR AMPLI-TUDE	ΔTIME
1 23:09				
03:05				
F				

N/A

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	_____ % FSH	50% FSH	_____ % FSH
90% "	_____ "	40% "	_____ "
80% "	<u>40</u> "	30% "	_____ "
70% "	_____ "	20% "	_____ "
60% "	_____ "		

SEE CH 10

CONTROL LINEARITY (MADE DAILY)		
80% FSH	-6db	_____ (32-48)
80% "	-12db	_____ (16-24)
40% "	+6db	_____ (64-96)
20% "	+12db	_____ (64-96)

SEE CH 10

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME
1/4										
1/2										
3/4										

N/A

CHANNEL 10 0° 45° 60° OTHER 0
 TRANSDUCER SIZE 1"φ FREQUENCY 2.25 MHZ
 TRANSDUCER S/N H11851 IIV-2 BEAM ANGLE 0°
 CABLE NO. 2 LENGTH 100' TYPE RG179

HOLE DEPTH "T" INCHES	TRANSIT TIME μsec	MAX AMP
1/4	2.11	18.2
1/2	4.22	36.4
3/4	6.33	54.5
BE	8.06	72.0

CALIBRATION CHECKS				
TIME	NEAR AMPLI-TUDE	ΔTIME	FAR AMPLI-TUDE	ΔTIME
1 23:09				
03:05				
F				

N/A

AMPLITUDE LINEARITY CHECK (MADE DAILY)			
100% FSH	<u>52</u> % FSH	50% FSH	<u>26</u> % FSH
90% "	<u>46</u> "	40% "	<u>20</u> "
80% "	<u>40</u> "	30% "	<u>15</u> "
70% "	<u>35</u> "	20% "	<u>10</u> "
60% "	<u>30</u> "		

CONTROL LINEARITY (MADE DAILY)		
80% FSH	-6db	<u>38</u> (32-48)
80% "	-12db	<u>18</u> (16-24)
40% "	+6db	<u>84</u> (64-96)
20% "	+12db	<u>84</u> (64-96)

ANGLE BEAM SPREAD AT 1 X 45° OR 60° (MADE ONCE PER CALIBRATED SYSTEM - CALIBRATION STANDARD COMBINATION)										
HOLE DEPTH	TRAILING RAY						LEADING RAY			
	25% DAC		50% DAC		100% DAC		50% DAC		25% DAC	
	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME	W	ΔTIME
1/4										
1/2										
3/4										

N/A

UT CALIBRATION DATA SHEET

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUR-5751 REV 3 CALIB BLOCK No. 019207
 DATE 12-13-79 COUPLANT H2O CAL STD TEMP 65°
 EXAMINER Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. HBI SERIAL No. 22588F
 TRANSDUCER PACKAGE No. 11 45° - 5db PRC
60° - 5db
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB			FREQUENCY					
OUT	IN		1.0	2.25	5.0	10.0	15	BB
✓		1	○	⊗	○	○	○	○
✓		2						
	✓	4						
	✓	8						
	✓	16						

FILTER

1 2 3 4

○ ○ ⊗ ○

AMPLITUDE GATE

FLAW GATE LEVEL

239

BACK ECHO LEVEL

374

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 806

TRANSDUCER DATA

SERIAL No. D03914 BEAM ANGLE 0°

SIZE 1"φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: Ramsey

REP RATE

601

SWEEP DELAY

321

REVIEWED BY [Signature] SNT-TC-1A LEVEL

W. J. Caldwell ANSI - 3-30-61
H53

UT CALIBRATION DATA SHEET

PAGE 1 PRR
 Cal Sheet No. A180 A181

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUN-5751 REV 3 CALIB BLOCK No. 019207
 DATE 12-14-79 COUPLANT H₂O CAL STD TEMP 65°
 EXAMINER Phamsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 11 45°-5db
60°-5db
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1.0	2.25	5.0	10.0	15	BB
✓			1	○	●	○	○
✓			2	○	○	○	○
	✓		4				
	✓		8				
	✓		16				

FILTER

1 2 3 4

○ ○ ● ○

AMPLITUDE GATE

FLAW GATE LEVEL

239

BACK ECHO LEVEL

374

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 8106

TRANSDUCER DATA

SERIAL No. H11851 BEAM ANGLE 0°

SIZE 1"Ø FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: Phamsey

REP RATE

607

SWEEP DELAY

321

REVIEWED BY [Signature] SNT-TC-1A LEVEL

W. J. Caldwell AN II - HSB
 3-30-81

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. H186

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. APUN-5751 REV 3 CALIB BLOCK No. 019207
 DATE 12-15-79 COUPLANT H2O CAL STD TEMP 63°
 EXAMINER Ramsey ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 11 45°-5db
60°-5db
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB		FREQUENCY					
OUT	IN	1.0	2.25	5.0	10.0	15	BB
✓			○	○	○	○	○
✓			○	○	○	○	○
	✓						
	✓						
	✓						
	✓						

FILTER

1 2 3 4

○ ○ ○ ○

AMPLITUDE GATE

FLAW GATE LEVEL

238

BACK ECHO LEVEL

373

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 8.06

TRANSDUCER DATA

SERIAL No. H11851 BEAM ANGLE 0°

SIZE 1"φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: Ramsey

REP RATE

607

SWEEP DELAY

321

REVIEWED BY C. G. King III SNT-TC-1A LEVEL

w. J. Caldwell ANIS-1452
3-30-81

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. A188

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. ADUN-5751 REV 3 CALIB BLOCK No. 019207
 DATE 12-17-79 COUPLANT H₂O CAL STD TEMP 63°
 EXAMINER Ramsley ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. KBI SERIAL No. 22587F
 TRANSDUCER PACKAGE No. 1' 45°-5db
60°-5db
 AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB			FREQUENCY					
OUT	IN		1.0	2.25	5.0	10.0	15	BB
✓		1	○	⊗	○	○	○	○
✓		2	○	○	○	○	○	○
	✓	4						
	✓	8						
	✓	16						

FILTER

1 2 3 4

○ ○ ⊗ ○

AMPLITUDE GATE

FLAW GATE LEVEL

237

BACK ECHO LEVEL

374

EQUIP DATA - ANGLE BEAM
FOR LINEARITY CHECKS

CODE BLOCK T 8.06

TRANSDUCER DATA

SERIAL No. H11851 BEAM ANGLE 0°

SIZE 1"φ FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: Ramsley

REP RATE

607

SWEEP DELAY

321

REVIEWED BY K.S. King III

SNT-TC-1A LEVEL

w. j. Caldwell ANIS-MSB
3-30-81

INSTRUMENT SETTINGS

CHANNEL	0	1	2	3	4	5	6	7	8	9	10	11
FINE GAIN			<u>147</u>		<u>158</u>	<u>085</u>					<u>132</u>	
TIME GATE DELAY			<u>108</u>		<u>403</u>	<u>215</u>					<u>518</u>	
FLAW GATE	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF
DELAY			<u>017</u>		<u>085</u>	<u>050</u>					<u>287</u>	
RANGE			<u>065</u>		<u>238</u>	<u>970</u>					<u>046</u>	
BACK ECHO GATE	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF
DELAY											<u>171</u>	
RANGE											<u>444</u>	
TIME CORRECT GAIN	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF	ON OFF
START 1			<u>848</u>		<u>996</u>	<u>982</u>						
START 2			<u>699</u>		<u>920</u>	<u>950</u>						
START 3			<u>706</u>		<u>874</u>	<u>916</u>						
SLOPE 1			<u>733</u>		<u>713</u>	<u>708</u>						
SLOPE 2			<u>693</u>		<u>733</u>	<u>734</u>						
SLOPE 3			<u>824</u>		<u>718</u>	<u>924</u>						

UT CALIBRATION DATA SHEET

PAGE 1

Cal Sheet No. A191
 DATA A192

SITE La Salle I PREOPERATIONAL INSERVICE
 PROCEDURE No. MPUN-557-REV 3 CALIB BLOCK No. 019207
 DATE 12-18-99 COUPLANT H2O CAL STD TEMP 63
 EXAMINER Ramsay ASNT LEVEL II
 RECORDER N/A ASNT LEVEL N/A
 EQUIPMENT DATA: INSTRUMENT MODEL No. NBE SERIAL No. 22587E
 TRANSDUCER PACKAGE No. 11 45°-540
60°-546

AMPLITUDE DIFFERENCE BETWEEN 3/4T AND 5/4T HOLES _____ dB
 (SHEAR WAVE ONLY, REQUIRED ONCE PER CALIBRATED SYSTEM/BLOCK COMBINATION)

INSTRUMENT SETTINGS

RF/VIDEO

dB			FREQUENCY					
OUT	IN		1.0	2.25	5.0	10.0	15	BB
✓		1	○	⊗	○	○	○	○
✓		2						
	✓	4						
	✓	8						
	✓	16						

FILTER

1 2 3 4

○ ○ ⊗ ○

AMPLITUDE GATE

FLAW GATE LEVEL

149

BACK ECHO LEVEL

374

EQUIP DATA - ANGLE BEAM FOR LINEARITY CHECKS

CODE BLOCK T 8.060

TRANSDUCER DATA

SERIAL No. 411851 BEAM ANGLE 0°

SIZE 1" Ø FREQ 2.25

SHOE No. N/A CABLE No. 2

CHECK MADE BY: Ramsay

REP RATE

611

SWEEP DELAY

321

REVIEWED BY R.S. [Signature] SNT-TC-1A LEVEL

w. J. Caldwell ANII-MSB
 3-30-81

VESSEL UT CALIBRATION DATA SHEET Cal. Sheet No. 84660

Site LaSalle County Nuclear Station I Preoperational I.S.L.

Procedure No. NIRZ2-N9-S751 Rev. 0 Calib. Block No. 01-91-04

Date 4/14/81 Couplant Glycerine Cal. Std. Temp. 15 °F

Examiner R.D. Whately ASNT Level III

Recorder M.E. Williams ASNT Level IT

Equipment Data:


Instrument Model No. Scout Mk I Shoe No. NA

Instrument Serial No. 732009 Cable No. NA

Transducer Size 0.5" DIA Frequency 2.25 MHz

Transducer Serial No. 112 IIW-2 Beam Angle 44

DAC Curve: Range 0 - 5 0 - 10



Instrument Settings:

	Start	Finish
Attenuation	NA	NA
Sweep	10/469	10/469
Delay	270	270
Scanning Gain	31	31
Evaluating Gain	60	60
Filter Position	OFF	OFF
Rep Rate	3k	3k
Damping	OFF	OFF
Reject	OFF	OFF

21 dB Change for 10 X

Initial Calibration Time 0950

Periodic Checks

Time	Value	Last Data Sheet
<u>1330</u>	_____	<u>84660</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____
Final Check	_____	_____
<u>1530</u>	_____	<u>18861</u>

Hole Depth	Gain @ 1X	Max. Amp.	"W" Inch	Depth Inch	SDH or FBH
1/4	1X	—	—	—	—
1/2	1X	80	22	32	SDH
3/4	1X	52	34	48	SDH
2% Notch	1X	14	4.7	68	N/A

NDE Sup.
SDH usually
4/14/81

R.D. Whately 4/22/81

J. I. Felton ANEI
4-23-81

FIGURE 4a

Angle Beam Spread @ 1X 45° or 60°
(Made once per calibrated system - Calibration standard combination)

Hole Depth	Trailing Ray								Leading Ray							
	10% DAC		25% DAC		50% DAC		100% DAC		50% DAC		25% DAC		10% DAC			
	W	D	W	D	W	D	W	D	W	D	W	D	W	D		
1/4T																
1/2T	NA															
3/4T	NA															

Amplitude Linearity Check
(Made Daily)

100%FSH	<u>49</u>	% FSH	50%FSH	<u>25</u>	% FSH
50%	<u>44</u>	-	40%	<u>19</u>	-
80%	<u>40</u>	-	30%	<u>15</u>	-
70%	<u>35</u>	-	20%	<u>9</u>	-
60%	<u>30</u>	-			

Control Linearity
(Made Daily)

80%FSH	-6db	<u>41</u>	(32-48)
80%	-12db	<u>24</u>	(16-24)
40%	+6db	<u>77</u>	(64-96)
20%	+12db	<u>78</u>	(64-96)

Equip. Data - Angle Beam
For Linearity Checks

Code Block T 4.65

Transducer Data

Serial No. 112

Beam Angle 44°

Size 0.5" DIA Freq. 2.25

Shoe No. NA Cable No. NA

Check Made By:
L. D. Whentley

Checks on IIW-2

Block on 1/8" SDH for Field Calib.
Checks @ Max Amp. for Both Near & Far
Positions in % Screen Height

1/8" SDH	Near	Far
Max. Amp.	<u>86 %</u>	<u>40 %</u>
Metal Path	<u>1.8</u>	<u>3.8</u>

Reviewed by L. D. Whentley III
SNT-TC Level:

*NDFS Sup
S. J. Connelly
4/16/80*

*S. J. Felton AEE
4-23-81*

FIGURE 4b

NOZZLE BLEND RADIUS EXAMINATION DATA SHEET

Site LaSalle County Station I Preoperational I.S.I. Date 4/14/81
 Examiner R.D. Whalley Level III Recorder M.E. Williams Level IT
 Nozzle ID No. I-NIR-N9A Nozzle Type. Jet Pump Instrumentation
 Procedure No. NIRZ2-N9-S751 Rev. 0 Shoe Numbers NA
 Scan Sensitivity 10 X Evaluation Sensitivity 1 X
 Couplant Glycerine Component Temperature 86 °F

Indication Record:

Location		Max Amp % DAC	Beam - Direction CW or CCW	Metal Path In.	Size & Type Length or Width, DAC 20%—20%, In.	Comments
Radial X"	Dist. X-in.					
			CW, CCW			No recordables. Scanned at +10dB over scanning gain to monitor clad roll. Unable to evaluate 0-19' due to wedge noise. RWW

Reviewed by R.D. Whalley III
 SNT-TC Level

NDE Sup
 S. P. ...
 4/16/81

S.A. ... ANII
 4-23-81

Exam Sheet No. 84662
 Cal. Sheet No. 84660

NOZZLE BLEND RADIUS EXAMINATION DATA SHEET

Site LaSalle County Station I Preoperational I.S.I. Date 4/12/81
 Examiner R.D. Whately Level III Recorder M.E. Williams Level IT
 Nozzle ID No. I-NIR-9AB Nozzle Type. Jet Pump Instrumentation
 Procedure No. NIRZ2-N9-S751 Rev. 0 Shoe Numbers NA
 Scan Sensitivity 10 Evaluation Sensitivity 1
 Couplant Glycerine Component Temperature 86 °F

Indication Record:

Location		Max Amp % DAC	Beam Direction CW or CCW	Metal Path In.	Size & Type Length or Width, DAC 20%-20%, In.	Comments
Radial X"	Dist. X-in.					
			CW, CCW			No recordables. Scanned at +10dB over scanning gain to monitor clad roll. Unable to evaluate 0-1.9" due to wedge noise & WW

Reviewed by R.D. Whately III
 SNT-TC Level

NDE Sup.
 S.D. Annally
 4/16/81

S.T. Feltner
 ANEE
 4-23-81

DATE: 1-14-80

EXAMINER: Jerry Stary LEVEL II DATA TAKER: Robert Schmitz LEVEL IT
INSTRUMENT: 810055 MODEL NO: BRANSON 301; BRANSON 303; SONIC MKI; OTHER _____

SEARCH UNIT: BEAM ANGLE: 0° (LONG. WAVE); 45° (SHEAR WAVE); 60° (SHEAR WAVE); OTHER _____

TRANSDUCER SIZE/FREQ: 0.25" DIA/2.25 MHZ; 0.25" X 0.25"/2.25MHZ; 0.25" X 0.5"/2.25 MHZ;

SERIAL NO. (V403)(4181) 0.5" X 0.5"/2.25 MHZ; 0.25" DIA/5.0 MHZ; 0.25" X 0.25"/5.0 MHZ;

0.25" X 0.5"/5.0 MHZ; 0.5" X 0.5"/5.0 MHZ; OTHER 0.5" X 1.0"/2.25 MHZ

DUAL TRANSDUCERS; SINGLE TRANSDUCER; SPECIAL WEDGE _____

CABLE TYPE: RG-58; RG-59; RG-57; RG-174 ^{BNC} (Microdot); OTHER _____ LENGTH: 12'

SCREEN HEIGHT LINEARITY CHECK:

1st REFLECTOR AMPLITUDE IN % FSH	2nd REFLECTOR AMPLITUDE IN % FSH	1st REFLECTOR AMPLITUDE IN % FSH	2nd REFLECTOR AMPLITUDE IN % FSH
100	50	50	25
90	43	40	21
80	40	30	18
70	37	20	10
60	30		

THE 2nd REFLECTOR SHALL BE 50% OF THE 1st REFLECTOR ± 5% FSH TO MEET SCREEN HEIGHT LINEARITY.

AMPLITUDE CONTROL LINEARITY:

REFLECTOR AMP. SET IN % FSH	dB CONTROL CHANGE	READING OFF SCREEN	REFLECTOR AMP. LIMITS IN % FSH
80%	-6dB	40	32 to 48%
80%	-12dB	20	16 to 24%
40%	+6dB	80	64 to 96%
20%	+12dB	82	64 to 96%

MINUS (-) DENOTES DECREASE IN AMPLITUDE; PLUS (+) DENOTES INCREASE.

McDonally 1/14/80 NDE Sup.

REVIEWED BY: L. J. Whitley DATE: 1/23/80

GENERAL ELECTRIC CO. LEVEL III

W. J. Caldwell 10-27-80 - ANEI

PROCEDURE NO. MPV-5751 REV. 2

EXAMINER: [Signature] LEVEL IT DATA TAKER: [Signature] LEVEL IT

INSTRUMENT:
SERIAL NO. 810055 MODEL NO: BRANSON 301; BRANSON 303; SONIC MKI; USL-32;
 OTHER

SEARCH UNIT:
BEAM ANGLE: 0° (LONG. WAVE); 45° (SHEAR WAVE); 60° (SHEAR WAVE); OTHER

TRANSDUCER SIZE/FREQ: 0.25" DIA/2.25 MHZ; 0.25" X 0.25"/2.25 MHZ; 0.25" X 0.5"/2.25 MHZ;

SERIAL NO. (V403)(4191) 0.5" DIA/2.25 MHZ; 0.25" DIA/5.0 MHZ; 0.25" X 0.25"/5.0 MHZ;

IIW BLOCK BEAM ANGLE CHECK 60° 0.25" X 0.5"/5.0 MHZ; 0.5" X 0.5"/5.0 MHZ; OTHER 10" X 0.5"/2.25 MHZ

DUAL TRANSDUCERS; SINGLE TRANSDUCER; SPECIAL WEDGE


CABLE: TYPE: RG-58; RG-59; RG-57; RG-174 (BALC); Other LENGTH: 12'

CAL. BLOCK: MATERIAL: CARBON STEEL; STAINLESS STEEL; INCONEL; OTHER

NUMBER: 01-92-07; T = 8.45; DIA. = N/A; CAL. BLK. & EXAM COMP. TEMPERATURES WITHIN 25° F YES NO

CALIBRATION CHECKS: 3 INITIAL CAL. TIME 9:00 COUPLANT: GLYCERINE; ULTRAGEL II; OTHER

DATE	TIME	LAST EDS NO.	LAST EDS LINE NO.	VERIFICATION OF 25° F LIMIT (YES OR NO)
1-14-80	9:00	N/A	N/A	YES
1-14-80	11:30	93031	11	YES
1-14-80	12:30	93031	11	YES
1-14-80	15:30	93032	6	YES



2X SCAN SENSITIVITY = 6 dB CHANGE
VESSEL BLOCK CLAD INTERFACE = 4 dB CHANGE

INSTRUMENT SETTINGS:

CONTROLS:	SET	CHECK	CHECK	CHECK
GAIN	100/797	X	X	X
SWEEP	0.87	X	X	X
DELAY	50/058	X	X	X
SCAN GAIN	100/797	X	X	X
FILTER	AUTO	X	X	X
REP. RATE	MED	X	X	X
DAMPENING	OFF	X	X	X
REJECT	OFF	X	X	X
OTHER:	N/A	X	X	X

REFLECTOR	PEAK AMP.	W ₁	W _m	W ₂	SRP ₁	SRP _m	SRP ₂	HOLE DEPTH
1/4 T or								
1/8 Vee	0%	26	3.85	4.85	1.3	2.0	2.2	2.15
1/2 T or								
2/8 Vee	1.8%	6.15	8.15	8.8	3.8	4.0	4.2	4.25
3/4 T or								
3/8 Vee	20%	10.95	12.0	12.5	5.6	6.0	6.2	6.35
B.R. or								
5/8 Vee	5%	-	-	-	-	9.0	-	-

Reviewed By: NDE Supervisor [Signature] Date 1/14/80


QC Supervisor [Signature] Date 1/23/80

ANII [Signature] Date 10-27-80

PROCEDURE NO. MPUV 5751 REV. NO. 2 EXAMINER [Signature] LEVEL II SYSTEM RPV

DATA RECORDER [Signature] LEVEL II COUPLANT: GLYCERINE; OTHER

SEARCH ANGLE: 0°; 45°; 60°; OTHER SCAN SENS: 2X; 5X; 10X; OTHER



DATE	LINE NO.	EXAM/COMP. I.D. NO.	COMP FIG.	REC. IND. YES/NO	MAX % DAC @ \$W_m\$	\$L_0\$ / \$W_0\$	\$L\$	\$W_1\$ (50% DAC)	\$W_m\$	\$W_2\$ (50% DAC)	\$SRP_1\$ (50% DAC)	\$SRP_m\$	\$SRP_2\$ (50% DAC)	SCAN	Comments (Thickness Meas.)
1-14-80	1	NZ-J	N/SH	NO		/									SCAN 360° OF W, & 2'
1-14-80	2	NZ-H	N/SH	NO		/									SCAN 360° OF W, & 2' 90°-105° & 20"
1-14-80	3	NZ-G	N/SH	NO		/									SCAN 360° OF W, & 2'
1-14-80	4	NZ-F	N/SH	NO		/									SCAN 360° OF W, & 2"
1-14-80	5	NZ-B	N/SH	NO		/									SCAN 360° OF W, & 2"
1-14-80	6	NZ-E	N/SH	YES	50%	/	28.5"								
1-14-80	7	NZ-E	N/SH	YES	100%	/	29"	.5	.8	.9	4.0	4.0	4.2	5a	29"
1-14-80	8	NZ-E	N/SH	YES	50%	/	29.5"								
1-14-80	9	NZ-E	N/SH	YES	+1 100%	/	INT 360°	.6	.9	.9	1.8	2.0	2.0	5A	360° INT
1-14-80	10	NZ-E	N/SH	YES	+1 100%	/	270° TO 90°	1.3	1.5	1.6	2.6	2.8	2.8	5a	45" TO TDC 270° TO 90°
1-14-80	11	ARD	N/SH	NO		/									

ADDITIONAL COMMENTS/ EVALUATION:


Line 6-8 was located 1" beyond centerline at 50% T's ID geometry from nozzle bore us signal rolls with rotation of transducer. Line 9,10 could only be seen at high gain. Suspect data was recorded at scanning gain.

Reviewed By: NDE Supervisor [Signature] Date 1/14/80
 QC Supervisor [Signature] Date 1-23-80
 ANII [Signature] Date 10-27-80

PROCEDURE NO. MPV-5751 REV. NO. 2 EXAMINER Jerry King LEVEL II SYSTEM RPV

DATA RECORDER Justin Himmelfarb LEVEL II COUPLANT: GLYCERINE; OTHER

SEARCH ANGLE: 0°; 45°; 60°; OTHER _____ SCAN SENS: 2X; 5X; 10X; OTHER _____




DATE	LINE NO.	EXAM/COMP. I.D. NO.	COMP FIG.	REC. IND. YES/NO	MAX % DAC @ W_m	L_0 / W_0	L	W_1 (50% DAC)	W_m	W_2 (50% DAC)	SRP ₁ (50% DAC)	SRP _m	SRP ₂ (50% DAC)	SCAN	Comments (Thickness Meas.)
1-14-80	1	NZ-A	YH	NO											SCAN 360° OF W & Z 2"
1-14-80	2	NI-A-1 NI-A-2	N/ SH	YES											SCAN 360° OF W & Z, 73.8°-98.4° E → 20" (INDICATION IN LINE # 3)
1-14-80	3	NI-A-2	N	YES	+10 100%		150° 70°	.5	1	1.5	5.7	5.8	5.8	5A	78" TO 0" 180° TO 0°
1-14-80	4	NZ-K	YH	NO											SCAN 360° OF W, & Z 2"
1-14-80	5	NZ-C	YH	NO											SCAN 360° OF W, & Z 2"
1-14-80	6	NZ-B	YH	NO											SCAN 360° OF W, & Z 2"
	7														
	8														
	9														
	10														
	11														

ADDITIONAL COMMENTS/ EVALUATION:

line 3 is ID geometry from inner radius 2W

Reviewed By: NOE Supervisor [Signature] Date 1/14/80
 QC Supervisor [Signature] Date 1/23/80
 ANII [Signature] /Date 10-27-80



-B- SEE NOTE #3

22 1/2 ± 2°

SS

*127" ± 1/8" R.

41" R
B7D
C.A.

45° ± 2°
1/16"

A-K
11-314 P-T U-T
(F-43)

*12.375 ± 0.020" DIA.

11.688 ± 0.010" DIA.

EDS 93032
CDS 93030

N1-A-2

3- ID reflector

Sabhidmanah

ELEVATION PLAN

*30" DIA.

7/32 (REF)
CLAD

APPROX.

A-K
7-314 P-T U-T

A-K
8-314 P-T U-T

314-09

45° ± 15° (MFR)
1/4" MIN.

REMOVE BACKING RING
ACKGROOVE TO SOUND
METAL AND WELD.

WET NOZZLE

12"

ALTERNATE WELD MA
BE MADE FROM OUTSIDE
SEE DETAIL "D" (A-8).

1/2 (REF)

PENETRANT INSPECTION DATA SHEET



WATER SPARGER SERIAL NUMBER _____

QUADRANT LOCATION _____

No.	Accept	Date	F.W.	Accept	Date	F.W.	Accept	Date	Remaining Welds		
									F.W.	Accept	Date
L1			L1			L1			1		
L2			L2			L2			2		
L3			L3			L3			3		
L4			L4			L4			4		
L5			L5			L5			5		
L6			L6			L6			9		
L7			L7			L7			10		
L8			L8			L8			11		
L9			L9			L9			12		
R1			R1			R1			Thermal Sleeve S/N _____		
R2			R2			R2			Quadrant		
R3			R3			R3			F.W.	Accept	Date
R4			R4			R4			13		
R5			R5			R5			14		
R6			R6			R6			15		
R7			R7			R7			16		
R8			R8			R8					
R9			R9			R9					

DESCRIPTION AND LOCATION OF UNACCEPTABLE INDICATIONS (when noted) DISPOSITION

THIS IS THE TYPICAL NUMBERING FOR WELDS 6, 7, + 8 ON ALL SPARGERS



FDI NO. 91-57434 Rev. 0 and FDDR No. HAL-207

Penetrant Procedure: RCI PE-1 Rev

Acceptance Criteria: GE Spec ESDYPI Rev 3 Section 4.1.4

PSI Ref. No.

RPV-13

Page 1 of 7

PENETRANT INSPECTION DATA SHEET

FEE/WATER SPARGER SERIAL NUMBER 1

QUADRANT LOCATION 150°

F.N. 6	Accept	Date	F.N. 7	Accept	Date	F.N. 8	Accept	Date	Remaining Welds		
									F.N.	Accept	Date
L1	BW Seal II	7/17/79	L1	BW Seal II	7/17/79	L1	BW Seal II	7/17/79	1	BW Seal II	7/16/79
L2	BW Seal II	7/17/79	L2	BW Seal II	7/17/79	L2	BW Seal II	7/17/79	2	BW Seal II	7/16/79
L3	BW Seal II	7/17/79	L3	BW Seal II	7/17/79	L3	BW Seal II	7/17/79	3	BW Seal II	7/16/79
L4	BW Seal II	7/17/79	L4	BW Seal II	7/17/79	L4	BW Seal II	7/17/79	4	BW Seal II	7/16/79
L5	BW Seal II	7/17/79	L5	BW Seal II	7/17/79	L5	BW Seal II	7/17/79	5	BW Seal II	7/17/79
L6	BW Seal II	7/17/79	L6	BW Seal II	7/17/79	L6	BW Seal II	7/17/79	9	BW Seal II	7/16/79
L7	BW Seal II	7/17/79	L7	BW Seal II	7/17/79	L7	BW Seal II	7/17/79	10	BW Seal II	7/17/79
L8	BW Seal II	7/17/79	L8	BW Seal II	7/17/79	L8	BW Seal II	7/17/79	11	BW Seal II	7/16/79
L9	BW Seal II	7/17/79	L9	BW Seal II	7/17/79	L9	BW Seal II	7/17/79	12	BW Seal II	7/16/79
R1	BW Seal II	7/16/79	R1	BW Seal II	7/16/79	R1	BW Seal II	7/16/79	Thermal Sleeve S/N <u>001</u> Quadrant		
R2	BW Seal II	7/16/79	R2	BW Seal II	7/16/79	R2	BW Seal II	7/16/79			
R3	BW Seal II	7/16/79	R3	BW Seal II	7/16/79	R3	BW Seal II	7/16/79	F.N.	Accept	Date
R4	BW Seal II	7/16/79	R4	BW Seal II	7/16/79	R4	BW Seal II	7/16/79	13	H Phillips	7/11/79
R5	BW Seal II	7/16/79	R5	BW Seal II	7/16/79	R5	BW Seal II	7/16/79	14	H Phillips	7/11/79
R6	BW Seal II	7/16/79	R6	BW Seal II	7/16/79	R6	BW Seal II	7/16/79	15	H Phillips	7/11/79
R7	BW Seal II	7/16/79	R7	BW Seal II	7/16/79	R7	BW Seal II	7/16/79	16	N/A	N/A
R8	BW Seal II	7/16/79	R8	BW Seal II	7/16/79	R8	BW Seal II	7/16/79			
R9	BW Seal II	7/16/79	R9	BW Seal II	7/16/79	R9	BW Seal II	7/16/79			

DESCRIPTION AND LOCATION OF UNACCEPTABLE INDICATIONS (When noted) DISPOSITION



FDI NO. 91-57434 Rev. 0 and FDDR No. HAL-207

Penetrant Procedure: RCI PE-1 Rev 5

Acceptance Criteria: GE Spec E5DYPH Rev 3 Section 4.1.4 PSI Ref. No.

PENETRANT INSPECTION DATA SHEET

FEEYATER SPARGER SERIAL NUMBER 002

QUADRANT LOCATION 210"

F.W. 6	Accept	Date	F.W. 7	Accept	Date	F.W. 8	Accept	Date	Remaining Welds		
									F.W.	Accept	Date
L1	<i>Handwritten</i>	7/16/79	L1	<i>Handwritten</i>	5/18/81	L1	<i>Handwritten</i>	5/18/81	1	<i>Handwritten</i>	7/16/79
L2	<i>Handwritten</i>	7/17/79	L2	<i>Handwritten</i>	5/18/81	L2	<i>Handwritten</i>	5/18/81	2	<i>Handwritten</i>	7/17/79
L3	<i>Handwritten</i>	7/17/79	L3	<i>Handwritten</i>	5/18/81	L3	<i>Handwritten</i>	5/18/81	3	<i>Handwritten</i>	7/17/79
L4	<i>Handwritten</i>	7/17/79	L4	<i>Handwritten</i>	5/18/81	L4	<i>Handwritten</i>	5/18/81	4	<i>Handwritten</i>	7/17/79
L5	<i>Handwritten</i>	7/17/79	L5	<i>Handwritten</i>	5/18/81	L5	<i>Handwritten</i>	5/18/81	5	<i>Handwritten</i>	7/17/79
L6	<i>Handwritten</i>	7/17/79	L6	<i>Handwritten</i>	5/18/81	L6	<i>Handwritten</i>	5/18/81	9	<i>Handwritten</i>	7/17/79
L7	<i>Handwritten</i>	7/17/79	L7	<i>Handwritten</i>	5/18/81	L7	<i>Handwritten</i>	5/18/81	10	<i>Handwritten</i>	7/17/79
L8	<i>Handwritten</i>	7/17/79	L8	<i>Handwritten</i>	5/18/81	L8	<i>Handwritten</i>	5/18/81	11	<i>Handwritten</i>	7/17/79
L9	<i>Handwritten</i>	7/17/79	L9	<i>Handwritten</i>	5/18/81	L9	<i>Handwritten</i>	5/18/81	12	<i>Handwritten</i>	7/17/79
R1	<i>Handwritten</i>	7/17/79	R1	<i>Handwritten</i>	5/18/81	R1	<i>Handwritten</i>	5/18/81	Thermal Sleeve S/N 002		
R2	<i>Handwritten</i>	7/17/79	R2	<i>Handwritten</i>	5/18/81	R2	<i>Handwritten</i>	5/18/81	Quadrant <i>Handwritten</i> 90°		
R3	<i>Handwritten</i>	7/17/79	R3	<i>Handwritten</i>	5/18/81	R3	<i>Handwritten</i>	5/18/81	F.W.	Accept	Date
R4	<i>Handwritten</i>	7/17/79	R4	<i>Handwritten</i>	5/18/81	R4	<i>Handwritten</i>	5/18/81	13	<i>Handwritten</i>	7/17/79
R5	<i>Handwritten</i>	7/17/79	R5	<i>Handwritten</i>	5/18/81	R5	<i>Handwritten</i>	5/18/81	14	<i>Handwritten</i>	7/17/79
R6	<i>Handwritten</i>	7/17/79	R6	<i>Handwritten</i>	5/18/81	R6	<i>Handwritten</i>	5/18/81	15	<i>Handwritten</i>	7/17/79
R7	<i>Handwritten</i>	7/17/79	R7	<i>Handwritten</i>	5/18/81	R7	<i>Handwritten</i>	5/18/81	16	N/A	N/A
R8	<i>Handwritten</i>	7/17/79	R8	<i>Handwritten</i>	5/18/81	R8	<i>Handwritten</i>	5/18/81			
R9	<i>Handwritten</i>	7/17/79	R9	<i>Handwritten</i>	5/18/81	R9	<i>Handwritten</i>	5/18/81			

DESCRIPTION AND LOCATION OF UNACCEPTABLE INDICATIONS (when noted) DISPOSITION



Handwritten: v. Balle 5-19-81



FDI NO. 91-57134 Rev. 0 and FDDR No. HAL-207

Penetrant Procedure: RCI P-1 Rev 5

Acceptance Criteria: GE Spec ESDYPI Rev 3 Section 1.1.4

PSI Ref. No. RPV-13

Page 3 of 7

PENETRANT INSPECTION DATA SHEET

FREY-WATER SPARGER SERIAL NUMBER 3

QUADRANT LOCATION 96°

F.N. 6	Accept	Date	F.W. 7	Accept	Date	F.N. 8	Accept	Date	Remaining Welds		
									F.W.	Accept	Date
L1	BW Seal II	7/18/79	L1	BW Seal II	7/18/79	L1	BW Seal II	7/18/79	1	Al Donath Seal II	7/17/79
L2	BW Seal II	7/18/79	L2	BW Seal II	7/18/79	L2	BW Seal II	7/18/79	2	BW Seal II	7/17/79
L3	BW Seal II	7/18/79	L3	BW Seal II	7/18/79	L3	BW Seal II	7/18/79	3	BW Seal II	7/17/79
L4	BW Seal II	7/18/79	L4	BW Seal II	7/18/79	L4	BW Seal II	7/18/79	4	BW Seal II	7/17/79
L5	BW Seal II	7/18/79	L5	BW Seal II	7/18/79	L5	BW Seal II	7/18/79	5	BW Seal II	7/19/79
L6	BW Seal II	7/18/79	L6	BW Seal II	7/18/79	L6	BW Seal II	7/18/79	9	BW Seal II	7/17/79
L7	BW Seal II	7/18/79	L7	BW Seal II	7/18/79	L7	BW Seal II	7/18/79	10	Al Donath Seal II	7/17/79
L8	BW Seal II	7/18/79	L8	BW Seal II	7/18/79	L8	BW Seal II	7/18/79	11	BW Seal II	7/17/79
L9	BW Seal II	7/17/79	L9	BW Seal II	7/14/79	L9	BW Seal II	7/17/79	12	BW Seal II	7/17/79
R1	BW Seal II	7/18/79	R1	BW Seal II	7/18/79	R1	BW Seal II	7/18/79	Thermal Sleeve S/N 003		
R2	BW Seal II	7/18/79	R2	BW Seal II	7/18/79	R2	BW Seal II	7/18/79	Quadrant		
R3	BW Seal II	7/18/79	R3	BW Seal II	7/18/79	R3	BW Seal II	7/18/79	F.N.	Accept	Date
R4	BW Seal II	7/18/79	R4	BW Seal II	7/18/79	R4	BW Seal II	7/18/79	13	Al Donath Seal II	7/20/79
R5	BW Seal II	7/18/79	R5	BW Seal II	7/18/79	R5	BW Seal II	7/18/79	14	Al Donath Seal II	7/10/79
R6	BW Seal II	7/18/79	R6	BW Seal II	7/18/79	R6	BW Seal II	7/18/79	15	Al Donath Seal II	7/10/79
R7	BW Seal II	7/18/79	R7	BW Seal II	7/18/79	R7	BW Seal II	7/18/79	16	N/A	N/A
R8	Al Donath Seal II	7/17/79	R8	BW Seal II	7/17/79	R8	CB Seal II	5/18/81			
R9	Al Donath Seal II	7/17/79	R9	BW Seal II	7/17/79	R9	CB Seal II	5/18/81			

DESCRIPTION AND LOCATION OF UNACCEPTABLE INDICATIONS (when noted) DISPOSITION

F.N. 13 had 2 unacceptable linear indications approximately 6" apart in the middle of the welds. (Beads apparently not completely tied in). Both indications were flapper-wheeled until the weld bead was flush with the pipe. At this point penetrant examination determined that one indication had been eliminated. G.E. then instructed RCI to remove additional metal from the remaining indication. At a depth of approximately .020, the indication was eliminated.

Al Donath Seal II
7/20/79



Al Donath Seal II
7/19/81



FDI NO. 91-57434 Rev. O and FDDR No. HAL-207

Penetrant Procedure: RCI PE-1 Rev 5

Acceptance Criteria: GE Spec E5DYPH Rev 3 Section 4.1.4 PSI Ref. No. RPV-13

PENETRANT INSPECTION DATA SHEET

FREY WATER SPARGER SERIAL NUMBER 4

QUADRANT LOCATION 270°

F.N. 6	Accept	Date	F.N. 7	Accept	Date	F.N. 8	Accept	Date	Remaining Welds		
									F.N.	Accept	Date
L1	BW Seal II	7/25/79	L1	BW Seal II	7/25/79	L1	BW Seal II	7/25/79	1	BW Seal II	8/7/79
L2	BW Seal II	7/25/79	L2	BW Seal II	7/25/79	L2	BW Seal II	7/25/79	2	BW Seal II	7/24/79
L3	BW Seal II	7/25/79	L3	BW Seal II	7/25/79	L3	BW Seal II	7/25/79	3	BW Seal II	7/24/79
L4	BW Seal II	7/25/79	L4	BW Seal II	7/25/79	L4	BW Seal II	7/25/79	4	BW Seal II	7/24/79
L5	BW Seal II	7/25/79	L5	BW Seal II	7/25/79	L5	BW Seal II	7/25/79	5	BW Seal II	7/25/79
L6	BW Seal II	7/24/79	L6	BW Seal II	7/24/79	L6	BW Seal II	7/24/79	9	BW Seal II	7/24/79
L7	BW Seal II	7/24/79	L7	BW Seal II	7/24/79	L7	BW Seal II	7/24/79	10	BW Seal II	7/25/79
L8	BW Seal II	7/24/79	L8	BW Seal II	7/24/79	L8	BW Seal II	7/24/79	11	BW Seal II	7/24/79
L9	BW Seal II	7/24/79	L9	BW Seal II	7/24/79	L9	BW Seal II	7/24/79	12	BW Seal II	7/24/79
R1	BW Seal II	7/24/79	R1	BW Seal II	7/24/79	R1	BW Seal II	7/24/79	Thermal Sleeve S/N 006		
R2	BW Seal II	7/24/79	R2	BW Seal II	7/24/79	R2	BW Seal II	7/24/79	Quadrant		
R3	BW Seal II	7/24/79	R3	BW Seal II	7/24/79	R3	BW Seal II	7/24/79	F.N.	Accept	Date
R11	BW Seal II	7/24/79	R11	BW Seal II	7/24/79	R11	BW Seal II	7/24/79	13	B. Waincott Level II	7/10/79
R5	BW Seal II	7/24/79	R5	BW Seal II	7/24/79	R5	BW Seal II	7/24/79	14	B. Waincott Level II	7/10/79
R6	BW Seal II	7/24/79	R6	BW Seal II	7/24/79	R6	BW Seal II	7/24/79	15	B. Waincott Level II	7/10/79
R7	BW Seal II	7/24/79	R7	BW Seal II	7/24/79	R7	BW Seal II	7/24/79	16	B. Waincott Level II	7/10/79
R8	BW Seal II	7/24/79	R8	BW Seal II	7/24/79	R8	BW Seal II	7/24/79			
R9	BW Seal II	7/24/79	R9	BW Seal II	7/24/79	R9	BW Seal II	7/24/79			

DESCRIPTION AND LOCATION OF UNACCEPTABLE INDICATIONS (When noted) DISPOSITION

F.N. 1 had an unacceptable linear indication in the middle of the weld. The indication was excavated out to a depth of 1/16". At this point, penetrant examination determined that the indication had been eliminated. The excavation was then filled in with weld metal in accordance with P-3, surface finished to blend with rest of weld and penetrant examined for final acceptance.

B. Waincott Level II
8/7/79



FDI NO. 91-57434 Rev. 0 and FDDR No. HAL-207

Penetrant Procedure: RCI PE-1 Rev 5
Acceptance Criteria: GE Spec ESDYPA Rev 3 Section 4.1.4

PSi Ref. No.

RPV-13
Page 5 of 7

PENETRANT INSPECTION DATA SHEET

FREY WATER SPARGER SERIAL NUMBER 5

QUADRANT LOCATION 330°

F.W. 6	Accept	Date	F.W. 7	Accept	Date	F.W. 8	Accept	Date	Remaining Welds		
									F.W.	Accept	Date
L1	BW Seal II	7/20/79	L1	BW Seal II	7/20/79	L1	BW Seal II	7/20/79	1	BW Seal II	7/23/79
L2	BW Seal II	7/20/79	L2	BW Seal II	7/20/79	L2	BW Seal II	7/20/79	2	BW Seal II	7/23/79
L3	BW Seal II	7/20/79	L3	BW Seal II	7/20/79	L3	BW Seal II	7/20/79	3	BW Seal II	7/23/79
L4	BW Seal II	7/20/79	L4	BW Seal II	7/20/79	L4	BW Seal II	7/20/79	4	BW Seal II	7/23/79
L5	BW Seal II	7/20/79	L5	BW Seal II	7/20/79	L5	BW Seal II	7/20/79	5	BW Seal II	7/23/79
L6	BW Seal II	7/20/79	L6	BW Seal II	7/20/79	L6	BW Seal II	7/20/79	9	BW Seal II	7/23/79
L7	BW Seal II	7/20/79	L7	BW Seal II	7/20/79	L7	BW Seal II	7/20/79	10	BW Seal II	7/23/79
L8	BW Seal II	7/20/79	L8	BW Seal II	7/20/79	L8	BW Seal II	7/20/79	11	BW Seal II	7/23/79
L9	BW Seal II	7/20/79	L9	BW Seal II	7/20/79	L9	BW Seal II	7/20/79	12	BW Seal II	7/23/79
R1	BW Seal II	7/23/79	R1	BW Seal II	7/23/79	R1	BW Seal II	7/23/79	Thermal Sleeve S/N <u>005</u> Quadrant		
R2	BW Seal II	7/23/79	R2	BW Seal II	7/23/79	R2	BW Seal II	7/23/79			
R3	BW Seal II	7/23/79	R3	BW Seal II	7/23/79	R3	BW Seal II	7/23/79	F.W.	Accept	Date
R4	BW Seal II	7/23/79	R4	BW Seal II	7/23/79	R4	BW Seal II	7/23/79	13	<i>H. Phillips</i>	7/11/79
R5	BW Seal II	7/23/79	R5	BW Seal II	7/23/79	R5	BW Seal II	7/23/79	14	<i>H. Phillips</i>	7/11/79
R6	BW Seal II	7/23/79	R6	BW Seal II	7/23/79	R6	BW Seal II	7/23/79	15	<i>H. Phillips</i>	7/11/79
R7	BW Seal II	7/23/79	R7	BW Seal II	7/23/79	R7	BW Seal II	7/23/79	16	N/A	N/A
P8	BW Seal II	7/23/79	R8	BW Seal II	7/23/79	R8	BW Seal II	7/23/79			
R9	BW Seal II	7/23/79	P9	BW Seal II	7/23/79	R9	BW Seal II	7/23/79			

DESCRIPTION AND LOCATION OF UNACCEPTABLE INDICATIONS (if then noted)

DISPOSITION



FDI NO. 91-57434 Rev. 0 and FDDR No. HAL-207

Penetrant Procedure: RCI PE-1 Rev 5

Acceptance Criteria: GE Spec E5DYPI Rev 3 Section 4.1.4

PSI Ref. No. RPV-13

Page 6 of 7

PENETRANT INSPECTION DATA SHEET

FREY WATER SPARGER SERIAL NUMBER 6 QUADRANT LOCATION 30°

F.N.	Accept	Date	F.N.	Accept	Date	F.N.	Accept	Date	Remaining Welds		
									F.N.	Accept	Date
6			7			8					
L1	BW Seal I	7/20/79	L1	BW Seal I	7/20/79	L1	BW Seal I	7/20/79	1	BW Seal I	7/20/79
L2	BW Seal I	7/20/79	L2	BW Seal I	7/20/79	L2	BW Seal I	7/20/79	2	BW Seal I	7/19/79
L3	BW Seal I	7/20/79	L3	BW Seal I	7/20/79	L3	BW Seal I	7/20/79	3	BW Seal I	7/19/79
L4	BW Seal I	7/20/79	L4	BW Seal I	7/20/79	L4	BW Seal I	7/20/79	4	BW Seal I	7/19/79
L5	BW Seal I	7/20/79	L5	BW Seal I	7/20/79	L5	BW Seal I	7/20/79	5	BW Seal I	7/20/79
L6	BW Seal I	7/19/79	L6	BW Seal I	7/19/79	L6	BW Seal I	7/19/79	9	BW Seal I	7/19/79
L7	BW Seal I	7/19/79	L7	BW Seal I	7/19/79	L7	BW Seal I	7/19/79	10	BW Seal I	7/20/79
L8	BW Seal I	7/19/79	L8	BW Seal I	7/19/79	L8	BW Seal I	7/19/79	11	BW Seal I	7/19/79
L9	BW Seal I	7/19/79	L9	BW Seal I	7/19/79	L9	BW Seal I	7/19/79	12	BW Seal I	7/19/79
R1	BW Seal I	7/19/79	R1	BW Seal I	7/19/79	R1	BW Seal I	7/19/79	Thermal Sleeve S/N 004		
R2	BW Seal I	7/19/79	R2	BW Seal I	7/19/79	R2	BW Seal I	7/19/79	Quadrant		
R3	BW Seal I	7/19/79	R3	BW Seal I	7/19/79	R3	BW Seal I	7/19/79	F.N.	Accept	Date
R4	BW Seal I	7/19/79	R4	BW Seal I	7/19/79	R4	BW Seal I	7/19/79	13	OK	7/10/79
R5	BW Seal I	7/19/79	R5	BW Seal I	7/19/79	R5	BW Seal I	7/19/79	14	OK	7/10/79
R6	BW Seal I	7/19/79	R6	BW Seal I	7/19/79	R6	BW Seal I	7/19/79	15	OK	7/10/79
R7	BW Seal I	7/19/79	R7	BW Seal I	7/19/79	R7	BW Seal I	7/19/79	16	N/A	N/A
R8	BW Seal I	7/19/79	R8	BW Seal I	7/19/79	R8	BW Seal I	7/19/79			
R9	BW Seal I	7/19/79	R9	BW Seal I	7/19/79	R9	BW Seal I	7/19/79			

DESCRIPTION AND LOCATION OF UNACCEPTABLE INDICATIONS (when noted) DISPOSITION



FPI NO. 91-57434 Rev. 0 and FDDR No. HAL-207
 Penetrant Procedure: RCI PE-1 Rev 5
 Acceptance Criteria: GE Spec B5DYPL Rev 3 Section 4.1.4

PSI Ref. No. RPV-13
 Page 7 of 7

LIQUID PENETRANT EXAMINATION DATA SHEET
LASALLE COUNTY STATION UNIT

E.D.S. NO. 40123

A. Procedure No. PP-S751 REV. 3

Examination Personnel:

NAME [Signature] LEVEL II

NAME N/A LEVEL _____

C. Penetrant Materials:

a. MANUFACTURER MAGNAFLUX-SPOTCHECK

b. PRE-CLEANING SOLVENT TYPE SKC-S BATCH NO. 78C130

c. PENETRANT TYPE SKL-HF /SKL-S BATCH NO. 78E073

d. PENETRANT REMOVER TYPE SKC-S BATCH NO. 78C130

e. DEVELOPER TYPE SKD-S BATCH NO. 78D056

f. POST EXAMINATION CLEANER TYPE SKC-S BATCH NO. 78C130

D. Pre-Examination Requirements:

a. TEMPERATURE:

1. PENETRANT MATERIALS BETWEEN 60° F & 125° F - YES NO Temp. _____

2. COMPONENT SURFACE BETWEEN 60° F & 125° F - YES NO Temp. _____

b. SURFACE PREPARATION:

*1. Grinding *2. Flapping *3. None *4. Other N/A

E. Data: Note: All Exam. Components are ASME Section XI C-F Category

LINE NO.	DATE	PRE-CLEAN. EVAP. TIME (MIN)	PEN. DWELL TIME (MIN)	DEV. TIME (MIN)	EXAMINATION COMPONENT I.D. NO.	MAT'L	SURF. PREP.	RELEVANT INDICATION		ACCEPTABLE		RELEVANT INDICATION LOCATION/SIZE OR COMMENTS
								YES	NO	YES	NO	
1	12-21	6	22	5	TR4-1008-28	CS	2	✓		✓		
2	12-21	6	22	5	TR4-1008-23	CS	2	✓		✓		
3	2-21	6	22	5	TR4-1008-33	CS	2	✓		✓		* Two linear indications which are side by side located 1" to 2" from top of the weld and in upstream. Also 5 1/2" Cr.C.W. from T23. Both are 4" long.
4												
5												
6												
7												
8												
9												
10	* Data on line 2 voided per MCCC MRD540 7056 LWW 4/30/81											
11												
12												
13												
14												
15												

* Note: For each exam component ID NO., place the applicable number(s) (1, 2, 3 etc) in its appropriate column.

Reviewed By: [Signature]

NDE SUPERVISOR [Signature] DATE 2-26-79

QC SUPERVISOR [Signature] DATE 3-1-79

AUTHORIZED INSPECTOR [Signature] DATE 3-8-79

INSTALLATION & SERVICE ENGINEERING DIVISION

LASALLE COUNTY NUCLEAR STATION UNIT 1

A. PROCEDURE NO. PP-S751 REV. 7

B. EXAMINATION PERSONNEL:

NAME C. Tomlin LEVEL II
 NAME NA LEVEL NA

C. PENETRANT MATERIALS:

a. MANUFACTURER MAGNAFLUX-SPOTCHECK
 b. PRE-CLEANING SOLVENT TYPE SKC-S BATCH NO. 79C014
 c. PENETRANT TYPE SKL-HF /SKL-S BATCH NO. 79B109
 d. PENETRANT REMOVER TYPE SKC-S BATCH NO. 79C014
 e. DEVELOPER TYPE SKD-S BATCH NO. 79E033
 f. POST EXAMINATION CLEANER TYPE SKC-S BATCH NO. 79C014

D. PRE-EXAMINATION REQUIREMENTS:

a. TEMPERATURE:

1. PENETRANT MATERIALS BETWEEN 60° F & 125° F - YES NO
 2. COMPONENT SURFACE BETWEEN 60° F & 125° F - YES NO

b. SURFACE PREPARATION:

*1. GRINDING *2. FLAPPING *3. NONE *4. OTHER

E. DATA: NOTE: All Exam components are ASME Sect. XI Category CF

LINE NO.	DATE	PRE-CLEAN EVAP. TIME	PEN. DWELL TIME	PEN. REM. EVAP. TIME	DEV. TIME	EXAMINATION COMPONENT I.D. NO.	MAT'L	SURF PREP #	RELEVANT INDICATION		ACCEPTABLE		RELEVANT INDICATION LOCATION/SIZE OR COMMENTS
									YES 09	NO 10	YES 11	NO 12	
1	4-2	5	10	5	15	1RH-1041-30	CS	2		X	X		
2	4-2	5	10	5	15	1RH-1023-2	CS	2		X	X		
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													

NOTE: FOR EACH EXAM COMPONENT ID NO., PLACE THE APPLICABLE NUMBER(S) (1,2,3 etc) IN ITS APPROPRIATE COLUMN.

REVIEWED BY: NCE SUPERVISOR A. J. Connelly DATE 4/2/81
 QC SUPERVISOR R. W. Whitley DATE 4/15/81
 AUTHORIZED INSPECTOR S. J. F. Han DATE 4-15-81

INSTALLATION & SERVICE ENGINEERING DIVISION

LASALLE COUNTY NUCLEAR STATION UNIT 1

A. PROCEDURE NO. PP-S751 REV. 7

EXAMINATION PERSONNEL:

NAME CA Bombardier LEVEL II
 NAME NA LEVEL NA

C. PENETRANT MATERIALS:

a. MANUFACTURER MAGNAFLUX-SPOTCHECK
 b. PRE-CLEANING SOLVENT TYPE SKC-S BATCH NO. 79C014
 c. PENETRANT TYPE SKL-HF /SKL-S BATCH NO. 79B109
 d. PENETRANT REMOVER TYPE SKC-S BATCH NO. 79C014
 e. DEVELOPER TYPE SKD-S BATCH NO. 79E033
 f. POST EXAMINATION CLEANER TYPE SKC-S BATCH NO. 79C014

D. PRE-EXAMINATION REQUIREMENTS:

a. TEMPERATURE:

1. PENETRANT MATERIALS BETWEEN 60° F & 125° F - YES NO
 2. COMPONENT SURFACE BETWEEN 60° F & 125° F - YES NO

b. SURFACE PREPARATION:

*1. GRINDING *2. FLAPPING *3. NONE *4. OTHER

E. DATA: NOTE: All Exam components are ASME Sect. XI Category. CF

LINE NO.	DATE	PRE-CLEAN EVAP. TIME	PEN. DUELL. TIME	PEN. REM. EVAP. TIME	DEV. TIME	EXAMINATION COMPONENT I.D. NO.	MAT'L	SURF. PREP. #	RELEVANT INDICATION		ACCEPTABLE		RELEVANT INDICATION LOCATION/SIZE OR COMMENTS
									YES 09	NO 10	YES 11	NO 12	
1	4-6	5	10	5	15	1RH1041-31	CS	2	X		X		
2													
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													

NOTE: FOR EACH EXAM COMPONENT ID NO., PLACE THE APPLICABLE NUMBER(S) (1,2,3 etc) IN ITS APPROPRIATE COLUMN.


REVIEWED BY: NCE SUPERVISOR AD Connelly DATE 4/7/81
 QC SUPERVISOR LW Wheatley DATE 4/15/81
 AUTHORIZED INSPECTOR S.A. Feltner DATE 4-15-81

A. Procedure No. MPUP-5751 REV. 6
 Examination Personnel: NAME Ch. Tomlin LEVEL 2 NAME A. Conolly LEVEL 1T
 Instrument: SERIAL NO. 1348 MAKE/MODEL: - BRANSON/303: SONIC/MK I; KK/USL32; OTHER
 D. Search Unit: BEAM ANGLE/MODE: STRAIGHT BEAM/LONG WAVE; 45°/TRANS WAVE; 60°/TRANS WAVE
 TRANSDUCER SIZE/FREQ: 0.25" DIA/2.25 MHz; 0.5" DIA/2.25 MHz; 1.0" DIA/2.25 MHz
 SERIAL NO.: D 05854; 1.0" DIA/2.25 MHz; 0.5"x0.5"/2.25 MHz
 TRANSDUCER TYPE: CERAMIC SINGLE ELEMENT; CERAMIC DUAL ELEMENT; OTHER
 WEDGE TYPE: STANDARD WEDGE; SPECIAL WEDGE/TYPE
 CALCULATED BEAM ANGLE IN MATERIAL: $\theta_2 = 45^\circ$
 E. Cable LENGTH: 6 FT. TYPE: RG-58; RG-59; RG-57; RG-174; OTHER
 F. Calibration Orientation: CALIBRATION REFERENCE REFLECTOR: PARALLEL; TRANSVERSE TO PIPE AXIS
 FOR DUAL ELEMENT: SPLIT FOR MAXIMUM RESPONSE PARALLEL; TRANSVERSE to hole centerline
 G. Calibration Standard: LSCS CAL STD. NO. 01-18-01 THICKNESS .57 DIAMETER 18"
 MATERIAL: CARBON; STAINLESS; INCONEL; OTHER
 H. Couplant: GLYCERINE; ULTRAGEL II; OTHER
 L. Comments: +6dB = 6/8 V To 100% DAC

J. Dac Curve -- Data

REFLECTOR	PEAK AMP	W1	Wm	W2	MP1	MPm	MP2	HOLE DEPTH
01	02	03	04	05	06	07	08	09
W-T of 4/8 V	80%		.58			.80		
W-T of 2/8 V	60%		1.16			1.60		
W-T of 12/8 V	45%		1.72			2.40		
S-R of 6-6	100% 6dB		.92			1.70		.28

K. Dac Curve -- Screen Representation



L. Instrument Settings/Checks

CONTROLS	SET	CHECK BOXES							
		01	02	03	04	05	06	07	08
GAIN	42 dB	✓							
SCAN GAIN	50 dB	✓							
SWEEP	2.5/870	✓							
DELAY	757	✓							
FILTER	AUTO	✓							
REP RATE	MED	✓							
DAMPENING	OFF	✓							
ECT.	OFF	✓							
OTHER	NA	✓							

M. Calibration Time -- Records

DATE	01 ORIG. CAL. TIME	02 CAL. CHECK TIME	03 LAST E.D.S. #	04 LAST E.D.S. LINE #	05 VERIFICATION OF 25°F LIMIT (YES/NO)
1981					
4-3	1245	NA	NA	NA	Yes
4-8	NA	1545	77620	5	Yes
4-8	NA	1545	77621	5	Yes
4-8	NA	1545	77622	8	Yes
4-8	NA	1545	77623	8	Yes

N. Reviewed By: NDE SUPERVISOR A. Conolly
 Q.C. SUPERVISOR [Signature]
 AUTHORIZED INSPECTOR [Signature]

DATE 4/9/81
 DATE 4/28/81
 DATE 4-29-81

EDS# 77620

CDS# 77619

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP 5751 REV. 6


EXAMINATION PERSONNEL:
 NAME LA Homer LEVEL II; NAME SD Connelly LEVEL IT

SEARCH UNIT BEAM ANGLE: 0°; 45°; X 60°; OTHER _____

COUPLANT: GLYCERINE: X ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION



DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/W1	Lm/Wm	L2/W2	MP1	MPm	MP2	SCAN	STAT.	COMMENTS
4-8	1	1RH1023 7	EP	100 +6	360	INT	1.0		1.9		5A	E	* FDFS
4-8	2	7	EP	75	300	INT	1.0		2.2		5A	E	* FDFS
4-8	3	7	EP	75	300	INT	1.2		2.6		5A	E	FDCL
4-8	4	1RH1023 7	EP	75	300	INT	1.82		2.5		5B	E	FONS
4-8	5				* STERED INDICATIONS APPEAR INDIVIDUALLY & SIMULTANEOUSLY. POSSIBLE MODE CONVERSION.								

REVIEWED BY: NDE SUPERVISOR SD Connelly DATE 4/9/81
 QC SUPERVISOR LW Whately DATE 4/28/81
 AUTHORIZED INSPECTOR w J Caldwell DATE 4-29-81

LASALLE UNIT 2

$T_E =$.68

WELD IRH-1023-7

$T_W =$.68

EDS 77620

$T_P =$.59

GENERAL  ELECTRIC



LINE	EVALUATION
1,2	OD geometry from weld cap
3,4	ID geometry from weld root

EVALUATED BY L D Wheatley
Level III

DATE 4/28/81

REVIEWED BY w J Caldwell
ANII

DATE 4-29-81

EDS # 77621

CDS # 77619

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. M.PUP 5751 REV. 6


EXAMINATION PERSONNEL:
 NAME EA Homer LEVEL II; NAME JD Connelly LEVEL IT

SEARCH UNIT BEAM ANGLE: 0°: _____ 45°: X 60°: _____ OTHER _____

COUPLANT: GLYCERINE: K ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION




DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/W1	L _n /W _m	L2/W2	MP ₁	MP _m	MP ₂	SCAN	STAT.	COMMENTS
4-8	1	IRH 1041 31	PE	60	360 INT	1.7			2.65		5A	E	FDNS
4-8	2	31	PE	75	360 INT	.75			1.9		5B	E	FDFS
4-8	3	31	PE	90	360 INT	1.1			2.65		5B	E	FDFS
4-8	4	IRH 1041 31	PE	75	360 INT	1.7			2.1		5B	E	FDNS
4-8	5	IRH 1023 4A	PE	100 +2	360 INT	1.0			1.95		5B	E	FDFS

REVIEWED BY: NDE SUPERVISOR JD Connelly DATE 4/9/81
 QC SUPERVISOR LQ Wheatley DATE 4/28/81
 AUTHORIZED INSPECTOR w j Caldwell DATE 4-29-81

LASALLE UNIT 1
 WELD 1RH 1041-31
 EDS 77621

$T_p =$.61
 $T_w =$.68
 $T =$.69

GENERAL  ELECTRIC



LINE	EVALUATION
1,3	ID geometry
2,4	OD geometry from weld cap

EVALUATED BY L D Wheatley DATE 4/28/81
 Level III
 REVIEWED BY w J Caldwell DATE 4-29-81
 ANII

LASALLE UNIT 1

$T_p =$.59


WELD JRH-1023-4A

$T_w =$.65

EDS 77621

$T_E =$.67

GENERAL  ELECTRIC



LINE	EVALUATION
5	OD geometry from weld cap

EVALUATED BY L D Wheatley
Level III

DATE 4/28/61

REVIEWED BY W J Caldwell
ANII

DATE 4-29-61

EDS# 77622

CDS# 77619

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP 5751 REV. 6


EXAMINATION PERSONNEL:
 NAME W. J. Colburn LEVEL II; NAME A. D. Connelly LEVEL IT

SEARCH UNIT BEAM ANGLE: 0°; X 45°; 60°; OTHER _____

COUPLANT: GLYCERINE: X ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION




DATE 1981	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/W1	Lm/Wm	L2/W2	MP1	MPm	MP2	SCAN	STAT.	COMMENTS
4-8	1	12H 1023 2	EP	100 +4	360 INT	1.9			2.6		5B	E	FDMS
4-8	2	2	EP	100	360 INT	1.1			2.3		5B	E	FDFS
4-8	3	2	EP	50		6.9			1.95		3A	A	FDOD-SPOT ONLY
4-8	4	2	EP	50		7.1			1.95		3A	A	FDOD-SPOT ONLY
4-8	5	2	EP	100 +4	360 INT	1.0			1.9		5A	E	FDFS
4-8	6	2	EP	75	360 INT	1.0			2.2		5A	E	FDFS
4-8	7	12H 1023 2	EP	100	360 INT	1.2			2.6		5A	E	FDCL
4-8	8				* STARRED INDICATIONS APPEAR INDIVIDUALLY & SIMULTANEOUSLY. POSSIBLE MODE CONVERSION.								

REVIEWED BY: NDE SUPERVISOR A. D. Connelly DATE 4/9/81
 QC SUPERVISOR L. V. Whetter DATE 4/28/81
 AUTHORIZED INSPECTOR W. J. Colburn DATE 4-29-81

LASALLE UNIT 1
 WELD IRH-1023-2
 EDS 77622

$T_E =$.65
 $T_W =$.71
 $T_D =$.62

GENERAL  ELECTRIC



LINE	EVALUATION
1-6	OD geometry + subsequent mode conversion from weld cap

EVALUATED BY L D Wheatly
 Level III

DATE 4/28/81

REVIEWED BY W J Caldwell
 ANII

DATE 4-29-81

EDS # 77623

CDS # 77619

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP 5751 REV. 6


EXAMINATION PERSONNEL:
 NAME W. Homler LEVEL II; NAME J. P. Connelly LEVEL IT

SEARCH UNIT BEAM ANGLE: 0°: _____ 45°: X 60°: _____ OTHER: _____

COUPLANT: GLYCERINE: X ULTRAGEL II: _____ OTHER: _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION



DATE	LIN# P.O.	EXAM I.D.	COMP FIG.	MAX AMP	L1/ W1	Lm/ Wm	L2/ W2	MP ₁	MP _m	MP ₂	SCAN	STAT.	COMMENTS
4-8	1	1R14 1023 14	PE	100	360	1.6	1.05				5B	E	
4-8	2	14	PE	100 +4	360	.85	1.7				5B	A	* FDFS
4-8	3	14	PE	60	360	.85	2.05				5B	E	* FDFS
4-8	4	14	PE	75	360	1.3	2.55				5B	E	FDCL
4-8	5	14	PE	100	360	1.6	2.4				5A	E	FDMS
4-8	6	14	PE	50	19.4	1.1	1.8				4A	A	FDOD-SPOT ONLY
4-8	7	1R14 1023 14	PE	75	11.6	.8	1.5				4A	A	SPOT ONLY
4-8	8				* STARRED INDICATIONS APPEAR INDIVIDUALLY & SIMULTANEOUSLY POSSIBLE MODE CONVERSION.								

REVIEWED BY: J. P. Connelly DATE 4/9/81
 NDE SUPERVISOR
 QC SUPERVISOR L. W. Wheatley DATE 4/28/81
 AUTHORIZED INSPECTOR W. J. Caldwell DATE 4-29-81

LASALLE UNIT 1

$T_p =$.57


WELD IRH-1023-14

$T_w =$.67

EDS 77623

$T_{E'} =$.61

GENERAL  ELECTRIC



LINE	EVALUATION
1,4,5	ID geometry
3	OD geometry of
3	Made conversion of weld cap

EVALUATED BY *R.D. Whately* DATE 4/28/81
 Level III

REVIEWED BY *W.J. Caldwell* DATE 4-29-81
 AWII

VISUAL EXAMINATION REPORT

LINE NO.	EXAM/COMPONENT I. D. NO.	SYS.	DWG.	SKETCH		DISCONTINUITIES	PHOTO	
				YES	NO		ROLL	FRAME
1	1E57-F063	MS	(IMS-1055)	/	/	NONE		
2	1E57-F008	RI	(IRI-1001)	/	/			
3	1E57-F064	RI	(IRI-1001)	/	/	Voided per mcco MRD 5446549		
4	1E57-F013	RI	(IRI-1002)	/	/			
5	1E12-F019	RI	(IRI-1003)	/	/			
6	1E57-F065-1	RI	(IRI-1005)	/	/			
7	1E57-F065-2	RH	(IRI-1003)	/	/			
8	1E12-F042B	RH	(IRH-1002)	/	/			
9	1E12-F042A	RH	(IRH-1003)	/	/			
10	1E12-F042C	RH	(IRH-1005)	/	/			
11	1E21-F005T	LP	(ILP-1001)	/	/			
12	1E21-F006-1	LP	(ILP-1001)	/	/			
13	1E21-F006-2	LP	(ILP-1001)	/	/			
14	1E21-F006-3	LP	(ILP-1001)	/	/			
15	1E33-F00D	RI	(IRI-1001)	/	/	Voided per mcco MRD 5417156		

* Attached

REVIEWED BY AND LEVEL

Ray Terry Level 2

Date: 12/17/80

A.N.I.

w J Caldwell

Date: 1-5-81

REVIEWED BY: *L D Wheatley* Date: *12/22/80*
 GENERAL ELECTRIC CO. LEVEL III

NDE Sup SAConnolly 12/17/80

VISUAL EXAMINATION

Site LA SAILE Preservice ISI DATE 5-6-81

Examiner and Level Ray Fung Level 2

Procedure PVI-15151 REV 2 Revision _____

I Hangers and Supports Discontinuities

- A. Settings
- B. Misalignment
- C. Broken Members
- D. Gouges
- E. Arc Strikes
- F. Grind Marks
- G. Movement
- H. Evidence of Leakage

II Pipe Welds and Base Material Discontinuities

- A. Ground Blend Areas
- B. Undercuts
- C. Corrosion Buildup
- D. Gouges
- E. Evidence of Leakage
- F. Arc Strikes
- G. Cracks

III Bolts, Studs and Washers Discontinuities

- A. Loose Members
- B. Cracks
- C. Corrosion
- D. Gouges
- E. Thread Damage

IV Pump and Valve Bodies, Casings, Internals Discontinuities

- A. Pitting
- B. Corrosion
- C. Erosion
- D. Foreign Material
- E. Gouges
- F. Wear
- G. Cracks

The Component Classification Number and Discontinuity Letter from above are to be used when completing attachment 2.

VT EXAMINATION DETAILS

Direct Visual; Remote Visual. Surface Condition SMOOTH

Surface Preparation Methods/Tools Used (if any) _____

Illumination Instruments Used FLASH LIGHT

Direct Visual Aides Used N/A

Remote Visual Equipment Used N/A

NDF Sup
SD Donnelly
5/6/81
200 Whately
5/11/81

W J Caldwell
5-13-81
AAFE

Ray Ferry Level 2

VISUAL EXAMINATION REPORT

LINE NO.	EXAM/COMPONENT I. D. NO.	SYS.	DWG.	SKETCH		DISCONTINUITIES	PHOTO	
				YES *	NO		ROLL	FRAME
1	1B33-F067A		IRR 1002			NONE		
2	1B33-F060A-1					"		
3	1B33-F060A-2					"		
4	1B33-F060A-3					"		
5	1B33-F060A-4		∨			"		
6	1B33-F023A		IRR 1003			"		
7	1B33-F067B		IRR 1006			"		
8	1B33-F060B-1					"		
9	1B33-F060B-2					"		
10	1B33-F060B-3					"		
11	1B33-F060B-4		∨			"		
12	1B33-F023B		IRR 1007			"		
13								
14								
15								

* Attached

REVIEWED BY AND LEVEL L. D. Whately Date: 5/11/81

A.N.I. W. J. Caldwell Date: 5-13-81

NDE Supp.
SD
5/6/81

Ray Terry Level 2

VT DATA SHT# 84520

5/6/81

Page 3 of 3

VISUAL EXAMINATION REPORT

LINE NO.	EXAM/COMPONENT I. D. NO.	SYS.	DWG.	SKETCH		DISCONTINUITIES	PHOTO	
				YES *	NO		ROLL	FRAME
1	1B21-F010 A-1	IFW 1001			-	NONE		
2	1B21-F010 A-2	↓			-	NONE		
3	1B21-F010 B-1	IFW 1002			-	NONE		
4	1B21-F010 B-2	↓			-	NONE		
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								

* Attached



REVIEWED BY AND LEVEL L D D Wheatley Date: 5/11/81

A.N.I. W J Calneel Date: 5-13-81

*NDE Sup
SD Connolly
5/6/81*

ULTRASONIC EXAMINATION DATA SHEET
LASALLE COUNTY STATION UNIT 1

A. Procedure No. MPDP-5751 REV. 4
 B. Examination Personnel:
 NAME Paul Walker LEVEL II NAME Fester Schmitz LEVEL II
 C. Search Unit Beam Angle ($\pm 2^\circ$): 0° 45° 60° Other _____
 D. Couplant: Glycerine Ultralag II Other _____
 E. Scan Sensitivity (+): 9 dB
 F. Reference System _____ G. Scan Orientation _____



H. Data: Data on lines 6,7 voided per MCCO MRP 5407056 KWW 4/30/81

01 DATE	02 EXAM/COMP. I.D. NO.	03 COMP. FIG.	04 REC. IND. YES/NO	05 MAX. DAC \ominus W _{mt}	06 L ₀ / W ₀	07 L	08 W ₁	09 W _m	10 W ₂	11 SRP ₁ or MP ₁	12 SRP _m or MP _m	13 SRP ₂ or MP ₂	14 SCAN	15 Comments (Thickness Meas.)
5-4-79	15	E-D	Yes	50%	4 / 360			1.5			6.0		5A	360 INT ODFD
5-4-79	15	E-D	Yes	50%	4 / 360			1.6			9.9		5A	360 INT
5-4-79	15	E-D	Yes	60%	4 / 360			3			6.0		5A	360 INT ODFD
5-4-79	15	E-D	Yes	100% ^{H30}	4 / 360			.3			6.0		5B	360 INT ODFD
5-4-79	15	E-D	Yes	55%	4 / 360			.3			3.0		5b	360 INT ID
5-4-79	23	P-E	Yes	100%	4 / 360			6			7.0		5A	360 INT FD
5-4-79	23	P-E	Yes	90%	4 / 360			1.5			6.0		5B	360 INT ED

L. Reviewed By: SD Corneley DATE 5/6/79
 NDE SUPERVISOR: _____ DATE 5/9/79
 QC SUPERVISOR: LW Whentley DATE _____
 AUTHORIZED INSPECTOR: William J. Caldwell DATE 6-12-79

INSTALLATION & SERVICE ENGINEERING DIVISION

A. Procedure No. MPUP-5751 REV. 6

Examination Personnel: NAME J. P. ... LEVEL 4 NAME J. ... LEVEL 17
Instrument SERIAL NO. 1348 MAKE/MODEL: - BRANSON/303: SONIC/MK I; KK/USL32; OTHER

D. Search Unit: BEAM ANGLE/MODE: STRAIGHT BEAM/LONG WAVE; 45°/TRANS WAVE; 60°/TRANS WAVE
TRANSDUCER SIZE/FREQ: 0.25" DIA/2.25 MHz; 0.5" DIA/2.25 MHz; 1.0" DIA/2.25 MHz
SERIAL NO.: H25831; 1.0" DIA/2.25 MHz; 0.5"x0.5"/2.25 MHz
TRANSDUCER TYPE: CERAMIC SINGLE ELEMENT; CERAMIC DUAL ELEMENT; OTHER
WEDGE TYPE: STANDARD WEDGE; SPECIAL WEDGE/TYPE
CALCULATED BEAM ANGLE IN MATERIAL: $\theta_2 = \underline{0}^\circ$

E. Cable: LENGTH: 6 FT. TYPE: RG-58; RG-59; RG-57; RG-174; OTHER

F. Calibration Orientation: CALIBRATION REFERENCE REFLECTOR: PARALLEL; TRANSVERSE TO PIPE AXIS
FOR DUAL ELEMENT: SPLIT FOR MAXIMUM RESPONSE PARALLEL; TRANSVERSE to hole center

G. Calibration Standard: LSCS CAL STD. NO. 01-18-01 THICKNESS .57 DIAMETER 1.5
MATERIAL: CARBON; STAINLESS; INCONEL; OTHER


H. Couplant: GLYCERINE; ULTRAGEL II; OTHER

I. Comments: _____

J. Dac Curve - Data

REFLECTOR	PEAK AMP	W1	Wm	W2	MP1	MPm	MP2	HOLE DEPTH
08	01	02	03	04	05	06	07	09
WT of 78 Vee								
WT of 78 Vee	50%					.23		.23
WT of 78 Vee								
B.R. of 78 Vee	100% +6					.57		

K. Dac Curve - Screen Representation



L. Instrument Settings/Checks

CONTROLS	SET	CHECK BOXES							
		02	03	04	05	06	07	08	09
GAIN	2	✓	✓						
SCAN GAIN	40	✓	✓						
SWEEP	5/684	✓	✓						
DELAY	7.46	✓	✓						
FILTER	AUTO	✓	✓						
REP RATE	MED	✓	✓						
COMPENSING	OFF	✓	✓						
JECT...	OFF	✓	✓						
OTHER	NA	✓	✓						

M. Calibration Time - Records

1981 DATE	01 ORIG. CAL TIME	02 CAL CHECK TIME	03 LAST E.D.S. #	04 LAST E.D.S. LINE #	05 VERIFICATION OF 25°F LIMIT (YES/NO)
3/27	0845	NA	NA	NA	YES
3/27	NA	1235	92284	2	YES
3/27	NA	1500	92284	4	YES

N. Reviewed By: NDE SUPERVISOR J. D. Connelly DATE 3/30/81
 Q.C. SUPERVISOR J. ... DATE 4/13/81
 AUTHORIZED INSPECTOR J. S. ... DATE 4-15-81

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP-5751 REV. 6


EXAMINATION PERSONNEL:
 NAME Jerry [Signature] LEVEL II; NAME [Signature] LEVEL IT

SEARCH UNIT BEAM ANGLE: 0°: X 45°: _____ 60°: _____ OTHER _____

COUPLANT: GLYCERINE: X ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION



1981 DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/W1	Lm/Wm	L2/W2	MP1	MPm	MP2	SCAN	STAT.	COMMENTS
3-27	1	1RH-1024 4A	P-V		P	W	U	NO SCAN VALUE				A	
3-27	2	1RH-1023 16	E-P		.61	.74	N/A	SIDE				A	
3-27	3	9	E-P		.68	.67	.61					A	
3-27	4	8	P-E		.63	.69	.58					A	
					P	W	E						
					.58	.62	.65						

REVIEWED BY: [Signature] DATE 3/30/81
 NDE SUPERVISOR _____
 QC SUPERVISOR [Signature] DATE 4/15/81
 AUTHORIZED INSPECTOR [Signature] DATE 4-15-81

INSTALLATION & SERVICE ENGINEERING DIVISION

A. Procedure No. MPUP-5751 REV. 6

B. Examination Personnel: NAME J. J. [unclear] LEVEL II NAME [unclear] LEVEL IT

Instrument: SERIAL NO. 339 MAKE/MODEL: - BRANSON/303: SONIC/MK I: KX-USL32: OTHER [unclear]

D. Search Unit: BEAM ANGLE/MODE: STRAIGHT BEAM/LONG WAVE: 45°/TRANS WAVE: 60°/TRANS WAVE
 TRANSDUCER SIZE/FREQ: 0.25" DIA/2.25 MHz: 0.5" DIA/2.25 MHz: 1.0" DIA/2.25 MHz
 SERIAL NO.: D05854; 1.0" DIA/2.25 MHz: 0.5" x 0.5" / 2.25 MHz
 TRANSDUCER TYPE: CERAMIC SINGLE ELEMENT CERAMIC DUAL ELEMENT OTHER
 WEDGE TYPE: STANDARD WEDGE SPECIAL WEDGE/TYPE
 CALCULATED BEAM ANGLE IN MATERIAL: $\theta_2 = 46.4^\circ$

E. Cable LENGTH: 6 FT. TYPE: RG-58 RG-59 RG-57 RG-174 OTHER

F. Calibration Orientation: CALIBRATION REFERENCE REFLECTOR: PARALLEL TRANSVERSE TO PIPE AXIS
 FOR DUAL ELEMENT: SPLIT FOR MAXIMUM RESPONSE PARALLEL TRANSVERSE to hole centerline

G. Calibration Standard: LSCS CAL STD. NO. 01-18-01 THICKNESS .57" DIAMETER 18"
 MATERIAL: CARBON STAINLESS INCONEL OTHER


H. Couplant: GLYCERINE ULTRAGEL OTHER

I. Comments: +4 dB = 6/8 V TO 100% DAC

J. Dac Curve - Data

W T or E R or L R or C R or	PEAK AMP dB	W1 dB	Wm dB	W2 dB	MP1 dB	MPm dB	MP2 dB	HOLE DEPTH in
4/8 Year	802		59			.79		
2/8 Year	682		1.2			1.61		
1/8 Year	522		1.75			2.41		
1/8 Year	1002		.93			1.2	.28	

K. Dac Curve - Screen Representation



L. Instrument Settings/Checks

CONTROLS	SET	CHECK BOXES								
		01	02	03	04	05	06	07	08	09
GAIN	60	/	/							
SPAN GAIN	68	/	/							
SWEEP	5/7.06	/	/							
DELAY	1/7.77	/	/							
FILTER	1	/	/							
REP RATE	1000	/	/							
CH. NING	OFF	/	/							
REFLECT	OFF	/	/							
OTHER	NA	/	/							

M. Calibration Time - Records

1981 DATE	01 ORIG CAL TIME	02 CAL CHECK TIME	03 LAST E.D.S. #	04 LAST E.D.S. LINE #	05 VERIFICATION OF 25°F LIMIT (YES/NO)
3-27	0900	NA	NA	NA	YES
3-27	NA	1235	92286	7	YES
3-27	NA	1500	92287	6	YES
3-27	NA	1500	92288	8 ^{P10}	YES
3-27	NA	1500	92288	2 ^{P10}	YES

N. Reviewed By: NDE SUPERVISOR [Signature]
 Q.C. SUPERVISOR [Signature]
 AUTHORIZED INSPECTOR [Signature]

DATE 3/30/81
 DATE 4/30/81
 DATE 4-30-81

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP-375-1 REV. 6

EXAMINATION PERSONNEL:
 NAME Larry Anderson LEVEL II; NAME J. E. Brady LEVEL IV


SEARCH UNIT BEAM ANGLE: 0°: _____ 45°: X 60°: _____ OTHER _____

COUPLANT: GLYCERINE: X ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION

* - APPEAR SAME TIME ON CRT



1981 DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/W1	Lm/Wm	L2/W2	MF1	MPm	MP2	SCAN	STAT.	COMMENTS
3-27	1	<u>14H-1023</u> <u>8</u>	<u>P-E</u>	<u>100%</u> <u>+4</u>	<u>360</u>	<u>INT</u>	<u>.95</u>		<u>1.81</u>		<u>SB</u>	<u>A</u>	<u>FDFT</u>
3-27	2	<u>8</u>	<u>P-E</u>	<u>80%</u>	<u>360</u>	<u>INT</u>	<u>.7</u>		<u>1.1</u>		<u>SB</u>	<u>E</u>	
3-27	3	<u>8</u>	<u>P-E</u>	<u>100%</u> <u>+6</u>	<u>360</u>	<u>INT</u>	<u>1.1</u>		<u>2.05</u>		<u>SB</u>	<u>E</u>	<u>FDFS</u> *
3-27	4	<u>8</u>	<u>P-E</u>	<u>60%</u>	<u>360</u>	<u>INT</u>	<u>1.1</u>		<u>2.4</u>		<u>SB</u>	<u>E</u>	<u>FDFS</u> *
3-27	5	<u>8</u>	<u>P-E</u>	<u>75%</u>	<u>360</u>	<u>INT</u>	<u>1.95</u>		<u>2.65</u>		<u>SA</u>	<u>E</u>	<u>FDNS</u>
3-27	6	<u>8</u>	<u>P-E</u>	<u>80%</u>	<u>360</u>	<u>INT</u>	<u>1.3</u>		<u>.81</u>		<u>SA</u>	<u>E</u>	
3-27	7	<u>8</u>	<u>P-E</u>	<u>60%</u>	<u>360</u>	<u>INT</u>	<u>1.5</u>		<u>1.4</u>		<u>SA</u>	<u>A</u>	<u>FDNT</u>

REVIEWED BY: A. J. Connelly DATE 3/30/81
 NDE SUPERVISOR _____
 QC SUPERVISOR L. W. Whately DATE 4/30/81
 AUTHORIZED INSPECTOR W. J. Colwell DATE 4-30-81

LASALLE UNIT 1

$T_p =$.58


WELD 1RH-1023-8

$T_w =$.62

EDS 92286

$T_e =$.65

GENERAL  ELECTRIC



LINE	EVALUATION
2	Made concession off weld root
3,4	OD geometry from weld cap
3,6	ID geometry from counter bore
5	ID geometry from weld root

EVALUATED BY L D Wheatley
Level III

DATE 4/30/81

REVIEWED BY W J Caldwell
ANII

DATE 4-30-81

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP-575-1 REV. 6


EXAMINATION PERSONNEL:
 NAME Tony B. Anderson LEVEL II; NAME J. E. Cooney LEVEL IT

SEARCH UNIT BEAM ANGLE: 0°: _____ 45°: X 60°: _____ OTHER _____

COUPLANT: GLYCERINE: X ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION



1981 DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/ W1	Lm/ Wm	L2/ W2	MP ₁	MP _m	MP ₂	SCAN	STAT.	COMMENTS	
3-27	1	1RH-1024 4A	P-V		NO SCAN			VALVE SIDE						
3-27	2	1RH-1024 4A	P-V	80%	38.6	38.8	39.1	.9	.95	1.1	1.65	1.8	1.95	3A E FDOD
3-27	3	1RH-1023 9	E-P	75%	360 INT				1.9		2.65		5B E FDNS	
3-27	4	9	E-P	80%	360 INT				.95		1.9		5A A FDET	
3-27	5	9	E-P	100% r2	360 INT				.6		1.1		5A E	
3-27	6	9	E-P	55%	360 INT				1.25		2.45		5A E FDFS	

REVIEWED BY: J. D. Connelly DATE 3/30/81
 NDE SUPERVISOR
 QC SUPERVISOR L. D. Wheatley DATE 4/30/81
 AUTHORIZED INSPECTOR w. g. Caldwell DATE 4-30-81

LASALLE UNIT 2

$T_p =$.61


WELD IRH-1024-4A

$T_w =$.74

EDS 92287

$T =$ _____

GENERAL  ELECTRIC



LINE	EVALUATION
2	Based on metal path & the fact that the indication jinger clamps, this is probably a localized OD geometric reflector

EVALUATED BY L D Wheatley
Level III

DATE 4/30/81


REVIEWED BY W J Callwell
AMII

DATE 4-30-81

LASALLE UNIT 2
 WELD IRH-1023-9
 EDS 92287

$T_R = .63$
 $T_w = .69$
 $T_p = .58$

GENERAL  ELECTRIC



LINE	EVALUATION
3,5	ID geometry from weld root
6	Made conversion off weld cap

EVALUATED BY L D Whitley
 Level III

DATE 4/30/81

REVIEWED BY w J Caldwell
 AMII

DATE 4-30-81

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP-575-1 REV. 6


EXAMINATION PERSONNEL:
NAME Fay Mitchell LEVEL II; NAME J. Kelly LEVEL IV

SEARCH UNIT BEAM ANGLE: 0°; 45°; X 60°; OTHER _____

COUPLANT: GLYCERINE: X ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION



1981 DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/W1	Lm/Wm	L2/W2	MP ₁	MP _m	MP ₂	SCAN	STAT.	COMMENTS	
3-27	1	16	E-P	75%	360	.9	INT		1.85		5B	A	FDFT	
3-27	2	16	E-P	100%	360	1.9	INT		2.75		5B	E	FDNS	
3-27	3	16	E-P	55%	360	1.7	INT		2.45		5B	E	FDNS	
3-27	4	16	E-P	55%	360	.9	INT		1.75		5A	A	FDFT	
3-27	5	16	E-P	100%	360	1.0	INT		1.65		5A	A	FDFT	
3-27	6	16	E-P	75%	360	1.45	INT		2.6		5A	E	FDNS	
3-27	7	16	E-P	80%	35.52	35.3	35.15	1.2	1.5	1.65	1.7	1.81	1.95	4B E FDOD
3-27	8	16	E-P	80%	37.7	38.0	38.2	1.4	1.6	2.1	1.75	1.9	2.1	3B E FDOD

REVIEWED BY: A. J. Connelly DATE 3/30/81
 NDE SUPERVISOR _____
 QC SUPERVISOR L. D. Wheatley DATE 4/30/81
 AUTHORIZED INSPECTOR W. J. Calhoun DATE 4-30-81

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET

LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP-5751 REV. 6


EXAMINATION PERSONNEL:
 NAME Ray M. Radant LEVEL III; NAME J. E. Conroy LEVEL IV

SEARCH UNIT BEAM ANGLE: 0°; 45°; X 60°; OTHER _____

COUPLANT: GLYCERINE: X ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION



1981 DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L ₁ /W ₁	L _m /W _m	L ₂ /W ₂	MP ₁	MP _m	MP ₂	SCAN	STAT.	COMMENTS
3-27	1	IRN-1023 16	E-P	50%		45.5			1.81		4B	E	SPOT ONLY FDOD
3-27	2	16	E-P	60%		48.4			1.81		3B	E	SPOT ONLY FDOD

REVIEWED BY: A. J. Connelly DATE 3/30/81
 NDE SUPERVISOR _____
 QC SUPERVISOR L. J. Wheatley DATE 4/30/81
 AUTHORIZED INSPECTOR W. J. Caldwell DATE 4-30-81

LASALLE UNIT 2

T_a = .63


WELD IRH-1023-16

T_w = .67

EDS 92288

T_p = .58

GENERAL  ELECTRIC



LINE	EVALUATION
2,3,6	ID geometry from weld root & counter bore
7,8,12	Based on metal path & the fact, the indication brings clamps these are from a localized OD geometry

EVALUATED BY R. W. Wheatley
Level III

DATE 4/30/81

REVIEWED BY W. G. Caldwell
ANII


DATE 4-30-81

- A. Procedure No. MPUP-5751 REV. 6
- B. Examination Personnel: NAME [Signature] LEVEL III NAME [Signature] LEVEL IV
- C. Instrument: SERIAL NO. 551 MAKE/MODEL: - BRANSON/303: SONIC/MK I; KX/USL32; OTHER
- D. Search Unit: BEAM ANGLE/MODE: STRAIGHT BEAM/LONG WAVE; 45°/TRANS WAVE; 60°/TRANS WAVE
 TRANSDUCER SIZE/FREQ: 0.25" DIA/2.25 MHz; 0.5" DIA/2.25 MHz; 1.0" DIA/2.25 MHz
 SERIAL NO.: 425831; 1.0" DIA/2.25 MHz; 0.5"x0.5"/2.25 MHz
 TRANSDUCER TYPE: CERAMIC SINGLE ELEMENT; CERAMIC DUAL ELEMENT; OTHER
 WEDGE TYPE: STANDARD WEDGE; SPECIAL WEDGE/TYPE
 CALCULATED BEAM ANGLE IN MATERIAL: $\theta_2 =$ C
- E. Cable: LENGTH: 6 FT. TYPE: RG-58; RG-59; RG-57; RG-174; OTHER
- F. Calibration Orientation: CALIBRATION REFERENCE REFLECTOR: PARALLEL; TRANSVERSE TO PIPE AXIS
 FOR DUAL ELEMENT: SPLIT FOR MAXIMUM RESPONSE PARALLEL; TRANSVERSE to hole centerline
- G. Calibration Standard: LSCS CAL STD. NO. C1-18-01 THICKNESS .57 DIAMETER 1.5"
 MATERIAL: CARBON; STAINLESS; INCONEL; OTHER
- H. Couplant: GLYCERINE; ULTRAGEL II; OTHER
- I. Comments: _____

J. Dbc Curve - Data

ECTOR	PEAK AMP	W1	Wm	W2	MP1	MPm	MPz	HOLE DEPTH
08	21	02	03	04	05	06	07	08
W T or R Vee								
W T or R Vee	508					.24		.24
W T or R Vee								
S.R. or R Vee	1008					.57		
	806							

K. Dbc Curve - Screen Representation



L. Instrument Settings/Checks

CONTROLS	SET	CHECK BOXES							
		02	03	04	05	06	07	08	09
GAIN	32	✓							
SCAN GAIN	40	✓							
SWEEP	675	✓							
DELAY	753	✓							
FILTER	AUTO	✓							
REP RATE	MED	✓							
COMPENSING	OFF	✓							
ECT	OFF	✓							
OTHER	LA	✓							

M. Calibration Time - Records

DATE	01 ORIG CAL TIME	02 CAL CHECK TIME	03 LAST E.D.S. #	04 LAST E.D.S. LINE #	05 VERIFICATION OF 25°F LIMIT (YES/NO)
1981					
4-8	0855	NA	NA	NA	YES
4-8	NA	1135	92290	5	YES

N. Reviewed By: NDE SUPERVISOR [Signature]
 Q.C. SUPERVISOR [Signature]
 AUTHORIZED INSPECTOR [Signature]

DATE 4/9/81
 DATE 4/5/81
 DATE 4-15-81

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP-5751 REV. 6


EXAMINATION PERSONNEL:
 NAME [Signature] LEVEL II; NAME [Signature] LEVEL IV

SEARCH UNIT BEAM ANGLE: 0°: 45°: _____ 60°: _____ OTHER _____

COUPLANT: GLYCERINE: ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION



1981 DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/W1	Lm/Wm	L2/W2	MP1	MPm	MP2	SCAN	STAT.	COMMENTS
4-8	1	IRH-1041 31	P-E		P	W	E					A	
4-8	2	IRH-1023 2	E-P		E	W	P					A	
4-8	3	4A	P-E		.59	.65	.67					A	
4-8	4	7	E-P		E	W	P					A	
4-8	5	14	P-E		.57	.67	.61					A	

REVIEWED BY: NDE SUPERVISOR [Signature] DATE 4/9/81
 QC SUPERVISOR [Signature] DATE 4/15/81
 AUTHORIZED INSPECTOR [Signature] DATE 4-15-81


INSTALLATION & SERVICE ENGINEERING DIVISION

- A. Procedure No. MPUP-5751 REV. 6
- B. Examination Personnel: NAME J. Connelly LEVEL UT NAME J. Connelly LEVEL UT
- C. Instrument: SERIAL NO. 521 MAKE/MODEL: - BRANSON/303: SONIC/MK I; K7USL32; OTHER
- D. Search Unit: BEAM ANGLE/MODE: STRAIGHT BEAM/LONG WAVE; 45°/TRANS WAVE; 60°/TRANS WAVE
 TRANSDUCER SIZE/FREQ: 0.25" DIA/2.25 MHz; 0.5" DIA/2.25 MHz; 1.0" DIA/2.25 MHz
 SERIAL NO.: A22010; 1.0" DIA/2.25 MHz; 0.5"x0.5"/2.25 MHz
 TRANSDUCER TYPE: CERAMIC SINGLE ELEMENT; CERAMIC DUAL ELEMENT; OTHER
 WEDGE TYPE: STANDARD WEDGE; SPECIAL WEDGE/TYPE
 CALCULATED BEAM ANGLE IN MATERIAL: $\theta_2 =$ 0.1
- E. Cable LENGTH: 6 FT. TYPE: RG-58; RG-59; RG-57; RG-174; OTHER
- F. Calibration Orientation: CALIBRATION REFERENCE REFLECTOR: PARALLEL; TRANSVERSE TO PIPE AXIS
 FOR DUAL ELEMENT: SPLIT FOR MAXIMUM RESPONSE PARALLEL; TRANSVERSE to hole centerline
- G. Calibration Standards: LSCS CAL STD. NO. C1-18-05 THICKNESS .38 DIAMETER 18"
 MATERIAL: CARBON; STAINLESS; INCONEL; OTHER
- H. Couplant: GLYCERINE; ULTRAGEL II; OTHER
- L. Comments:

J. Dac Curve - Data

ECTOR	PEAK AMP	W1	Wm	W2	MP1	MPm	MP2	HOLE DEPTH
01	01	02	03	04	05	06	07	08
W T or 78 Vee								
W T or 48 Vee	50%					16		16
W T or 78 Vee								
B.R. or 48 Vee	100%					38		

K. Dac Curve - Screen Representation



L. Instrument Settings/Checks

CONTROLS	SET	CHECK BOXES							
		02	03	04	05	06	07	08	09
GAIN	48								
SCAN GAIN	56								
SWEEP	1/671								
DELAY	751								
FILTER	AUTO								
REP RATE	MED								
DAMPENING	OFF								
ECT	OFF								
OTHER	NA								

M. Calibration Time - Records

1981 DATE	01 ORIG CAL TIME	02 CAL CHECK TIME	03 LAST E.D.S. #	04 LAST E.D.S. LINE #	05 VERIFICATION OF 25°F LIMIT (YES/NO)
4-9	0910	NA	NA	NA	YES
4-9	NA	1130	92292	1	YES

N. Reviewed By: NDE SUPERVISOR J. Connelly DATE 4/10/81
 Q.C. SUPERVISOR J. Connelly DATE 4/15/81
 AUTHORIZED INSPECTOR J. Connelly DATE 4-15-81

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP-575-1 REV. 6


EXAMINATION PERSONNEL:
 NAME Larry M. ... LEVEL II; NAME J. ... LEVEL IT

SEARCH UNIT BEAM ANGLE: 0°: X 45°: _____ 60°: _____ OTHER _____

COUPLANT: GLYCERINE: X ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION



1981 DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/ W1	Lm/ Wm	L2/ W2	MP1	MPm	MP2	SCAN	STAT.	COMMENTS
4-9	1	IRH-1024 4B	V-P		V N/A	W .58	P .37	NO SIDE	SCAN	VALUE		A	

REVIEWED BY: A. D. Connelly DATE 4/10/81
 NDE SUPERVISOR _____ DATE _____
 QC SUPERVISOR R. D. Whately DATE 4/15/81
 AUTHORIZED INSPECTOR S. J. Felton DATE 4-15-81

INSTALLATION & SERVICE ENGINEERING DIVISION

A. Procedure No. MPUP-5751 REV. 6
Examination Personnel: NAME [Signature] LEVEL II NAME [Signature] LEVEL IT
Instrument: SERIAL NO. 1348 MAKE/MODEL: - BRANSON/303: SONIC/MK I; KK/US-32; OTHER

D. Search Unit: BEAM ANGLE/MODE: STRAIGHT BEAM/LONG WAVE; 45°/TRANS WAVE; 60°/TRANS WAVE
TRANSDUCER SIZE/FREQ: 0.25" DIA/2.25 MHz; 0.5" DIA/2.25 MHz; 1.0" DIA/2.25 MHz
SERIAL NO.: 407944; 1.0" DIA/2.25 MHz; 0.5"x0.5"/2.25 MHz
TRANSDUCER TYPE: CERAMIC SINGLE ELEMENT; CERAMIC DUAL ELEMENT; OTHER
WEDGE TYPE: STANDARD WEDGE; SPECIAL WEDGE/TYPE
CALCULATED BEAM ANGLE IN MATERIAL: $\theta_2 = \underline{44.2}^\circ$

E. Cable LENGTH: 6 FT. TYPE: RG-58; RG-59; RG-57; RG-174; OTHER

F. Calibration Orientation: CALIBRATION REFERENCE REFLECTOR: PARALLEL; TRANSVERSE TO PIPE AXIS
FOR DUAL ELEMENT: SPLIT FOR MAXIMUM RESPONSE PARALLEL; TRANSVERSE to hole centerline

G. Calibration Standard: LSCS CAL STD. NO. 01-18-05 THICKNESS .38" DIAMETER 1.8"
MATERIAL: CARBON; STAINLESS; INCONEL; OTHER


H. Couplant: GLYCERINE; ULTRAGEL II; OTHER

L. Comments: + 8 dB = 14/8 V TO 100% DAC

J. Dec Curve - Data

ECTOR DE	PEAK AMP RT	W1 02	Wm 03	W2 04	MP1 05	MPm 06	MPz 07	SOLE DEPTH 08
WT of 8/8 Vase	90%		.82			1.1		
WT of 12/8 Vase	59%		1.22			1.65		
WT of 16/8 Vase	70%		1.61			2.15		
B.R. of 14/8 Vase	100%		1.42			1.9	.18	

K. Dec Curve - Screen Representation



L. Instrument Settings/Checks

CONTROLS 00	SET 01	CHECK BOXES							
		02	03	04	05	06	07	08	09
GAIN	46	/							
SCAN GAIN	54	/							
SWEEP	2.5"/5.87	/							
DELAY	756	/							
FILTER	AUTO	/							
REP RATE	MED	/							
DAMPENING	OFF	/							
CGT	OFF	/							
OTHER	NA	/							

M. Calibration Time - Records

1981 DATE	01 ORIG CAL TIME	02 CAL CHECK TIME	03 LAST E.D.S. #	04 LAST E.D.S. LINE #	05 VERIFICATION OF 25°F LIMIT (YES/NO)
4-10	0925	NA	NA	NA	YES
4-10	NA	1115	92294	1	YES

N. Reviewed By: NDE SUPERVISOR [Signature]
Q.C. SUPERVISOR [Signature]
AUTHORIZED INSPECTOR [Signature]

DATE 4/13/81
DATE 4/13/81
DATE 4-15-81

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP-5751 REV. 6


EXAMINATION PERSONNEL:
 NAME Fred [Signature] LEVEL II; NAME [Signature] LEVEL IT

SEARCH UNIT BEAM ANGLE: 0°; 45°; 60°; OTHER _____

COUPLANT: GLYCERINE: X ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION



1981 DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/W1	Lm/Wm	L2/W2	MP1	MPm	MP2	SCAN	STAT.	COMMENTS
4-10	1	1RH-1024 4B	V-P									A	NO SCAN VALUE SIDE

REVIEWED BY: NDE SUPERVISOR [Signature] DATE 4/13/81
 QC SUPERVISOR [Signature] DATE 4/10/81
 AUTHORIZED INSPECTOR [Signature] DATE 4-15-81

A. PROCEDURE NO. PP-5751 REV. 7

EXAMINATION PERSONNEL:

NAME [Signature] LEVEL II

NAME [Signature] LEVEL II

C. PENETRANT MATERIALS:

- a. MANUFACTURER MAGNAFLUX-SPOTCHECK
- b. PRE-CLEANING SOLVENT TYPE SKC-S BATCH NO. 79C014
- c. PENETRANT TYPE SKL-HF /SKL-S BATCH NO. 79B109
- d. PENETRANT REMOVER TYPE SKC-S BATCH NO. 79C014
- e. DEVELOPER TYPE SKD-S BATCH NO. 79E033
- f. POST EXAMINATION CLEANER TYPE SKC-S BATCH NO. 79C014

D. PRE-EXAMINATION REQUIREMENTS:

a. TEMPERATURE:

- 1. PENETRANT MATERIALS BETWEEN 60° F & 125° F - YES NO
- 2. COMPONENT SURFACE BETWEEN 60° F & 125° F - YES NO

b. SURFACE PREPARATION:

- *1. GRINDING *2. FLAPPERING *3. NONE *4. OTHER

E. DATA: NOTE: All Exam components are ASME Sect. XI Category. C-F

LINE NO.	DATE	02 PRE-CLEAN EVAP. TIME	03 PEN. DWELL TIME	04 PEN. REM. EVAP. TIME	05 DEV. TIME	06 EXAMINATION COMPONENT I.D. NO.	07 MAT'L	08 SURF. PREP. *	RELEVANT INDICATION		ACCEPTABLE		RELEVANT INDICATION LOCATION/SIZE OR COMMENTS
									09 YES	10 NO	11 YES	12 NO	
1	4-28	5	10	5	15	1RH-1008-23	CS	2	X		X		
2	4-28	5	10	5	15	1RH-1023-4A	CS	2	X		X		INSPECT 5" EACH SIDE TDC - REPAIR AREA
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													

NOTE: FOR EACH EXAM COMPONENT ID NO., PLACE THE APPLICABLE NUMBER(S) (1,2,3 etc) IN ITS APPROPRIATE COLUMN.

REVIEWED BY: NCE SUPERVISOR [Signature] DATE 4/29/81
 QC SUPERVISOR [Signature] DATE 5/1/81
 AUTHORIZED INSPECTOR [Signature] DATE 5-11-81

INSTALLATION & SERVICE ENGINEERING DIVISION

LASALLE COUNTY NUCLEAR STATION UNIT 1

A. PROCEDURE NO. PP-S751 REV. 7

B. EXAMINATION PERSONNEL:

NAME J.P. [Signature] LEVEL II
 NAME NA LEVEL NA

C. PENETRANT MATERIALS:

a. MANUFACTURER MAGNAFLUX-SPOTCHECK
 b. PRE-CLEANING SOLVENT TYPE SKC-S BATCH NO. 79C014
 c. PENETRANT TYPE SKL-HF /SKL-S BATCH NO. 79B109
 d. PENETRANT REMOVER TYPE SKC-S BATCH NO. 79C014
 e. DEVELOPER TYPE SKD-S BATCH NO. 79E033
 f. POST EXAMINATION CLEANER TYPE SKC-S BATCH NO. 79C014

D. PRE-EXAMINATION REQUIREMENTS:

a. TEMPERATURE:

1. PENETRANT MATERIALS BETWEEN 60° F & 125° F - YES NO
 2. COMPONENT SURFACE BETWEEN 60° F & 125° F - YES NO

b. SURFACE PREPARATION:

- *1. GRINDING *2. FLAPPING *3. NONE *4. OTHER _____

E. DATA: NOTE: All Exam components are ASME Sect. XI Category C-E-1

LINE NO.	DATE	PRE-CLEAN EVAP. TIME	PEN. DWELL TIME	PEN. REM. EVAP. TIME	DEV. TIME	EXAMINATION COMPONENT I.D. NO.	MAT'L	SURF. PREP. *	RELEVANT INDICATION		ACCEPTABLE		RELEVANT INDICATION LOCATION/SIZE OR COMMENTS
									YES 09	NO 10	YES 11	NO 12	
1	4-29-81	5	10	5	15	1R11-1024-5	CS	2	X		X		
2													
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													

NOTE: FOR EACH EXAM COMPONENT ID NO., PLACE THE APPLICABLE NUMBER(S) (1,2,3 etc) IN ITS APPROPRIATE COLUMN.

REVIEWED BY: NDE SUPERVISOR J.D. Connelly DATE 4/30/81
 QC SUPERVISOR L.V. Wheatley DATE 5/1/81
 AUTHORIZED INSPECTOR W.J. Caldwell DATE 5-11-81

A. Procedure No. MPUP-5751 REV. 6
 Examination Personnel: NAME J. King LEVEL H NAME M.E. Williams LEVEL IT
 Instrument: SERIAL NO. 1348 MAKE/MODEL: - BRANSON/303: SONIC/MK I; KK/USL32; OTHER


D. Search Unit: BEAM ANGLE/MODE: STRAIGHT BEAM/LONG WAVE; 45°/TRANS WAVE; 60°/TRANS WAVE
 TRANSDUCER SIZE/FREQ: 0.25" DIA/2.25 MHz; 0.5" DIA/2.25 MHz; 1.0" DIA/2.25 MHz
 SERIAL NO.: A22010; 1.0" DIA/2.25 MHz; 0.5"x0.5"/2.25 MHz
 TRANSDUCER TYPE: CERAMIC SINGLE ELEMENT; CERAMIC DUAL ELEMENT; OTHER
 WEDGE TYPE: STANDARD WEDGE; SPECIAL WEDGE/TYPE
 CALCULATED BEAM ANGLE IN MATERIAL: $\theta_2 = 0^\circ$

E. Cable: LENGTH 6 FT. TYPE: RG-58; RG-59; RG-57; RG-174; OTHER
 F. Calibration Orientation: CALIBRATION REFERENCE REFLECTOR: PARALLEL; TRANSVERSE TO PIPE AXIS
 FOR DUAL ELEMENT: SPLIT FOR MAXIMUM RESPONSE: PARALLEL; TRANSVERSE to hole center
 G. Calibration Standard: LSCS CAL. STD. NO. 01-12-01 THICKNESS .42 DIAMETER 1.2
 MATERIAL: CARBON; STAINLESS; INCONEL; OTHER
 H. Couplant: GLYCERINE; ULTRAGEL II; OTHER
 I. Comments:

J. Dac Curve - Data

REFLECTOR	PEAK AMP	W1	Wm	W2	MP1	MPm	MPz	HOLE DEPTH
OF	21	02	03	04	05	06	07	08
W.T. of 78 Year								
W.T. of 78 Year	50?					.23		.23
W.T. of 78 Year								
B.P. of 48 Year	100?					.42		

K. Dac Curve - Screen Representation



L. Instrument Settings/Checks

CONTROLS	SET	CHECK BOXES								
		01	02	03	04	05	06	07	08	09
GAIN	36	/								
SCAN GAIN	44	/								
SWEEP	5/285	/								
DELAY	7.52	/								
FILTER	AUTO	/								
REP RATE	MED	/								
OPENING	OFF	/								
JECT	OFF	/								
OTHER	NA	/								

M. Calibration Time - Records

DATE	01 ORIG. CAL. TIME	02 CAL. CHECK TIME	03 LAST E.D.S. #	04 LAST E.D.S. LINE #	05 VERIFICATION OF 25°F LIMIT (YES/NO)
1981					
4-29	0900	NA	NA	NA	YES
4-29	NA	1135	92402	1	YES

N. Reviewed By: NDE SUPERVISOR J.D. Connelly
 Q.C. SUPERVISOR J. J. Smith
 AUTHORIZED INSPECTOR W. J. Caldwell

DATE 4/30/81
 DATE 5/1/81
 DATE 5-11-81

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET
LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP-S751 REV. 6


EXAMINATION PERSONNEL:
 NAME [Signature] LEVEL IT; NAME M E Williams LEVEL IT

SEARCH UNIT BEAM ANGLE: 0°: 45°: _____ 60°: _____ OTHER _____

COUPLANT: GLYCERINE: ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION



DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/W1	Lm/Wm	L2/W2	MP1	MPm	MP2	SCAN	STAT.	COMMENTS
4-29	1	IRH-1008 23	P-E		.42	.49	.51					A	

REVIEWED BY: NDE SUPERVISOR [Signature] DATE 4/30/81
 QC SUPERVISOR [Signature] DATE 5/1/81
 AUTHORIZED INSPECTOR [Signature] DATE 5-11-81

INSTALLATION & SERVICE ENGINEERING DIVISION

A. Procedure No. MPUP-5751 REV: 6
Examination Personnel: NAME [Signature] LEVEL II NAME ME Williams LEVEL IT
Instrument SERIAL NO. 521 MAKE/MODEL: - BRANSON/303: SONIC/MK I; KK/USL32; OTHER


D. Search Unit BEAM ANGLE/MODE: STRAIGHT BEAM/LONG WAVE; 45°/TRANS WAVE; 60°/TRANS WAVE
TRANSDUCER SIZE/FREQ: 0.25" DIA/2.25 MHz; 0.5" DIA/2.25 MHz; 1.0" DIA/2.25 MHz
SERIAL NO.: L07944 1.0" DIA/2.25 MHz; 0.5"x0.5"/2.25 MHz
TRANSDUCER TYPE: CERAMIC SINGLE ELEMENT; CERAMIC DUAL ELEMENT; OTHER
WEDGE TYPE: STANDARD WEDGE; SPECIAL WEDGE/TYPE
CALCULATED BEAM ANGLE IN MATERIAL: $\theta_2 = \underline{44.7^\circ}$

E. Cable LENGTH: 6 FT. TYPE: RG-58; RG-59; RG-57; RG-174; OTHER
F. Calibration Orientation: CALIBRATION REFERENCE REFLECTOR: PARALLEL; TRANSVERSE TO PIPE AXIS
FOR DUAL ELEMENT: SPLIT FOR MAXIMUM RESPONSE PARALLEL; TRANSVERSE to hole center
G. Calibration Standard: LSCS CAL STD. NO. 01-12-01 THICKNESS .42" DIAMETER 12"
MATERIAL: CARBON; STAINLESS; INCONEL; OTHER
H. Couplant: GLYCERINE; ULTRAGEL; OTHER
I. Comments: +6dB = 1/8 V TO 100% DAC

J. Dac Curve - Data

REFLECTOR	PEAK AMP	W1	Wm	W2	MP1	MPm	MPz	HOLE DEPTH
	DB	DB	DB	DB	DB	DB	DB	DB
W.T. of 8/8 Vee	80%		.83			1.2		
W.T. of 12/8 Vee	50%		1.34			1.85		
W.T. of 16/8 Vee	60%		1.77			2.4		
S.R. of 14/8 Vee	100%		1.51			2.05	.21	

K. Dac Curve - Screen Representation



L. Instrument Settings/Checks

CONTROLS	SET	CHECK BOXES								
		01	02	03	04	05	06	07	08	09
GAIN	50	/								
SCAN GAIN	58	/								
SWEEP	5/8.83	/								
DELAY	754	/								
FILTER	AUTO	/								
REP RATE	MED	/								
OPENING	OFF	/								
REJECT	OFF	/								
OTHER	NA	/								

M. Calibration Time - Records

1981 DATE	01 ORG. CAL TIME	02 CAL CHECK TIME	03 LAST E.D.S. #	04 LAST E.D.S. LINE #	05 VERIFICATION OF 25°F LIMIT (YES/NO)
4-29	0920	NA	NA	NA	YES
4-29	NA	1135	92404	7	YES

N. Reviewed By: NDE SUPERVISOR [Signature]
Q.C. SUPERVISOR [Signature]
AUTHORIZED INSPECTOR [Signature]

DATE 4/30/81
DATE 5/1/81
DATE 5-11-81

EXHIBIT 3

ULTRASONIC EXAMINATION DATA SHEET

LaSALLE COUNTY NUCLEAR STATION UNIT 1

PROCEDURE NO. MPUP-575-1 REV. 6

EXAMINATION PERSONNEL:
 NAME J. E. [Signature] LEVEL II; NAME M. E. Williams LEVEL IT


SEARCH UNIT BEAM ANGLE: 0°: _____ 45°: X 60°: _____ OTHER _____

COUPLANT: GLYCERINE: X ULTRAGEL II: _____ OTHER _____

SCAN SENSITIVITY: (+) 8 dB

SCAN ORIENTATION

* - APPEAR ON
 CRT AT SAME TIME



1981 DATE	LINE NO.	EXAM I.D.	COMP FIG.	MAX AMP	L1/ W1	Lm/ Wm	L2/ W2	MP1	MPm	MP2	SCAN	STAT.	COMMENTS
4-29	1	IRH-1008 23	P-E	100?	360 INT	1.4			2.5		5A	A	FDFT
4-29	2	23	P-E	50?	360 INT	.85			1.85		5A	E	FDFS
4-29	3	23	P-E	60?	360 INT	1.5			1.75		5B	E	FDNS *
4-29	4	23	P-E	80?	360 INT	1.5			2.0		5B	E	FDNS *
4-29	5	23	P-E	100?	360 INT	1.5			2.2		5B	E	FDNS *
4-29	6	23	P-E	60?	360 INT	1.4			1.25		5B	A	FDNT
4-29	7	23	P-E	75?	360 INT	1.7			2.75		5B	E	FDFT

REVIEWED BY: NDE SUPERVISOR AD Connelly DATE 4/30/81
 QC SUPERVISOR L. D. [Signature] DATE 5/1/81
 AUTHORIZED INSPECTOR w. J. [Signature] DATE 5-11-81

LASALLE UNIT 1

$T_p =$.42

WELD 1RH-1008-23

$T_w =$.49

EDS 92404

$T_E =$.51

GENERAL  ELECTRIC



LINE	EVALUATION
2,6	OD geometry from weld cap
3-5	ID geometry & subsequent mode conversion from weld root

APPROVED BY W. J. Whalley
Level III

DATE 5/1/81

REVIEWED BY W. J. Caldwell
ANII

DATE 5-11-81

A. PROCEDURE NO. PP-S751 REV. 7

P. EXAMINATION PERSONNEL:

NAME [Signature] LEVEL II
 NAME N/A LEVEL N/A

C. PENETRANT MATERIALS:

- a. MANUFACTURER MAGNAFLUX-SPOTCHECK
- b. PRE-CLEANING SOLVENT TYPE SKC-S BATCH NO. 79C014
- c. PENETRANT TYPE SKL-HF /SKL-S BATCH NO. 79B109
- d. PENETRANT REMOVER TYPE SKC-S BATCH NO. 79C014
- e. DEVELOPER TYPE SKD-S BATCH NO. 79E033
- f. POST EXAMINATION CLEANER TYPE SKC-S BATCH NO. 79C014

D. PRE-EXAMINATION REQUIREMENTS:

a. TEMPERATURE:

- 1. PENETRANT MATERIALS BETWEEN 60° F & 125° F - YES NO
- 2. COMPONENT SURFACE BETWEEN 60° F & 125° F - YES NO } 57° F

b. SURFACE PREPARATION:

- *1. GRINDING *2. FLAPPERING *3. NONE *4. OTHER

E. DATA: NOTE: All Exam components are ASME Sect. XI Category. SEE COMMENTS



00 LINE	01 DATE	02 PRE-CLEAN EVAP. TIME	03 PEN. DWELL TIME	04 PEN. REM. EVAP. TIME	05 DEV. TIME	EXAMINATION COMPONENT I.D. NO.	07 MAT'L	08 SURF. PREP. *	RELEVANT INDICATION		ACCEPTABLE		13 RELEVANT INDICATION LOCATION/SIZE OR COMMENTS
									09 YES	10 NO	11 YES	12 NO	
1	5-11	5	20	5	15	IRI-1028-1	S/S	2		X	X		ASME CATEGORY C-F
2	5-11	5	20	5	15	IRI-1028-1A	S/S	2		X	X		ASME CATEGORY C-F
3	5-11	5	20	5	15	IRI-1028-2	S/S	2		X	X		ASME CATEGORY C-E-1
4	5-11	5	20	5	15	IRI-1027-1	S/S	2		X	X		ASME CATEGORY C-F
5	5-11	5	20	5	15	IRI-1026-10	S/S	2		X	X		ASME CATEGORY C-E-1
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													

NOTE: FOR EACH EXAM COMPONENT ID NO., PLACE THE APPLICABLE NUMBER(S) (1,2,3 etc) IN ITS APPROPRIATE COLUMN.

REVIEWED BY: NDE SUPERVISOR [Signature] DATE 5/14/81
 QC SUPERVISOR [Signature] DATE 5/15/81
 AUTHORIZED INSPECTOR [Signature] DATE 5-19-81

ULTRASONIC EXAMINATION DATA SHEET
LASALLE COUNTY STATION UNIT 1

A. Procedure No. MPUP-5751 REV. 4
 B. Examination Personnel:
 NAME ~~John~~ LEVEL II NAME Larry Fredrick LEVEL I
 C. Search Unit Beam Angle ($\pm 2^\circ$): 0° 45° 60° Other _____
 D. Couplants: Glycerine Ultrageel II Other _____
 E. Scan Sensitivity (+): 8 dB
 F. Reference System _____ G. Scan Orientation _____



H. Data: Data on line 9 void per MCCO M.R.D. 540 7056 RWW 4/30/81

01 DATE	02 LINE NO.	03 EXAM/COMP. I.D. NO.	04 COMP. FIG.	05 REC. IND. YES/NO	06 MAX. IND. DAC W_{mt}	07 L_0	08 L	09 W_1	10 W_m	11 W_2	12 SRP ₁ or MP ₁	13 SRP _m or MP _m	14 SRP ₂ or MP ₂	15 SCAN	16 Comments (Thickness Meas.)
5-4-79	1	IRH 1006 29	Elbow to Pipe	NO										1 1/2	Elbow weld 480 Pipe 400
5-4-79	2	IRH 1006 31	Pipe to Elbow	NO										1 1/2	Elbow weld 450 Pipe 390
5-4-79	3	IRH 1006 27	Pipe to Elbow	NO										1 1/2	Elbow weld 460 Pipe 420 390
5-4-79	4	IRH 1006 25	Elbow to Pipe	NO										1 1/2	Elbow 440 Weld 400 Pipe 390
5-4-79	5	IRH 1006 24	Pipe to Elbow	NO										1 1/2	Elbow 450 Weld 480 Pipe 400
5-4-79	6	IRH 1006 21	Reducer to Pipe	NO										2	PIPE 400 Weld 420
5-4-79	7	IRH 1008 14	Pipe to Elbow	NO										1 1/2	Elbow 440 Weld 500 Pipe 400
5-4-79	8	IRH 1008 15	Elbow to Pipe	NO										1 1/2	Elbow 410 Weld 400 Pipe 390
5-4-79	9	IRH 1009 23	Pipe to Elbow	NO										1 1/2	Elbow 540 Weld 400 Pipe 400

L. Reviewed By: SD Connelly DATE 5/6/79
 NDE SUPERVISOR: L W Wheatley DATE 5/10/79
 QC SUPERVISOR: W J Caldwell DATE 7-31-79