

Docket No. 50-254
and 50-265

SEP 1 1981



Mr. L. DelGeorge
Director of Nuclear Licensing
Commonwealth Edison Company
P. O. Box 767
Chicago, Illinois 60690

RE: QUAD CITIES UNITS 1 AND 2

Dear Mr. DelGeorge:

Item II.K.3.22 of the TMI Action Plan (NUREG-0737) required the automatic switchover of Reactor Core Isolation Cooling (RCIC) System suction to the suppression pool when condensate storage tank level is low. As an interim measure until automatic switchover modifications are accomplished licensees should verify that clear and cogent procedures exist for manual switchover.

Enclosed is an evaluation of the interim measures taken at your facility. This evaluation concludes that the manual switchover procedures have been reviewed and found acceptable.

Based upon the above, Item II.K.3.22a has been satisfactorily completed for your facility. Item II.K.3.22b, actual plant modifications, remains unresolved and will be the subject of future correspondence.

Sincerely,

Original Signed by
T. A. Ippolito
Thomas A. Ippolito, Chief
Operating Reactors Branch #2
Division of Licensing

Enclosure:
As stated

cc w/enclosure
See next page

Distribution:			
Docket File	NSIC	J. Heltemes, AEOD	D. Verrelli
NRC PDR	TERA	T. Ippolito	R. Emch
Local PDR	GRAY (1)	S. Norris	P. Polk
ORB#2 Reading	ACRS (10)	R. Bevan	E. Jordan
D. Eisenhut	J. Olshinski	OI&E(3)	OELD

8109210160 810901
PDR ADOCK 05000254
PDR

OFFICE	ORB#2	CRB#2	ORB#2	ORB#2	ORB#2	
SURNAME	P. Polk	S. Norris	R. Bevan	T. Ippolito	D. Verrelli	
DATE	8/31/81	8/25/81	8/31/81	9/1/81	9/1/81	

TITLE: IE REVIEW AND EVALUATION OF LICENSEE CONFORMANCE WITH TMI
ACTION PLAN REQUIREMENTS

ACTION PLAN ITEM NO: II.K.3(22a)

TITLE: FINAL RECOMMENDATIONS B&O TASK FORCE

U.S. NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT

UTILITY: Commonwealth Edison Company
FACILITY: Quad-Cities Nuclear Power Station
UNIT NO: Units 1 and 2
DOCKET NO: 50-254; 50-265

Signature: RC Knopf, Director, Division of Resident
and Project Inspection, RIII

Date: JUN 29 1981

PARENT REGION CONTACT: F. W. Reimann

II.K.3(22a) FINAL RECOMMENDATIONS B&O TASK FORCE

Position

The reactor core isolation cooling (RCIC) system takes suction from the condensate storage tank with manual switchover to the suppression pool when the condensate storage tank level is low. This switchover should be made automatically. Until the automatic switchover is implemented, licensees should verify that clear and cogent procedures exist for the manual switchover of the RCIC system suction from the condensate storage tank to the suppression pool.

Discussion and Conclusion

By letter dated December 31, 1980, the licensee verified that procedures calling for manual switchover to the suppression pool if the condensate storage tank level is low are presently in place.

We have found that the licensee's response is adequate and in compliance with NUREG-0737 interim position on manual switchover.

Mr. L. DelGeorge
Commonwealth Edison Company

cc:

Mr. D. R. Stichnoth
President
Iowa-Illinois Gas and
Electric Company
206 East Second Avenue
Davenport, Iowa 52801

The Honorable Tom Corcoran
United States House of Representatives
Washington, D.C. 20515

Mr. Philip Steptoe
Isham, Lincoln & Beale
Counselors at Law
One First National Plaza, 42nd Floor
Chicago, Illinois 60603

Mr. Nick Kalivianakas
Plant Superintendent
Quad Cities Nuclear Power Station
22710 - 206th Avenue - North
Cordova, Illinois 61242

Moline Public Library
504 - 17th Street
Moline, Illinois 61265

Susan N. Sekuler
Assistant Attorney General
Environmental Control Division
188 W. Randolph Street
Suite 2315
Chicago, Illinois 60601

Resident Inspector
U. S. Nuclear Regulatory Commission
22712 206th Avenue N.
Cordova, Illinois 61242

James L. Kelley, Chairman
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. Peter A. Morris
Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. Richard F. Foster
P.O. Box 4263
Sunriver, Oregon 97701