

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE BOX 764

COLUMBIA, SOUTH CAROLINA 29218

T. C. NICHOLS, JR.  
VICE PRESIDENT AND GROUP EXECUTIVE  
NUCLEAR OPERATIONS

September 15, 1981

Mr. James P. O'Reilly, Director  
U. S. Nuclear Regulatory Commission  
Region II, Suite 3100  
101 Marietta Street, N. W.  
Atlanta, GA 30303

Subject: Virgil C. Summer Nuclear Station  
Docket No. 50/395  
Interim Report of Potential Significant  
Deficiency  
Nuclear Engineering File: 3.1051


Dear Mr. O'Reilly:

On August 17, 1981, Mr. Virgil Brownlee of NRC Region II was notified of a potential significant deficiency concerning cable termination in the connection box of the Boric Acid Transfer Pump 1A exceeding bending radius.

This interim report serves as the 30 day report. Nuclear Engineering has taken steps to increasing the size of the connection box, thus reducing the bending radius problem.

Specific details including cause of the problem and corrective action will be provided in the final report.

Very truly yours,



T. C. Nichols, Jr.

TB:TCN:tdh



IE27  
S  
1/1

8109220490 810915  
PDR ADOCK 05000395  
S PDR

Mr. James P. O'Reilly  
Page two  
September 15, 1981

cc: V. C. Summer  
G. H. Fischer  
H. N. Cyrus  
T. C. Nichols, Jr.  
O. W. Dixon, Jr.  
J. C. Ruoff  
D. A. Nauman  
W. A. Williams, Jr.  
R. B. Clary  
O. S. Bradham  
A. R. Koon  
A. A. Smith  
H. Radin  
M. N. Browne  
H. E. Yocom  
B. A. Bursey  
J. K. Skolds  
J. B. Knotts, Jr.  
I & E  
Document Management Branch  
NPCF  
file