

DMB/50.55(e)

THE CINCINNATI GAS & ELECTRIC COMPANY



September 4, 1981
QA-1483

E. A. BORGMANN
SENIOR VICE PRESIDENT

U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. James G. Keppler
Director

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1
50.55(e) - ITEM M-16 - ROSEMOUNT MODEL 1152
PRESSURE TRANSMITTERS - DOCKET NO. 50-358,
CONSTRUCTION PERMIT CPPR-88, W.O. #57300-957,
JOB E-5590



Gentlemen:

This letter constitutes an interim report under 10CFR50.55(e) regarding defects in Rosemount Model 1152 Pressure Transmitters with output Codes "A" or "D". Rosemount Inc. notified the NRC under 10CFR Part 21 that the mentioned transmitters produced ambiguous output currents under extreme over or under pressurized situations.

An investigation of available options indicated that the best alternative was to replace the "A" or "D" output circuit boards with "E" boards which did not appear to have the problem. A quotation was obtained from Rosemount for replacement boards.

On August 18, 1981, as a purchase order was about to be placed for "E" boards, a Rosemount Bulletin was received which stated that at an undetermined minimum radiation exposure, the "E" boards also experience the same ambiguous output problem. Since all of the Zimmer essential transmitter will receive some degree of radiation, simply replacing the boards is no longer a total solution.

In light of this information, the systems containing such transmitters will be analyzed for the most adverse conditions of pressure and radiation which they may experience to determine whether or not any of them could experience the phenomena in question. We will inform you of the results of our analysis by October 30, 1981.

IS27
5
1/0

8109250234 810904
PDR ADDCK 05000358
S PDR

SEP 11 1981


Mr. James G. Keppler
Director
U. S. Nuclear Regulatory Commission
Region III
September 4, 1981
QA-1483
Page 2

We trust this letter will fulfill the requirements of an interim letter under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By


V. A. BORGMANN
SENIOR VICE-PRESIDENT

FKP:ac

cc: NRC Resident Inspector
Attn: W. F. Christianson
NRC Office of Inspection & Enforcement
Washington, D.C. 20555