

ORIGINAL
NUCLEAR REGULATORY COMMISSION

T-1006

In the Matter of:

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
SUBCOMMITTEE ON FLUID DYNAMICS



DATE: September 25, 1981 PAGES: 168 thru 202

AT: San Francisco, California

*TR04
Soli*
*Delete
B. White*

*TR04
delete B. White*

ALDERSON  REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 554-2345

8109300188 810925
PDR ACRS
T-1006 PDR

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION

3 - - -

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
5 SUBCOMMITTEE ON
6 FLUID DYNAMICS
7

8 Bellevue Hotel
9 Riviera Room
10 505 Geary Boulevard
11 San Francisco, California

12 Friday,
13 September 25, 1961

14 The Subcommittee met, pursuant to adjournment, at
15 8:30 a.m.

16 BEFORE: DR. M. PLESSET, Chairman

17 ACRS MEMBERS PRESENT:

18 MR. J. EBERSOLE

19 DR. D. WARD
20

21 ACRS CONSULTANTS PRESENT:

22 DR. T. THEOFANOUS

23 DR. I. CATTON

24 DR. Z. ZUDANS

25 DR. S. BUSH

DR. J. LIENHARD

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ACRS STAFF PRESENT:

MR. P. BOEHNERT, Designated Federal Employee

NRC STAFF PRESENT:

MR. J. KUDRICK

MR. M. FIELDS

DR. W. BUTLER

P R O C E E D I N G S

8:30 a.m.

1
2 CHAIRMAN PLESSET (presiding): Well, let's reconvene
3 and continue the discussion that we were having yesterday.

4 Dr. Bush raised a question to which I don't think an
5 adequate answer was given. And I think this is brought up
6 again by him and Mr. Ebersole.

7 We've heard a lot about the possible damage to the
8 grill and the floor, and so on, but more important is the pos-
9 sible damage to important equipment that's being supported
10 there.

11 Now I don't think we got an answer to that. Of
12 course the really important equipment has to do with capability
13 of shutdown. So could you say a word about that, Jack? Has
14 that been looked at carefully? Or whoever has looked at it.
15 We don't care about the walks or the floor. It's the equip-
16 ment that's important. Will it fall down in the pool? Will
17 it get amaged?

18 MR. KUDRICK: We have just become aware of the degree
19 of the problem rather recently, so we really haven't delved in-
20 to exactly what equipment is located on the grill as opposed
21 to the concrete, and what type of damage would occur if the
22 loads were exceeded on the grating.

23 We have asked that question to Mississippi Power and
24 Light, and I believe they are looking at it. I don't know if
25 they have any additional comments that they'd like to share

1 with the Committee right now or not.

171

2 The question is what type of equipment is located on
3 or around the grating of Grand Gulf.

4 CHAIRMAN PLESSET: Come up and use the mike. We want
5 to get this on the record.

6 What we want to know is will this equipment survive?

7 MR. RICHARDSON: John Richardson, Mississippi Power
8 and Light.

9 On the hydraulic control unit floor, the grating por-
10 tion is primarily instrument control racks, some piping and
11 valves, control hydraulic system, the hydraulic units for the
12 flow control valve for recirc system. But primarily the instru-
13 mentation and control racks are on that floor.

14 And the panels and racks are designed for the impact
15 loads.

16 CHAIRMAN PLESSET: Well, yes, go ahead. This sounds
17 like very important information, and it's not clear to me that
18 you can tell us with assurance that it would survive. What
19 assurance can you give us?

20 You want to add to that, Frank?

21 DR. BUSH: Well, I'll let him answer that. I have a
22 more general question. I'd like to rephrase what I said yester-
23 day. And I'll wait until we get this in.

24 CHAIRMAN PLESSET: All right.

25 Go ahead.

1 MR. RICHARDSON: Okay. I'm not prepared right now
2 to tell you specific requirements. I can find those, the re-
3 quirements that we've imposed on that equipment, the design
4 criteria for the hydrodynamic loads.

5 CHAIRMAN PLESSET: Go ahead.

6 MR. EBERSOLE: You say that the equipment has been
7 designed for the impact loads. Was the equipment put there
8 originally with the thought in mind that there wouldn't be any
9 impact and such things, and now you have sort of patched it
10 over by putting barriers or something up?

11 MR. RICHARDSON: I don't --

12 MR. EBERSOLE: Why does the equipment have to be
13 within range of damage of something like that? Why can't it
14 be moved to a safer place, free from all the worries about the
15 variability of these things like foam velocity and impact load?

16 MR. RICHARDSON: I don't know the exact history of
17 why it was put in that area, and if it was designed there with-
18 out knowledge of the fact that, you know, there would be the
19 impact loads, etcetera.

20 I wasn't around then. Maybe GE could address the
21 philosophy behind that.

22 CHAIRMAN PLESSET: Okay.

23 MR. SMITH: My name's Al Smith, from General Elec-
24 tric.

25 One of the reasons that the instrumentation is

1 located at that area is to maintain the proper criteria for
2 the instrument line slope, and given that penetrations exist
3 in certain areas, there isn't much flexibility in moving the
4 instrumentation to another area. So that was one of the major
5 criteria, and it doesn't allow us too much flexibility.

6 Some of the instrumentation, essential instrumentation,
7 has been removed from some of the racks and put out of this
8 area of impingement. There remains however some instrumenta-
9 tion and some racks that we could not move because of the slope
10 criteria, and so therefore other forms of protection have been
11 looked into, such as deflector shields, that type of thing.

12 MR. EBERSOLE: Well, the instrumentation can be
13 broadly put into two classes: Those that shutdown the reactor
14 in the minutes lock shutdown, and so they can be damaged or
15 whatever after that; and those that have to sustain some active
16 function by being energized or otherwise actively supporting
17 the operation.

18 This latter class is the critical class, the ones
19 that have to go on and on and on. The first can sometimes do
20 whatever it has to do, and then be considered as having perform-
21 ed its function, and be subsequently damaged. Is it the second
22 kind that we're worried about here?

23 MR. SMITH: We are concerned with the type that must
24 perform its action or monitoring function during a LOCA and
25 post-LOCA.

1 MR. EBERSOLE: Post-LOCA.

2 CHAIRMAN PLESSET: Spence?

3 DR. BUSH: Yes. Let me rephrase my concern or my
4 interest at least more generally.

5 We're talking of a spectrum of loads. I would clas-
6 sify some of them as being relatively inconsequential, but I
7 would say there are a few others that are significant and are
8 still under negotiation, so they have a fair possibility of
9 moving up in value.

10 I have a concern that again can be divided in two
11 parts, once we stabilize what loads are to be used.

12 The first is will the loads have an adverse effect
13 on structures. Now if a load simply cracks concrete, and you
14 haven't lost the functional capability of equipment that's sit-
15 ting on the concrete, because this is a folded condition, I
16 can't get too concerned.

17 However, if there are loads that will either damage
18 platforms and in the process essentially have a high probability
19 of rendering certain equipment non-functional, then I think
20 that's very important.

21 I think we have to look at it on the basis that under
22 dynamic loads and a one-shot folded condition, we do a realistic
23 analysis for those conditions and establish the response of the
24 structures themselves, and in the process, if that response is
25 adverse, we have to look and see at the next step, does it

1 result in the damage of equipment -- and in equipment, I in-
2 clude piping, etcetera -- that have to provide a vital function
3 with regard to the shutdown, shutting down the reactor or fold-
4 ing it down.

5 That's really the bottom line. And we can talk all
6 we want to about loads. But our concern, ultimately, should
7 be can that unit be -- assuming we have such and such an acci-
8 dent -- can it be held down, and so we minimize any further
9 effects? And that I think is what we have to address here.

10 Now I won't get into the argument of whether some
11 of the loads are realistic or not. That's another matter.
12 But I think once there's a decision made on it, then the ana-
13 lysis has to be on the basis of those particular loads. And
14 I don't think it's been done.

15 CHAIRMAN PLESSET: Well, I don't think we can get an
16 answer to these questions. But as you can see, they're really
17 vital ones. We don't care about the concrete walks or the
18 grills. But we do very much -- we are very much concerned
19 with these matters that have just been brought up.

20 I think of course we have got to know what the loads
21 are before we can tell whether the instrumentation will sur-
22 vive. But we'd like to see this thing emphasized in the study.

23 Okay?

24 MR. KUDRICK: We definitely share your concern.

25 CHAIRMAN PLESSET: All right. Yes, I'm sure. Thank

1 you.

2 And we'll go back to the regular agenda. Jack, you
3 want to take over?

4 DR. BUTLER: Let me just add one point on that.

5 I don't believe we have yet crossed that threshold
6 of giving up on the grates. We're still working to make sure
7 that the grates stay in place.

8 We will be looking into the effect of -- if these
9 loads in fact exceed the capability of the grate, then what
10 are the consequences? But we are still looking towards assur-
11 ing that the loads are within the capability of the grates.

12 CHAIRMAN PLESSET: Okay, that's all right. We don't
13 mind that. Fine, thank you.

14 DR. ZUDANS: Along those same lines, just a couple
15 of remarks?

16 CHAIRMAN PLESSET: Okay, not too long, because I
17 think they've got the idea.

18 Go ahead.

19 DR. ZUDANS: It's just an addition to the same thing.

20 I think it would be important to calibrate these
21 loads in terms of their importance. Some of the loads have no
22 potential of damaging anything, the others do.

23 And that's what one would like to see.

24 CHAIRMAN PLESSET: Yes, okay.

25 Jack, back to you.

1 MR. KUDRICK: To continue on with our scheduled
 2 agenda, I would like to introduce Dr. George Bienkowski, who
 3 will be presenting the structure of submerged structure drag
 4 loads on both the generic aspect as well as Grand Gulf speci-
 5 fically.

6 He is a Consultant from Princeton, and has worked in
 7 this particular area for both the Is and IIs.

8 DR. BIENKOWSKI: Good morning.

9 (Pause.)

10 I thought I would put up a slide just giving an over-
 11 view, which I think summarizes partly my feeling on the subject.
 12 There is not a lot of controversy left in this area. I think
 13 the reasons are fairly clear why.

14 One is that I think unlike some other issues such as
 15 CO and chugging, where the phenomena themselves are not clearly
 16 understood, one can have a lot of controversy about what data
 17 one should use and so forth.

18 Now clearly submerged structure loads associated
 19 with CO and chugging have those same questions associated
 20 with them. But as far as the issue of how does one compute
 21 forces on an object, given a flow field, there are still some
 22 questions associated with maybe what kind of flow field one
 23 should be taking data from, but the the phenomenon is at least
 24 reasonably well understood. So I think that eliminates some
 25 of the potential controversy.

1 For those of you familiar with the Mark I and Mark
2 II history on this, I think it's a little bit -- Mark III has
3 some advantage here that one looks at the pool, it's relatively
4 less cluttered in the area of submerged structures that could
5 suffer due to LOCA bubbles and so forth.

6 The other part is that we also have had the history
7 of the various concerns on Mark I and Mark II, which have been
8 batted around back and forth. So we don't have to fight those
9 battles again.

10 And thirdly, there is actually some experimental
11 data in the Mark III type geometry which can be used at least
12 as a benchmarking verification of theoretical calculations.

13 Somewhat arbitrarily, submerged structure loads are
14 -- well, not arbitrarily. They are divided into LOCA and SRV
15 loads. But then within the LOCA load, the chronology is clear-
16 ly just a somewhat arbitrary division of what phenomena take
17 place, and the names have gone into the record as such and we
18 will stick with them.

19 There's something called water jet loads, which basi-
20 cally we are talking about the clearing of the water through
21 the vent, up the vent clearing, followed by air bubble loads
22 which presumably take the pool all the way up to the riser,
23 fall back loads, when the pool falls back down after the air
24 has all come out of the drywell, condensation oscillation loads
25 and chugging loads. And finally for SRV, there's still a dis-

1 distinction to made between water jet loads and quencher bubble
2 and so on. So I will try to treat these subjects in that or-
3 der, although it may be clear that some of these divisions are
4 somewhat arbitrary, such as clearly the division between water
5 jets and bubble loads is somewhat arbitrary, because in the
6 actual phenomenon it just goes from one to the other and also
7 clearly as the amount of air and steam mixture changes gradu-
8 ally, rather than a sudden change from all air to all steam.

9 The first subject, on the water jets, the thing that
10 makes this sort of a non-issue for Mark III is that if one
11 takes the most conservative calculations from experimental
12 data, one can at least designate a region of influence, a zone
13 of influence, in which one would expect not necessarily that
14 there is no jet mode associated with flow field induced by the
15 jet, but that those those flow fields induced by the jet are
16 smaller within that region of influence than will be the sub-
17 sequent loads due to the flow field induced by the bubble
18 growth, once the air starts coming out of the vent.

19 So one can designate a certain region of influence,
20 and ask: Are there any structures in that region of influence?
21 I will try to use this approach the data approached. The basis,
22 in this case the experiments are the Mark III one-third scale
23 experiments which tend to indicate a separate structure rela-
24 tively close to the vent in the path directly of the jet. The
25 loads are generally substantially bounded by the subsequent

11
1 air clearing and the step loads. The theory of the very con-
2 servative bounds was this Moody jet model, which tends to pre-
3 dict a much, much higher penetration of the jet than other ex-
4 periments have measured.

5 Well, the conclusion is essentially there are no
6 structures in Mark II for which jet load is not bounded by the
7 bubble load. I don't know whether it's worth showing the next
8 two slides, which just show if one takes such a very conserva-
9 tive estimate of the zone of influence, you can see that most
10 of the structures are near the opposite wall from the vents
11 and therefore would not be impacted by the jets directly.

12 The only structures that have some -- I mean if one
13 takes a conservative estimate of something -- well, basically
14 the zone of influence shown on the slide, one sees that SRV
15 quencher arms could potentially be in -- parts of the quencher
16 arms could potentially be in the zone of influence. GE has
17 done some calculations showing what -- taking I believe the
18 Moody jet model calculations for that and showing that the cal-
19 culation that they use for LOCA air bubble bounded substantially
20 with the forces that you'd even predict from that.

21 So the conclusion is that one does not need to worry
22 about the jet load.

23 MR. EBERSOLE: Pardon me just a minute.

24 Is there sufficient time delay in the starting of
25 some of those heavy pumps to insure that they uptake some

1 substantial void fraction and thereby will bind themselves?
2 If there's a time delay, of course it's all right. I'm not
3 sure what that is.

4 DR. BIENKOWSKI: I'm not sure what you're referring
5 to.

6 MR. EBERSOLF: Okay.

7 There's some very large pumps that take suction on
8 the pool.

9 DR. BIENKOWSKI: Yes?

10 MR. EBERSOLE: If they were to start instantaneously,
11 they would be in the direct path of these large air bubbles
12 and they would ingest that, and then lose their NPSH function
13 and cease to function.

14 I hope that's not the case. The pump uptakes --

15 MR. KUDRICK: Yes. They're on the outside wall.
16 The penetration that we're talking about here is nowhere near
17 the end of the wall.

18 MR. EBERSOLE: We have no concern about air uptake
19 of the pump suction.

20 MR. KUDRICK: No we do not.

21 MR. EBERSOLE: Thank you.

22 DR. BIENKOWSKI: I assume you are referring to the
23 subsequent air bubble, not to the water jet, because the water
24 jet is still working.

25 MR. EBERSOLE: I am, yes.

1 DR. BIENKOWSKI: Okay.

2 The normal division for the next load is to talk
3 about the LOCA air bubble. And the approach is to consider
4 spherical, essentially radial, bubble growth. That is clearly
5 not an exact representation of what is going on, because clear-
6 ly the flow as it was coming -- the jet that was coming out --
7 has initial induced velocities in the pool, so the bubble would
8 not be spherical.

9 However, the experimental evidence shows that the
10 -- especially since eventually there is a factor of two, mul-
11 tiplier applied to the thing -- and it bounds the spherical
12 calculations.

13 The pool boundar-es and the flow field is considered
14 using the method of images that has been in the other Mark Is
15 and Mark IIs. The multiplier of two is applied to account --
16 rather than to couple for the LOCA, rather than to couple the
17 bubble motion, the rise of the bubble -- I assume due to bouy-
18 ancy -- together with the volume increase of the bubble due
19 to charging of the bubble, the simple factor of two is applied
20 to the calculations done for a stationary bubble, and some
21 evidence is presented that this is conservative.

22 This was indeed one of the questions and concerns
23 that I have expressed, and I will mention something about it
24 in a moment.

25 Once the bubble calculation is done for each parti-

1 cular structure, an equivalent local uniform flow field approx-
2 imation is made, local acceleration and standard drag is then
3 computed for each segment on the structure in the same way it
4 was done for Mark Is and Mark IIs.

5 The basis, again, is primarily theoretical, with
6 some experimental confirmation.

7 The conclusions are that there is not much difference
8 in this from the Mark Is and Mark IIs, so the issues that have
9 all been discussed there need to be discussed in the same way.
10 The Mark III, people have agreed essentially, that some of
11 those detailed issues, like what drag coefficients to use,
12 whether one must consider standard drag or only acceleration
13 drag, should be done on the same basis.

14 So unless somebody has some specific questions, I
15 will not discuss those nitty-gritties.

16 The one new thing was the multiplier for bubble
17 motion. And the question was: Is that a conservative bound
18 to account for a bubble motion? Well, if one looks at the
19 induced flow field due to the volume expansion, together with
20 the induced flow field due to motion, the one thing that imme-
21 diately strike ones is that, sure enough, at some peak it may
22 be true that the motion term can add no more than double the
23 load, but clearly the time-history of the bubble rise is dif-
24 ferent from the time-history of expansion. Clearly, by simply
25 multiplying the bubble expansion by a factor of two, one gets

1 a significantly different time-history.

2 And so then the issue was: Is it necessary to apply
3 these loads dynamically to the structure, or does one really
4 basically have a quasi-static application?

5 If it was to be dynamic, then one might indeed worry
6 about the different time-history. If it's quasi-static, then
7 clearly it's a non-issue, because it's really the largest load
8 that's going to matter.

9 And so I have asked some information, and received
10 essentially the information for all of the structures of concern.
11 The -- I guess it should be ω -sub-n rather than w -sub-n --
12 but the natural frequency of the structures times the charac-
13 teristic time for the bubble growth is generally substantially
14 larger than one for all of the structures of concern, and there-
15 fore, the load to the structures essentially is quasi-static-
16 ally applied. And so as long as the factor of two bounds the
17 peak load, there should be no worry about the different time-
18 history.

19 DR. CATTON: Before you leave that, Jesse, how much
20 air intake can these pumps handle.

21 MR. EBERSOLE: I wouldn't want to say very much.

22 DR. CATTON: because following the clearing of the
23 bubble out of the pool, all that violent motion, there are
24 small bubbles everywhere, and it takes several seconds for
25 them to clear.

1 MR. EBERSOLE: Well, it depends on the pump design.
2 Some pumps can take up a few cubic inches of air, and stop.
3 And other pumps can ingest large amounts.

4 And I don't know. It depends on the individual
5 pump.

6 DR. CATTON: I don't think it's a non-problem, with-
7 out looking at it.

8 CHAIRMAN PLESSET: Well, I think if you're down to
9 very small bubbles, it won't matter.

10 DR. CATTON: Well, they're not all that small.

11 CHAIRMAN PLESSET: Well, if they are big, then of
12 course it's a question.

13 DR. CATTON: Well, you've just blown a big bubble in
14 this pool, and it just stirs everything up. And it takes a
15 little while to quiet down.

16 CHAIRMAN PLESSET: That's true.

17 But it takes some time for them to vibrate to the
18 pump suction. And in that time, they can disappear, or get
19 very small. That's their idea.

20 DR. LIENHARD: In fact, in modeling experiments,
21 you see the pool whipped up into a froth that goes quite far
22 down, yes.

23 CHAIRMAN PLESSET: That's right.

24 DR. CATTON: But the question is not that there's
25 a lot of froth, but how long does it last and how long do the

1 bubbles stay significant.

2 DR. LIENHARD: Or does it get near the pump intake.

3 CHAIRMAN PLESSET: Yes.

4 DR. LIENHARD: I believe it does. I'm not certain.

5 DR. CATTON: The jets that come from the --

6 CHAIRMAN PLESSET: Let this man -- we're just talk-
7 ing -- let him say something that contributes.

8 DR. CATTON: I just want to get the concern on the
9 record.

10 CHAIRMAN PLESSET: It's on.

11 MR. HUCIK: My name is Steve Hucik.

12 In general, the ECCS pumps have about a 30-second
13 delay to come up to full speed before they run and inject, so
14 there's a delay time of about 30 seconds before they are called
15 upon to actually pull suction and start.

16 That's sufficient time to have the pool swell pheno-
17 mena calm down by the time they then take suction and start to
18 inject.

19 MR. EBERSOLE: As I recall, the pumps are called
20 upon to perform their thing instantly, and if AC power is
21 available, they attempt to do that once the valves clear.

22 MR. HUCIK: But that takes about 30 seconds.

23 MR. EBERSOLE: Is that a positive number, of about
24 a half a minute?

25 MR. HUCIK: It takes about 30 seconds to come up to

1 full flow.

2 MR. EBERSOLE: Are the LOCA temperature calculations
3 based on the 30-second rise time to full flow?

4 MR. HUCIK: I believe so.

5 MR. EBERSOLE: I thought in the past it's been 10
6 seconds.

7 MR. HUCIK: No.

8 MR. EBERSOLE: And that really was an allowance for
9 the diesels to start.

10 MR. HUCIK: Ten seconds for the diesels to come up
11 to speed, 30 seconds for the pumps to be available.

12 MR. EBERSOLE: Well, thank you.

13 DR. LIENHARD: But you're not going to get air into
14 the pump intake during the pool swell period?

15 MR. HUCIK: No, no.

16 DR. LIENHARD: You'll get air into the pump intake
17 after the pool swell is finished, and you've started churning
18 things around, mixing. I think that's the problem, isn't it?

19 MR. EBERSOLE: Well, if it exists 30 seconds, it's
20 a potential problem.

21 CHAIRMAN PLESSET: Well, I think the 30-second kind
22 of relieves my anxiety. It was a good question, but I think--
23 Are you satisfied.

24 MR. EBERSOLE: If it's 30 seconds, it seems to me
25 that's a long time.

1 CHAIRMAN PLESSET: Oh, yes, that's quite a while.

2 MR. EBERSOLE: And it seems to contradict the local
3 calculations, but maybe that's been changed.

4 CHAIRMAN PLESSET: Well, I thought that that was also
5 addressed. Has that been --

6 MR. EBERSOLE: No pull for 30 seconds on the flooding
7 pumps.

8 Is that correct? No pull on the field for 30 seconds?

9 MR. HUCIK: I believe in the calculational models,
10 there is no credit taken for flow up to 30 seconds, before they
11 come up to power.

12 DR. LIENHARD: That doesn't mean a pump has really
13 come on.

14 CHAIRMAN PLESSET: Please continue.

15 DR. BIENKOWSI: It's clear what we've been talking
16 about now is substantially beyond the time I've been consider-
17 ing, and I don't have that in the slides and what I handed
18 out.

19 But this is at least the calculation on the rising
20 bubble, and you can see the time-scale here is less than a
21 second. So we're talking about the LOCA bubble here, we're
22 talking about a much shorter time-scale.

23 And the concern I was expressing essentially was that
24 the factor of two multiplier may indeed apply to the the peak
25 acceleration, but it would certainly be a different time-history

1 but because of the fact that the time-scale here is of the
2 order of a second, natural frequencies of the order of 10, 12,
3 and above, the load is essentially quasi-statically applied to
4 the structure.

5 The fallback loads, which seem to happen after the
6 pool has risen to its maximum height and is coming back down,
7 the calculation is based on a freefall of the slug of water
8 from 20 feet high, which gives a velocity of something like
9 35 feet per second. One of the issues -- the GESSAR suggested
10 that essentially standard drag alone be calculated at that
11 velocity, based on an appropriate drag coefficient.

12 The question was I guess whether the -- is it always
13 true that the acceleration drag force is negligible compared
14 to the standard drag force. It clearly depends on the size of
15 the structure.

16 One can essentially make a simple calculation and
17 show that effectively, for this kind of assumption, the acce-
18 leration force over the drag force is proportional to the size
19 of the structure divided by twice the freefall height. And
20 it's fairly clear that all structures will be substantially
21 smaller, so the standard drag calculation is sufficient.

22 DR. THEOFANOUS: Can I ask a question?

23 DR. BIENKOWSKI: Sure.

24 DR. THEOFANOUS: Associated process with that is
25 the generation of waves in the pool. So if you look at some

1 bounding situations where maybe you have more area on one side,
2 you generate the higher swell on the other side, then with the
3 fallback maybe generate a circumferential wave. And do you look
4 into those waves and the effects on structures?

5 DR. BIENKOWSKI: I have not personally looked at it
6 in connection with Mark III.

7 I think those kinds of things had been discussed
8 previously with Mark II. Just my own guy feeling and reaction,
9 I suspect that these initial forces associated with very highly
10 accelerated pool rise and so forth would be substantially higher
11 than anything you would get from the sloshing.

12 DR. THEOFANOUS: Yes, but the times are different,
13 and the time-scale of the forces is different, and that de-
14 pends on what kind of structure you are talking about, and
15 how sensitive it is to different kinds of loads.

16 But here we have substantially higher shelves. They
17 go up to 18-20 feet. And I think somebody ought to look at
18 that. I'm not saying it is a problem, but somebody ought to
19 look at it.

20 DR. BIENKOWSKI: Okay. If you believe that the one-
21 third area scale is at least somewhat of a representation of
22 the real thing, the data I recollect from seeing those tests
23 of submerged structures, once they -- for the submerged struc-
24 tures now I'm talking about -- once the air bubble load is
25 over, the data you see looks like hash.

1 DR. THEOFANOUS: But that's not the point.

22
2 Because in these experiments, you're only talking
3 about at most three cells. And here we're wide circumferen-
4 tial variations. The wave would be propogating along the cir-
5 cumference of the pool. And you can see that in the experi-
6 ments.

7 DR. BIENKOWSKI: Yes, yes.

8 Those waves would clearly be lower frequency rather
9 than higher frequency.

10 DR. THEOFANOUS: Yes, right.

11 DR. LIENHARD: You can do it in your head. It's
12 just the velocity is the square root of gH . It's a deep water
13 wave. Just do it in your head.

14 DR. THEOFANOUS: What are you saying?

15 Are you speaking to me?

16 DR. LIENHARD: Yes.

17 I'm not answering your question. I'm saying it's
18 just a deep water wave, and it has a velocity of square root
19 of gH . And just do it in your head.

20 DR. THEOFANOUS: So what?

21 DR. LIENHARD: It's a very low frequency.

22 DR. THEOFANOUS: I'm aware it's low frequency.

23 DR. BIENKOWSKI: If it's low frequency, then are you
24 worrying about exciting some sort of specific mode in the struc-
25 ture, or are you worried -- I mean if it's low frequency,

1 presumably then it means it's going to be essentially quasi-
2 static in most of the structures.

3 And if it's quasi-static, then the question is is
4 its amplitude comparable to amplitudes we're already consider-
5 ing. And I think again one can conclude that the amplitudes
6 are much smaller.

7 If it has to do with wave heights, and the velocity
8 induced on that, clearly 20-foot fallback is a lot higher than
9 any wave heights one would expect in the waves thereafter.

10 DR. THEOFANOUS: Well, I don't want to pursue that.
11 But I still think that somebody ought to look at the numbers
12 for some bounding cases of waves propagating alongside in this
13 manner.

14 CHAIRMAN PLESSET: Let me just say I think there was
15 a slip. They're not deep water waves. They're shallow water
16 waves.

17 You said the square root of gH . I think that's for
18 shallow water waves.

19 No, it's shallow water. But let's not belabor the
20 point.

21 DR. THEOFANOUS: Are you saying that the waves will
22 be small-sized waves?

23 CHAIRMAN PLESSET: No, no.

24 I was just saying that it's a shallow water wave.
25 The wavelength could be anything.

1 DR. BIENKOWSKI: Okay.

2 After the pool swell, and a significant amount of the
3 air has come out of the drywell and primarily steam is coming
4 through, the next division of the oscillating condensation has
5 traditionally been called condensation oscillations.

6 The approach here has been to essentially use the
7 same basic methodology for the calculation of the forces, but
8 clearly one must now put in some information on what the volume
9 source strengths are of the oscillating bubbles or interfaces
10 at the vent exit.

11 The source strengths are -- clearly have to come
12 from some experimental evidence, and that comes from the same
13 evidence that was used for the boundary load calculations for
14 CO. The flow field, again, uses the method of images, uni-
15 form equivalent flow field.

16 The question then arose as to whether acceleration
17 drag alone needs to be inserted. It turns out that for the
18 kind of sources one gets, there is more -- it is relatively
19 low amplitude oscillations at some reasonable frequencies, so
20 for typical structures, one indeed would expect that the acce-
21 leration forces -- or you might call them acoustic loads on
22 the structures -- would be more significant than would be the
23 standard drag proportional to U-squared. The issue that was
24 raised, that was asked to be addressed, was to quantify this
25 in some way and to essentially say under what conditions, since

25
1 it clearly depends on both the distance from the source and
2 size of the structure, under what conditions is the standard
3 drag negligible. And as a matter of fact, I guess I did not
4 include that in a slide either, because I wasn't sure whether
5 it was something that would be considered proprietary or not.
6 But I don't believe it's labeled proprietary, so I can show it.

7 The calculation was made just for what essentially
8 the boundary between -- for what structures standard drag is
9 or is not important. And it's essentially an equation relat-
10 ing the size of the structure versus the distance from the
11 wall.

12 And it turns out that the only one worry that might
13 be of importance is the RHR, a couple of RHR lines, and indeed
14 I believe the new revision mentions that for those structures
15 the standard drag will have to be computed. It ought to be
16 a minor point. It's going to be only a relatively small cor-
17 rection.

18 The only thing that at least in my mind still is not
19 -- I cannot give you a total conclusion on it yet, because we
20 are still passing information back and forth on this issue, so
21 I will have to leave a question mark at the end of this one,
22 is having to do with chugging loads.

23 Okay, again the source strength clearly must come
24 from an empirical data base. And it is the same data base as
25 for the boundary chugging loads. However, there clearly is an

1 important distinction here, and that is that when one is com-
2 puting boundary loads, one can take some credit for the fact
3 that one does not expect all chugs to be maximum strength every-
4 where around the boundary.

5 And so one can take some credit for the fact that
6 one then does not have to compute a total symmetric load with
7 all chugs at maximum strength, and synchronized, and so forth.

8 Whereas when one is talking about submerged structure
9 loads, there is always the possibility that it's precisely the
10 maximum chug that's going to occur through the whole LOCA oc-
11 curs right next to the particular structure that you're consider-
12 ing, so clearly one has to use somewhat different criteria for
13 deciding whether a source strength is conservative or not.

14 And that's the one remaining issue that we're still
15 discussing, as to whether it is or is not.

16 Okay, in this particular case, rather than computing
17 the whole flow field and going through all the details, a sort
18 of an approximate acoustic model is taken for all the chugs
19 propogating through the pool and arriving at the strucutres.

20 It actually turns out that what is eventually done
21 is that conservative assumptios are made that simply all of
22 the chugs that could reach a particular structure from differ-
23 ent neighboring vents within the duration of the chug are
24 taken as being all totally synchronized. So no advantage is
25 taken of the dephasing or arrival times of the various pulses

1 at the structure.

27
2 Then what is done is just the force is taken propor-
3 tional to the pressure difference one would compute from such
4 pulses. And that clearly has some questions that could be ask-
5 ed about it. But what is done, again to be conservative, is
6 rather than taking one pressure gradient that would exist at
7 the structure, due to the pulse arriving at that structure, the
8 full pressure difference across the pulse is taken across the
9 whole structure.

10 Now that sounds conservative. And indeed, if you
11 look at the conclusions, it turns out that if you just ask
12 what is that pressure gradient, taking the whole pressure dif-
13 ference across the structure, compared to the pressure gradi-
14 ent that you'd get for the pulse arriving at the structure
15 for the largest structure that exists in the pool, you find
16 out that you get a factor of 2.54.

17 Well, that sounds like enough conservatism to not
18 worry about anything else, except for the fact that we all
19 know that if I have a pressure gradient existing in a flow
20 field, and I put a structure in it, the actual force that I
21 get is not proportional -- is not just equal to essentially
22 the pressure difference across the structure, if the structure
23 hadn't been there -- but there is a hydrodynamic mass effect
24 which, for a cylindrical structure, is about two. And it is
25 around two here because in spite of the fact that its acoustic

1 propagation is taken into account, on a scale of the structures
2 themselves, the flow field, the induced flow field, is essential-
3 ly incompressible.

4 So it turns out that there is an adequate conservat-
5 ism for the calculation associated with taking the pressure
6 gradients and so forth, provided the source strength is still
7 conservative.

8 There is additional conservatism -- and this is the
9 part that's the hardest to put your finger one -- associated
10 with the fact that no phasing is taken between these pulses
11 arriving at the structure. And secondly, that all of the
12 pulses, all of the pressure gradients, are assumed to act in
13 the same direction. In other words, no geometric consideration
14 is taken that the pressure pulses are coming from different
15 directions to the structure.

16 However, these conservatisms are difficult to quan-
17 tify. And it is precisely the issue that still exists is are
18 those conservatisms sufficient to compensate for any potential
19 lack of conservatism in the interpretation of the data base
20 of deducing the source strength.

21 And at this stage, I am not prepared to say yes or
22 no yet.

23 On the SRV, there is -- I guess partly as a result
24 of the history having to do with the Ram's-head type design,
25

1 one worried about the water jet coming from the quencher. It's
2 clear that it's a kind of a misnomer for a quencher, because
3 clearly there are a lot of little jets coming out of the quen-
4 cher holes which coalesce into larger areas of sphere of flow
5 around each of the quenchers, which then presumably penetrate
6 some distance until the air starts coming out of the quencher.

7 We can still call it a water jet if we like. The
8 experimental evidence on that, however, suggested that that
9 effect is limited to some region which is something like a
10 sphere of influence around each quencher.

11 And the conclusion is essentially that there is no
12 structure within that region for each quencher, and therefore
13 one doesn't have to worry about that part of the load.

14 The bubble loads -- the methodology is essentially
15 similar to either LOCA or CO methodology. Again, the only
16 issue is where do I put the bubbles, and what their strengths
17 are.

18 The strengths come from a conservative estimate of
19 what -- I mean one can obviously -- There are four bubbles
20 taken, coming in between each of the quencher arms, and clearly
21 one can take a conservative estimate of the pressure and the
22 size based on the volume of the air that would come through
23 and the initial conditions with which one would start.

24 In this particular case, however, since these bubbles
25 are smaller than a LOCA bubble and there's actually an oscil-

1 lation involved in the rise of these bubbles, the calculation
2 includes both the oscillations and the trajectory. And then
3 an equivalent uniform flow field is computed, each structure
4 location, and standard and acceleration drags are taken. And
5 the various issues associated with using the conservative
6 bounds on the drag coefficients to account for oscillating
7 flow and so forth have all been agreed to.

8 The only issue that came to my mind was the question
9 of phasing of the four bubbles at a single quencher, since
10 clearly if one does the calculation totally in phase, one would
11 expect that there would be -- I mean certain loads, let's say
12 on the quenchers themselves, might exactly cancel out and one
13 would get no asymmetric load.

14 So the question was asked: What evidence is there
15 that these are in phase? And clearly, like everything in any
16 experiment, the things are not totally in phase, but the amount
17 of phase difference and amplitude difference in the four bub-
18 bles around the quencher are sufficiently small that one does
19 not expect that load to be significant compared to all of the
20 other loads that have to be computed on the quencher.

21 /////

22 /////

23 /////

24 /////

25 /////

1 DR. BIENKOWSKI: Well, that's all I have, unless
2 there are any questions. I have some slides in connection
3 with the chugging source strength if there are questions.

4 (No response.)

5 Okay, thank you.

6 CHAIRMAN PLESSET: Are there any questions?

7 (No response.)

8 I guess not.

9 MR. KUDRICK: I suggest that we continue on with our
10 agenda now.

11 CHAIRMAN PLESSET: All right.

12 MR. KUDRICK: We have two remaining areas of consid-
13 eration associated with local pool dynamic load. They are
14 thermal stratification and its effects, as well as flow-struc-
15 ture interaction.

16 Dr. Economus, of Brookhaven National Laboratory,
17 will present those areas.

18 DR. ECONOMUS: Good morning.

19 As pointed out by Dr. Theofanous yesterday, there
20 are two aspects to this non-issue, one of which has to do with
21 the concern in designing the structure for thermal stress.
22 The other one, that has to do with long-term heat-up, is not
23 the one that I am going to deal with today.

24 Okay, in order for the AE to design the structure
25 to accomodate thermal stresses he needs some definition of a

32
1 temperature gradient. Experiments indicate that you do have
2 a vertical temperature gradient. The one that GE has provided
3 -- the basis for it is the one-third scale area PSTF tests.
4 Mel showed you that profile yesterday; it increases upward at
5 -- the specification as an overall delta-t of around 60 degrees
6 Fahrenheit. And, it was developed by the finite cell energy
7 deposition application to the experiment.

8 DR. CATTON: That also includes the mixing process,
9 doesn't it?

10 DR. ECONOMUS: I beg your pardon?

11 DR. CATTON: The mixing process plays a r in what
12 that temperature gradient is.

13 DR. ECONOMUS: Well, sure. What they did was take
14 the measured profiles and sort of divvy-up the pool into five
15 cells, as a matter of fact, and estimate how energy would be
16 deposited on that basis, on the background of temperature flow.

17 MR. EBERSOLE: I believe Dr. Catton is talking about
18 mixing as it is enhanced by the pump operation, are you not?

19 DR. CATTON: Well, no, the pump operation would tend
20 to destroy the thermal gradient.

21 MR. EBERSOLE: All right.

22 DR. CATTON: The fact that they have just used
23 scaling --

24 MR. EBERSOLE: This is early on, that you are talking
25 about.

1 DR. CATTON: Different geometric scaling may decrease
2 the thermal gradient.

3 DR. ECONOMUS: Sure.

4 DR. CATTON: Have you looked at that?

5 DR. ECONOMUS: Well, one of the concerns -- which
6 the next slide will address -- of course, is exactly that
7 issue.

8 The one point that, I guess, Mel didn't mention yes-
9 terday when he showed the profile is that the profile varies
10 with time, consistent with the global temperatures in the pool.

11 The concern, of course, as Dr. Catton points out,
12 is how applicable is the one-third scale data for the proto-
13 type. And, also, another question is: what sort of effect of
14 break size may we expect?

15 The way GE resolved these concerns was to do a series
16 of numerical calculations using the RELAP code. Most specifi-
17 cally, to address the question of distorted scale, as to what
18 that would do to the profile.

19 DR. CATTON: For natural convection in that particu-
20 lar geometry using the RELAP code is nonsense.

21 Just a comment.

22 CHAIRMAN PLESSET: Well, that's a strong comment.

23 DR. ECONOMUS: We will have to take that comment
24 into account

25 DR. CATTON: I can expand on that if you want.

1 DR. ECONOMUS: Well, sure.

2 DR. CATTON: It's a natural convection problem and
3 the RELAP code is not set up to solve that kind of a problem.

4 It's not a trivial problem. You have very high
5 Rayleigh numbers, you have turbulence resulting from the con-
6 vection process, you have stratification that wipes these
7 things out, and the RELAP code is not a code that was designed
8 to look at that kind of a problem.

9 DR. ECONOMUS: Well, the confirmation proceeded as
10 follows: they modeled the actual number of facilities and
11 generated profiles for the actual one-third scale blowdown,
12 and first demonstrated that RELAP was doing a reasonable job
13 of predicting the profile.

14 DR. THEOFANOUS: Which RELAP was that?

15 DR. ECONOMUS: Well, Steve could give us the number.
16 I don't remember it at this point.

17 STEVE HUCIK: It was RELAP 4.

18 CHAIRMAN PLESSET: RELAP 4, MOD 5.

19 DR. THEOFANOUS: Thank you.

20 DR. ECONOMUS: The first step was to generate some
21 predictions for the actual one-third scale area tests. The
22 predictions look reasonable.

23 Then, having satisfied oneself that the thing does
24 a reasonable job in the one-third scale, they proceeded to
25 make predictions for a full scale PSTF, and an actual Mark III

35
1 238 plant. What they showed primarily was that the scale had
2 a very slight effect on the slope form.

3 DR. CATTON: I'm not sure that with RELAP you can
4 show much of anything in that problem.

5 DR. ECONOMUS: Okay, we'll have to take that into
6 account.

7 DR. CATTON: They are very tough to model using
8 computer codes because of the coupling between the energy
9 equation and the momentum equation.

10 RELAP was just not designed to be that kind of a
11 code, and I would be very surprised if it were to solve the
12 problem, without a lot of empirical adjustment.

13 DR. ECONOMUS: Well, as I say, presumably --

14 DR. CATTON: I think that's enough.

15 DR. ECONOMUS: That's enough, okay.

16 Well, in any case, basically the comparisons that
17 they show us with the actual measurements, we concluded that
18 the RELAP code does a reasonable job of modeling the profile,
19 and quantitatively the calculations for Mark III showed that
20 the overall delta-t, which is specified -- namely, that 60
21 degrees Fahrenheit that I showed you earlier -- is conserva-
22 tive, because the RELAP prediction is only 56 degrees.

23 DR. THEOFANOUS: Does that mean that the Staff
24 accepts this?

25 DR. ECONOMUS: At the present time the Staff's posi-

36
1 tion is that that temperature profile is acceptable for use in
2 the design of the structure.

3 DR. THEOFANOUS: On the basis of this RELAP calcu-
4 lation, that's the basis you used to accept it?

5 DR. ECONOMUS: On the basis of comparison of tests
6 as well.

7 DR. THEOFANOUS: So, you used the RELAP to take
8 those tests up to full scale. So, you are really using RELAP
9 as the basis of your thinking?

10 DR. ECONOMUS: Yes.

11 DR. THEOFANOUS: Because you believe it has accep-
12 table meaning.

13 DR. ECONOMUS: It was benchmarked against actual
14 experiments as a first step.

15 DR. CATTON: It was benchmarked against the one-third
16 scale tests, which have skewed geometry.

17 I think you first have to address the question of
18 the skewed geometry from the natural circulation that is taking
19 place in the pool.

20 DR. ECONOMUS: Well, I don't understand.

21 Do you mean that when applied to the one-third area
22 scale geometry -- I mean, the actual geometry that was --

23 DR. CATTON: As indicated earlier, that one-third
24 scale -- or one-ninth scale -- makes the whole problem more
25 one-dimensional. That makes it kind of like a chimney.

1 So, if anything I suppose you are going to get more
2 stratification as you extend that wall out, because you have
3 got more room for that hot fluid to flow out across the sur-
4 face and be stratified.

5 Until you address that, somehow -- the effects of
6 the scaling -- you can't use the code for a different scale.

7 DR. THEOFANOUS: Well, you know, from my point of
8 view, I'm sure you used the facilities and you used certain
9 constants -- which facilities' momentum and energy -- to do
10 the calculations. And, you fixed those numbers so that you
11 can predict the one-third scale.

12 And, again, even if they work in a one-third scale,
13 nothing tells you that they can be used in a larger scale.
14 There are many problems.

15 DR. CATTON: They don't have a second-order term in
16 RELAP, so they don't have diffuse energy.

17 DR. THEOFANOUS: They must have something, otherwise
18 it would --

19 DR. CATTON: I don't know where.

20 MR. TOWNSEND: Hal Townsend from General Electric.

21 Let me make one comment about the distorted scaling.
22 We did measure temperatures in the one-ninth scale as well.
23 As we go from the one-third scale to the one-ninth scale we
24 are getting progressively narrower and more chimney-like.

25 We saw that the temperature gradients were greater

38
1 in the one-ninth scale and it indicated more stratification
2 than we have in the one-third scale.

3 So, it has a very superficial extrapolation and you
4 would expect smaller gradients in the full scale, I believe,
5 independent of what you do with RELAP, or that type of thing.

6 DR. CATTON: Well, if you have got other arguments
7 they might be acceptable. But, RELAP is a one-dimensional
8 code.

9 MR. TOWNSEND: Yes, I don't dispute that.

10 CHAIRMAN PLESSET: Well, I don't think that we need
11 to go into RELAP anymore. It's pretty well trampled on, I
12 think.

13 But, I think that -- the idea that I get out of all
14 of this is that there are a certain amount of problems, okay?

15 Do you agree with that?

16 DR. ECONOMUS: Yes, I do.

17 MR. FIELDS: You know, in the Mark III pool there
18 are a lot of pump suction devices; there is a lot of mixing
19 in there.

20 CHAIRMAN PLESSET: There is another question about
21 this.

22 MR. EBERSOLE: I suspect that a more critical pro-
23 blem is the rapidity with which the pool liner -- it is lined,
24 is it not?

25 DR. ECONOMUS: Yes.

1 MR. EBERSOLE: It heats up relative to the concrete;
2 the concrete stays in place, in essence, and the liner tries
3 to crawl out of there. At the points of anchorage it will
4 tear itself unless you design specifically for that purpose
5 and create leaks exactly when you don't want them to occur.

6 I would be interested in your showing that the rap-
7 idity of the heat-up of the pool has not caused the liner to
8 depart from the concrete at the anchor points and develop
9 leaking points all along its side.

10 DR. BUSH: But, even if it does it, it doesn't matter
11 that much, Jesse, from a safety point of view.

12 I admit that it causes a gap in the heat transfer
13 process.

14 MR. EBERSOLE: No, what it is is radioactive fluid,
15 now, that has a leakage past two atmospheres.

16 DR. BUSH: You are assuming that the concrete, by
17 definition, is going to leak, and I don't agree with that.

18 MR. EBERSOLE: Oh, that's okay, yes.

19 If you agree that the concrete is inadequate --

20 DR. BUSH: I agree that the tanks that are not lined
21 are weak.

22 MR. EBERSOLE: Dr. Bush is right. Unless we have
23 established the leakage I have no problem.

24 DR. ZUDANS: But, even if this temperature would be
25 twice as much -- for twenty feet height distribution -- you

1 would have no structural effects.

2 MR. EBERSOLE: Well, the steel moves very fast
3 relative to the concrete.

4 DR. ZUDANS: It starts from the bottom. The bottom
5 is at the same temperature as the side, and it regularly heats
6 up as you go up, and that's within some fifteen of twenty
7 feet. The gradient is insignificant.

8 MR. EBERSOLE: I'm not talking about the gradient.
9 I'm talking about the absolute mixed temperature of the water
10 versus that of the concrete at the steel/concrete interface.

11 If the water, that suddenly gets up to near 200
12 degrees, leaks I have no gradient problem. It's the gradient
13 into the concrete out of the steel.

14 CHAIRMAN PLESSET: Right.

15 But, I think that Spence has a good point --

16 MR. EBERSOLE: Yes.

17 CHAIRMAN PLESSET: -- that the concrete itself will
18 work, even if it does separate.

19 MR. EBERSOLE: If it can stand cracks and still
20 retain the function.

21 DR. ZUDANS: How can it separate? It's backward
22 compression if it gets hotter.

23 MR. EBERSOLE: I don't think the concrete -- is the
24 concrete designed as a membrane to hold leakage? Doesn't it
25 have seals in certain places where leakage could come out at

1 steel-to-concrete interfaces?

2 I didn't know that the concrete was actually a vapor
3 containment shell.

4 MR. KUDRICK: The liner is in place for that --

5 MR. EBERSOLE: For that purpose.

6 MR. KUDRICK: However, if the liner were not there,
7 it's not obvious that you would have any leakage.

8 MR. FIELDS: The concrete surrounding the suppres-
9 sion pool is seven to eight feet thick.

10 MR. EBERSOLE: Yes, but that would be no good if
11 there were a gap.

12 MR. FIELDS: Right.

13 (Pause.)

14 CHAIRMAN PLESSET: Are you finished?

15 DR. ECONOMUS: I'm finished with thermal stratifica-
16 tion.

17 CHAIRMAN PLESSET: Okay.

18 DR. ECONOMUS: Jack, should I go on to FSI?

19 MR. KUDRICK: Yes, just continue on.

20 DR. ECONOMUS: Well, let me try another non-issue
21 and see how far I get.

22 Once again, there are two aspects to this issue.
23 One is the one that is highlighted by that question: has there
24 been any FSI effect on the measurements that were obtained
25 which introduce non-conservatism?

42

1 The other question has to do with: does the AE
2 correctly account for FSI when he does his structural evalua-
3 tion?

4 On the basis of what has transpired before, in Mark I
5 and Mark II, I believe that the answer is that they do account
6 for that by added masses, and so on. I believe that the AEs
7 recognize at this point that they have to properly model the
8 presence of the water on the boundary.

9 So, we are addressing this issue here. Once again,
10 the approach to demonstrate that the FSI is either negligible
11 or did not introduce non-conservatism, or was to use numerical
12 modeling, to demonstrate that. A variety of models were used
13 and predictions were generated for all three scales, all three
14 facilities.

15 The general conclusion was that it had very little
16 effect and that when it does have an effect, the effect is to
17 add conservatism to the load specification.

18 As I said, they used different numerical modeling;
19 for the one-ninth and one-third scale tests they used NASTRAN.

20 How do you feel about NASTRAN?

21 DR. CATTON: You will have to ask Zenon about
22 NASTRAN.

23 DR. ECONOMUS: That's all right.

24 (Laughter.)

25 In general, the NASTRAN code showed that there is --

1 that very little FSI should be expected in those facilities.

2 DR. ZUDANS: It's such a heavy structure.

3 DR. ECONOMUS: Yes, it's -- well, it turned out --
4 I'm preceding myself a little bit here -- the full scale
5 facility had the south wall -- the south wall is a drywell
6 wall?

7 (Affirmative response from a person in the audience.)

8 The south wall was somewhat flexible, but that flex-
9 ibility introduced conservatism.

10 In any case, the conclusion is that there is very
11 little effect and they tend to introduce conservatism.

12 For the full scale facility, as I said, they use
13 different methods. They used the 2-degree-of-freedom model
14 and also three-dimensional compressible finite element model,
15 and they examined the transfer functions, and so on. And,
16 again, they showed that -- they tended to overestimate FSI
17 effects, in that they were important or non-conservative.

18 I just have one example of the sort of thing that
19 one sees when comparing this acoustic model -- that I just
20 talked about -- with the actual measurements. You see there
21 is very little FSI indicated on the basemat or the north wall,
22 or containment wall. But, a significant effect on the drywell
23 wall. And, the solid profile is the actual forcing function
24 that is used in defining the loads.

25 CHAIRMAN PLESSET: Thank you, Dr. Economus.

1 MR. KUDRICK: That concludes our prepared presentation
2 in LOCA-related pool dynamic loads.

3 Since we're going so well, I've been told we can pro-
4 ceed into the area of SRVs.

5 And I would like to introduce Nelson Su, who is the
6 Task Manager on Task Action Plan A39, who is responsible for
7 the SRV-related loads for Mark III.

8 (Pause.)

9 DR. SU: Good morning.

10 Just to introduce myself, I am the Task Manager for
11 Task Action Plan A39, which deals with SRV-related pool dynamic
12 loads for Mark I, II and III.

13 We have had opportunity to discuss this subject with
14 the subcommittees in the past several years. Therefore, I will
15 just quickly provide you an overview of what we have done,
16 and the current status of our review of Mark III SRV loads.

17 First of all, I would like to provide you the back-
18 ground of the SRV-related issues. In 1975, GE proposed the
19 use of the X-quenchers. This quencher device was a modified
20 version of the KWUs X-quenchers. The modification includes
21 the lengths of arms and the number of holes in each arm.

22 The whole pattern is identical with the KWUs X-
23 quencher. As you know, the KWUs had performed the rest of
24 the scale test and incline test on these particular devices.
25 Based on this data base, GE developed a methodology to predict

45
1 loads for the GE version of the X-quenchers. As a result of
2 the reviews on GE's methodology, we concluded that GE's pro-
3 posed methodology is conservative and acceptable. Subsequent
4 inplant tests, both in Caorso and the one I'm going to talk
5 about -- Kuosheng Nuclear Power Plant SRV test -- to confirm
6 that.

7 Therefore, we issued acceptance criteria in 1976.
8 The acceptance criteria include the GE proposed methodology.
9 In one area, with regard to multiple activations, we imposed
10 a very conservative assumption, that is, a bubble oscillating
11 in phase, to be used.

12 We also encouraged the load cases should be analyzed
13 to demonstrate the piping equipment and structures to accomo-
14 date these load cases.

15 Since we issued our acceptance criteria in 1976,
16 GE proposed three key area of modifications -- or you can say
17 exceptions -- to our acceptance criteria.

18 The first one is so-called low-low set logic. The
19 second one is load reduction factors, based on the Caorso in-
20 plant tests. The third one is the bubble phasing, to be de-
21 termined by Monte Carlo's approach.

22 DR. CATTON: What is low-low set logic?

23 DR. SU: Yes, I will go briefly into the descrip-
24 tions. I am not prepared to go in detail into discussion in
25 these particular areas. Low-low set logic is a system designed

1 to limit the number of SRVs to not more than one. The German
2 experiment shows SRV-subsequent activation results in higher
3 loads than the first activation. And they proposed that only
4 one valve will pump subsequently. On that basis, the piping
5 equipment and containment structures were determined on that
6 basis. Subsequent to that time, GE found some mistake in their
7 analysis.

8 If we pump more than one, as high as ten, in order
9 to maintain that design load, GE proposed a so-called low-low
10 set logic, which means they will allow some of the valves to
11 continue to maintain open, after the first activation. So
12 the valve released the energy to the pool, and adds to the
13 primary system below the set point. Some of the valves will
14 close, but some of them will continue to open. This will re-
15 duce the primary system as such, and if the pressure rises
16 again, they will pump only one.

17 Recently, we have completed a review on this parti-
18 cular system, in conjunction with the Grand Gulf review.

19 As I say, I'm not prepared to discuss this in detail,
20 but I will answer any questions the members of the subcommit-
21 tee may have.

22 Yes?

23 DR. BUSH: That gets to be a very interesting code
24 problem, because it sounds to me now as if the reliability of
25 this circuit response is going to be very critical. You can

1 either -- you could go one of two ways: In theory, you could
2 hold open and get a control blowdown, but in practice it might
3 be a continuing one.

4 Or the other possibility is, depending on what type
5 of circuitry, that you can't get an adequate blowdown.

6 DR. SU: Well, I am not the right person to give you
7 detail. I always say the staff and the instrumentation and the
8 electrical system have reviewed it, and some single failure may
9 result more than once. The most is two.

10 And we also requested risk and probabilities, the
11 assessments branch, to review the probability of this type of
12 failure.

13 And the conclusion would be it ranged from 10^{-3} to
14 10^{-6} . Now when I come to the discussions on the Taiwan Power
15 Company implant test to show, suppose this happens, a single
16 failure -- although the low probability -- has happened from
17 that point of view would not be substantial. This will be
18 bound by the design load.

19 Does that satisfy you, Dr. Bush?

20 DR. BUSH: Well, I'm just thinking that I believe
21 that this deviates enough from the code that states might not
22 accept it.

23 So any utility that has them better check with their
24 states.

25 DR. SU: Okay. I will take your comments.

1 Dr. Economus from BNL will discuss in more detail
2 the second item and the third item.

3 Our current status has no open items for GESSAR
4 dockets, virtually its generic applications for all the Mark III
5 containment.

6 The result of staff evaluations of the Mark III SRV
7 load will be included in a new report. The draft of NUREG
8 0802, entitled "Safety Relief Valves," our evaluation report,
9 Mark II and IIIs containment, is scheduled to be issued for
10 management's comments and concurrence by November, 1981.

11 With respect to the performance of cross-quenchers,
12 the draft of NUREG 0783 entitled "Suppression Pool Temperature
13 Limits for BWR Containments" was issued to ACRS for comment.

14 I talked to the ACRS staff, Mr. Paul Boehnert. I
15 was told they have received no comment.

16 On that basis, we proceeded to issue our final
17 form of the NUPEG 0783. By issuance of NUREG 0783 and 0802,
18 we will complete our evaluations on this particular issue.
19 In fact, we will complete the Task Action Plan A39 by that
20 time.

21 My next topic of my presentation today may be more
22 interesting. I will talk about the recent SRV inplant test
23 conducted in the Kuosheng Nuclear Power Stations.

24 First I will provide you general information regard-
25 ing the Kuosheng Nuclear Power Station.

49

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Kuosheng Nuclear Power Station is located near the northern tip of Taiwan. It is a twin unit, which means the shell; a number of buildings, including the control room. Each unit is rated at 985 megawatts.

The first unit started construction in September, 1974. The work was completed in January, 1981, probably a little more than six years from the time construction started to the time of fuel loading.

Both units are BWR 6/Mark III containment. The first unit was operating at 60 per cent power in August, 1981, at the time performing the SRV test. This would be actually the first BWR 6/Mark III in the world.

The second unit is scheduled to have fuel loading by the second quarter of 1982.

This cross-sectional view of the Kuosheng Nuclear Power Plant primary containment, as you can see, is a reinforced concrete Mark III containment. It is essentially the same type of containment for the Grand Gulf. In fact, the Bechtel Corporation is the architectural engineer for both the Kuosheng Nuclear Power Plant and Grand Gulf.

As I understand, the Kuosheng Nuclear Power Plant was following the Grand Gulf. Then by now, it is way ahead of the Grand Gulf.

As I mentioned previously, Kuosheng Nuclear Power is the first BWR 6/Mark III containment in the world. Taiwan

1 Power Company, under the supervision of the Atomic Energy
2 Council for the Republic of China, decided to perform SRV
3 inplant tests. The object of the test was to confirm SRV
4 loads for piping, equipment and structures.

5 Second, the result of the test will provide a data
6 base for the structure model. Now as I understand it, the
7 Bachtel Corporation will use this data to generate so-called
8 low reduction factors for their structural response model.

9 The third objective is to provide a data the X-
10 quenchers' thermal performance, namely in pool mixing. By
11 these data, they will be able to demonstrate the GE cross-
12 quenchers at the Kuosheng Nuclear Power Plant will meet the
13 pool temperature limits.

14 I may want to make a note. Taiwan Power Company
15 and the NRC counterparts followed closely what we have been
16 doing here.

17 Now this slide shows a plan view of the suppression
18 pools. The Kuosheng Nuclear Power Plant has 16 quenchers,
19 with seven of them designated as ADS. That is the pressure
20 sensor, as you can see it. The low-low set SRVs, that's the
21 one identified V8. This one is V8.

22 This is a cross section of the suppression pools,
23 where the quenchers are and the quencher supports. You can
24 see they're very richly supported to the wall with an almost
25 solid steel block, supported to the drywell wall.

51
1 As you see, there are also a number of the pressure
2 sensors around to measure the pressure attenuation effect.

3 The inplant test was started on August 22nd, 1981,
4 and completed on August 23th, 1981, roughly eight days, 24
5 hours around the clock.

6 The total number of the tests was 32. The instru-
7 mentation you can see here appeared to as more than adequate
8 just for the purpose of confirmation. They have 128 accelero-
9 meters located inside the containment building and outside the
10 containment building on the select equipment and piping system.
11 They have the pressure sensors around the pools, in the ver-
12 tical direction and the horizontal direction, which measures
13 the pressure attenuation.

14 They also have pressure sensors located in the piping.
15 Strain gauges here, and a quencher support. They have 22
16 thermocouples at this point to aid the normal flow temperatures
17 monitoring system.

18 The test included the single-valve first activation,
19 which means they popped the valve to simulate normal operating
20 conditions. And they had single-valve consecutive activations,
21 which means they first pop the valves and instead of waiting,
22 say two hours, for the next test, they wait on a range less
23 than one minute, and then pop. At that time, the line would
24 be in the high temperature condition, because of the heat from
25 the previous activation.

1 The test also included two adjacent valves' activa-
2 tion, to demonstrate the asymmetric loads on the containment.
3 Now the four valve test was primarily to provide a data base
4 for the structural response model.

5 Finally, they had three extended blowdown tests.
6 One without RHR -- the pool stands still. Second, with the
7 RHR in operation one hour before the SRV was activated. The
8 third test was with RHR put in operation five minutes after
9 the SRV was activated.

10 Yes, sir?

11 DR. BUSH: You said there were three extended tests.
12 That means there were 29 of them divided, I presume, among the
13 first four -- the single valve first, the single valve conse-
14 cutive, the adjacents and the four valves.

15 Exactly how many were run on those?

16 DR. SU: For the single valves first activation,
17 the test on the V8 and V5 each one I believe was four, in
18 order to provide some statistical significance.

19 DR. BUSH: Is that eight in all?

20 DR. SU: Yes.

21 I can't be exact. Just the rough ideas.

22 DR. BUSH: Yes, right.
23
24
25

1

1

DR. BUSH: How about the others?

2

3

DR. SU: Excuse me for one moment. Consecutive saturations will be 12. Was 12 and the ----- involved was 3.

4

5

DR. BUSH: It was 6 for the SRV?

6

DR. SU: Right.

7

8

DR. BUSH: So that from a structural response point of view there were a fair number of tests under that four valve ---?

9

10

DR. SU: Yes.

11

DR. BUSH: Thank you.

12

13

MR. EBERSOLE: May I ask a question? In your general valve design you've got 16 valves. You've got by-pass of some capacity, I don't know.

14

15

Presumably when you have a turbine trip and your by-pass fails, you're going to get most of these valves, aren't you, at once?

16

17

18

DR. SU: That's right.

19

MR. EBERSOLE: Not once, you get them all?

20

DR. SU: Not once, at different set points.

21

22

MR. EBERSOLE: But they'll come up and will they all be functional for the full power turbine trip without by-pass?

23

24

DR. SU: I don't -----.

25

MR. EBERSOLE: What's the capacity of the by-pass?

1 DR. SU: I don't recall. I would say probably
2 10%.

3 MR. EBERSOLE: And what's the capacity in terms
4 of full steam flow of these 16 valves?

5 DR. SU: Each one is designed for 7%.

6 MR. EBERSOLE: 7%?

7 DR. SU: Right.

8 MR. EBERSOLE: So it's 70% -- no, well over 100%?

9 DR. SU: Yes.

10 MR. EBERSOLE: That's a notable difference
11 between some twr's that I know and yours.

12 DR. SU: I believe so. They have acquired margins.

13 MR. EBERSOLE: Does this help you out with that
14 one?

15 DR. SU: I don't know.

16 MR. EBERSOLE: If you can -- them all at once.

17 DR. SU: I try to stay away ---.

18 In 1980's NRC and AC's, the Republic of China
19 and Taiwan Power Company reached informal agreement for the
20 NRC participation in -- SRV and plant tests.

21 Primarily the NRC staff would provide technical
22 assistance in exchange for access to the data.

23 You may know or not, the total cost of the test
24 was reported around \$5 million dollars, U.S. dollars.

25 In mid-1980, the staff review and comment on the

3 1 test plan, subsequently the staff was invited to witness
2 the test.

3 The NRC teams, during the test includes myself,
4 and three consultants from RES, because the original set-up
5 was with the research people.

6 And since I happened to be working in this area,
7 so I was to get involved.

8 During the test, the NRC staff participated in
9 review of the test results to determine whether the next
10 test can proceed.

11 That means to see any surprise or any test result
12 that showed to exceed the design barrier to make a decision or
13 recommendation to the management whether to stop or change
14 the program.

15 We also provided technical guidelines for the
16 test programs.

17 I would like to mention the participation
18 includes the G.E.'s, Bechtel, the NRC and some observers
19 from Italy and the Mississippi Power and Light Company.

20 The tests were conducted by Nutech and Wyle Labs.
21 Well, I have to apologize. I will not be able to provide
22 you the test results in specific terms because at this
23 point, it's still not clear how the Taiwan Power Company
24 will handle the test data. They may regard that as
25 company proprietary information, and will have limit the

4
1 the release of the data, or they won't make it public.

2 Because of this situation, I will present to
3 you in the general term, instead of the specific number.

4 One -- shows in the slides, the test results
5 show a substantial data scattering. It's not, I would
6 say, it's not as good as CAORSO data in terms of repeat-
7 ability. What reason caused that, to wait until we have
8 an opportunity to evaluate the data.

9 In general, the test results show the strain
10 gauge measurement are very small in comparison with the
11 expected value.

12 When I say the very small it means only a
13 fraction of the expected value.

14 The accelerations measurement -- they are also
15 very -- I would say -- small, not as small as the strain
16 gauge to compare. I still have significant margin.

17 The test results show you have significant
18 acceleration in pool region. Now, this, I put a note
19 that it requires further investigation because the
20 accelerators, the way they set up may pick up the motion
21 of the pool in addition to the building response.

22 In the same relative location, inside a pool,
23 and outside a pool or say outside containments, very close
24 similar locations, the one inside the pools measures
25 almost a factor of 6 or 8 higher than the one measures

5
1 outside the pool.

2 MR. EBERSOLE: The acceleration of what part,
3 please?

4 DR. SU: The building.

5 MR. EBERSOLE: The building.

6 DR. SU: ----- the building because it's a small
7 distance. I don't know but I really suspect the building
8 --- would cause such a big difference.

9 MR. EBERSOLE: That was measured with a maximum
10 of four valves discharging?

11 DR. SU: No, sir. Single valves.

12 MR. EBERSOLE: Would you expect a substantial
13 increase, added increase with all 16 working?

14 DR. SU: I would say so. Keep this in mind.
15 The so-called expected values I mean for the single
16 valve --- the pressure measurements in general are
17 within their expected values. Some exceed as I note
18 in my slide.

19 Now what this one really means in terms of
20 design is not clear from the on-site data. I will
21 categorize that as localized loads because you have to
22 look at the overall in terms of global pressures on the
23 containment.

24 The last slide really reflects what I said
25 previously, on the low-low set logic.

6 1 Now, the test result shows no significant
2 pressure increase from consecutive acceleration.

3 This is somewhat contradictory to the German
4 data. Dr. Zudans, the questions there on the subsequent
5 accelerations there, I believe the Germans' test may
6 have very small vacuum breakers in comparison with what
7 was used in Mark III and also Mark II and Mark I. We
8 made some before on Mark I -- also shows no significant
9 pressure increase from subsequent accelerations.

10 Let me back up a little bit to the Low-low
11 set logic.

12 If a single values so occurs on the low-low
13 set logic will result ---- subsequently instead of single
14 one.

15 On this, the basis, this would be bound by
16 the design case. All 16 pums or even --.

17 DR. ZUDANS: Would you show where those
18 vacuum breakers were located on this plant?

19 DR. SU: Locate inside the dry wells.

20 DR. ZUDANS: You have a sketch there.

21 DR. SU: Although it is a schematic diagram,
22 it's very close, to where they locate each one. They
23 won't really show the vacuum breaker locations -- what
24 I see is in the unit 2 is locate around this region,
25 pretty close to the discharge.

7
1 DR. ZUDANS: So if it would get stuck open
2 it would pressurize the dry well without --

3 DR. SU: You say in terms of --there you become
4 small on break.

5 DR. ZUDANS: That's right.

6 And that's what confused me because in the
7 G.E. report they said they are located in such a way
8 that that cannot happen and obviously that's not true.

9 DR. SU: Well, I really don't know the section
10 you quote.

11 I would say it would not happen -- not in terms
12 of stuck open, in terms of stuck closed because they
13 have two vacuum breakers in series so that is a simple
14 flip-flop. You want to stop close after both of them
15 fail and the CAORSO test with one of the valves closed,
16 intentionally to test what the consequence and the
17 results shows how much change because the capacity of
18 the valves ---, I believe the dangers.

19 MR. EBERSOLE: The item that you have on the four
20 valve test which shows significant acceleration on the
21 crane girder, I don't believe you went over that.

22 Do you mean the crane girder at the top of the --

23 DR. SU: All the way at the top, yes sir.

24 MR. EBERSOLE: Was that just due to building
25 resonance or --

8
1 DR. SU: Not clear to me. All I have heard is
2 ---- on-site at the analysis and very quick look and I
3 was --- keep this one in mind, if we have the opportunity
4 to participate the evaluation of the data.

5 MR. EBERSOLE: Would you throw the smaller
6 cross-section up on the board a moment please?

7 The other picture you have.

8 DR. SU: Okay.

9 MR. EBERSOLE: I notice you extended the guard
10 pipe on the SRV discharge line right down to the 45^o line.
11 Why did you do that? I don't believe the G.E. design does
12 that.

13 DR. SU: I really can't answer that, sir.
14 Because the nuclear power plant designed that way. I believe
15 the use of the GESSAR, just up to the point there was ---
16 and you can see the ----, the design, different from what
17 we have or what you will see in this country, for instance,
18 Grand Gulf. The floors are different. The guard pipe
19 I see ---- different.

20 MR. EBERSOLE: Has the staff noticed any
21 difference between the Taiwan plant and the Grand Gulf
22 plant. The issue to bring out is the significant engineering
23 difference from a safety viewpoint.

24 MR. FIELDS: For the SRV loads or in general.

25 MR. EBERSOLE: In general.

MR. FIELDS: I don't think we've really done any

9
1 detailed comparison in that fashion. The only reason
2 we have looked at the differences that could effect the
3 SRV loads is because we may be using their test data.

4 MR. EBERSOLE: For instance, are the instruments
5 located in the same place? Do they have the same catwalk?

6 MR. FIELDS: Maybe G.E. could answer that.

7 MR. HUCIK: I think the general design of
8 Koshang is similar to the all standard Mark IIIs so that
9 the HCU floor and that sort of thing is pretty much
10 designed in general.

11 There are several plant unique features for
12 all plants.

13 MR. EBERSOLE: I didn't notice the grating.

14 MR. HUCIK: It's there.

15 MR. EBERSOLE: It is?

16 MR. HUCIK: Yes.

17 That may be another Mickey Mouse cartoon -- it
18 may be only showing a certain section where it maybe is
19 concrete but they do have the grating also.

20 MR. EBERSOLE: Do you know then if there is
21 no particular engineering significant difference that
22 you know of from a safety context?

23 MR. HUCIK: No, not that I can think of.

24 MR. EBERSOLE: Thank you.

25 MR. FIELDS: The SRV supports are different.

1 MR. EBERSOLE: I saw that.

2 DR. SU: The final item from the test results
3 for the pool mixing -- the total discharge times was 9
4 minutes for each test and the bulk to local temperature
5 difference is 19°F without RHR and decrease to 9°F with
6 RHR operating one hour before SRV was actuated.

7 The highest temperatures that were measured
8 is around the quenchers and they compare with the bulk
9 temperatures about 30 minutes after the closures of SRV.

10 I came out -- I have to mention this. That
11 is the number I came out--not really officially Taiwan
12 Power Company's number.

13 DR. BUSH: Did they start with ambient
14 temperatures in the pool? For these tests, essentially?

15 DR. SU: I would say essentially about 90° to
16 start with. It really cannot cool down further. The
17 ocean temperature is about 87°.

18 I have to put a note on my presentations.
19 The results and my conclusions, I have to emphasize, my
20 presentations and the test results and conclusions of
21 the test results were based on a very preliminary
22 assessment of the on-site data. With that note, I
23 will mention the nuclear the ---- nuclear power plants
24 have fulfilled the objective of the SRV test. In general,
25 the structural model way over predicts the piping equipment

11
1 and building response, with respect to the forcing
2 functions. The methodologies for predicting the pressures
3 is marginal in terms of maximum pressures. That's the
4 way, here note, I have to investigate in terms of global
5 pressures, because the ---, the methodologies provide
6 a very conservative pressure attenuation, the effect.

7 The other conclusions, the forcing functions,
8 is the consecutive actuations, the methodologies over-
9 predict most of the cases.

10 The final terms regarding the applicability
11 of the test result is -- you notice, the methodologies
12 marginally predict the forcing functions and I really
13 cannot make -- distinguish the conclusions before a
14 detailed investigation we make.

15 However, the thermal mixings, I believe,
16 the -- and SRV tests will provide a good data base for
17 all the Mark III plants.

18 MR. EBERSOLE: Can I ask you a question about
19 these tests in a little bit different aspect.

20 Were the people inside the containment when
21 you ran the test?

22 DR. SU: Yes, I was there. I put my ears
23 against the containment walls and the sections, the
24 quencher discharging and I really don't feel much
25 the building response.

12

1 MR. EBERSOLE: Well, normally you don't have
2 people inside the containment -- about how many? Do
3 you know?

4 DR. SU: Inside the containment, I don't believe
5 they do.

6 MR. EBERSOLE: Won't they be maintaining some
7 of the instruments in there?

8 DR. SU: No, no.

9 MR. EBERSOLE: There's normal maintenance
10 in the building.

11 MR. FIELDS: There's normal maintenance in the
12 building.

13 DR. SU: No, I have to say, not inside the
14 containment. I was outside the containment.

15 MR. EBERSOLE: You were outside the containment.

16 DR. SU: In fact, the -- when they performed
17 the last series of tests, 4 valve test, the plant super-
18 intendent request some of his staff went inside the
19 containment to get a feel.

20 MR. FIELDS: Did he go in?

21 DR. SU: No, no, the plant superintendent --.

22 MR. EBERSOLE: I think the older the better
23 because I'm getting around to a radioactive dose question.

24 With an old core and its ultimate limit of
25 damage, before you have to take it out, because of -- defects,

13 1 when you experience a turbine trip you get many of these
2 valves discharged.

3 The steam will stop in the suppression pool
4 but the available gases will come up to be breathed
5 by the occupants.

6 What dose will he get?

7 DR. SU: I really can't answer your question.

8 DR. BUSH: I don't think they're permitted to
9 be in there, are they?

10 MR. EBERSOLE: You're working in there.

11 DR. BUSH: You're working in there?

12 CHAIRMAN PLESSET: I think we have a volunteer
13 from G.E.

14 MR. HUCIK: One of the G.E. personnel did go
15 in with the Tripower people during that one acuation.
16 He said the noise level was barely audible above the
17 norma. plant noise.

18 The radiation levels that were measured during
19 all of the SRV tests were well below the limits that the
20 Republic of China AEC asked for.

21 MR. EBERSOLE: It has no relevance to my question.
22 I'm talking about with an old and worn out core and a full
23 turbine trip.

24 MR. HUCIK: I would imagine one could scale
25 up those readings to get a feeling of --

14 1 MR. EBERSOLE: I think it would be necessary
2 that we have an estimate of radiation dose in keeping
3 with our other requirements.

4 CHAIRMAN PLESSET: I think we have more comment
5 here. Mississippi Light?

6 MR. RICHARDSON: John Richardson, Mississippi
7 Power and Light.

8 There are two things. I don't remember the
9 exact source terms that were used but G.E. did do calcula-
10 tions based on normal occupancy, times and duration of
11 time to get out of the containment during those consequences
12 and I don't remember, like I said, what the source terms
13 were, but there is a NEDO report and G.E. could probably
14 find out the number or we could find out the number, which
15 gives those calculations.

16 In addition, we were asked by the staff for
17 some numbers on the dose rates to an operator or a mainten-
18 ance man if he was in the containment under certain
19 conditions and we did respond and give those dose rates
20 and I don't have them on the top of my head but that
21 issue has been looked and addressed.

22 CHAIRMAN PLESSET: Then we'll get it. Thank you.

23 DR. BUSH: Referring to your last item, I
24 presume your conclusion is based on the fact that you had
25 thermal mixing for just a very short time. I mean, if you

1 are talking about an extended period --

2 DR. SU: No, ---. The Mark III containment, the
3 shell can take such the temperature difference, that would
4 be very conservative.

5 DR. BUSH: One other question. On your -- model
6 over-predicting, of course, you've got two aspects of it
7 and I presume Bechtel will address both forcing functions
8 and also the conservatism in the damping factors would
9 certainly be a very important thing and they are generally
10 very conservative.

11 If you look if one combines them, perhaps
12 one can understand the over-predicting.

13 DR. SU: I believe so. We have some discussion
14 on the Mark I before. Sometime they over-predict by
15 a factor of 10.

16 CHAIRMAN PLESSET: Do they have ignitors in
17 the containment at the plant?

18 DR. SU: I don't think so.

19 CHAIRMAN PLESSET: I didn't think they would.
20 Okay.

21 DR. SU: They didn't take the fast speed
22 pictures.

23 MR. FIELDS: Are those the hydrogen guiders?

24 DR. SU: Oh, hydrogen guiders, I don't believe
25 so.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. BUSH: I'm sorry. I misunderstood.

CHAIRMAN PLESSET: I'm sorry. Yes.

DR. ZUDANS: Did you say the structural model of the piping equipment and building response -- did they have the analysis before for these systems to compare to measurements?

DR. SU: Yes.

DR. ZUDANS: And the forcing function in the analysis was the forcing function as specified by G.E. and not the one that was observed in experiment?

DR. SU: The question -- yes. Based on G.E.'s predicted values.

DR. THEOFANOUS: I noticed in the NUREG report that you mentioned earlier that makes reference to this test. I got the impression by reading the report that the experimental data were somewhat different, of course, lower than what you expected, but I got the impression that you attribute that to imperfect knowledge of the actual experimental conditions of the reactor.

I was wondering if I got the correct impression, number one, and number two, if that is the case, what were the amounts and why there were such amounts that limit the comparability between what one would calculate and what one measured?

DR. SU: The in-plant test was required -- at the

17 1 we issued the acceptance criterias in 1976, at the time
2 the quenchers, there was developing and we don't know much
3 about it. Since then, a number of in-plant tests have
4 been performed. If you want me to make a judgement at
5 this point, I would say the requirements on the in-plant
6 test would be much in a narrow scope to have now. We
7 specify in NUREG-0763 essentially we call for that.

8 CHAIRMAN PLESSET: Thank you, Mr. Su. It was
9 a very interesting presentation.

10 MR. EBERSOLE: May I ask one more question that
11 is relevant to the safety of the system.

12 In your design do you also lose water in the
13 suppression pool to a central region under the core and
14 you have to make it up with an elevated pool supply?

15 DR. SU: That is not my design.

16 CHAIRMAN PLESSET: It's not his. It's NRC's.

17 MR. EBERSOLE: In that design.

18 DR. SU: I believe so. As I say, it very much
19 borrows the old way of doing here. It may have small
20 deviations.

21 MR. EBERSOLE: In essence, they have to make
22 up the water after certain loss --- from an elevated pool
23 exactly as Mississippi Power and Light does.

24 DR. SU: I would say so, sir.

25 DR. BUSH: May I ask a quick question?

1 DR. SU: Yes, sir.

2 DR. BUSH: You have NUREG-0763 released and
3 you mentioned the other two reports.

4 Do these three complete A-39?

5 DR. SU: Yes, sir.

6 DR. BUSH: Or are there others I'm not aware of?

7 DR. SU: That's the three reports in con-
8 junction with NUREG-0661 for the Mark I. That wil complete
9 the A-39.

10 DR. BUSH: I'd like to second Dr. Plesset's
11 comments. I thought this was a very well presented and
12 very interesting discussion.

13 DR. SU: Thank you very much.

14 CHAIRMAN PLESSET: Yes, very much so.

15 Let's take a ten minute break at this point.

16 (Whereupon, a ten minute break was taken.)

17 ///

18 ///

19 ///

20 ///

21 ///

22 ///

23 ///

24 ///

25 ///

1 CHAIRMAN PLESSET: Let's reconvene and I believe
2 that Dr. Economus comes on again. Is that right, Jack?

3 MR. KUDRICK: That's correct.

4 CHAIRMAN PLESSET: If he's ready.

5 (Pause)

6 DR. ECONOMUS: This is slightly -- the presentation
7 will be slightly different than the way it is shown in the
8 agenda, I think, but it is not too important.

9 I'm going to describe what is referred to as the
10 GE cross quencher load methodology to be distinguished from
11 the bubble phasing aspects of the methodology. The applica-
12 tion for this methodology is for structural design, again,
13 to be distinguished from piping and equipment evaluation.

14 It is a dynamic pressure loading which is applied
15 directly to the wetted boundaries. It uses and idealized
16 pressure signature which is -- you could characterize as
17 a damped Rayleigh bubble. The- this wave form is totally
18 characterized by specification of a peak pressure amplitude
19 and a dominant bubble frequency. The latter is arbitrarily
20 arranged from five to twelve hertz and the peak pressure
21 amplitude is derives from a algorithm or an equation which
22 is a function of plant parameters and the initial conditios
23 -- operating conditions.

24 It evolved from a regression analysis of small
25 scale, large scale and in plant test data which were performed

1 by a foreign licensee. Namely, the Germans.

2 It -- as I say, it is a regression analysis of
3 the data and it uses -- It uses a 95-95 confidence level
4 margin. Aside from the features of the pressure signature,
5 some of the other features are the spacial distribution.
6 There is a two quencher arm radius plateau. In other words,
7 any boundaries which are intersected by sphere of radius
8 $2R$, twice the quencher arm, maintain the maximum pressure.
9 Beyond that point, there is a one over R attenuation, coupled
10 with what is called a line of sight cut off. In other words,
11 if the line projected from the quencher arm to a boundary
12 intersects another boundary, the pressure is set equal to ²
13 zero beyond that point and all of this applies below a
14 certain point in the pool. That point being a 75 percent
15 depth.

16 Above that point, there is a linear decay to zero
17 at the pool surface. Now, for this methodology which is
18 for structural design, the way multiple valve effects are
19 treated is to assume there are synchronized bubble oscillations
20 and to SRSS the individual contributions with a cutoff
21 at the peak pressure amplitude.

22 Of course, part of that methodology is a specifica-
23 tion of a variety of load cases. The load cases that are
24 considered are first actuation at low pool temperature --
25 this is of a single valve. A subsequent actuation at an

1 elevated pool temperature, two adjacent valves, first
2 actuation at low temperature, ten valves, one low and the
3 next high set point group -- again, at low pool temperature.
4 ADS valves, a first actuation at elevated pool temperature
5 and all valves first actuation at low pool temperature.

6 Now, this figure simply shows how the wave form
7 looks. As you can see, all features of it are defined. This
8 figure shows POP. It's the same as PPE. Once you define
9 POP in the DBF, this signature is completely defined.

10 Now, this methodology as Nelson pointed out earlier
11 was originally accepted by the NRC by in 1976. Since that
12 time, as the result of the data base made available by the
13 Caorso tests, GE proposed some modification of the methodology.

14 Specifically, they proposed that it was appropriate
15 to reduce the peak pressure amplitude by 20 percent for
16 first actuations and 35 percent for subsequent actuations.
17 We are -- This says Staff Review in Progress. That's true.
18 We haven't completely finished taking our positions. In fact
19 we received formal information at this meeting here from
20 GE which we're going to be reviewing.

21 The issues that came up in the course of our review
22 were really only three and we really consider them minor.
23 In first developing -- in first justifying the reductions,
24 we felt that they used the load trend with line volume that
25 the original methodology had in non conservative manner.

1 We also found that when applying the same reduction
2 to the under pressure that there was an incorrect application
3 of the reduction made and also there was a vacuum breaker
4 effect which was observed during the Caorso tests which was
5 not accounted for. I can talk about that in some detail,
6 if you want, a little later.

7 In any case, there is complete agreement on these
8 issues between the staff and General Electric and we expect
9 and I would say that we have a solution on all of them.
10 Primarily because after taking these reductions, there still
11 remains sufficient margin to account for correct interpre-
12 tation of the Caorso data base.

13 I can sort of indicate the extent of that margin
14 with this bar chart that General Electric has provided us.
15 This shows how one takes the Caorso measured data, adjust it
16 to account for various differences between a standard
17 plant and the GESSAR plant conditions and shows how far up
18 you would have to go based on Caorso to get the 95-95
19 confidence level and this is compared with what the new
20 modified GESSAR design would be. So, as you see there is
21 substantial margin still between the -- what you would infer
22 from the Caorso data and what the design uses.

23 Now, I have to point out that this calculation for
24 modifying the Caorso data has already taken account of our
25 concern with regard to the line volume effect, but not our

1 concern with respect to the vacuum breaker effect.

2 I'm going to show a proprietary slide here, which
3 is not in your handout to indicate that when you account for
4 that concern, you do increase what you would extrapolate
5 from the Caorso data somewhat if you look at the value there.
6 You see it turned out to be like 13.2, whereas without
7 properly accounting for the vacuum breaker effect, you would
8 project 11.7. Still a substantial margin remains and after
9 all we don't consider that as a concern.

10 DR. CATTON: What is the vacuum breaker effect?

11 DR. ECONOMUS: Well, okay, specifically what was
12 observed at Caorso was that -- well, the bulk of the tests --
13 I would say that 90 percent of the tests were done with so-
14 called Valve A, which had a prototypical pair of vacuum
15 breakers, but one of them was blocked and as I say, essen-
16 tially all the data base came from a valve with only one
17 operating vacuum breaker.

18 A limited number of tests were done with Valve U,
19 which essentially had the same line volume. Geometrically,
20 they were pretty similar. The only difference was when they
21 actuated Valve U, both vacuum breakers were operating. What
22 was observed was that there was a substantial increase in
23 subsequent actuation loads with Valve U.

24 We speculate that this is a vacuum breaker effect,
25 to wit, by having both vacuum breakers operating you let

1 enough air in to crank up the loads.

2 The parameters that control such actuations are
3 very complicated. They depend on what your initial water
4 leg is, how much air content there is, etcetera.

5 DR. CATTON: Time between actuations.

6 DR. ECONOMUS: Oh, sure, absolutely, but as I
7 say, I mean, everything else being nominally the same, Valve
8 U tended to show significantly higher loads -- subsequent
9 actuation loads than Valve A.

10 (Pause)

11 Now, that sort of covers --

12 DR. ZUDANS: I have a question.

13 DR. ECONOMUS: Yes.

14 DR. ZUDANS: In this sort of Valve U, was the
15 subsequent actuations were associated with higher loads than
16 the first association on the same valve?

17 DR. ECONOMUS: Well, actually the ratio between
18 first and subsequent of Valve U was in both in proportion and
19 absolute sense higher. The first actuations of Valve U were
20 somewhat lower than the first actuations with Valve A.

21 And the subsequent actuations with Valve U were
22 higher than the subsequent actuations with Valve A.

23 DR. ZUDANS: But the Valve U, by itself, first and
24 subsequent.

25 DR. ECONOMUS: That ratio was higher than Valve A.

1 DR. ZUDANS: That's interesting. With the more
2 air, that would be contrary to waht --

3 DR. SU: I just want to make a note. Caorso
4 has a much larger air -- inside a line comparing with the
5 -- would be. The effect is very difficult to determine.

6 DR. ECONOMUS: I would certainly agree with. It's
7 a very complicated process and it depends on conditions
8 inside the line when you do a subsequent actuation, it is
9 highly variable.

10 DR. ZUDANS: Does anyone have a precise physical
11 understanding why in Caorso there subsequent actuation is
12 higher than the first actuation?

13 DR. ECONOMUS: My speculation is that what you
14 wound up with is a situation with a hot pipe and lots of air.
15 In other words, more air than in the --

16 DR. ZUDANS: First actuation?

17 DR. ECONOMUS: Not in the first actuation, but in
18 the subsequent actuation with Valve A with only vacuum
19 breaker operating.

20 DR. ZUDANS: No, no. Looking at the same line.

21 DR. ECONOMUS: Yes.

22 DR. ZUDANS: You have a first actuation and a
23 subsequent actuation.

24 DR. ECONOMUS: Yes, sir.

25 DR. ZUDANS: In the first actuation, I assume that

1 the water level is right where the pool level is --

2 DR. ECONOMUS: Nominal water level and cold pipe.

3 DR. ZUDANS: -- and you had the same area in there.

4 And cold pipe.

5 DR. ECONOMUS: Yes.

6 DR. ZUDANS: In the second case, you had a hot
7 pipe and the same water level, presumably?

8 DR. ECONOMUS: I think that's correct, yes.

9 DR. ZUDANS: And actually less air volume in there
10 -- less mass, because it was hotter.

11 DR. ECONOMUS: That's true, because the pipe was
12 hotter, yes.

13 DR. ZUDANS: Why would that show high load. That's
14 a physical difficulty to understand.

15 DR. ECONOMUS: The mechanism is suppose to be that
16 the steam that is driving what air you have in there out --
17 when the pipe is cold, more of it condenses and you don't
18 have as much of a drive to compress the air in the pipe.
19 That's sort of the qualitative mechanism that we expect.
20 Gives rise to higher subsequent actuation loads.

21 It's a complicated process.

22 DR. BUSH: May I ask one question?

23 DR. ECONOMUS: Yes.

24 DR. BUSH: Vacuum breakers come in a lot of sizes.
25 In Caorso, what was the throat size?

1 DR. ECONOMUS: We've gone through that. It's a
2 ten inch.

3 Now, I'm going to the subject that is listed here
4 in the agenda. Namely, the multiple phasing -- multiple
5 valve bubble phasing of it. I tried to make the distinction
6 earlier and I repeat this again. This feature of the proposed
7 methodology is to be used to do the piping system and the
8 equipment response evaluation. The motivation is that when
9 you make the synchronise bubble assumption that you're
10 exciting the structure with an overly conservative forcing
11 function and GE approach is to demonstrate quantitatively
12 how much you can reduce that by Monte Carlo simulation so
13 that you can develop, still a conservative, but a more
14 realistic estimate of what the excitation is.

15 Now, some features of the methodology and of course
16 since it is a probabalistic one, you have to decide what are
17 your random variables. The ones that were selected by
18 General Electric were the reactor pressure rise rate which
19 triggers the valves at different times as opposed to simul-
20 taneously, because of the different set points.

21 They choose the valve set point tolerance as a
22 random variable. They choose valve opening time as a random
23 variable. They choose the dominant bubble frequency as a
24 random variable.

25 Now, for each of the variables if you've decided a

1 random, you have to specify the probability density function.
2 General Electric derives these for PRR from operating
3 experience and plant transient analysis. For the valve
4 set point tolerance, the GAussian distribution is used.
5 And note, it needs to be made here. The testability feature
6 that is employed in Mark III SRV controls preclude the
7 drifting of nominal set points between groups. So that the
8 potential for randomly actuating groups simultaneously is
9 sort of precluded by only using the set point tolerance as
10 a random variable.

11 Valve opening time, the density function is derived
12 from shop tests and the density function for the dominant
13 bubble frequency comes from foreign in plant test data.

14 The confidence level for the load specification
15 fifty-nine Monte Carlo trials are used to generate it and
16 a 95-95 confidence level is claimed. For design a total
17 of as many as nine is used to actually excite the structure
18 and the way the nine are selected from the total fifty-nine
19 is by examining the spectral peaks and vertical and over-
20 turning moments to assure that you have some sort of a
21 envelope of the fifty-nine trials.

22 Those are the features of the methodology -- some
23 of the features of the methodology. Other features -- there
24 is one Rinko. The DBF probability density function is shifted
25 to account for differences in line volume. It is reasonably

1 well established that the bubble frequency is a function of
2 line volume and that is taken into account in the methodology
3 deterministically.

4 In this methodology, the contributions from different
5 valves are now added algebraically. Since the credit is
6 -- The SR assess was sort of an indirect way of getting some
7 credit for randomness or phasing, now you phase them in a
8 probabilistic fashion. Now, you superimpose the loads
9 algebraically.

10 All the other features, the pressure signature,
11 the peak to peak amplitude, the special distribution, the
12 load cases are essentially as they were for the original
13 methodology.

14 Staff evaluation -- We've looked at each of the
15 individual ingredients of the methodology and we can't say
16 that we're completely satisfied that each and everyone of
17 them is a precise -- is totally validated.

18 Some examples -- The probability density function
19 for DBF, we feel, is not really prototypical, for example,
20 of the -- of what was exhibited by the Caorso data. In
21 particular, the mean frequency and the standard deviation in
22 Caorso was significantly different than the one that was
23 employed by this methodology. We can speculate on why there
24 are those differences.

25 Also, another example of where we couldn't quite

1 agree with General Electric about the methodology is the
2 claimed 95-95 confidence level. That can only be claimed
3 if you were to use all fifty-nine trials for design. There-
4 fore, we don't agree with General Electric about that.

5 Nevertheless, if you consider the methodology in
6 its entirety, we feel that the result is acceptable. We've
7 satisfied ourselves that this is so based on series of
8 sensitivity studies that we asked them to make with respect
9 to changing the probability density functions and the standard
10 deviations and so on to demonstrate that the final results
11 were not too sensitive for that. But primarily, our con-
12 clusion that the methodology is acceptable is based on an
13 actual application of the methodology to a multiple valve
14 test conducted in the Caorso plant.

15 I will show one of the typical results that show
16 there is a considerable conservatism. Then, of course,
17 pending the actual execution of the Grand Gulf inplant tests,
18 we will have further confirmation that the methodology is
19 acceptable.

20 Now, let me just show you a couple of examples of
21 the conservatism which are demonstrated when it's applied
22 to an actual test result. This is what has been predicted
23 by the the multiple SRV methodology for the conditions of
24 -- for the conditions that existed in one of the four valve
25 Caorso tests.

1 In this case, the only random parameters are the
2 valve opening time and the dominant bubble frequency, because
3 first of all, we knew precisely when the signal to open the
4 valves was -- occurred and therefore we knew exactly -- that
5 was a deterministic input. The only parameters that are
6 random here, as I'll repeat, is the valve opening time and
7 the bubble frequency.

8 As you can see, the margin is -- well, it varies
9 from almost a factor of 100 down in the frequency range
10 with the bubble -- where we expect the bubble to really be
11 active to a factor of two out at high frequency. The margin
12 of course is not so great at high frequency, but we're not
13 really concerned with this, because chugging loads would
14 take over at this end anyway.

15 One final comparison of that sort --

16 DR. THEOFANOUS: What do you attribute this
17 discrepancy? Is there is something that you can attribute
18 it to?

19 DR. ECONOMUS: The large margin?

20 DR. THEOFANOUS: Yes.

21 DR. ECONOMUS: Even when you phase, you still have
22 very high pressure amplitudes that would be used. I mean,
23 the PPA that you used for the conditions of the Caorso tests
24 are significantly higher than what actually occurred.

25 The nature of the wave form that concentrates lots

1 of power --

2 DR. THEOFANOUS: To you contribute to the method-
3 ology or to the input of the methodology?

4 DR. ECONOMUS: No, we've cut the inputs to the
5 methodology out as far as possible. As I say, they're only
6 getting credit for slight differences in bubble frequency
7 and slight differences for valve opening time. Primarily,
8 it's the methodology itself.

9 Just one final figure that is sort of like this,
10 but what it does is show a comparison of what the envelope
11 looks for all fifty-nine trials and in fact, I thought I'd
12 show the upper bound of the fifty-nine trials and the lower
13 bound of the fifty-nine trials compared with the measurements.

14 When it was presented, there was some wag, was it
15 you, Terry? Maybe not. He said, well maybe a reasonable
16 specification is a lower bound of our Monte Carlo simulation
17 which, of course, we didn't go along with.

18 That concludes --

19 VOICE: That says something for bounding techniques.

20 DR. ZUDANS: This of course refers to a specific
21 point.

22 DR. ECONOMUS: Yes, as I stated. A selected point
23 on a wetwel.

24 DR. ZUDANS: Are you sure that there are no other
25 points where the picture is the worst?

1 DR. ECONOMUS: I'm pretty sure. They showed us --
2 several tests, several sensors.

3 CHAIRMAN PLESSET: Have you completed your
4 presentation?

5 DR. ECONOMUS: Yes, sir, if there are no other
6 questions.

7 CHAIRMAN PLESSET: Yes, let's continue.

8 MR. KUDRICK: That basically concludes our planned
9 presentation on the dynamic individual loads for both LOCA
10 and SRV and now what we would like to do is share with the
11 subcommittee on what changes have been made to plants other
12 than Grand Gulf since the issuance of the CP to give you some
13 idea of the type of modifications that are being made in
14 the plants out in the field. Other than Grand Gulf.

15 Grand Gulf, you heard of the modifications that
16 you made yesterday.

17 MR. FIELDS: We felt that the ACRS would be
18 interested in knowing what modifications the various plants
19 have made in the design of their plants, because of the
20 refinement of the load definitions in the pool dynamic load
21 area, since the issuance of the CP for Grand Gulf and the
22 PDA for GESSAR.

23 Basically, the objective of this presentation is
24 to show the extent of plant modifications and the methods
25 we selected for plants. Two plants at the OL stage and two

1 plants at the CP stage.

2 The four plants are Clinton, River Bend, Black
3 Fox, Allens Creek.

4 We'll just start first with Clinton along with
5 Perry, the most advanced Mark III in the United States except
6 for Grand Gulf.

7 Clinton said that the suppression pool liner was
8 strengthened. This is basically because of the SRV negative
9 bubble load. There were some general modifications at the
10 HCU floor because of the pool swell loads. The equipment
11 moved from grating on to concrete where ever possible.
12 Piping under the HCU floor was moved as high as possible to
13 get out of the solid water impact zone. A lot of the SRE
14 piping and supports were modified and also the ECCS suction
15 strainers and supports that are in the suppression pool were
16 redesigned because of submerged structure loads.

17 The polar crane girder and brackets were redesigned,
18 basically because of the higher frequency content in the
19 load definition. Primarily from the SRV actuation. There
20 was a lot of gentle upgrading of piping, pipe supports,
21 snubbers and etcetera. Again, because of the higher
22 frequency content of the load definition.

23 CHAIRMAN PLESSET: Where is this plant located?

24 MR. FIELD: Clinton? Illinois. It sounds familiar.
25 Decatur, Illinois.

1 DR. ZUDANS: The quencher itself is still supported
2 either laterally only or vertically only and no two supports.

3 MR. FIELDS: I don't believe that it's supported
4 in two directions, is it Nelson? Basically, how is the
5 SRV supported at Clinton?

6 DR. ZUDANS: Not the SRV, --

7 MR. FIELDS: The quencher.

8 So, his response is basically that it is supported
9 both laterally and vertically.

10 DR. ZUDANS: Okay.

11 DR. BUSH: I presume that by general upgrading of
12 piping and pipe supports, that means that they've added a lot
13 more supports --

14 MR. FIELDS: Yes.

15 DR. BUSH: I'm not sure that I define that as up-
16 grading. It's negative upgrading.

17 MR. FIELDS: There is two ways of looking --

18 River Bend, the other operating plant we looked
19 at added steel hoops and stiffeners to the outside of the
20 free standing steel containment up to the elevation of the
21 suppression pool service to make basically stiffen the steel
22 containment and they have decided recently that that wasn't
23 quite enough. They're going to fill the annulus between the
24 concrete shield building and steel containment with concrete
25 to a level of five feet above the suppression pool surface.

1 Basically a generic approach is being taken on all
2 of the free standing steel shell Mark III containments.

3 DR. BUSH: Depending on how they did the first one,
4 you could actually reduce the reliability of that system.

5 MR. FIELDS: Hopefully. The problem with making
6 the containment so rigid that you have no -- for the SRV
7 loads, then you have problems with the seismic loads. The
8 two would have to be traded off.

9 Black Fox is of course the SP and therefore is
10 not become construction. The design changes are on paper
11 only. They have modified the stud patterns on the weir wall
12 because of the chugging loads in the top vent. They're
13 considering adding stiffeners to the free standing steel
14 containment and they will fill the annulus between the
15 concrete shield building and the steel containment to the
16 same level as the other plants.

17 The other plant I contacted was Allens Creek.
18 This was basically done verbally last week, because it
19 really wasn't too much time to get too much information.

20 Allens Creek -- again they're adding vertical
21 stiffeners in the suppression pool region. They modified
22 their -- design from an elipsodial to a hemispherical design
23 because of the higher frequency content of the design loads
24 and they have relocated all piping out of the solid impact
25 area. That's the zero to 18 feet above the initial suppres-

1 sion pool temperature -- suppression pool level.

2 DR. THEOFANOUS: Which dome is that?

3 MR. FIELDS: This is the containment dome. It's
4 a free standing containment dome. The previous design was
5 an elipsodial design and as it was described to me, the way
6 the middle of the dome wall responds to high frequency loads,
7 is more pronounced in an elipsodial design than it is for
8 a hemispherical design.

9 Another method would be to add stiffeners to the
10 dome instead of changing the dome design. They decided to
11 go in this direction. I'm pretty sure they're -- I'm not
12 sure if Allens Creek is filling the annulus with concrete or
13 not.

14 DR. ZUDANS: That was generically done, I under-
15 stood yesterday from GE.

16 MR. FIELDS: GE is definitely doing it on the
17 stride package which is basically the Heartsville. This would
18 be an individual decision made by the architect/engineer.

19 In summary, the Staff feels that the load require-
20 ments do not require major design modifications and major
21 should be defined that modifications can be made late in
22 the construction of the plant. It doesn't require stream
23 delays in the plant construction.

24 That's about it for this presentation.

25 There is a comment was that Perry should make a

1 presentation on their modifications. I have talked briefly
2 with them. They're basically doing the same thing that the
3 other plants are. If the staff would be interested, perhaps
4 someone from Perry could talk to you.

5 Is there someone from Perry who could make a brief
6 impromptu discussion?

7 (Pause)

8 MR. VATH: My name is Carl Vath from Gilbert
9 Associates in the Perry Project.

10 CHAIRMAN PLESSET: Where is that located?

11 MR. VATH: Perry is located about 20 miles north-
12 east of Cleveland, Ohio.

13 CHAIRMAN PLESSET: Thank you.

14 MR. VATH: We are a free standing steel contain-
15 ment. We've added fill concrete between the containment
16 and shield building, roughly five feet above the suppression
17 pool upper elevation. We have moved a lot of equipment out
18 of the bulk pool swell area. There is still some equipment
19 there.

20 We have had to heavily strengthen the platform
21 supports and attachment points to the drywell and have
22 significant redesign on the two lower platforms effected by
23 pool swell itself.

24 We've had extensive modification and equipment
25 qualification due to high responses because of timing, the

1 full effect of the fix and reduction of the appropriate
2 containment ringing problem or excitation of the containment.
3 We had a timing problem there in being able to take the
4 full reduction on the equipment qualification, but -- so
5 we've had some equipment mods and some very significant
6 amounts of piping support redesign and support additions.

7 DR. EBERSOLE: I want to go back on the general
8 topic of equipment modifications to point out that our
9 concern is basically what happens to equipment rather than
10 structures. Of course, if the structures fall and carry
11 equipment with them, than that's structure involvement, or
12 rather equipment involvement.

13 I'd also like to recall an earlier remark that I
14 made that while we're looking at jet and dynamic loads --
15 this equipment list re-examined the interior of the drywell
16 with such aspects as blast loads on the -- gravity -- recalling
17 that the dry tubing is necessary to insert the rods at the
18 LOCA because the primary pressure is going down extremely
19 rapidly. You don't have the auxillary pressure to help you
20 in completing this problem.

21 The accumulator will put you in if you retain the
22 pipe, that is, because of the residual pressure having placed
23 a lower operating pressure in the reactor.

24 But, if you look very carefully, and I looked at
25 this -- you find that the jump shifts certain piping in sub-

1 containment makes you suspicious of where LOCA breaks might
2 occur and carry away substantial number of the drag pipes
3 as well as perhaps --

4 There is also the matter of other instrumentation
5 in the drywell which might bare further examination and
6 aspect of the same kind load that we're looking at down
7 in the suppression pool.

8 MR. VATH: To address that is to really not address
9 it. Jet impingement loads have been designed for it. I'm
10 not prepared to discuss any jet impingement loads outside of
11 hydrodynamic effects which is the main purpose of the meeting.

12 MR. EBERSOLE: This hydrodynamic effects of
13 course is the concern of other parties.

14 MR. VATH: Correct. Rephrase that to, quote, new
15 loads. Pool swell and SRV is the only thing --

16 MR. EBERSOLE: It would be the equipment load
17 and dynamic effects inside the drywell.

18 MR. VATH: Right. And we have a very significant
19 amount of analysis and design on that, but I'm not prepared
20 to discuss this.

21 MR. RICHARDSON: John Richardson, Mississippi
22 Power and Light. The effects that you're asking about, Mr.
23 Ebersole are required to be evaluated by the mechanical
24 engineering branch specifically, jet impingement, the blast
25 effects, etcetera and you're required to protect essential

1 equipment. Those effects and the analysis are discussed, I
2 think, in section 3.6 of the final safety analysis report.

3 MR. EBERSOLE: Those reports are so brief that
4 one can only gather -- supporting data to show how well you
5 analyse these affects.

6 MR. RICHARDSON: Well, we've got the data that
7 was used in the analysis in our files.

8 MR. EBERSOLE: Particularly the area in the
9 vicinity of the -- land piping where the quadrant of the
10 control drive was located. I would be particularly interested
11 in your presentation of that area.

12 MR. RICHARDSON: I remember that area specifically
13 we have looked at and the analysis was under taken. As far
14 as how much supporting information we have, I'm not sure.
15 We can look into that. But those affects are evaluated by
16 the mechanical engineering branch and they have basically
17 accepted what we have done today.

18 CHAIRMAN PLESSET: Thank you. Is there any further
19 presentation on this line, Jack?

20 MR. KUDRICK: Not in the area of design modifica-
21 tions. The subcommittee did hear the Grand Gulf discussion
22 in this particular area yesterday. So that concludes our
23 area relative to containment modifications. If you desire,
24 we can continue on.

25 CHAIRMAN PLESSET: Sure.

1 MR. KUDRICK: The next topic on the agenda is a
2 description of the inplant SRV test as proposed by Grand
3 Gulf.

4 CHAIRMAN PLESSET: We were going to get a presen-
5 tation from GE on general plant design?

6 MR. FIELDS: Well, that is what I did.

7 CHAIRMAN PLESSET: Does GE back you?

8 MR. FIELDS: GE wouldn't do it.

9 (Laughter)

10 MR. JOHNSON: My name is McKinley Johnson, project
11 engineer with Mississippi Power and Light Company on the
12 Grand Gulf project.

13 What I would like to discuss with you this morning
14 is the inplant testing program that we presently have
15 scheduled at Grand Gulf. Very briefly the background of
16 that program and a brief discussion and description of the
17 test itself -- the pressure measurements that we expect to
18 take -- the accelerometer measurements that we expect to take.
19 What schedule this work will be performed under and also
20 our conclusions relative to the test that we are presently
21 planning.

22 (Pause)

23 With regard to background, the NRC has indicated
24 in a review of the GESSAR 238 plant that verification of
25 quencher loads would be required by the first plant -- the

1 GESSAR Nuclear Island design. They also indicated that
2 prototypical tests would be required for each type of
3 containment structure that is still in concrete.

4 As was discussed this morning, Kuosheng has recently
5 completed inplant testing with the objective of
6 demonstrating significant reductions in structural response
7 and therefore reducing loads to piping equipment.

8 The Kuosheng and the Grand Gulf plant are reinforced
9 concrete containments and we presently have plans for
10 inplant testing in addition we are reviewing Kuosheng data
11 and it's applicability to Grand Gulf to determine if additional
12 testing is required at this time.

13 I think the terminology of the test description
14 that you probably heard this morning and maybe look familiar
15 to you. We have six single valve actuation tests planned
16 or SVA tests. We also have six consecutive valve actuations
17 scheduled. Seven multi-valve actuations and one extended
18 valve actuation for the thermal mixing consideration.

19 The instrumentation that is scheduled and I'll show
20 you a little bit about where it is located consists of about
21 27 pressure sensors, 34 string gages on submerged structures
22 and 16 temperature sensors and 41 acclerometer channels
23 in 17 separate locations.

24 DR. CATTON: You have less instrumentation than
25 the Kuosheng.

1 MR. JOHNSON: That's correct.

2 DR. CATTON: Are you basing that on the UHL of
3 the Kuosheng test?

4 MR. JOHNSON: I think that the real issue there
5 is -- the objective of the test. Their objective was more
6 to demonstrate significant reductions in containment response
7 for a number of load combinations throughout the plant.

8 Our position was one of 100 percent of containment
9 response has been built into our design and that load input
10 has been put into all type of equipment. So, although we're
11 interested in what the margins are, we're more interested
12 in just observing that there are margins as opposed to trying
13 to quantitatively trying to describe exactly what those
14 numbers are.

15 (Pause)

16 This slide basically demonstrates where your
17 pressure sensors are located. It demonstrates the arrange-
18 ment of the quencher in the pool. Basically, you can see
19 pressure sensors are located on the base mat within five feet
20 of the quencher. They are also located on the containment
21 wall at three different elevations. Along with the asimuth of
22 the quencher being tested.

23 Also -- on the drywell wall at three elevations
24 along the asmuth of the quencher being tested.

25 MR. EBERSOLE: After the test, is any of these going

1 to be left in place, because about ten times in the first
2 year, you're going to see a whole lot of these go off at
3 once. Do you intend to leave any of them and monitor the
4 -- effect of all of them?

5 MR. JOHNSON: I do know that obviously the instru-
6 mentation in the pool will remain in the pool at least the
7 first few --

8 MR. EBERSOLE: I think it might be interesting to
9 see the full -- trip without bypass.

10 MR. JOHNSON: We have built into our test plan the
11 contingency that the instrumentation will be operated during
12 other transient testing and MSI -- closure internmentship is
13 one of those --

14 This slide projects certain locations of acceler-
15 ameters that are being incorporated in the test plan. There
16 again of a lesser magnitude than the Kuosheng test. And
17 actually, if you review the Grand Gulf test plan, these
18 accelerameters are not even shown in that test plan. The
19 test plan was a basically load conformatory test plan with
20 the understanding and agreement and it was spelled out in
21 the test plan that at any time level one or level two values
22 are exceeded, we would evaluate the significance of that
23 before proceeding on with the test. So these accelerameters
24 were put in to aid us with that evaluation should any level
25 one or level two pressures be exceeded in the test.

1 We tried to get a variety of elevations along the
2 containment and drywell wall. Another criteria that we used
3 was to try and select through review of the structural
4 model where locations where peak response was predicted.

5 Also you see one in the low input to the crane
6 and mid point of the crane. We mentioned yesterday that we
7 made significant qualifications to that crane so we wanted
8 to observe whether we wasted our time and efforts in that or
9 maybe it would be really worthwhile.

10 (Pause)

11 The schedule for our evaluations calls for a fuel
12 load, right now, on December 31st. If that occurs, we should
13 be testing at 50 percent power in the mid April time frame
14 which will allow for a quick look reports to be issued about
15 June 15th and a final report on September 1.

16 Conclusions relative to our test at this time, is
17 that we feel like the test program is sufficient to provide
18 a data base so that we can evaluate the load definitions in
19 our plant. Another conclusion and significant conservatism
20 are about to exist in the structural model as Mr. Su pointed
21 this morning which will result in additional safety margins.

22 The third item is that we will complete evaluations
23 of Kuosheng data in early October and if appropriate, we
24 would like to meet with the staff at that time for the purpose
25 of deleting further testing. As I say, if it's appropriate

1 at that time. We don't have all the data at this point.

2 Two other slides that I'd like to discuss very
3 briefly. I mentioned that we're looking at the data and would
4 like to meet with the Sta. to determine if that data is
5 applicable to us. There are some items that lead us to
6 believe that at this time. They are in no way conclusive
7 at this point, but I would like to at least share with you
8 the things that we see that tell us that we should look at
9 that.

10 NUREG 0763, as Mr. Su mentioned this morning,
11 basically describes in what area plants must be similar for
12 the data from one plant to be prototypical to the other.

13 The first item has to do with quencher devise
14 geometry and in general, although we need to look at much
15 more detail, we both have exquenchers with identical arm
16 and hold patterns on the structures.

17 The parameters that affect the bubble pressure
18 would need to be similar and we feel that they are. If you
19 through the emperical calculations of pressures and you
20 increase those for standard deviation and confidence factor
21 adjustments, you'll see that the final design value for
22 consecutive valve actuation at Grand Gulf is 18.2 as compared
23 to 16.6 at Kuosheng.

24 Another items mentioned in the NUREG is steam
25 flow per line area and the flow rates are identical with
no impact on predicted pressures expected. Line diameters

1 are also identical.

2 With regard to quencher pool geometry, as you can
3 see, I made a slight change on that one yesterday. I apologize
4 for that. And the change has been made on the handouts that
5 were given as well. Both quenchers are located center line
6 five feet and zero inches from the drywell wall. At Grand
7 Gulf, the center line of the arm is located five feet zero
8 inches from the floor. At Kuosheng, it is five feet, six
9 inches.

10 The pool depth normal water level at Grand Gulf is
11 18 feet, 10 inches. At Kuosheng it is 19 feet, two inches.

12 With regard to containment characteristics, both
13 are reinforced concrete containments -- drywell and pedestal
14 of similar construction, platforms and floors similarly
15 located. And as I mentioned, this data is rather preliminary.
16 I just wanted to share with you the things that we know now
17 that would have to be looked at in more detail.

18 DR. THEOFANOUS: Have you thought about making
19 an effort of locating at least some of your instrumentation
20 in locations exactly the same like the Caorso tests or do
21 you have an exact one to one comparison?

22 MR. JOHNSON: I guess the thought process has been
23 more of locating the instruments in exact spots that relate
24 to the structural model for our plant. So that we would
25 really have a comparison of test data to predict it as

1 opposed --

2 DR. THEOFANOUS: I'm sure that the same time the
3 logic went through their mind -- they were getting their
4 instruments, so I'm not sure that they're positions were
5 too far from where they should be. It might be worthwhile
6 in view of this comparison that they're showing to locate
7 your instruments, at least some of them, in exactly corres-
8 ponding positions so that we can see more or less the same
9 -- conditions to see what kind of a position we get. We
10 might get some idea about the --

11 MR. JOHNSON: Are you speaking relative to Kuosheng
12 or Caorso.

13 DR. THEOFANOUS: Yes.

14 MR. JOHNSON: Kuosheng. I understand your comment
15 is well taken. I feel like if we go back and look you'll
16 find that we do have the same spots, but I can't say for
17 sure right now.

18 (Pause)

19 The last slide is just a pictorial display of what
20 I just on the preceding slide show the two quenchers. The
21 pool width at Kuosheng is 17 feet, six inches. Grand Gulf
22 is slightly wider, 20 feet and six inches.

23 We discussed the five foot dimension from the dry-
24 well to the center line of the quencher on both plants. We
25 also discussed the 18 feet, 10 inch pool depth as opposed to

1 19 feet, two inches.

2 DR. CATTON: Why is that outer wall so much thicker
3 at Kuosheng?

4 MR. JOHNSON: They have a higher seismic requirement
5 at Taiwan than we have at south Mississippi. They do have
6 a thicker containment wall. They are both reinforced con-
7 crete, but there's is thicker due to seismic considerations.

8 As you can see there is a slight difference in the
9 bracing of the quencher arms as well. Mr. Su commented on that.
10 They have, I guess, a shell steel arrangement above and below
11 the quencher arms. Ours is supported below the quencher
12 arms.

13 MR. EBERSOLE: Is that 19 feet, two, I see up
14 there for the height of the pool?

15 MR. JOHNSON: Yes.

16 MR. EBERSOLE: Than it's about six feet higher
17 than yours.

18 MR. JOHNSON: Ours is 18 feet, 10 inches.

19 MR. EBERSOLE: Sorry, I thought it was 13.

20 MR. JOHNSON: No, sir. That should be 18 feet,
21 10 inches.

22 You mentioned earlier, I think, there was a question
23 with regard to the --

24 MR. EBERSOLE: I see the guard pipe.

25 MR. JOHNSON: The guard pipe, yes, sir. I believe

1 that is extended quite aways down into the pool to preclude
2 the possibility of a transient and a low water level and
3 a simultaneous break in the discharge line which would
4 potentially bypass this --

5 MR. EBESOLE: I notice that your guard pipe,
6 however, practically intersects the wall at the water line,
7 whereas at Kuosheng, it is several feet below. The guard
8 pipe covers that spot.

9 MR. JOHNSON: Yes, I think so.

10 DR. ZUDANS: I notice that you have a much longer
11 unsupported length in the SRV discharge pipe line than
12 Kuosheng. Much longer and you show something like a ball
13 joint at the bottom of the quencher?

14 MR. JOHNSON: My understanding of the quencher
15 support is that it's pretty much free standing at its base.
16 It's not bolteđ down. It has obviously portable support
17 from the floor.

18 DR. ZUDANS: Do you have any acclerometers where
19 you arrow quencher B12.2 to see how that arm moves during the
20 discharge?

21 MR. JOHNSON: I do not believe we do. Moses, do
22 you know, if there are accelerometers on the discharge line
23 itself above the quenchers?

24 I don't believe there is.

25 DR. ZUDANS: Because this is a significant different

1 system of support .

2 MR. KOTOZON: My name is Paul Kotozon and --
3 AE for the plant. At this location right above here, we
4 have two eight inch supports that go back to the drywell
5 wall and to give support for any lateral loads. This is
6 just in bearing that McKinley was discussing here. The
7 loads were taken here. In the test there are strain gages
8 on this support as well as strain gages on this piping for
9 -- loads.

10 DR. ZUDANS: What does this ball type of configura-
11 tion mean right below the quencher? Is that a rotating
12 joint? No, higher up.

13 MR. KOTOZON: Right here? That's just the bottom
14 plate of the quencher. It's welded into this.

15 DR. ZUDANS: It's welded solid?

16 MR. KOTOZON: It's welded, yes, all the way around.

17 CHAIRMAN PLESSET: Any other questions.

18 DR. CATTON: RES was involved with the Kuosheng
19 test. Do they have any involvements with your tests?

20 MR. JOHNSON: Who is this?

21 DR. CATTON: RES, the research office of NRC.

22 There were two people who were at the Kuosheng test. I
23 was wondering whether there was anybody involved from RES
24 with your tests?

25 MR. JOHNSON: We have not conducted tests.

1 DR. CATTON: Do you plan to?

2 MR. JOHNSON: The test plan has been submitted to
3 the NRC.

4 DR. CATTON: It seems to me that you have a well
5 instrumented building and tests and it would just be a darn
6 shame to not make good use of that data.

7 MR. JOHNSON: The instrumentation is not installed
8 as of this date. It should be taking place in the next
9 few months for testing.

10 CHAIRMAN PLESSET: What were you going to say?

11 MR. FIELDS: I was going to say that it was being
12 submitted to our division for review.

13 CHAIRMAN PLESSET: Well, I think that what Dr.
14 Catton was mentioning was the research was involved.

15 DR. CATTON: There were two people, I believe, who
16 were --

17 CHAIRMAN PLESSET: They were observers. Are you
18 suggesting that they might let Research see the instrumenta-
19 tion.

20 DR. CATTON: One of the problems is getting full
21 scale data in order to confirm your calculation on pools.
22 That is always a problem and we never have it. Here is a
23 circumstance where maybe RES got involved and put up a little
24 bit of the money, the Grand Gulf people would cooperate and
25 we'd get the data.

1 CHAIRMAN PLESSET: Dreamer.

2 MR. JOHNSON: It would take over five million
3 dollars to repeat the data that was already available from
4 Kuosheng.

5 DR. CATTON: I understand, but that's probably
6 five million dollars well spent. It's a full scale system.

7 MR. JOHNSON: So was Kuosheng.

8 DR. CATTON: I understand, but it's money well
9 spent.

10 CHAIRMAN PLESSET: Yes, Dave?

11 MR. WARD: Did I understand that after your review
12 of the Kuosheng data you may not run this series of 14 tests
13 that you described or you may not run additional tests. Which
14 did you mean?

15 MR. JOHNSON: What we would like to have the option
16 of doing once we reviewed the Kuosheng data is sitting down
17 with the Staff, discussing the licensing requirements and
18 the technical requirements of conformatory testing. And if
19 the Kuosheng testing is available and applicable, and if our
20 tests would just be nothing but redundant tests with redundant
21 data, then, yes, we would like to discuss the potential
22 for deleting our tests.

23 That -- I don't give you that impression that that
24 would be an issue. I feel certain that the Staff and Grand
25 Gulf would be able to come to an agreement on what should be

1 done.

2 CHAIRMAN PLESSET: Yes, Jack?

3 MR. KUDRICK: I'd like to comment on that. That's
4 in agreement with what our stated requirements are relative
5 to inplant testing. That if other inplant tests can be
6 demonstrated to be applicable, it can be used in place of
7 a separate inplant test program.

8 CHAIRMAN PLESSET: Yes, we understand.

9 Thank you. We appreciate your presentation.

10 Jack, do you have further --

11 MR. KUDRICK: We have one possible addition. As
12 a result of some of these questions concerning equipment
13 survivability on the grating at Grand Gulf, Mississippi
14 Power and Light has gotten some additional information that
15 they would like to share with the Committee. It is not a
16 co-answer, but it is certainly some additional information.

17 CHAIRMAN PLESSET: I think we would like to hear
18 it.

19 MR. KUDRICK: John Richardson has prepared to
20 discuss that.

21 MR. RICHARDSON: John Richardson with Mississippi
22 Power and Light. This morning you raised a question about
23 the equipment on the grating at the hydraulic control unit
24 floor level and as I say, this morning, it primarily consists
25 of the -- some instrumentation and control racks, the

1 hydraulic units for the recirculation control valve --
2 recirculation system flow control valve and some piping
3 valves and equipment for the control hydraulic system --
4 specifically like a flow control valve station and other
5 things associated with it.

6 The issue was how did we account for protecting
7 essential instrumentation. Basically , we first identified
8 and located all of the instrumentation which would be required
9 to function during and after the LOCA event. First we tried
10 to relocate that out of the pool swell region, if possible.
11 If it was not possible to do that, then we protected the
12 panels that the instrumentation was located on by placing
13 deflector shields underneath the panels which are designed
14 to handle the froth impact and drag loads.

15 CHAIRMAN PLESSET: Any comment?

16 MR. EBERSOLE: Other than some physical represen-
17 tation of what you did, I understand, you built deflectors.

18 This tells me that you will still
19 be submerged by the froth -- this instrumentation. Is there
20 electrical apparatus which will be submerged?

21 MR. RICHARDSON: There is some instrumentation.
22 All the instrumentation is from the equipment qualification
23 standpoint, is designed for the post LOCA environmental
24 effects.

25 MR. EBERSOLE: Does this include submerging?

1 MR. RICHARDSON: Full submergence of water, no.
2 Just the effects of the froth spray or whatever.

3 MR. EBERSOLE: How do you intend to validate that
4 this equipment can stand such an environment in situ? Are
5 you going to go in and hose it down?

6 MR. RICHARDSON: We had no plans to do that, no.

7 MR. EBERSOLE: Why not? You're going to see it,
8 presumably.

9 MR. RICHARDSON: I'm sorry --

10 MR. EBERSOLE: Why are you apprehensive about
11 holding it down?

12 MR. RICHARDSON: Well, we just didn't feel like
13 from the equipment qualifications standpoint, you do an analy-
14 sis and testing for the instruments.

15 MR. EBERSOLE: I realize that, but that always
16 has the nagging problem of being type tested and due to the
17 variation in field installation techniques, you never really
18 are quite sure that a type testing advise has materialized
19 in your actual installation and final proof of it is the
20 in situ installation after some transients when it has
21 actually physically moved about a little bit.

22 Do you follow me?

23 MR. RICHARDSON: Well, I understand what you're
24 saying is that you have some -- the in situ or the installing
25 condition may be slightly different from the testing

1 condition.

2 MR. EBERSOLE: As a matter of fact, there is a
3 problem, in I guess, the permanenticity or some such word --
4 the fact that an instrument mechanic may take a cover off
5 and reinstall it. If he installs an overhand or equivalent
6 seals like this, it may in fact, not represent the type
7 tested model.

8 So there are a host of variables in this matter of
9 instrumental reliability under hostile environmental condi-
10 tions.

11 MR. RICHARDSON: From an installation standpoint,
12 this equipment is necessary and there are certain requirements
13 on how it's installed to be sure that it is not damaged in
14 and under those effects. It's obviously a safe delay pro-
15 cedure for installation and quality assurance program.

16 MR. EBERSOLE: It is highly administrative in
17 character.

18 MR. RICHARDSON: That's true. It is administrative.

19 MR. EBERSOLE: And let's leave it with a weakness
20 which can only be tested really by -- tests.

21 I really don't know why you would be apprehensive
22 about holding down this equipment.

23 MR. RICHARDSON: I think your point is well taken.
24 I'd have to think about that a little further. Right now,
25 we don't plan to go into the containment and start spraying

1 our equipment down if we don't have to.

2 MR. EBERSOLE: That reflects a great deal of faith
3 in the viability of your equipment, I must say.

4 CHAIRMAN PLESSET: Thank you about the hose.

5 DR. BUSH: I would also suggest looking at the
6 LERs because if you look at it at the point of view of the
7 maintenance errors, the list can go on for hundreds and
8 hundreds and hundreds of items. Some of them more severe
9 than others.

10 CHAIRMAN PLESSET: Jack, is all you had at the
11 present?

12 MR. KUDRICK: Other than a summary.

13 We have talked over the last day and a half and
14 hopefully we haven't given the impression that every area
15 is full of problems, but we have tried to identify those
16 areas where we still have discussions going on with both
17 GE and Grand Gulf and we'd like to take the opportunity to
18 summarize where we believe we are and where we think we're
19 going in the near term future.

20 Mel Fields will make some comments in that area.

21 (Pause)

22 MR. FIELDS: Our initial idea was to summarize
23 verbally, but we thought we would maybe throw up a few
24 slides, handwritten, I'm afraid, to help clarify.

25 The first slide I'd like to put down is not really

1 a summary, but a possible response to an ACRS concern on the
2 upper pool dump. And the questions, as I understand it is
3 one operator action is needed to initiate upper pool dump
4 and yet questions about the time requirements needed and
5 basically upper pool dump is automatically initiated by
6 safety grade signals.

7 There are two that are used. ECCS actuation plus
8 30 minute delay time. ECCS actuation is of course derived
9 from other signals of low low rack water etcetera etcetera.

10 The other signal that is used is low low pool
11 level and there is no delay on that. Once that level is
12 reached, the valves will be automatically opened to have water
13 come from the upper pool down to the suppression pool.

14 Now, how reliable is this equipment? There are
15 two sets of lines. My memory is somewhat unclear on this.
16 But there are complete subsets. Only one of the systems is
17 needed to assure suppression pool coverage.

18 The valves in these lines are powered from ESF
19 sources. Each line has two separate valves to minimize the
20 possibility of invert and actuation. Each valve in a
21 particular line is powered from the same power source and
22 the two lines have separate power sources -- you know, train
23 A and B so you open up at least one of them concerning any
24 single failure.

25 Only one line is needed to meet the flow requirements.

1 What they have done is that they have shown that the maximum
2 drain from the suppression pool, from the ECCS suction line,
3 is matched -- actually exceeded by the flow in one line from
4 the upper pool down to the suppression pool.

5 So, therefore, your level will not be any lower
6 until after pool dump. After complete pool dump, then you
7 have your collection of water in the dead area as your lowest
8 level which is approximately two feet.

9 MR. EBERSOLE: From an environmental qualification
10 standpoint, is this float level equipment submerged -- is it
11 inside the suppression pool or above it or at the surface
12 of it.

13 MR. FIELDS: The exact type of instrumentation
14 that is used to measure the suppression pool level -- I
15 don't know exactly what Grand Gulf has. It is of course --
16 has to meet the rigid environmental requirements. It's going
17 to be safety grade instrumentation.

18 MR. EBERSOLE: Is it typically type tested? That
19 is one of a kind and the number made.

20 MR. FIELDS: I don't know exactly.

21 CHAIRMAN PLESSET: Grand Gulf wants to respond to
22 that.

23 MR. RICHARDSON: The suppression pool water level,
24 I think, is what you're asking. Those are located outside
25 the containment.

1 MR. EBERSOLE: That's a prudent thing to do.
2 What about the valves? Are they subject to any
3 environmental problems?

4 MR. FIELDS: The valves in the lines?

5 MR. EBERSOLE: Yes.

6 MR. FIELDS: They are -- I'm not sure whether they
7 are exposed to the drywell environment or the containment
8 environment, but so -- they would have to be designed against
9 containment environment which is quite a bit less severe
10 than the drywell environment.

11 MR. EBERSOLE: There are individual timers part
12 trained?

13 MR. FIELDS: As far as the 30 minute delay on the
14 test actuation?

15 MR. EBERSOLE: Yes.

16 MR. FIELDS: I believe it's two complete separate
17 trains. It has to meet the separation criteria, right?

18 MR. EBERSOLE: I guess the crux of the whole thing
19 is how many instances we would have in containment where
20 we are subject to environmental conditions which are under
21 heavy investigation at this moment. The environmental
22 investigation program has lagged for some ten odd years and
23 it is just beginning to pick up and so you are all subject
24 to what may be found in that program as it evolves.

25 MR. FIELDS: That's correct.

1 With this information presented, is there still
2 further information that you would like to see on the upper
3 pool dump?

4 MR. EBERSOLE: I don't think so.

5 DR. ZUDANS: What is the estimated or calculated
6 pressure differential that promotes the expulsion of suppres-
7 sion pool water into the cavity? What is the delta P --
8 in the containment and the drywell?

9 MR. FIELDS: Basically, as the water is dumped into
10 the -- vessel from the ECCS system, it spills out from the
11 broken pipes into the bottom of the drywell. The bottom
12 of the drywell collects dead area water and the water level
13 rises until it reaches the top of the weir wall and then
14 it spills into the suppression pool.

15 DR. ZUDANS: The other way that I'm interested in.
16 That's how you loose suppression pool water.

17 MR. FIELDS: That's how you loose suppression pool
18 water.

19 DR. ZUDANS: But the containment pressure gets
20 to be higher than the drywell pressure and pushes the water
21 through the vents --

22 MR. FIELDS: There are drywell vacuum breakers to
23 equalize the pressure between the containment and the drywell
24 that prevents this from happening.

25 DR. ZUDAN: -- closing suppression pool water?

1 MR. FIELDS: By entrapment of the suppression pool
2 water in the area directly below the reactor vessel. That
3 is not part of the suppression pool.

4 DR. ZUCAN: How did that water get there?

5 MR. FIELDS: Out of the broken pipe, because you
6 pump suppression pool water into the vacuum vessel that would
7 cool off the core. It comes out of the broken pipe and drops
8 to the floor.

9 DR. ZUDANS: It's a long process. It is not instan-
10 taneous.

11 MR. FIELDS: It's long process, correct.

12 DR. CATTON: Why don't they fill that dead space
13 up with concrete?

14 MR. FIELDS: I think there's a recirculation pump
15 down there in casing and the -- it would be very difficult
16 to get at it to have it solid concrete.

17 What they have done instead to put enough water in
18 the upper pool dump to account for any losses here. It's just
19 in the specific method.

20 DR. CATTON: Along with that, all the problems that
21 are associated with having it up there that are being
22 discussed now.

23 MR. FIELDS: Well, they need to have the upper
24 pool dump, not only for the dead areas, but also to account
25 for the -- to lesson the pool dynamic loads.

1 CHAIRMAN PLESSET: Is there a comment back there?

2 MR. EBBESON: My name is Bruce Ebbeson from
3 Stone and Webster. I represent the River Bend plant. I'm
4 not sure. It's not my area, but I just want to correct some-
5 thing. I think yesterday somebody said that all of the
6 plants have the upper pool dump.

7 MR. FIELDS: All the Mark III plants.

8 MR. EBBESON: I'm not sure that River Bend does.
9 And we do have concrete in that annulus.

10 MR. FIELDS: They do have the upper pool dump.

11 MR. EBBESON: I'm not sure.

12 MR. RICHARDSON: That's correct. River Bend has
13 a -- where they don't lose that water. It returns back to
14 the suppression pool.

15 MR. EBBESON: I'm not sure how it works. We do
16 have the concrete in that annulus.

17 MR. FIELDS: The upper pool dump was basically to
18 reduce the pool dynamic loads and if it isn't there, we'll
19 check it out.

20 DR. ZUDANS: How to reduce the pool dynamic loads.

21 MR. FIELDS: By reducing the water level over the
22 top vent.

23 DR. ZUDANS: That's all right. So, if you got the
24 water back, you wouldn't be losing it. If you got the
25 water back, as I understand River Bend or someone else has,

1 in the suppression pool, you wouldn't need that.

2 MR. FIELDS: The fact is that if you have an
3 initial submergence higher than seven and a half feet from
4 -- containments, the low definition that GE supplied for
5 genetic Mark III containments is no longer valid.

6 But if you don't loose the water and you have
7 seven and a half feet, then you may not need an upper pool
8 dump to retain -- recover the loss fluids.

9 DR. ZUDAN: Now we agree.

10 MR. FIELDS: Yes.

11 CHAIRMAN PLESSET: Well, I think that maybe we
12 can terminate this discussion, if that's agreeable with you?
13 Are there any other comments.

14 MR. FIELDS: I'd like to go into, basically, the
15 summary.

16 We would like to leave the ACRS with an idea of
17 how we're going to pursue the approach for resolution of
18 the pool dynamic loads. Now for the generic load definition,
19 we're going to examine GE's justification for the current
20 load definitions and where we find this current load defini-
21 tions not acceptable, we're going to propose alternative
22 acceptance criteria. We plan to do this in our draft SER,
23 which we'll get out in December of '80.

24 I should make another point. We're talking about
25 LOCA related pool dynamic loads and as Nelson Su mentioned --

1 DR.THEOFANOUS: You said '80.

2 MR. FIELDS: '81, sorry.

3 Nelson Su mentioned that the SRV loads will be
4 completely finished by November. We will issue the conserva-
5 tive pool dynamic load for generic Mark III containments in
6 our NUREG which is scheduled for February of '82.

7 Grand Gulf has a schedule problem in that this
8 schedule for the generic is not acceptable. So, we are going
9 to use the generic load criteria that have been found
10 acceptable at this time by the staff and for the other load
11 criteria, we're going to suggest a bounding approach so that
12 we can have a quick resolution because of schedule require-
13 ments.

14 We would like to discuss with the ACRS the bounding
15 approach that the Staff is currently --

16 For each of the loads that we still have problems
17 with GE, the 40 feet GE specification we have problems with.
18 We're suggesting that Grand Gulf use the bounding approach
19 of 50 feet per second as the pool swell velocity and recalcu-
20 late the drag loads in both the solid and froth zones.

21 Show that the current impact specifications is
22 conservative, which we have preliminary information that they
23 can do for the solid water impact. They have done some
24 analysis to show that the 60 feet per second is still bounded
25 by the impact data for solid water.

1 For froth impact on the on the HCU floor and also
2 the equipment on the HCU floor as the ACRS has -- is trying
3 to highlight, we want Grand Gulf to provide a bounding
4 specification namely 15 psi D is still under review by the
5 Staff. We want Grand Gulf to provide a grounding specifi-
6 cation and to show that the structure is impacted can
7 withstand this bounding load.

8 I should mention that the point that we're discussing
9 here today, we also provided to Grand Gulf and GE in a
10 meeting last night and we expect some feedback from Grand
11 Gulf early next week on this particular approach. Whether
12 or not they think we can meet it.

13 The froth drage on the ACU floor grading is tied
14 in with the pool swell velocity indirectly, but there are
15 some other problems that are unique to Grand Gulf. We have
16 asked Grand Gulf to recalculate the Delta p across the HCU
17 floor using the Grand Gulf unique parameters.

18 The generic specifications, 11 psi, but because
19 of basically the elevation of the HCU floor, we feel that
20 this Delta P can be lower for Grand Gulf using the same
21 conservative assumptions that we definitely find acceptable.

22 The biggest problem is basically we need a
23 conservative method for transferring the Delta p into a load
24 specification across the HCU floor grading. We have done
25 some preliminary examination of this effect and we think that

1 we see a way out. We think we see a method for transferring
2 this load into a Delta P.

3 Now, the GE specification of using a total area
4 of 11 psi is definitely conservative. We have no problems
5 with that. Grand Gulf, however, cannot use that load, because
6 they're grading swell will start --

7 DR. ZUDANS: It is conservative because I under-
8 stood that you have a great part of that support is solid
9 concrete surface.

10 MR. FIELDS: We're talking about the grating only.
11 Grating experiences only a drag load, not an impact load.
12 The impact load from the HCU floor is still under investi-
13 gation and the approach we are taking for Grand Gulf is to
14 try to arrive at a bounding impact for the froth on the HCU
15 floor and then design against it.

16 DR. ZUDANS: Then what happens for the solid
17 concrete portion after the impact load?

18 MR. FIELDS: It will fill an 11 psi drag load.
19 11 psi static drag load.

20 DR. ZUDANS: Because of the grating resistance,
21 right?

22 MR. FIELDS: Because of the bottom of the upper
23 HCU floor.

24 CHAIRMAN PLESSET: I'll have to explain it to Dr.
25 Zudans.

1 DR. ZUDANS: No, you don't have to explain it. I
2 understand it. I just want to make sure that the whole thing
3 is taken into consideration.

4 MR. FIELDS: Again, I would like to emphasize that
5 we feel that we definitely have a path of resolution for the
6 frot's drag on the HCU floor gratings and of course that would
7 ease our concerns about the equipment on the HCU floor grating.

8 There are a couple of areas on the condensation and
9 chugging load specifications -- real small areas that we
10 would like to see cleaned up. And basically for the
11 condensation oscillation, we would like Grand Gulf to
12 evaluate the significance of the low frequency excedients
13 that the CO forcing function that was calculated using the
14 60 percent break area had.

15 We discussed this yesterday afternoon that the
16 fact that this was not bounded by the CO DBA design forcing
17 function.

18 Two methods come to light. One, it is possibly
19 bounded by the pool swell design load and the low frequency
20 which is what we're concerned about. The other is the
21 low frequency content is not really a significant structural
22 impact on structures and this is really really low frequency
23 range. So, we're asking Grand Gulf to come back with a
24 plant unique look at this particular load.

25 Also, the CO parameters that have significance

1 in determination of the frequency, the mass flux, the air
2 content and the pool temperature -- we would like Grand
3 Gulf to assure us that the parameters at Grand Gulf, because
4 of the slightly different design are bounded by the GE
5 sensitivity study. Grand Gulf has a slightly larger drywell
6 volume. They could have possibly slightly higher mass fluxes.
7 For completeness sake, we would like them to make this parti-
8 cular area of review.

9 Chugging? There was a data point in experiments
10 that exceeded the chugging design specification in the 30 to
11 40 hertz range for the weir wall. GE has told us that there
12 is no structural significance. Grand Gulf has also told us
13 this. It's basically just something that they had to put
14 down in writing.

15 And that's all I have to say about the approach
16 that the staff is pursuing for resolution of this issue, both
17 with GE and Grand Gulf. The full committee meeting will
18 of course, here more about the Grand Gulf unique approach
19 to full dynamic loads.

20 That's all.

21 MR. KUDRICK: I believe that concludes our portion
22 of the agenda. Unless there are some individual questions
23 still outstanding.

24 CHAIRMAN PLESSET: Could we get copies of this
25 last outline?

1 MR. FIELDS: Sure.

2 CHAIRMAN PLESSET: You're planning to come into
3 the full committee at the October meeting of the fu'l
4 committee?

5 MR. FIELDS: I'm sure that you'll be asking for
6 our presence.

7 CHAIRMAN PLESSET: That's on a Thursday, right?

8 Well, I think we'll see some of you again on
9 October 15th and until then, we'll just adjourn.

10 (Whereupon, at 12:10 p.m., the meeting was
11 adjourned.)

12

13

14

15

16

17

18

19

20

21

22

23

24

25

This is to certify that the attached proceedings before the
Nuclear Regulatory Commission

in the matter of: ACRS Subcommittee Meeting on Fluid Dynamics

Date of Proceeding: September 24, 1981

Docket Number: _____

Place of Proceeding: San Francisco, CA

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Michael Connolly

Official Reporter (Typed)

Michael Connolly
API

Official Reporter (Signature)

9/12/81

ACRS FLUID DYNAMICS SUBCOMMITTEE MEETING
 SEPTEMBER 24-25, 1981
 SAN FRANCISCO, CA

- TENTATIVE SCHEDULE OF PRESENTATIONS -

	<u>PRESENTATION⁺ TIME</u>	<u>ACTUAL TIME</u>
<u>SEPTEMBER 24, 1981</u>		
I. INTRODUCTION - M. P. OSSET, CHAIRMAN	10 min	8:30 am
II. NRC INTRODUCTION		
A. Background of Mark III Program J. Kudrick (NRC)	60 min	8:45 am
B. Current Status - M. Fields	30 min	9:45 am
- BREAK -	10 min	10:15 am
III. GENERAL ELECTRIC MARK III TEST FACILITY* GE (PERSONNEL)		10:25 am
A. Overview	15 min	
B. Full Scale Tests	20 min	
C. 1/3 Scale Tests	20 min	
D. 1/9 Scale Tests	20 min	
E. Data Interpretation	60 min	
F. Summary	10 min	
- LUNCH -	60 min	1:00-2:00 pm
IV. LOCA LOADS (BNL)		2:00 pm
A. Pool Swell Velocity	50 min	
B. Impact Loads	30 min	
C. Condensation Oscillation (CO) Loads	45 min	
D. Chugging Loads	45 min	
V. RECESS		5:30 pm

*NOTE - Portions Of This Session Will Be Closed To Protect Proprietary Information.

+Includes time for Subcommittee questions/discussion

- TENTATIVE SCHEDULE OF PRESENTATIONS -

	<u>PRESENTATION⁺ TIME</u>	<u>ACTUAL TIME</u>
<u>SEPTEMBER 25, 1981</u>		
VI. RECONVENE - M. PLESSET, CHAIRMAN	5 min	8:30 am
VII. SURMERGED STRUCTURE LOADS (BNL)		8:40 am
A. Jet Loads	30 min	
B. Air Bubble Drag Loads	30 min	
VIII. POOL THERMAL STRATIFICATION (BNL)	20 min	
IX. FLUID STRUCTURE INTERACTION EFFECTS (BNL)	20 min	
- BREAK -	10 min	10:30 am
X. SAFETY-RELIEF VALVE (SRV) LOADS		10:40 am
A. Overview - T. Su (NRC)	15 min	
B. Tripower Mark III Inplant Tests - T. Su	30 min	
C. Multiple Valve Bubble Phasing - C. Economus (BNL)	30 min	
D. SRV Loads Reduction Factor - C. Economus	30 min	
- LUNCH -	60 min	12:30-1:30 pm
XI. MARK III CONTAINMENT MODIFICATIONS		1:30 pm
A. General Plant Design (GE)	30 min	
B. Grand Gulf Design (MP&L)	30 min	
XII. GRAND GULF IN-PLANT SRV TEST PROGRAM (MP&L)	30 min	2:30 pm
XIII. SUMMARY OF MARK III PROGRAM (NRC)	30 min	3:00 pm
XIV. SUBCOMMITTEE DISCUSSION	30 min	3:30 pm
XV. ADJOURN		4:00 pm

+Includes time for Subcommittee questions/discussion

MARK III CHUGGING LOADS -
DESCRIPTION AND BASIS

DYNAMIC PRESSURE FLUCTUATION APPLIED DIRECTLY TO WETTED BOUNDARIES

WEIR WALL.

TOP VENT.

DRYWELL - BASEMAT - CONTAINMENT WALL.

IDEALIZED PRESSURE WAVE FORMS

PRECHUG UNDERPRESSURE.

PRESSURE SPIKE/TRAIN.

POST-CHUG OSCILLATION.

RANGE OF DURATION AND/OR FREQUENCY CONSIDERED.

SPATIAL DISTRIBUTION - BOUNDING FIT OF MEASUREMENTS.

LOCAL LOADS USE PEAK OBSERVED VALUES.

GLOBAL LOADS USE IN-PHASE CHUGGING WITH MEAN OF OBSERVED VALUES

TOP VENT AND WEIR (39 CHUGS)

DRYWELL AND CONTAINMENT (113 CHUGS)

BASIS - FULL-SCALE SINGLE CELL TEST DATA

MULTIPLE VENT EFFECTS EXAMINED VIA 1/9-SCALE TESTS - SUBSTANTIAL PHASING DEMONSTRATED.

MARK III CHUGGING LOADS -
STAFF EVALUATION

SUBSTANTIAL CONSERVATISM DEMONSTRATED IN MANY AREAS. CONSERVATISM STEMS FROM:

PRESSURE WAVE FORMS - IMPULSE AMPLIFIED.

CONSERVATIVE SELECTION OF DATA-POOL TEMPERATURE.

LOAD APPLICATION - TOP VENT LOADS.

SPATIAL DISTRIBUTION.

MONTE CARLO SIMULATION SHOWS LARGE MARGIN RELATIVE TO DESIGN FOR SYMMETRIC LOAD CASE. (GLOBAL LOADS).

SOME CONCERNS:


WEIR WALL EXCEEDANCE (30-40 Hz).

ABSENCE OF ASYMMETRIC CHUGGING LOAD.

RESOLUTION (IN PROGRESS)

WEIR WALL EXCEEDANCE DOES NOT HAVE STRUCTURAL SIGNIFICANCE.


ASYMMETRIC CHUGGING LOADS IMPLIED BY MONTE CARLO SIMULATION MAY BE BOUNDED BY ASYMMETRIC POOL SWELL LOAD.



DRYWELL
BASEMAT
CONTAINMENT




TCP VENT




WEIR

IDEALIZED CHUGGING PRESSURE
WAVE FORMS



AMPLIFICATION OF IMPULSE


POOL TEMPERATURE



MASS FLUX


COMPARISON OF PSTF AND PROTOTYPICAL BLOWDOWN
CONDITIONS FOR CHUGGING

ARS COMPARISON - LOCAL TOP VENT



ARS COMPARISON LOCAL DRYWELL


RESPONSE



FREQUENCY

ARS COMPARISON LOCAL WEIR

RESPONSE




FREQUENCY

DESIGN

PEAK WEIR CHUG

ARS COMPARISON - VERTICAL FORCE


RESPONSE



FREQUENCY

ARS COMPARISON - My


RESPONSE



FREQUENCY

ARS COMPARISON - My

RESPONSE



FREQUENCY

MARK III CO LOAD METHODOLOGY - DESCRIPTION

DYNAMIC PRESSURE LOADING APPLIED TO WETTED BOUNDARIES.

SOURCE (TOP VENT) PRESSURE SPECIFIED AS FUNCTION OF TIME FOR ENTIRE CO DURATION.

ATTENUATION FACTORS ESTABLISH DISTRIBUTION OF PRESSURE AWAY FROM SOURCE.

TIME DEPENDENCE ENTERS VIA TIMEWISE VARIATION OF G , C_A AND T_P .

DBA VARIATION OF G , C_A AND T_P USED FOR DESIGN.

BASIS - 1/3 SCALE PSTF TESTS.

DATA BASE FOR CO LOAD METHODOLOGY

- 1/9 AREA SCALE PSTF (3 CELLS)
 - .. DEMONSTRATES ABSENCE OF MULTI-VENT EFFECTS (CO SYNCHRONOUS)
 - .. USED FOR CONFIRMATION OF SCALING LAWS
- 1/3 AREA SCALE PSTF (SINGLE CELL)
 - .. MOST COMPREHENSIVE; COVERS ENTIRE RANGE OF G , C_A , T_p FOR STANDARD PLANT
 - .. USED TO GENERATE FUNCTIONS $PPA(G, C_A, T_p)$; $F(G, C_A, T_p)$
- FULL SCALE PSTF (SINGLE CELL)
 - .. ONLY TWO TESTS WITH USEFUL CO DATA
 - .. USED FOR CONFIRMATION OF SCALING LAWS

DEVELOPMENT OF CO LOAD DEFINITION

PRESSURE HISTORY IS SINUSOIDAL WITH AMPLITUDE (PPA) AND FUNDAMENTAL FREQUENCY (F) CONSIDERED TIME DEPENDENT.

REGRESSION ANALYSIS OF 1/3 AREA SCALE DATA YIELDS

$$PPA_{1/3} = f(G, C_A, T_P)$$

$$F_{1/3} = f(G, C_A, T_P)$$

SCALING LAWS USED TO CONVERT $PPA_{1/3}$, $F_{1/3}$ TO PPA_{FS} , F_{FS} .

POTENTIAL FLOW ANALYSIS DETERMINES ATTENUATION FACTORS FOR ALL SCALES.

PLANT ANALYSIS FOR DBA DETERMINES $G(t)$, $C_A(t)$, $T_P(t)$.

THREE HARMONICS ADDED.

CO LOAD METHODOLOGY - CONFIRMATION OF ADEQUACY

• CONCERNS

- .. APPLICABILITY OF $\frac{1}{3}$ AREA SCALE TESTS FOR PROTOTYPE (SCALING LAWS)
- .. BOUNDING OF ALL MEASUREMENTS
- .. IS DBA "WORST" CASE?


• METHOD OF APPROACH

- .. APPLY METHODOLOGY AND GENERATE PREDICTIONS FOR $\frac{1}{9}$, $\frac{1}{3}$, FULL SCALE TESTS
- .. COMPARE WITH ALL AVAILABLE MEASUREMENTS
 - ... TIME (PPA, RMS, F) AND FREQUENCY (ARS) DOMAINS
- .. DEMONSTRATE BOUNDING OF ALL DATA
- .. DEMONSTRATE CORRECT PREDICTION OF ALL TRENDS WITH SCALE
- .. APPLY METHOD PARAMETRICALLY WITH VARIATIONS IN PLANT INITIAL CONDITIONS (C_A , T_P) AND BREAK SIZE TO SHOW STANDARD DBA IS WORST CASE


CO LOAD METHODOLOGY - RESULTS OF CONFIRMATORY STUDIES

- PREDICTIONS EXCEEDED MEASURED PRESSURE IN ALL CASES
 - .. BUT SOME UNCERTAINTY REMAINS (LACK OF COMPLETE SET OF FULL SCALE RESULTS)
- UNCERTAINTIES IN SOURCE FREQUENCY SCALING REMAIN
 - .. SCALING ARGUMENTS WERE
 - .. EXPERIMENTAL CONFIRMATION INSUFFICIENT
 - .. UP TO 50% UNCERTAINTY IN PREDICTED STANDARD PLANT FREQUENCIES
- DATA EXCEEDANCES FOUND AT LOW AND HIGH FREQUENCY ENDS OF LOAD SPECIFICATION IN TERMS OF SIGNAL POWER (ARS COMPARISONS)
- SMALL BREAK SIZE RESULTS NOT COMPLETELY BOUNDED BY DESIGN LOAD (STANDARD DBA)

ARS COMPARISON



FREQUENCY




PPA

TIME
EFFECT OF BREAK SIZE ON PPA

CO LOAD METHODOLOGY

- CONCERN: LACK OF COMPLETE SET OF FULL SCALE TEST RESULTS
- RESOLUTION: ADDED CONSERVATISMS
 - THREE HARMONICS
 - AMPLIFIED ENERGY CONTENT
 - DEMONSTRATED MARGINS

AIR5 COMPARISON




RESPONSE

FREQUENCY

CO LOAD METHODOLOGY

- CONCERN: UNCERTAINTY IN SOURCE FREQUENCY SCALING
- POTENTIAL RESOLUTION (IN PROGRESS)
 - .. CO LOAD DEFINITION ARS WITH 15% PEAK BROADENING BOUNDS SCALING PREDICTION WITH 50% UNCERTAINTY
 - .. PEAK BROADENING DICTATED BY REGULATORY GUIDE
 - .. ARGUMENT HAS MERIT ONLY IF REQUISITE BROADENING IS INTENDED TO BOUND UNCERTAINTY IN FORCING FUNCTION

ARS COMPARISON



CO LOAD METHODOLOGY

CONCERN: DATA EXCEEDANCES AT LOW AND HIGH END OF FREQUENCY SPECTRUM ON I-RS BASIS

• RESOLUTION (IN PROGRESS)

•• LOW FREQUENCIES NOT STRUCTURALLY SIGNIFICANT

•• HIGHER FREQUENCY LOADS ~~ARE~~ BOUNDED BY SHUDDING LOAD SPECIFICATION


CO LOAD METHODOLOGY

CONCERN: STANDARD DBA NOT "WORST" CASE

RESOLUTION (IN PROGRESS):

- .. DESIGN WITH 15% PEAK BROADENING BOUNDS ALL CASES FOR FREQUENCIES ABOVE 3Hz. ON ARS BASIS
- .. NO STRUCTURAL SIGNIFICANCE BELOW 3Hz.

ARS COMPARISON



RESPONSE

FREQUENCY

FROTH LOAD ON HCU FLOOR


A.C.R.S.

San Fransisco

24 Sept. 1981.

Ain A. Sonin

FROTH LOAD ON HCU FLOOR



POST-BREAKTHROUGH
FLOW

SPECIFICATION FOR 238 PLANT :

$$\Delta p = 11 \text{ psi}$$

BASIS : A simplistic model, whose conservatism is demonstrated against $1/3$ -scale tests, predicts 10.8 psi.


AD HOC MODEL :

- froth flow through HCU floor modeled as homogeneous, incompressible flow with loss coefficient K .
($K = 5$ in Mark III application).
- froth density taken as constant, corresp. to assumption that all water initially above top vent mixes homogeneously with available air beneath HCU floor.
- mass balance written for wetwell region, based on inflow from vents (via a drywell model), froth outflow through HCU floor, and numerous assumptions.
- wetwell mixture is assumed to obey perfect gas equation (!), with temperature constant. This closes the problem.

Conservatism claimed in

- froth density
- loss coefficient K
- drywell model
- etc.

COMPARISON OF MEASURED AND
 PREDICTED TWO PHASE PRESSURE
 DROP - $K = 5.0$



For 238 plant with 25% open area.

- Model predicts $\Delta p = 10.8 \text{ psi}$
- Empirical conservatism $3.5 \pm 1 \text{ psi}$
- Other conservatism: plant has K less than 2; hence, expect conservatism to be greater than for $1/3$ -scale system.
- Possible nonconservatism? Simplistic model, relies more on conservatism than realistic prediction. Not checked at full scale.

BASIS FOR GESSAR II BULK POOL

IMPACT SPECIFICATION

OF 115 PSI:

TEST
SERIES/RUN

5706/4

TARGET
GEOMETRY

20 INCH SQUARE
PLATE

VELOCITY AT
IMPACT

21 FT/SEC



MAX. SLUG VELOCITY
IN MARK III

> 40 FT/SEC

GE ANALYSIS IN RESPONSE TO NRC
QUESTION NO. 4 (FIRST ROUND)

- IN ANY PARTICULAR STRUCTURE, STRESS IS PROPORTIONAL TO $P_{MAX} \times DLF$.
- CALCULATE $P_{MAX} \times DLF$ USING GESSAR II (115 PSI, 7 MSEC).
- CALCULATE $P_{MAX} \times DLF$ USING MARK II A.C. (NUREG-0487), WITH V OF MARK III POOL AND PULSE DURATIONS APPROPRIATE FOR MARK III.
- IF GESSAR II $P_{MAX} \times DLF$ GREATER THAN MARK II $P_{MAX} \times DLF$, SPECIFICATION IS BOUNDING.

PSTF FACILITY DURING STRUCTURES
IMPACT TEST (SERIES 5805)



MINIMUM PULSE DURATIONS:

6.8 MSEC FOR RADIAL

2.0 MSEC FOR CIRCUM.

BASIS FOR GESSAR II FROTH POOL

IMPACT SPECIFICATION OF


15 PSI:

TEST SERIES/RUN	5706/6
TARGET GEOMETRY	20 INCH SQUARE PLATE
VELOCITY AT IMPACT	27 FT/SEC
FROTH TRAVEL PRIOR TO IMPACT	~ 10 FEET
VOID FRACTION (APPROXIMATE)	0.75


MAX. FROTH
VELOCITY IN
MARK III

50 FT/SEC

ONE-THIRD SCALE PSTF



ONE-THIRD SCALE PSTF AS A
GEOMETRICALLY SCALED
 $\frac{1}{\sqrt{3}}$ FACILITY



MARK III POOL SWELL
VELOCITY.

A.C.R.S.
San Fransisco

Ain A. Sonin

SUMMARY OF LOAD, LOAD BASIS
AND NRC EVALUATION

G.E.'s DESIGN VALUE (FOR 238 PLANT) : 40 FT/S.

JUSTIFICATION:

I. "FUI" SCALE TEST — 38 FT/S

NRC : simulation poor & nonconservative.

II. DISTORTED-GEOMETRY TESTS

$\frac{1}{9}$ AREA SCALE } "below 40 FT/S"
 $\frac{1}{3}$ AREA SCALE }

NRC : Extrapolation from $\frac{1}{9}$ to $\frac{1}{3}$ to $\frac{1}{1}$
would suggest value > 40 FT/S!

III. "MODIFIED FROUDE SCALED" TESTS.

G.E. : "below 42 FT/S".

NRC : "below 47 FT/S \pm , with
considerable uncertainty".

CONCLUSIONS :

1. ALL AVAILABLE POOL SWELL DATA IS
FLAWED IN SOME WAY.
2. MAXIMUM POOL SWELL VELOCITY FOR
238 PLANT MAY WELL EXCEED 40 FT/s.

I. "FULL-SCALE" TEST 5705-4

- full scale poor area .
 - full scale break area.
-
- two vents, not three
 - half-size drywell
 - air blowdown
 - post-vent-clearing drywell pressure far below design value.

Measurement : 38 FT/s.

TWO VENTS:


- One vent tests produced half the pool swell velocity of two-vent tests.
- Hence, two-vent tests may well be lower than three-vent tests (i.e. prototype). By how much?

NONCONSERVATIVE DRYWELL PRESSURIZATION

(Next two slides)

PEAK DRYWELL PRESSURE PREDICTIONS FOR
238 PLANT :

- A. GESSAR DESIGN VALUE 23 psig.
- B. GESSAR PRE-BREAKTHROUGH MODEL 20 psig
- C. G.E.'s "BEST ESTIMATE" 16 psig.



3B.3-4.2.3-16





Figure 3B.3-4. Comparison of 238 Standard Plant and Test 5705-4 Drywell Pressure Histories

CESSAR II
238 NUCLEAR ISLAND
GE COMPANY PROPRIETARY
CLASS III

22A7000
Rev. 2
061581

II. DISTORTED GEOMETRY TESTS.



- Flow areas scaled-down by scale factor
- Flow-wise dimensions full scale

Implicit hypothesis (if results are to be invoked):

Pool swell not significantly affected by scaledown of areas.




Figure 1

MAXIMUM VELOCITIES FROM DISTORTED - GEOMETRY
STEAM TESTS. (FT/S).

	@ 16 psig	@ 20 psig.
1/9 SCALE	23 ± 2	26 ± 2
1/3 SCALE	35 $\begin{matrix} +3 \\ -5 \end{matrix}$	42 $\begin{matrix} +3 \\ -5 \end{matrix}$
1/1 SCALE	?	?

III. MODIFIED FROUDE SCALED ($1/3$ -SCALE)
TESTS.

"MFS" \equiv imperfect Moody scaling

$$\left. \begin{array}{l} \Delta p \propto L \\ V \propto \sqrt{L} \end{array} \right\} \text{retained}$$

$$\left. \begin{array}{l} h_{om} \propto L^{1/2} \\ p \propto L \\ \text{geometric similarity} \end{array} \right\} \text{relaxed}$$

• ABSOLUTE PRESSURE TOO HIGH (BY 1.5)

• NO ORIFICES IN VENTS

• VENTS TOO LONG (BY 1.5)

• VENT SEPARATIONS TOO LARGE (BY 1.5)


• STEAM

} 0-10% CONS.

?

NONCONSERVATIVE,
POSSIBLY SIGNIFICANTLY

—



Mk III pool swell velocity predicted from
1/3-scale tests based on "Modified Froude scaling"

SUMMARY

SOURCE	V_{max} (FT/S)		COMMENTS
"FULL-SCALE" TEST	38		DRYWELL PRESS. TOO LOW; 2 VENTS ONLY.
	BASED ON 16 psig MAX. DRYWELL	BASED ON 20 psig MAX. DRYWELL	
DISTORTED-GEOM. TESTS :			
$1/9$ -SCALE	23 ± 2	26 ± 2	EXTRAPOLATION TO $1/1$ SCALE?
$1/3$ -SCALE	$35 \pm$	$42 \pm$	
"MODIFIED FROUDE SCALED" FROM $1/3$ -SCALE	42	47	UNCERTAINTIES IN "SCALING"

CURRENT STATUS
OF
MARK III POOL DYNAMIC LOADS

MEL B. FIELDS
CONTAINMENT SYSTEMS BRANCH
NUCLEAR REGULATORY COMMISSION

MARK III OL REVIEW
MILESTONES

- o 5/80 - NRC QUESTIONS ON SRV MONTE CARLO APPROACH TO PHASING SENT TO GE
- o 11/80 - NRC QUESTIONS ON LOCA-RELATED POOL DYNAMIC LOADS SENT TO GE
- o 11/80 - AMENDMENT 1 TO GESSAR-II CONTAINING RESPONSES TO NRC QUESTIONS ON SRV PHASING
- o 5/81 - NRC QUESTIONS ON SRV LOAD REDUCTION FACTOR SENT TO GE
- o 6/81 - AMENDMENT 2 TO GESSAR-II CONTAINING RESPONSES TO NRC QUESTIONS ON LOCA-RELATED POOL DYNAMIC LOADS
- o 9/81 - NRC POSITIONS ON LOCA-RELATED POOL DYNAMIC LOADS SENT TO GE
- o 11/81 - ISSUE NUREG ON SRV POOL DYNAMIC LOADS
- o 12/81 - ISSUE DRAFT SER ON LOCA-RELATED POOL DYNAMIC LOADS
- o 2/82 - ISSUE NUREG ON LOCA-RELATED POOL DYNAMIC LOADS

NUREG ON MARK III LOCA-RELATED

POOL DYNAMIC LOAD CRITERIA

WILL INCLUDE:

- o DESCRIPTION OF THE MARK III LOCA-RELATED HYDRODYNAMIC PHENOMENA
- o DESIGN LOAD SPECIFICATION FOR EACH PHENOMENA
- o EVALUATION OF EACH DESIGN LOAD SPECIFICATION
- o ALTERNATIVE DESIGN LOAD SPECIFICATIONS (IF NECESSARY)

REVIEW APPROACH


- o USE GESSAR-II STANDARD 238 NUCLEAR ISLAND AS MODEL
- o POOL DYNAMIC DESIGN LOAD DEFINITIONS ARE CONTAINED IN APPENDIX 3D OF GESSAR-II
- o THESE LOAD DEFINITIONS ARE APPLICABLE TO ALL MARK III PLANTS

MARK III

POOL SWELL LOADS

MARK III

POOL SWELL LOADS



MARK III

POOL SWELL LOADS


LOAD DEFINITION

<u>LOAD</u>	<u>VALUE</u>
o POOL BOUNDARY	DRYWELL 21.8 PSID CONTAINMENT = 10 PSID
o WATER VELOCITY, - TYPICAL DRAG LOAD	40 FPS (CONSTANT) ~ 20 PSI
o BREAKTHROUGH HEIGHT	13 FT
o FROTH VELOCITY - TYPICAL DRAG LOAD	50 FPS ~ 10 PSI

MARK III

POOL SWELL LOADS

BUBBLE PRESSURE ON BOUNDARY




LICENSING ISSUES

POOL SWELL VELOCITY

- o CURRENT GE SPECIFICATION IS 40 FT/SEC
- o STAFF'S JUDGEMENT IS THAT 60 FT/SEC IS
A CONSERVATIVE VALUE
- o SCALING RELATIONS ARE BEING PURSUED BY
GE AND THE STAFF TO RESOLVE DIFFERENCES

"CONTAINS GENERAL ELECTRIC COMPANY
PROPRIETARY INFORMATION"

GESSAR II IMPACT SPECIFICATIONS



LICENSING ISSUES

FROTH DRAG ON GRATINGS
AT THE HCU FLOOR

- o GE SPECIFICATIONS IS 11 PSID
- o LOAD TO BE APPLIED TO TOTAL AREA OF GRATING
- o GRAND GULF APPLIED LOAD TO SOLID AREA OF GRATING
- o WITHOUT MODIFICATIONS, HCU FLOOR GRATINGS AT GRAND GULF CAN WITHSTAND 3.5 PSID WHEN LOAD IS APPLIED TO TOTAL AREA
- o STAFF AND GRAND GULF APPLICANT CURRENTLY PURSUING METHODS OF RESOLVING THIS PROBLEM

MARK III

POOL SWELL IMPACT LOADS

LOAD DESCRIPTION

- o SEQUENCE OF EVENTS
 - WATER LIGAMENT IMPACTS COMPONENTS
 - THEN WATER DRAG OCCURS
 - FROTH IS FORMED AND IMPACTS COMPONENTS
 - THEN FROTH DRAG OCCURS _

- o WATER IMPACT AND DRAG OCCURS FOR STRUCTURES ≤ 18 FT ABOVE THE INITIAL POOL SURFACE


- o FROTH IMPACT AND DRAG OCCURS FOR STRUCTURES ≥ 19 FT ABOVE THE INITIAL POOL SURFACE

- o FOR STRUCTURES BETWEEN 18 AND 19 FEET
TRANSITION IMPACT LOAD CRITERIA ARE APPLIED

MARK III

POOL SWELL IMPACT LOADS

POOL SWELL IMPACT AND DRAG



MARK III


LOAD DEFINITION


POOL SWELL IMPACT LOADS

<u>LOADS</u>	<u>VALUE</u>
o WATER IMPACT ON BEAMS —	115 PSI
o WATER IMPACT ON PIPES	60 PSI
o WATER DRAG (BEAM)	22 PSI
o FROTH IMPACT	15 PSI
o FROTH DRAG (BEAM)	10 PSI

MARK III

POOL SWELL IMPACT LOADS
IMPACT LOADS ON PIPES AND BEAMS





Loads at HCU Floor Elevation Due to Pool-Swell
 Froth Impact and Two-Phase Flow

LICENSING ISSUES

POOL SWELL IMPACT LOADS

- o IMPACT LOADS ARE UNDER INVESTIGATION
BECAUSE:
 - 1) POOL VELOCITY OF 40 FT/SEC MAY NOT
BE BOUNDING
 - 2) IMPACT DURATION MAY BE NONCONSERVATIVE.


MARK III

CONDENSATION OSCILLATIONS

PHENOMENA DESCRIPTION


- o OSCILLATING PRESSURE ON SUPPRESSION
POOL WETTED BOUNDARIES -
- o CAUSED BY MOVEMENT OF CONDENSATION
INTERFACE AT THE VENT EXIT
- o INTERFACE MOVEMENTS CAUSE POOL
MOVEMENTS
- o LOAD DEFINITION GENERATED FROM THE 1/3
SCALE DATA

CONDENSATION OSCILLATION




TYPICAL CONTAINMENT WALL
PRESSURE TIME HISTORY

LOAD DEFINITION
CO FORCING FUNCTION WAVE FORM
DRYWELL WALL



LOAD DEFINITION
CO PRESSURE DISTRIBUTION



CONDENSATION OSCILLATION

LICENSING ISSUES

- o FREQUENCY SCALING ($F \propto 1/D_{\text{VENT}}$)
- o EFFECT OF VARYING INITIAL PLANT PARAMETERS
- o HIGH FREQUENCY DATA NOT BOUNDED BY CO LOAD SPECIFICATION


MARK III

CHUGGING LOADS


DESCRIPTION

- LOCA PHENOMENA
 - STEAM CONDENSATION
 - LOW MASS FLUX
- INTERMITTANT CLEARING OF TOP VENT
- PRODUCES DYNAMIC LOADS
 - TOP VENT
 - WEIR ANNULUS
 - POOL BOUNDARY

MARK III
CHUGGING LOADS
DESCRIPTION




MARK III
 CHUGGING LOADS
 LOAD DEFINITION




TOP VENT CHUGGING LOAD

MARK III
CHUGGING LOADS
LOAD DEFINITION



POOL BOUNDARY CHUGGING LOAD

MARK III
CHUGGING LOADS
LOAD DEFINITION



SUPPRESSION POOL CHUGGING SPIKE ATTENUATION

CHUGGING LOADS

LICENSING ISSUES



- o EXPERIMENTAL WEIR WALL CHUG EXCEEDS DESIGN VALUE IN 30-40 HZ FREQUENCY RANGE
- o SPACIAL DISTRIBUTION ON WETTED BOUNDARIES DURING THE CHUGGING PHASE NEEDS FURTHER JUSTIFICATION
- o ASYMMETRIC CHUGGING LOAD NOT DEFINED
- o CHUG SOURCE STRENGTH SELECTED NEEDS FURTHER JUSTIFICATION

MARK III

SUBMERGED STRUCTURE LOADS

- o LOCA WATER JET
- o LOCA AIR BUBBLE LOAD
- o CONDENSATION OSCILLATION LOADS
- o CHUGGING LOADS

MARK III
SUBMERGED STRUCTURE LOADS
LOCA WATER JET



SECTION A-A


SIDE AND FRONT VIEWS OF MARK III GESSAR CONTAINMENT

POOL TEMPERATURE

LOAD DESCRIPTION

- NON-UNIFORM TEMPERATURE
 - IN SUPPRESSION POOL
 - DURING A LOCA
 - DUE TO UNEVEN HEATING
 - DUE TO BUOYANCY

LOAD DEFINITION



FLUID-STRUCTURE INTERACTION

DESCRIPTION

- o ADDITIONAL PRESSURE COMPONENT IN A FLUID
CONFINED IN AN ELASTIC CONTAINER, DUE TO
MOTION OF THE CONTAINER

FLUID-STRUCTURE INTERACTION

LOAD DEFINITION

- o GESSAR RIGID WALL LOADS ARE APPLIED TO MARK III CONTAINMENT

- o A/E'S ACCOUNT FOR FLUID IN STRUCTURAL ANALYSIS

FLUID-STRUCTURE INTERACTION

LOAD BASIS

PSTF DATA BASE FROM THREE SCALED TESTS

- o FULL SCALE - CHUGGING LOADS
- o 1/3 AREA SCALE - CONDENSATION OSCILLATION LOADS
- o 1/9 AREA SCALE - MULTIVENT EFFECTS

THREE SCALED TESTS SEPARATELY ANALYZED FOR FSI (ALL SCALES USED SAME PSTF)

- o CONCLUSION FROM ANALYSES
FSI WAS SHOWN TO BE A SMALL EFFECT ON MEASURED WALL LOADS

ACRS FLUID
DYNAMICS SUBCOMMITTEE
MEETING

MARK III
CONTAINMENT POOL
DYNAMIC LOADS

MEETING OBJECTIVE

- . DISCUSS RESOLUTION OF ISSUES FOR GENERIC MARK III POOL DYNAMIC LOADS.
- . APPLICATION OF THESE ISSUES TO THE GRAND GULF NUCLEAR PLANT.

AGENDA

SEPTEMBER 24, 1981

TIME

I. INTRODUCTION - M. PLESSET, CHAIRMAN 8:30 A.M.

II. NRC INTRODUCTION

A. BACKGROUND OF MARK III PROGRAM 8:45 A.M.

J. KUDRICK (NRC)

B. CURRENT STATUS - M. FIELDS 9:45 A.M.

- BREAK -

III. GENERAL ELECTRIC MARK III TEST FACILITY

GE (PERSONNEL) 10:25 A.M.

A. OVERVIEW

B. FULL SCALE TESTS

C. 1/3 SCALE TESTS

D. 1/9 SCALE TESTS

E. DATA INTERPRETATION

F. SUMMARY

- LUNCH -

1:00-2:00 P.M.

IV. LOCA LOADS (BNL)

2:00 P.M.

A. POOL SWELL VELOCITY - A. SONIN

B. IMPACT LOADS - G. MAISE

C. CONDENSATION OSCILLATION (CO) LOADS - C. ECONOMYDS

D. CHUGGING LOADS - C. ECONOMYDS

V. RECESS

5:30 P.M.

SEPTEMBER 25, 1981


TIME

- | | |
|---|-----------------|
| VI. RECONVENE - M. PLESSET, CHAIRMAN | 8:30 A.M. |
| VII. SUBMERGED STRUCTURE LOADS (BNL - G. BIENKOWSKI | 8:40 A.M. |
| A. JET LOADS | |
| B. AIR BUBBLE DRAG LOADS | |
| VIII. POOL THERMAL STRATIFICATION (BNL) - C. ECONOMUS | |
| IX. FLUID STRUCTURE INTERACTION EFFECTS (BNL) - | |
| C. ECONOMUS | |
| - BREAK - | 10:30 A.M. |
| X. SAFETY RELIEF VALVE (SRV) LOADS | 10:40 A.M. |
| A. OVERVIEW - T. SU (NRC) | |
| B. TRIPower MARK III INPLANT TESTS - T. SU | |
| C. MULTIPLE VALVE BUBBLE PHASING (BNL) - | |
| C. ECONOMUS | |
| - LUNCH - | 12:30-1:30 P.M. |
| XI. MARK III CONTAINMENT MODIFICATIONS | 1:30 P.M. |
| A. GENERAL PLANT DESIGN - M. FIELDS | |
| B. GRAND GULF DESIGN (MP&L) | |
| XII. GRAND GULF IN-PLANT SRV TEST PROGRAM (MP&L) | 2:30 P.M. |
| XIII. SUMMARY OF MARK III PROGRAM (NRC) | 3:00 P.M. |
| XIV. SUBCOMMITTEE DISCUSSION | 3:30 P.M. |
| XV. ADJOURN | 4:00 P.M. |


ACRS MEETING SUMMARY

<u>DATE</u>	<u>DESCRIPTION</u>
MAY 9, 1974	GRAND GULF FULL COMMITTEE
DECEMBER 29-30, 1975	MARK I, II, III POOL DYNAMIC LOADS
JANUARY 31, 1978	MARK III TEST PROGRAM
MAY 23, 1978	MARK II POOL DYNAMIC LOADS
NOVEMBER 29-30, 1978	MARK II POOL DYNAMIC LOADS
SEPTEMBER 13-14, 1979	MARK II POOL DYNAMIC LOADS
APRIL 29, 1981	MARK II POOL DYNAMIC LOADS
JULY 1981	MARK II POOL DYNAMIC LOADS


INVERTED LIGHT-BULB AND TORUS



**BWR-MARK I
PRESSURE SUPPRESSION**



BWR-MARK II
PRESSURE SUPPRESSION



COMPARISON OF BWR CONTAINMENT DESIGNS

DRYWELL

MARK I

(BROWN'S FERRY)

TYPE OF CONSTRUCTION

STEEL SHELL

AIR VOLUME (FT³)

1E+000

DESIGN PRESSURE (PSI)

56

WETWELL

TYPE OF CONSTRUCTION

STEEL SHELL

AIR VOLUME (FT³)

119,000

POOL VOLU. W. WATER (FT³)

85,000

DESIGN PRESSURE (PSI)

56

THERMAL POWER (MWT)

1,293

MARK II

(ZIMMER)

STEEL-LINED REINFORCED CONCRETE

184,000

45

MARK III

(GRAVEL GOLF)

REINFORCED CONCRETE

280,000

70

STEEL-LINED REINFORCED CONCRETE

101,000

700,000

43

STEEL-LINED REINFORCED CONCRETE

174,000

157,000

15



275

DOMESTIC MARK III
PRESSURE SUPPRESSION PLANTS

<u>PLANT NAME</u>	<u>LICENSING STATUS</u>
GRAND GULF	OL SER 9/81
CLINTON 1, 2	OL SER 1/82
PERRY 1, 2	OL SER 5/82
RIVER BEND	OL SER 10/82
ALLENS CREEK	CP HEARING
BLACK FOX 1, 2	CP HEARING
SKAGIT 1, 2	POST CP
HARTS... 1, 2, 3, 4	POST CP
PHIPPS BEND 1, 2	POST CP

NRC ORGANIZATIONAL APPROACH

POOL DYNAMIC LOADS



NRC
ORGANIZATION

TAP B-10

TASK MANAGER - M. FIELDS

NRR BRANCHES INVOLVED

- CONTAINMENT SYSTEMS BRANCH
- STRUCTURAL ENGINEERING BRANCH
- MECHANICAL ENGINEERING BRANCH

CONSULTANTS INVOLVED

- BROOKHAVEN NATIONAL LABS.

BNL ORGANIZATION

LOCA-RELATED POOL DYNAMIC LOADS

C. ECONOMOS (BNL) - COORDINATOR

G. MAISE (BNL)

J. RANLET (BNL)

R. KAMM (MIT)

A. SONIN (MIT)

G. BIENKOWSKI (PRINCETON)

SRV RELATED POOL DYNAMIC LOADS

C. ECONOMOS (BNL) - COORDINATOR

J. RANLET (BNL)

C. C. LYN (BNL)


P. HUBER (MIT)


A. SONIN (MIT)

PROGRAM APPROACH


- . GENERIC WHERE POSSIBLE
- . DOCUMENTATION WITHIN GESSAR II
- . GENERAL ELECTRIC THE FOCAL POINT RATHER
THAN AN OWNERS GROUP
- . LIMITED PLANT SPECIFIC AREAS

LOSS OF COOLANT ACCIDENT CHRONOLOGY







Short Term Drywell and Containment Pressure Response to a Large Steamline Break (DBA)




Schematic of the Mark III Pool Swell Phenomenon



DRYWELL WALL MAXIMUM PRESSURE TRACE



Basemat Chugging Pressure Time History



Typical Top Vent Pressure Trace During Chugging]


STATUS OF MARK III
GENERIC LICENSING POOL
DYNAMIC PROBLEMS
AT CP STAGE

- . FULL SCALE TESTS (PSTF) OF A SINGLE ROW OF THREE VENTS SIMULATING THE WET AND DRYWELL VOLUMES TO STUDY VENT CLEARING, CONDENSATION AND SEQUENTIAL VENT CLEARING (TESTS INDICATED UNEXPECTED AND SIGNIFICANT POOL RISE).
- . FULL SCALE TESTS (PSTF) AS IN ABOVE TO MEASURE IMPACT FORCES.
- . 1/3 SCALE TESTS (PSTF) PERFORMED TO PROVIDE LICENSING DATA BASE ON POOL MOTION, VELOCITY, AND IMPACT LOADS FOR EQUIPMENT; E.G., GRATINGS.
- . 1/3 SCALE TESTS (PSTF) PERFORMED TO INVESTIGATE CONDENSATION AND STEAM CHUGGING.

MK III OVERVIEW

- . BWR6/MK III CONCEPT TAKEN TO ACRS 1972
- . MK III TEST PROGRAM 1973-1975
 - . 11/73 MODEL CONFIRMATION
#5701-5703
 - . 2/74 POOL SWELL (AIR)
#5705-5706
 - . 3/74 CONVERT TO 1/3 AREA SCALE VENT SYSTEM
 - . 6/74 POOL SWELL (STEAM & LIQUID)
#5801-5804
 - . 1/75 POOL SWELL (SATURATED STEAM)
#5805
 - . 6/75 POOL SWELL (AIR)
#5806
- . NEDO 11314-08 SUBMITTED (LOAD DEFINITION REPORT) 7/75
- . GESSAR - PDA NO 1 GRANTED 12/75
- . GESSAR - PDA NO 1 CONDITIONS REMOVED 7/76-6/77

PSIF TEST FACILITY



TESTING SINCE
CP STAGE

- . FULL SCALE TESTS (PSTF) TO INVESTIGATE CHUGGING.
- . 1/3 SCALE TESTS (PSTF) TO INVESTIGATE STEAM CONDENSATION.
- . 1/9 SCALE TESTS (PSTF) TO INVESTIGATE MULTI-VENT EFFECTS.

MK III OVERVIEW

ADDITIONAL MK III CONFIRMATORY TESTS

- . 12/76 1/3 SCALE PSTF
5807
- . 2/78 FULL SCALE
#5707
- . 4/78 ICLR REV 1 (1/3 SCALE)
- . 10/78 ICLR REV 2 (FULL SCALE)
- . 5/79 MULTIVENT
#5002-6003
- . 11/79 ICLR REV 3 (MULTIVENT #6002)

ADDITIONAL SRV X-QUENCHER TESTS

- . 5/79 CAORSO PHASE I TEST REPORT
- . 5/80 CAORSO PHASE II TEST REPORT

SEPTEMBER 25, 1981

TIME

- VI. RECONVENE - M. PLESSET, CHAIRMAN 8:30 A.M.
- VII. SUBMERGED STRUCTURE LOADS (BNL) - G. BIENKOWSKI 8:40 A.M.
- A. JET LOADS
- B. AIR BUBBLE DRAG LOADS
- VIII. POOL THERMAL STRATIFICATION (BNL) - C. ECONOMUS
- IX. FLUID STRUCTURE INTERACTION EFFECTS (BNL) -
C. ECONOMUS
- BREAK - 10:30 A.M.
- X. SAFETY RELIEF VALVE (SRV) LOADS 10:40 A.M.
- A. OVERVIEW - T. SU (NRC)
- B. TRIPOMER MARK III INPLANT TESTS - T. SU
- C. MULTIPLE VALVE BUBBLE PHASING (BNL) -
C. ECONOMUS
- LUNCH - 12:30-1:30 P.M.
- XI. MARK III CONTAINMENT MODIFICATIONS 1:30 P.M.
- A. GENERAL PLANT DESIGN - M. FIELDS
- B. GRAND GULF DESIGN (MP&L)
- XII. GRAND GULF IN-PLANT SRV TEST PROGRAM (MP&L) 2:30 P.M.
- XIII. SUMMARY OF MARK III PROGRAM (NRC) 3:00 P.M.
- XIV. SUBCOMMITTEE DISCUSSION 3:30 P.M.
- XV. ADJOURN 4:00 P.M.

GRAND GULF NUCLEAR STATION
IN PLANT TESTING

- 0 BACKGROUND
- 0 TEST DESCRIPTIONS
- 0 PRESSURE MEASUREMENTS
- 0 ACCELEROMETER MEASUREMENTS
- 0 SCHEDULE
- 0 CONCLUSIONS

BACKGROUND

- 0 NRC INDICATED IN REVIEW OF GESSAR-238 NUCLEAR ISLAND APPLICATION THAT VERIFICATION OF QUENCHER LOADS WOULD BE REQUIRED BY THE FIRST PLANT REFERENCING THE GESSAR NUCLEAR ISLAND DESIGN.

- 0 NRC INDICATED THAT A PROTOTYPICAL TEST WOULD BE REQUIRED FOR EACH TYPE OF CONTAINMENT STRUCTURE (I.E. CONCRETE AND STEEL).


- 0 KUOSHENG PLANT RECENTLY COMPLETED IN PLANT TEST WITH OBJECTIVE OF DEMONSTRATING SIGNIFICANT REDUCTIONS IN STRUCTURAL RESPONSE AND THEREFORE REDUCED LOADS TO PIPING AND EQUIPMENT.

- 0 KUOSHENG AND GRAND GULF ARE REINFORCED CONCRETE CONTAINMENTS.

- 0 MP&L PRESENTLY HAS PLANS FOR IN PLANT TESTING, IN ADDITION, MP&L IS REVIEWING KUOSHENG DATA AND ITS APPLICABILITY TO GRAND GULF TO DETERMINE IF ADDITIONAL TESTING IS NECESSARY.

TEST DESCRIPTION

0	6	SINGLE VALVE ACTUATIONS	(SVA)
0	6	CONSECUTIVE VALVE ACTUATIONS	(CVA)
0	7	MULTIVALVE ACTUATIONS	(MVA)
0	1	EXTENDED VALVE ACTUATIONS	(ESVA)
0	27	PRESSURE SENSORS	
	34	STRAIN GAUGES	
	16	TEMPERATURE SENSORS	
	41	ACCELEROMETER CHANNELS IN 17 LOCATIONS	



DETAIL A

P23 AND P24 MEASURE
QUENCHER INTERNAL
PRESSURE




Figure 4-2. SUPPRESSION POOL PRESSURE SENSORS - ELEVATION VIEW




Figure 3.1

GRAND GULF ACCELEROMETER LOCATIONS
 (Elevation View - Accelerometers Rotated into View)

EVALUATIONS

- 0 DEC. 31 FUEL LOAD
- 0 APRIL 10 TEST AT 50% POWER
- 0 JUNE 15 QUICK LOOK REPORT
- 0 SEPT. 1 FINAL REPORT

CONCLUSIONS

- 0 TEST PROGRAM, AS DEFINED IS CONSIDERED SUFFICIENT TO PROVIDE A DATA BASE FOR EVALUATION OF LOAD DEFINITIONS.
- 0 SIGNIFICANT CONSERVATISMS THOUGHT TO EXIST IN THE STRUCTURAL MODEL RESULTING IN ADDITIONAL SAFETY MARGINS.
- 0 MP&L WILL COMPLETE EVALUATIONS OF KUOSHENG DATA IN EARLY OCTOBER AND, IF APPROPRIATE, MEET WITH NRC STAFF AT THAT TIME WITH THE OBJECTIVE OF DELETING FURTHER TEST PLANS.

SIMILARITY BETWEEN GRAND GULF AND KUOSHENG

WITH REGARD TO IN PLANT TESTING

REF. NUREG 0763

TMJ 9/17/81

° QUENCHER DEVICE GEOMETRY:

BOTH X-QUENCHERS
IDENTICAL ARMS AND HOLE PATTERN

° BUBBLE PRESSURE PARAMETERS:

18.2 PSI CVA DESIGN VALUE FOR GRAND GULF
16.6 PSI CVA DESIGN VALUE FOR KUOSHENG

° STEAM FLOW PER LINE AREA

FLOW RATES IDENTICAL WITH NO IMPACT ON PREDICTED PRESSURES,
LINE DIAMETER SIZE IDENTICAL.

° QUENCHER/POOL GEOMETRY

5'-0"	DRY WELL TO QUENCHER	☐	BOTH UNITS
5'-0"	ARM TO FLOOR	GGNS	BOTH UNITS KUOSHENG
18'-10"	POOL DEPTH @ NWL		GGNS
19'-2"	POOL DEPTH @ NWL		KUOSHENG

° CONTAINMENT CHARACTERISTICS


REINFORCED CONCRETE CONTAINMENT BOTH UNITS DRYWELL AND PEDESTAL
OF SIMILAR CONSTRUCTION PLATFORMS AND FLOORS SIMILARLY LOCATED.

° THIS DATA IS PRELIMINARY AND IN SUMMARY FORM. DETAILS TO BE DEVELOPED
AND DISCUSSED WITH NRC STAFF IN NEAR FUTURE.


FIGURE 2. QUENCHER ARRANGEMENTS

MPL-01-104
8/11/81

PRELIMINARY
9/17/81



KUOSHENG
(CVA DESIGN)
(VALUE 16.6 PSI)



GRAND GULF
(CVA DESIGN)
(VALUE 18.2 PSI)

EL. 107'-0"

EL. 102'-4"

EL. 98'-04"

MARK III MODIFICATIONS

MEL B. FIELDS
CONTAINMENT SYSTEMS BRANCH
NUCLEAR REGULATORY COMMISSION

Fields

MARK III MODIFICATIONS

OBJECTIVE - DETERMINE EXTENT OF PLANT MODIFICATIONS
MADE DUE TO CHANGES IN GENERIC MARK III
POOL DYNAMIC LOAD CRITERIA

METHOD - SELECTED 4 PLANTS FOR EXAMINATION:
CLINTON 1&2 - OL STAGE UNIT 1 80% COMPLETE
RIVER BEND - OL STAGE -35% COMPLETE
BLACK FOX - CP STAGE
ALLENS CREEK - CP STAGE

MARK III MODIFICATIONS

CLINTON 1&2

- o SUPPRESSION POOL LINER STRENGTHEN
- o GENERAL MODIFICATION OF HCU FLOOR, EQUIPMENT MOVED FROM GRATING ONTO CONCRETE, PIPING RAISED
- o SRV PIPING AND SUPPORTS MODIFIED, ECCS SUCTION STRAINERS AND SUPPORTS REDESIGNED
- o POLAR CRANE GIRDERS AND BRACKETS REDESIGNED
- o GENERAL UPGRADING OF PIPING, PIPE SUPPORTS

MARK III MODIFICATIONS.

RIVER BEND

- o STEEL HOOPS AND STIFFENERS ADDED TO OUTSIDE OF FREE-STANDING STEEL CONTAINMENT, UP TO THE ELEVATION OF THE SUPPRESSION-POOL SURFACE
- o WILL FILL THE ANNULUS BETWEEN THE CONCRETE SHIELD BUILDING AND STEEL CONTAINMENT WITH CONCRETE TO A LEVEL 5 FEET ABOVE SUPPRESSION POOL SURFACE

MARK III MODIFICATIONS

BLACK FOX 1&2

- o MODIFIED STUD PATTERNS ON WEIR WALL
- o MAY ADD STIFFENERS TO FREE-STANDING STEEL CONTAINMENT
- o WILL FILL THE ANNULUS BETWEEN THE CONCRETE SHIELD BUILDING AND STEEL CONTAINMENT UP TO A LEVEL OF 25 FEET ABOVE SUPPRESSION POOL BOTTOM

MARK III MODIFICATIONS

ALLENS CREEK

- o ADDED VERTICAL STIFFENERS TO OUTSIDE OF FREE-STANDING STEEL CONTAINMENT IN THE SUPPRESSION POOL REGION
- o MODIFIED DOME DESIGN FROM ELLIPSODIAL TO HEMISPHERICAL
- o RELOCATED ALL PIPING OUT OF SOLID IMPACT AREA

GE CROSS QUENCHER SRV LOAD METHODOLOGY -
DESCRIPTION

APPLICATION - STRUCTURAL DESIGN.

DYNAMIC PRESSURE LOADING APPLIED DIRECTLY TO WETTED BOUNDARIES.

IDEALIZED PRESSURE SIGNATURES - DAMPED RAYLEIGH BUBBLE.

FREQUENCY CONTENT - DOMINANT BUBBLE FREQUENCY (DBF) ARBITRARILY RANGED FROM 5 TO 12 Hz.

PEAK PRESSURE AMPLITUDE (PPA) - FUNCTION OF PLANT PARAMETERS AND OPERATING CONDITIONS - STATISTICAL MODEL OF SMALL (0.1), LARGE (0.5) AND IN-PLANT (1.0) TEST DATA - (95-95) CONFIDENCE LEVEL.

SPATIAL DISTRIBUTION

$2 \pi_0$ PLATEAU

$1/\pi$ ATTENUATION

"LINE OF SIGHT" CUTOFF

ABOVE $3/4$ POOL LINEAR DECAY TO ZERO AT POOL SURFACE

MULTIPLE VALVE EFFECTS

SYNCHRONOUS BUBBLE OSCILLATIONS

SRSS INDIVIDUAL CONTRIBUTIONS

"CUTOFF" AT PPA

GE CROSS QUENCHER SRV LOAD METHODOLOGY -

DESCRIPTION

(CONTINUED)

LOAD CASES

SVÀ AT LOW POOL TEMPERATURE.

CVA AT ELEVATED POOL TEMPERATURE.

TWO ADJACENT (FIRST) AT LOW POOL TEMPERATURE.

TEN VALVES (ONE LOW - NINE NEXT LOW-FIRST) AT LOW
POOL TEMPERATURE.

ADS (FIRST) AT ELEVATED POOL TEMPERATURE.

ALL VALVES (FIRST) AT LOW POOL TEMPERATURE.




Figure Q1 - Cross Quencher Design Pressure Signature

GE CROSS QUENCHER SRV LOAD METHODOLOGY -
REVIEW STATUS

ORIGINAL METHODOLOGY ACCEPTED BY STAFF SEPTEMBER 1976 (NUREG-75/110).

GE PROPOSES MODIFICATION TO METHODOLOGY (1980).

PPA REDUCED BY 20% FOR FIRST ACTUATION.

PPA REDUCED BY 35% FOR SUBSEQUENT ACTUATION.

BASIS - CAORSO (MARK II CONTAINMENT) IN-PLANT TESTS.

STAFF REVIEW IN PROGRESS.

ISSUES -

NON-CONSERVATIVE APPLICATION OF LOAD TREND WITH LINE VOLUME.


MODIFICATION APPLIED INCORRECTLY FOR MAXIMUM UNDER-PRESSURE.

VACUUM BREAKER EFFECT NOT ACCOUNTED FOR.

AGREEMENT ON ISSUES - RESOLUTION EXPECTED SINCE SUFFICIENT MARGIN EXISTS TO ACCOMMODATE CORRECT INTERPRETATION OF CAORSO DATA BASE.

GESSAR DESIGN

18.3



CAORSO ADJUSTED TO MK III DESIGN

11.7
11.5

PEAK ADJUSTED
95/95 ADJUSTED

9.0

ADJUSTED MEAN

8.2
8.0

PEAK OF DATA
95/95 OF DATA

5.4

DATA MEAN



CONSECUTIVE VALVE ACTUATION COMPARISON

MULTIPLE VALVE BUBBLE PHASING

APPLICATION - PIPING SYSTEM AND EQUIPMENT RESPONSE
EVALUATION.

SYNCHRONOUS BUBBLE OSCILLATION OVERLY CONSERVATIVE.

METHODOLOGY EMPLOYS MONTE CARLO SIMULATION TO DEVELOP
MORE REALISTIC BUT CONSERVATIVE LOADING.

MULTIPLE VALVE BUBBLE PHASING -
PROBABALISTIC FEATURES

CHOICE OF RANDOM VARIABLES

REACTOR PRESSURE RISE RATE (PRR),
VALVE SET POINT TOLERANCE (VST),
VALVE OPENING TIME (VOT),
DOMINANT BUBBLE FREQUENCY (DBF),

PROBABILITY DENSITY FUNCTIONS

PRR - OPERATING EXPERIENCE AND PLANT TRANSIENTS ANALYSIS,
VST - GAUSSIAN - TESTABILITY FEATURE PRECLUDES DRIFTING
OF NOMINAL SETPOINT FOR VALVE GROUPS,
VOT - SHOP TESTS,
DBF - FOREIGN LICENSEE IN-PLANT TEST DATA,

CONFIDENCE LEVEL OF LOAD SPECIFICATION

59 MONTE CARLO TRIALS,
(95-95) CLAIMED,

SELECTION OF DESIGN MONTE CARLO TRIALS

AS MANY AS 9 USED FOR DESIGN,
SELECTED TO BOUND SPECTRAL PEAKS IN VERTICAL AND OVER-
TURNING MOMENTS,

MULTIPLE VALVE BUBBLE PHASING -
OTHER FEATURES

DBF PROBABILITY DENSITY FUNCTION SHIFTED DETERMINISTICALLY
TO ACCOUNT FOR DISCHARGE LINE VOLUME VARIATION.

ALGEBRAIC SUPERPOSITION OF LOCAL PRESSURE CONTRIBUTION
FROM EACH VALVE.

PRESSURE SIGNATURE PPA, SPATIAL DISTRIBUTION, LOAD CASES,
AS BEFORE.

MULTIPLE VALVE BUBBLE PHASING -
STAFF EVALUATION

INDIVIDUAL ELEMENTS OF METHODOLOGY NOT COMPLETELY VALIDATED
TO STAFF SATISFACTION.

PDF FOR DBF NOT PROTOTYPICAL OF BEHAVIOUR EXHIBITED
BY CAORSO TESTS (μ AND σ OF FORMER TOO HIGH).
(95-95) CONFIDENCE LEVEL CANNOT BE CLAIMED FOR FINAL
LOAD SPECIFICATION.


METHODOLOGY ACCEPTABLE WHEN CONSIDERED IN ITS ENTIRETY
SENSITIVITY STUDIES.

OVERALL CONSERVATISM DEMONSTRATED BY APPLICATION TO
CAORSO TESTS.

IN-PLANT TESTS (GRAND GULF) TO PROVIDE FURTHER CONFIRMATION

ARS COMPARISON - SELECTED POINTS ON WETWELL

RESPONSE




PREDICTED BY MSRVA

CAORSO MEASUREMENT
(4 VALVES)

FREQUENCY

ARS COMPARISON • SELECTED POINT ON WETWELL

RESPONSE



UPPER BOUND OF 59 MONTE CARLO TRIALS
VIA MSRVA

LOWER BOUND OF 59 MONTE CARLO TRIALS

CAORSO MEASUREMENT
(4 VALVES)

FREQUENCY

MARK III
SRV RELATED POOL
DYNAMIC LOADS
OVERVIEW

- I. BACKGROUND
- II. AREAS OF REVIEW
- III. STATUS

9/17/81

I. BACKGROUND

- METHODOLOGY FOR PREDICTING SRV LOAD

- USE KWU X-QUENCHER DATA
- GE X-QUENCHER - MODIFIED VERSION OF KWU X-QUEN
- STATISTICAL METHOD (1975)

- ACCEPTANCE CRITERIA (1976)

1. GE PROPOSED LOAD METHODOLOGY, CONSERVATIVE, ACCEPTABLE
2. ALL BUBBLES OSCILLATING IN-PHASE
3. LOAD CASES

9/17/81

II. AREAS OF REVIEW

GE PROPOSED MODIFICATIONS TO THE 1975

METHODS:

1. LOW-LOW SET LOGIC
2. 35% LOAD REDUCTION FACTOR
BASIS: CAORSO INPLANT TEST
3. BUBBLE PHASING -
MONTE CARLO APPROACH

9/17/81

III. STATUS

- NO OPEN ITEMS FOR GESSAR DOCKET
- NUREG-0802, "SAFETY/RELIEF VALVES -
LOAD EVALUATION REPORT - MARK II
AND III CONTAINMENTS," NOVEMBER 1981 (SCHEDULES)
- NUREG-0783, "SUPPRESSION POOL TEMPERATURE
LIMITS FOR BWR CONTAINMENTS." DRAFT ISSUED
TO ACRS IN JULY 1981. FINAL ISSUANCE:
OCTOBER 1981.


9/17/81

KUOSHENG NUCLEAR POWER STATION

BACKGROUND

- LOCATION: NORTHERN TIP OF TAIWAN
- 2 UNITS, 985 MW EACH
- FIRST OPERATING BWR6/MARK III IN THE WORLD
- FIRST UNIT: 60% POWER IN AUGUST 1981
- SECOND UNIT: FUEL LOADING - 2ND QUARTER 1982

9/17/81



KUOSHING PRESSURE SUPPRESSION CONTAINMENT

KUOSHENG SRV INPLANT TEST

- OBJECTIVES

1. CONFIRM SRV LOADS
 - PIPING, EQUIPMENT AND CONTAINMENT STRUCTURES
2. PROVIDE DATA BASE FOR STRUCTURAL MODEL
3. PROVIDE DATA BASE FOR X-QUENCHER THERMAL PERFORMANCE - POOL MIXING

9/17/81

● GENERAL INFORMATION

● TESTS STARTED ON AUGUST 22, 1981

● TESTS COMPLETED ON AUGUST 28, 1981

● TOTAL NUMBER OF TESTS - 32


● INSTRUMENTATION

- 128 ACCELEROMETERS
- 71 PRESSURE SENSORS
- 62 STRAIN GAGES
- 22 THERMOCOUPLES

● TESTS INCLUDED


- SINGLE VALVE FIRST ACTUATION
- SINGLE VALVE CONSECUTIVE ACTUATION
- TWO ADJACENT VALVE ACTUATION
- FOUR VALVE ACTUATION
- EXTENDED BLOWDOWN
 - WITH RHR
 - WITHOUT RHR

9/17/81




* INDICATES ADS SAFETY RELIEF VALVES

SUPPRESSION POOL PRESSURE SENSOR LOCATIONS
(PLAN VIEW)



DETAIL 'A'
 QUENCHER ARMS ROTATED INTO VIEW
 (P46, P47 MEASURE INTERNAL PRESSURE)



PRESSURE SENSOR LOCATIONS - QUENCHER V-8
(Elevation View)

NRC PARTICIPATION
IN THE
KUOSHENG SRV INPLANT TEST

O REVIEW AND COMMENT ON TEST PLAN (JULY 1980)

O NRC TEAM DURING THE TEST INCLUDED:

T. M. SU	NRR/NRC
P. HUBER	MIT/RES/NRC
E. MCCAULEY	LLL/RES/NRC
C. MOORE	EG&E/RES/NRC

O PARTICIPATE IN REVIEW OF TEST RESULTS TO DETERMINE
WHETHER THE SUBSEQUENT TEST CAN PROCEED

O PROVIDE TECHNICAL GUIDANCE FOR THE TEST PROGRAM

9/23/81

SUMMARY OF THE TEST RESULTS

1. SRV LOADS

- STRAIN GAGE MEASUREMENT
 - VERY SMALL IN COMPARISON WITH EXPECTED VALUES

- ACCELERATION
 - WITHIN EXPECTED VALUES
 - SIGNIFICANT ACCELERATION IN POOL REGION ONLY (REQUIRES FURTHER INVESTIGATION)
 - FOUR VALVE TEST SHOWS SIGNIFICANT ACCELERATION ON CRANE GIRDER

- PRESSURE MEASUREMENT
 - WITHIN EXPECTED VALUES
 - SOME EXCEEDANCES (LOCALIZED LOADS)
 - NO SIGNIFICANT PRESSURE INCREASE FROM CONSECUTIVE ACTUATIONS

9/17/81

II. POOL MIXING

- TOTAL DISCHARGE TIME - 9 MINUTES
- BULK-TO-LOCAL TEMPERATURE DIFFERENCE
 - 19⁰F WITHOUT RHR
 - 9⁰F WITH RHR OPERATING ONE HOUR
BEFORE SRV WAS ACTUATED

9/17/81

CONCLUSION

- FULFILL THE OBJECTIVES OF THE TEST
- STRUCTURAL MODEL OVERPREDICTED PIPING, EQUIPMENT AND BUILDING RESPONSE
- FORCING FUNCTION PREDICTION
 - FIRST ACTUATION MARGINALLY PREDICTED
MAXIMUM PRESSURE FOR FIRST ACTUATION
(REQUIRES FURTHER INVESTIGATION ON
GLOBAL PRESSURE)
 - CONSECUTIVE ACTUATION OVERPREDICTED IN
MOST OF THE CASES
- APPLICABILITY OF THE TEST RESULTS
 - SRV FORCING FUNCTION REQUIRES DETAILED
INVESTIGATION BEFORE ANY CONCLUSIONS
CAN BE MADE
 - THERMAL MIXING DATA WILL BE APPLICABLE
FOR ALL MARK III PLANTS

9/17/81

MARK III LOCA LOADS
FLUID-STRUCTURE INTERACTIONS

ARE PSTF PRESSURE MEASUREMENTS INFLUENCED BY FSI?

- GE APPROACH: (1) NUMERICAL MODELS USED TO PREDICT
FSI EFFECTS.
- (2) PREDICTIONS COMPARED TO 1/9 - 1/3 -
AND FULL-SCALE PSTF MEASUREMENTS.

CONCLUSION: FSI HAS LITTLE EFFECT.
WHEN FSI IS SIGNIFICANT, IT LEADS TO
CONSERVATIVE LOAD ESTIMATES.

FSI IN 1/9 - AND 1/3 - AREA SCALE TESTS

(ONLY CO CONSIDERED)

NUMERICAL ANALYSIS:

- FSI EFFECTS SIMULATED USING NASTRAN CODE.
- NO SIGNIFICANT EFFECTS FOUND IN EITHER TEST FACILITY IN THE RANGE OF CO FREQUENCIES (≤ 20 Hz).

EXPERIMENTAL VERIFICATION:

- PSTF PRESSURE DISTRIBUTIONS COMPARED TO RIGID-WALL, POTENTIAL FLOW PREDICTIONS.
- RIGID-WALL ANALYSIS GENERALLY OVERESTIMATES PRESSURES AT ALL LOCATIONS.

NRC ASSESSMENT:

- AGREEMENT BETWEEN EXPERIMENTS AND ANALYTICAL PREDICTIONS IS POOR.
- ERRORS TEND TO MAKE LOAD DEFINITION MORE CONSERVATIVE.

FSI IN FULL-SCALE PSTF

(CHUGGING ONLY)

NUMERICAL ANALYSES:


- TWO DOF MODEL WITH CHUGGING FORCING FUNCTION
- FINITE ELEMENT MODEL INCLUDING THE EFFECTS OF FLUID COMPRESSIBILITY

EXPERIMENTAL VERIFICATION:

- PREDICTED TRANSFER FUNCTIONS ($P_{\text{TOP VENT}}/P_{\text{CONT.}}$) COMPARED TO PSTF RESULTS
- AVERAGE OF SEVERAL CHUGS EXHIBITS ALMOST NO FREQUENCY DEPENDENCE

NRC ASSESSMENT:

- ANALYSIS APPEARS TO OVERESTIMATE FSI EFFECTS
- TRANSFER FUNCTION SHOWS ALMOST NO DEPENDENCE ON FREQUENCY
- FSI NOT IMPORTANT IN FULL-SCALE PSTF



COMPARISON OF MEASURED PRESSURE
WITH PREDICTION OF ACOUSTIC ANALYSIS
(FULL SCALE PSTP)

POOL THERMAL STRATIFICATION

- VERTICAL TEMPERATURE GRADIENT NEEDED FOR DESIGN (THERMAL STRESSES ON CONTAINMENT)
- DESIGN GRADIENT DEVELOPED FROM $\frac{1}{3}$ AREA SCALE PSTF TESTS
 - MONOTONICALLY INCREASING UPWARD
 - OVERALL ΔT MAX = 60°F
 - BASED ON FINITE CELL ENERGY DEPOSITION
 - TIMELISE VARIATION OF GLOBAL (BULK) TEMPERATURE ACCOUNTED FOR

POOL THERMAL STRATIFICATION

• CONCERN:

- .. APPLICABILITY OF $\frac{1}{3}$ SCALE AREA DATA FOR PROTOTYPE (DISTORTED GEOMETRY)
- .. BREAK SIZE EFFECT (SBA, IBA, DBA)

• RESOLUTION

- .. NUMERICAL MODELING VIA RELAP COMPUTER CODE
- .. SHOWS SCALE EFFECT NEGLIGIBLE
- .. SHOWS IBA WORST CASE
- .. RELAP PREDICTION FOR STANDARD PLANT SHOWS ΔT_{MAX} USED FOR DESIGN IS CONSERVATIVE (RELAP PREDICTS $\Delta T_{MAX} = 56^{\circ}F$)

MARK III - SUBMERGED STRUCTURE LOADS

OVERVIEW

- PHENOMENA WELL UNDERSTOOD-METHODOLOGY
PRACTICAL AND CONSERVATIVE
- RELATIVELY UNCLUTTERED POOL
- HERITAGE FROM MARK I AND MARK II CONCERNS
- SOME EXPERIMENTAL INFORMATION

MARK III - SUBMERGED STRUCTURE LOADS

- LOCA

WATER JET LOADS (TO VENT CLEARING)

AIR BUBBLE LOADS

FALLBACK LOADS

CONDENSATION OSCILLATION LOADS

CHUGGING LOADS

- S/RV ACTUATION

QUENCHER WATER JET LOADS

QUENCHER BUBBLE LOADS

MARK III - SUBMERGED STRUCTURE LOADS

• LOCA WATER JET

APPROACH - REGION OF INFLUENCE

BASIS - EXPERIMENT AND CONSERVATIVE BOUNDS

CONCLUSIONS - NO STRUCTURES IN MARK III FOR WHICH JET LOAD
IS NOT BOUNDED BY BUBBLE LOAD




Figure 3B.31(a)-1. LCCA Water Jet Zone of Exclusion

GKB 9/25/81-4





Figure 3B.31(a)-2. LOCA Water Jet Zone of Exclusion

GKB 9/25/81-5

MARK III - SUBMERGED STRUCTURE LOADS

• LOCA AIR BUBBLE

APPROACH - SPHERICAL BUBBLE GROWTH
METHOD OF IMAGES
MULTIPLIER OF TWO FOR BUBBLE MOTION
EQUIVALENT UNIFORM FLOWFIELD
LOCAL ACCELERATION AND STANDARD
DRAG ON EACH SEGMENT

BASIS - THEORETICAL/SOME EXPERIMENTAL CONFIRMATION

CONCLUSIONS - APPROACH ESSENTIALLY SIMILAR TO MARK I AND
MARK II

MULTIPLIER FOR BUBBLE MOTION GIVES CONSERVATIVE
BOUND ALTHOUGH DIFFERENT TIME HISTORY. O.K.
BECAUSE $w_N T_D \gg 1$

MARK III - SUBMERGED STRUCTURE LOADS

● FALLBACK LOAD

APPROACH - FREEFALL FROM S = 20 ft.
STANDARD DRAG ALONE AT U = 35 ft/sec

BASIS - THEORETICAL BOUND

CONCLUSIONS - CONSERVATIVE
- ACCELERATION FORCE NEGLIGIBLE

$$\frac{F_A}{F_D} \sim \frac{gD}{U^2} \sim \frac{D}{2s} \ll 1$$

MARK III - SUBMERGED STRUCTURE LOADS

● CONDENSATION OSCILLATIONS

APPROACH - SOURCE STRENGTH BOUNDS DATA
METHOD OF IMAGES
EQUIVALENT UNIFORM FLOWFIELD
ACCELERATION DRAG
STANDARD DRAG (ONLY WHEN SIGNIFICANT)

BASIS - THEORY + EMPIRICAL SOURCE STRENGTH
+ DRAG COEFFICIENT BASED ON OSCILLATING
FLOW DATA

CONCLUSIONS - CONSERVATIVE SOURCE EVALUATION
- STANDARD DRAG NEGLIGIBLE EXCEPT FOR RHR
TEST LINES ($D \approx 1.5''$)

MARK III - SUBMERGED STRUCTURE LOADS

• CHUGGING LOADS

APPROACH - EMPIRICAL SOURCE STRENGTH
- APPROXIMATE ACOUSTIC MODEL
- FORCE \propto PRESSURE DIFFERENCE
- USE FULL PRESSURE DIFFERENCE IN CHUG PULSE

BASIS - THEORY
- EMPIRICAL CHUG SOURCE (FULL SCALE TESTS)

CONCLUSIONS - HYDRODYNAMIC MASS EFFECT BOUNDED BY CONSERVATIVE REPRESENTATION OF PRESSURE GRADIENT
MINIMUM CONSERVATISM ($2.54/2.00$)
- PHASING AND GEOMETRIC CONSERVATISMS
DIFFICULT TO QUANTIFY
- SOURCE STRENGTH??

MARK III - SUBMERGED STRUCTURE LOADS

• S/RV LOADS

- APPROACH - WATER JET - SPHERE OF INFLUENCE
- QUENCHER BUBBLE - SIMILAR TO LOCA BUBBLE
AND CO METHODOLOGY
- USE FOUR BUBBLES AND INCLUDE BUBBLE TRAJECTORY
CALCULATIONS
- ACCELERATION AND STANDARD DRAG
- BASIS - THEORY WITH CONSERVATIVE INITIAL BUBBLE
CONDITIONS
- EXPERIMENTAL VERIFICATION (CAORSO)
- CONCLUSIONS - CONSERVATIVE LOAD EVALUATION FOR IN-PHASE
BUBBLES
- NEGLIGIBLE PHASE DIFFERENCES ESTABLISHED BY
TESTS