

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | S | I | C | N | | E | F | F | | 1 | 2 | 0 | 0 | 0 | - | 1 | 0 | 0 | 0 | 0 | 0 | - | 1 | 0 | 0 | 3 | 4 | | | | | | | | 4 | | | | 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

CONT
01 | REPORT SOURCE | 2 | 5 | 0 | 5 | 0 | 0 | 0 | 2 | 6 | 9 | 7 | 0 | 9 | 1 | 1 | 8 | 1 | 8 | 1 | 1 | 0 | 1 | 0 | 9 | 8 | 1 | 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

012 | On September 11, 1981 it was determined that safety-related battery surveil-
013 | lance procedures did not fully comply with the requirements of Technical
014 | Specification 4.6.9 since its revision in May 1980. The procedures did not
015 | meet the requirements of ONS Technical Specifications 4.6.9.a(1), 4.6.9.a(2),
016 | and 4.6.9.b(1). The batteries were not rendered inoperable by this incident;
017 | thus, the health and safety of the public were not affected.

018 | _____

09 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP SUBCODE | VALVE SUBCODE
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
E | C | A | C | B | A | T | T | R | Y | Z | Z
17 | LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.
8 | 1 | 0 | 1 | 1 | 8 | 0 | 3 | L | 1
18 | ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NRC FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
G | Z | Z | Z | 0 | 0 | 0 | 0 | Y | N | L | E | 3 | 5 | 1 | 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

110 | Personnel failed to identify the necessary changes to the safety-related
111 | battery surveillance procedures after implementation of a change to Technical
112 | Specification 4.6.9. Changes have been initiated to the appropriate surveil-
113 | lance procedures to correct this discrepancy.

114 | _____

15 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
H | 0 | 0 | 0 | 0 | NA | A | NA
16 | ACTIVITY CONTY | AMOUNT OF ACTIVITY | LOCATION OF RELEASE
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
Z | Z | NA | NA
17 | PERSONNEL EXPOSURES NUMBER | TYPE | DESCRIPTION
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
0 | 0 | 0 | 0 | Z | NA
18 | PERSONNEL INJURIES NUMBER | DESCRIPTION
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
0 | 0 | 0 | 0 | NA
19 | LOSS OF OR DAMAGE TO FACILITY TYPE | DESCRIPTION
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
Z | NA
20 | PUBLICITY ISSUED | DESCRIPTION
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40
N | NA