

Alabama Power Company
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201
Telephone 205 868-5581

W. G. Hairston, III
Senior Vice President
Nuclear Operations



Alabama Power
the southern electric system

February 7, 1990

Docket Nos. 50-348
50-364

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Joseph M. Farley Nuclear Plant
Quarterly NPDES Noncompliance Report

Enclosed in accordance with Subsection 3.2 of the Joseph M. Farley Nuclear Plant Environmental Protection Plan (Units 1 and 2), Appendix B to Facility Operating License Nos. NPF-2 and NPF-8, is a summary of NPDES noncompliances for the fourth quarter of 1989 as transmitted to the Alabama Department of Environmental Management.

If you have any questions, please advise.

Respectfully submitted,

W. G. Hairston, III

WGH, III/TCM
Enclosure

cc: Mr. S. D. Ebnetter
Mr. E. A. Reeves
Mr. G. F. Maxwell

9002220552 900207
PDR ADOCK 05000348
S PNU

1525
1/8

This table is submitted to fulfill requirements of Part 1.8.6 and Part III.0

Farley Nuclear Plant NPD&S Permit No. AL0024619

<u>Discharge Point</u>	<u>Parameter</u>	<u>Permit Limit</u>	<u>Analytical Value</u>	<u>Cause of Noncompliance</u>	<u>Corrective Measures</u>	<u>Test Date</u>	<u>Period of Noncompliance</u>	
							<u>Began</u>	<u>Ended</u>
River Water Building Sump Discharge (DSN 022)	Oil & Grease	15.0 mg/l (daily average)	15.1 mg/l	No specific cause could be determined. The area was inspected upon notification and no indication of oil leaks was found. A review of records of previous area inspections indicated no oil leaks were detected.	Since no cause could be determined, no specific action could be taken. The sump was resampled on 1/10/90, the day the plant was notified of the value of 15.1 mg/l, and the value was 1.2 mg/l.	1/10/90	12/21/89	prior to 1/10/90