

Calculation
Cover
Sheet

Project	Pilgrim Nuclear Power Station	Job No	90089
Client	Boston Edison Company	File No	1/F
Subject	Salt Service Water Pump P208A, Casing stresses due to Accidental Drop	Calc Set No	A
		No. of Sheets	2 3

Statement of Problem

Estimate the banding stresses in the service water pump casing due to a drop of 6 to 12 inches of the impeller end of the pump onto a 6" inch concrete slab on grade.

Sources of Data

See Calculation, Section 4.0.

Sources of Formulae & References

See Calculation, Section 4.0.

Revised sheets 4, 7, 14, 20. Replaced sheet 5. Added sheets 21 - 23

Signatures	Checkers	Distribution	Revision No	1
R. Howard	W. Gallagher		Supersedes Calculation Set No	
			0	
			Approved By	Date
			<i>James Palmer</i>	1-19-90



Calculation Sheet

Project: Boston Edison Co.
Subject: Pump Impact Analysis
System: -
Analysis No. A Rev. No. 0

Prepared By <u>M. Engleman</u>	Date <u>1/19/90</u>
Checked By <u>ar. H.C.</u>	Date <u>1/15/90</u>
Job No <u>90089</u>	File No <u>1/F</u>
Sheet No <u>1</u>	

TABLE OF CONTENTS

- 1.0 Background and Problem Statement
- 2.0 Method of Analysis
- 3.0 Summary of Results
- 4.0 References and Drawing List
- 5.0 Calculations

SYGNA

Calculation Sheet

Project	Boston Edison Co.	Prepared By	M. Ergenham	Date	1/10/90
Subject	Pump Impact Analysis	Checked By	Mr. Galy	Date	1/15/90
System	-	JOB NO	90089	FILE NO	1/F
Analysis No	A	Rev No	0	Sheet No	2

1.0 Background and problem statement

On January 11, 1990, Salt Service Water Pump P208A was being transported from the maintenance shop (on the first floor of the New Administration Building) enroute to the Intake Structure Building. The pump, without the motor attached, was being carried in a horizontal orientation, supported by slings from forklift trucks at either end. The pump assembly is shown on BECo Drawing M8-4, Rev. E4, and has an overall length in excess of 42' from its discharge head baseplate to the tip of the suction bell.

The pump discharge head was leading and the bowl/impeller end was following. The lead end was passing through the overhead door, on the north side of the maintenance shop, and was just beginning to make a turn. The rear forklift and bowl/impeller portion of the pump was still within the building line of the maintenance shop.

Just prior to the turn of the lead forklift, the individual who was directing the handling operation had walked toward that operator, and had his back to the rear forklift. As the lead forklift operator began to execute a turn, the bowl/impeller end fell to the floor. None of the people present actually saw the bowl/impeller end as it was falling.

Immediately after the bowl/impeller end fell, it was observed that one of the five column sections had a 360 degree through-wall fracture. The fracture occurred in the second 80" column section up from the bowl/impeller end, approximately 3" from the flange away from the bowl/impeller end. The pump discharge head was still suspended in the sling from the lead end forklift. The column sections from the fracture back to the bowl/impeller end were resting flat on the ground. The impeller/bowl with its sling was laying on the concrete surface just inside the overhead door. The two

SYGNA**Calculation Sheet**

Project Boston Edison Co.
Subject Pump Impact Analysis
System -
Analysis No A Rev No 0

Prepared By <u>M. Engleman</u>	Date <u>1/14/90</u>
Checked By <u>as. J.L.</u>	Date <u>1/15/90</u>
Job No <u>90089</u>	File No <u>1/F</u>
Sheet No <u>3</u>	

abutting column sections were laying on the pavement just outside the building. The impeller shaft was intact preventing significant axial or lateral separation at the fracture. Subsequent examination showed it did not experience any permanent deformation. The position of the impeller/bowl end was such that the forks of the forklift were no longer directly over the sling point, as if the sling had been pulled off the forks.

The impeller/bowl end was estimated to be somewhere between 4" and 12" above the maintenance shop floor when the accident occurred. The pump end, suspended in its sling, was estimated to be approximately 12" to 24" off the ground. The most likely accident scenario is that the forklift movements were not fully coordinated resulting in the slings of the rear forklift slipping off the forks. A less likely scenario is that the column section fractured suddenly under its own weight, and then slipped off the forks of the rear forklift. The evidence supporting the former is as follows:

- The pump had been lifted and moved some distance before the accident. Thus it was successfully "proof tested", and had sustained its own dead weight.
- The front slings were restrained from coming off the forks by an "A" frame assembly while the rear slings were not. The rear slings depended on friction to remain on the forks if the pump were to move away from the forklift.
- The position of the rear forklift and the impeller/bowl immediately after the accident suggests relative movement occurred in a direction which would pull the slings off the forks.

The purpose of this calculation is to estimate the bending stresses in the pump casing resulting from a drop of 6 to 12 inches of the impeller end of the pump onto a six inch concrete slab on grade.



Calculation Sheet

Project Boston Edison Co.
Subject Pump Impact Analysis
System _____
Analysis No. A Rev No. 0

Prepared By <u>M. Engelman</u>	Date <u>1/16/90</u>
Checked By <u>awj</u>	Date <u>1/15/90</u>
Job No. <u>90089</u>	File No. <u>1/F</u>
Sheet No. <u>4</u>	

2.0 Method of Analysis

The pump casing is modeled as a beam with lumped masses. An energy balance approach is used to estimate the stresses in the beam after impact with the concrete slab. The work associated with the gravity forces acting over the displacements due to angular rotation of the pump just prior to impact is calculated. The work is then equated to the strain energy of deformation of the beam after impact. Additional work done by the forces acting over the beam displacements are neglected for the strain energy calculations. This is conservative. The strain energy is calculated by replacing the beam by a series of springs representing the stiffness of the beam at the mass points. Each spring exactly represents the resistance of the beam to the kinetic energy of the mass. The spring forces are then calculated by conservation of energy. These forces represent the dynamic loads imparted on the structure from the masses. The forces are used to calculate beam shears, moments and bending stresses. Due to the stiffness of the concrete/soil spring, the frequency of response near the contact point will be much greater than the natural frequency of the pump casing (approximately 0.6 Hz, Reference 4.1.3), therefore high frequency contact forces will not significantly alter the stresses near the break location. The concrete soil spring is assumed rigid and acts as a support point after the initial impact. Local forces near the contact point were not investigated.



by
288
4-1-1
1/16/90



Calculation Sheet

Prepared By <u>L. Husted</u>		Date <u>10-19-90</u>
Checked By <u>G.W.</u>		Date <u>10-19-90</u>
Project <u>Boston Edison Co</u>	Job No <u>98089</u>	File No <u>1/F</u>
Subject <u>Pump Impact Analysis</u>	Sheet No <u>5</u>	
System <u>-</u>	Analysis No <u>A Rev No 1</u>	

3.0 Summary of Results

The highest bending stresses occur at about 17 feet from the impeller end of the pump. The actual break occurred at or very near the predicted point of highest stress. The maximum stress ranged from about 29.6 ksi for a drop of 6 inches, to 41.9 ksi for a 12 inch drop. These represent lower bound values due to conservative estimates of the pump flange and bearing weights, and neglect of additional work energy associated with the beam deflections.



Calculation Sheet		Prepared By M. Engelman	Date 1/16/70
Project	Boston Edison Co.	Checked By A. Huy	Date 1/15/70
Subject	Pump Impact Analysis	JOB NO 90089	FILE NO 11F
System		Sheet No	
Analysis No	A	Rev No	0
			6

4.0 References and Drawing List

4.1 References

- 4.1.1 Dynamics, by J.L. Meriam, 2nd Edition, John Wiley and Sons, 1971.
- 4.1.2 Ladish Catalog No. 55, "Forged and Stainless Welding Pipe Fittings".
- 4.1.3 Seismic Stress Analysis of Vertical Pumps, Model VIT-X-SD size 16 DHLA 1, McDonald Engineering Analysis Company.
- 4.1.4 Vibrations of Soils and Foundations, by F.E. Richart, Jr. et al, Prentice-Hall, 1970.

4.2 Drawing List

- 4.2.1 Boston Edison Company, Drawing No. M8-4, Rev. E4, "Service Water Pump Assembly Drawing".
- 4.2.2 Boston Edison Company, Drawing No. 1065, Rev. E0, "Administration Building Foundation Plan".

other References as noted in Calculation




Calculation Sheet

Project: Boston Edison Co.
 Subject: Pump Impact Analysis
 System: _____
 Analysis No: A Rev No: 0

Prepared By M. Engelman	Date 1/10/90
Checked By W. Tak	Date 1/15/90
JOB NO. 90089	FILE NO. 1/F
Sheet No. 7	

5.0 Calculations

For dimensions, see Ref. 4.2.1
 4.1.3



$d = 6'' \text{ to } 12''$, Use 6" for initial calculations

$$R = 6'' \quad O.O. = 12.75'' \quad I.O. = 12''$$

Ref. 4.1.3

$$A = 2\pi R t = 14.6 \text{ in}^2$$

$$I = 279 \text{ in}^4 \quad \begin{array}{l} \text{Note: impeller end slightly} \\ \text{higher I for last 3'} \\ - \text{ignore} \end{array}$$

$$S = 43.8 \text{ in}^3$$



$L = 0.375$

$$\text{Shaft Diameter} = 2.93'' \quad \therefore W = 15.88 \text{ #/ft}$$

$$\text{Casing, } W = 49.56 \text{ #/ft} \quad \text{Ref. AISCP1-89}$$

$$\text{Bearings, Flanges & Misc, } W = 15 \text{ #/ft} \quad \left\{ \begin{array}{l} \text{Note: Actual min} \\ W = 18.3 \text{ #/ft} \\ \text{Ref. 4.1.2} \end{array} \right.$$

$$W = 49.56 + 15.88 + 15 = 80.44, \text{ say } 80 \text{ #/ft}$$

$$W = Wl = 80 \times 43 = 3440 \text{ lb}$$

Note: Material Density for Aluminum Bronze C95200 $\approx 490 \text{ lb/in}^3$
 (see sheet 21)


BY EBD
 1-19-90
 20-21
 20-21



Calculation Sheet		Prepared By M. Engelman	Date 1/14/90
Project	Boston Edison Co.	Checked By W. H. J.	Date 1/15/90
Subject	Pump Impact Analysis	Job No T0089	File No 11F
System	-	Sheet No	8
Analysis No	A	Rev. No	0

The free fall distance is small and the casing was essentially horizontal.

Use the following model to approximate the dynamic behavior of the pump casing. The numbers refer to the location of lumped masses



$$M_{1,11} = \frac{W/g}{20} = \frac{3490/386.4}{20} = .445 \text{ in-lb/sec}^2$$

$$M_{2-10} = \frac{W/g}{10} = \frac{3490/386.4}{10} = .890 \text{ in-lb/sec}^2$$


After release of the impeller end, the pump casing rotates about point 1.

At the instance before impact, the model is represented as shown following

Calculation Sheet

Project Boston Edison Co.
 Subject Pump Impact Analysis
 System -
 Analysis No. A Rev No. 0

Prepared By M. Ergun Date 1/14/90
 Checked By aw. M. Date 1/15/90
 Job No. 90089 File No. 1/F
 Sheet No. 9



F_i = Tangential forces on masses M_i
 due to angular acceleration α

Equations of motion for fixed rotation:

$$\sum F_i = m \bar{F} \alpha \quad \text{Ref. Dynamics}$$

$$\sum M_o = I_o \alpha \quad (O \text{ represents pt. 1}) \quad \text{eq. 116}$$

$$M_o = W \times l/2 = mg l/2$$

$$I_o = m \left(\frac{l^2}{12} + r^2 \right) = m \left(\frac{l^2}{12} + \left(\frac{l}{2} \right)^2 \right) = \frac{m l^2}{3} \quad \text{Ref. 4.1.1}$$

$$\alpha = \sum M_o / I_o = \frac{m g l / 2}{m l^2 / 3} = \frac{3g}{2l} \text{ rad/sec}^2$$

$$\sum F_i = m \bar{F} \alpha = \frac{m l}{2} \times \frac{3g}{2l} = \frac{3}{4} W$$

at any point i :

$$F_i = m_i \times X_i \times \frac{3g}{2l}, \quad X_i = .1\ell, .2\ell \text{ etc}$$

$$F_i = \frac{3}{2} W_i \frac{X_i}{l}$$



Calculation Sheet

M. Engleman

1/19/90

Project: Boston Edison Co.
Subject: Pump Impact Analysis
System: -
Analysis No: A

Checked By

C.W. Y

Date

1/15/90

JOB NO

70089

FILE NO

1/E

Sheet No

Rev No 0

10

The work done by gravity just before impact is :

$W_e = k_e = \sum F_i d_i$ where d_i = displacement of node i just before impact

$$d_i = \frac{x_i}{l} \times d$$

Calculate the work or kinetic energy, k_e , for each mass location :

$$k_{e,i} = F_i \times d_i = \frac{3}{2} w_i \left(\frac{x_i}{l}\right)^2 \times d$$

$$\sum k_{e,i} = \frac{3d}{2l^2} \sum w_i x_i^2$$

Now equate the total work done just before impact to the internal strain energy in the beam at the time of maximum deflection from the dynamic loads. The following assumptions are made :

- 1) The strain energy in the beam can be represented by springs at the mass point locations
- 2) The springs have a stiffness represented by the inverse of the deflection at point




Calculation Sheet		Prepared By M. Engelman	Date 1/10/90
Project	Boston Edison Co.	Checked By E.W. Hart	Date 1/15/90
Subject	Pump Impact Analysis	Job No. 90089	File No. 1/F
System	-	Sheet No.	
Analysis No	A	Rev No	11

i due to a unit load at i.

- 3) The maximum deflection of the springs occurs simultaneously. This should be reasonable for all nodes except those very near the point of contact. This is because the frequency of the pump casing is extremely low (~ .6 Hz) relative to the Ref. 9.13 contact response frequency of the casing impacting slab on grade concrete. Any high frequency response near the impact point will be highly localized and will not significantly affect the response at the points of interest near mid-span

The model at the maximum deflection is:



The Strain Energy, S_e for each spring is $S_e = \frac{1}{2} k_i \delta_i^2$ at max. deflection



Calculation Sheet

Prepared By <u>M. Engelman</u>		Date <u>1/16/90</u>
Checked By <u>Mr. Glavin</u>		Date <u>1/15/90</u>
Project <u>Boston Edison Co.</u>	Job No. <u>90089</u>	File No. <u>1/F</u>
Subject <u>Pump Impact Analysis</u>	Sheet No.	
System —		
Analysis No. <u>A</u>	Rev No. <u>0</u>	12

Therefore, for each spring, equating work with strain energy is

$$ke_i = Se_i = F(+)\cancel{\delta_i} \approx \frac{1}{2} k_i \delta_i^2$$

$$\delta_i = (2 ke_i / k_i)^{1/2}$$

Note: Additional work done by gravity forces over δ_i are small - neglect, conservative.

The spring force, $F_s_i = k_i \delta_i$ or

$$F_s_i = (2 ke_i \times k_i)^{1/2}$$

This represents the equivalent force on the beam at location i required to deflect the beam δ_i

From the equivalent forces acting on the beam, the reactions, loads, moments & stresses can be determined. These calculations and results follow:




Calculation Sheet		M. Enginner	1/14/90
Project	Boston Edison Co.	Checked By	Date
Subject	Pump Impact Analysis	an M	1/15/90
System		JOB NO	File No
Analysis No	A	90069	1/F
		Sheet No.	
			13

Calculate Soil Spring :
at Contact Pt

Ref. 4.2.2

SLAB ON
GRADE



$$K = \frac{4 G R_0}{1 - v} \quad \text{soil stiffness}$$

Ref 4.1.4
pg 205

G = Soil Shear Modulus

R₀ = Radius of Contact Area = 6"

v = Poissons Ratio = 0.33

G is estimated as 3000 psi for a lower bound for compacted backfill. It is much higher in reality based on the chart on pg 205, Ref. 4.1.4 for granular material.

$$K = 4 \times 3000 \times 6 / 1 - .33 = 107,963 \text{ lb/in} \gg \text{Beam Stiffness}$$

Assume support is rigid for this analysis will have negligible effect on stresses.



Calculation Sheet

Project Boston Edison Co.
 Subject Pump Impact Analysis
 System -
 Analysis No. A Rev No. 0

Prepared By <u>M. Engelmann</u>	Date <u>1/14/90</u>
Checked By <u>Mr. H. J.</u>	Date <u>1/15/90</u>
Job No. <u>90029</u>	File No. <u>1/F</u>
Sheet No. <u>14</u>	

$E := 29000000$ Modulus of Length in inches
 (SPP, S-T 21) Elasticity Ref. 4.1.3

$I := 279.0$ Moment of Section Modulus $(\text{A} = 14.7, \text{DFT} = 1/10)$
 Inertia

$i := 2 .. 10$ Perform operations for points 2 to 10

$$x := \frac{i - 1}{10} \cdot 1 \quad \text{Distance to location } i$$

$$k := \frac{3 \cdot E \cdot I \cdot 1}{\frac{1}{2} \cdot \frac{1}{x^2} \cdot \left[\frac{1-x}{1} \right]^2}$$

Spring stiffness of beam at
location i Ref. AISC
Manual 8th Ed.
Case 8, pg 2-116

i	x	k
2	51.6	21811.7
3	103.2	6901.4
4	154.8	4006.2
5	206.4	3067.3
6	258	2826.8
7	309.6	3067.3
8	361.2	4006.2
9	412.8	6901.4
10	464.4	21811.7

$d := 6$ inches Assumed free fall distance of impeller end
of the pump casing

$w := 6.67$ lbs per in (88 lbs per foot)

$s := 386.4$ in/sec²

(See
SNT 21
- 23 -)

By EHD
1-19-90
CSD WJ
1/14/90



Calculation Sheet

Project Boston Edison Co.
Subject Pump Impact Analysis
System -
Analysis No A Rev No 0

Prepared By M. Engelman Date 1/19/90
Checked By Mr. R.Y. Date 1/15/90
JOB NO 90089 FILE NO 1/F
Sheet No 15

$$W := W \cdot 1 \quad \text{total weight}$$

$$m := \frac{W}{g} \quad \text{total mass}$$

$$w_i := \frac{W}{10} \quad \text{weight at location } i, i = 2 \text{ to } 10$$

$$w_{11} := \frac{W}{20} \quad F_i := -w_i \begin{bmatrix} x \\ 1 \\ 1 \end{bmatrix} \quad \begin{array}{l} \text{Force at location } i \\ \text{due to gravity} \end{array}$$

$$K_E := F_i \cdot \begin{bmatrix} x \\ 1 \\ 1 \end{bmatrix} \cdot d \quad \text{kinetic energy at each spring.}$$

$$\delta_i := \begin{bmatrix} K_E \\ 1 \\ 1 \end{bmatrix}^{.5} \quad \begin{array}{l} \text{deflection of the beam at location } i \\ \text{Note - This deflection is } \underline{\text{not}} \text{ the} \\ \text{total deflection of the beam.} \end{array}$$

$$F_R := \delta_i \cdot k \quad \begin{array}{l} \text{restoring force at location } i \\ \text{Note - This deflection is } \underline{\text{not}} \text{ the} \\ \text{total deflection of the beam.} \end{array}$$




Calculation Sheet

Project Boston Edison Co.
 Subject Pump Impact Analysis
 System -
 Analysis No. A Rev. No. 0


M. Engelman	1/14/90
Checked By <u>W. J. H. S.</u>	Date 1/15/90
JOB NO 90089	File No 1/F
Sheet No 16	

	x_i		F_i	K_e	S_i	F_S
1	1		1	1	1	1
2	344.2		0.1	51.6	0.1	1162.4
3	344.2		0.2	103.3	0.2	1307.7
4	344.2		0.3	154.9	0.4	1494.6
5	344.2		0.4	206.5	0.6	1743.7
6	344.2		0.5	258.1	0.7	2092.4
7	344.2		0.6	309.8	0.9	2615.5
8	344.2		0.7	361.4	0.9	3487.3
9	344.2		0.8	413	0.8	5231
10	344.2		0.9	464.6	0.5	10461.9



Deflection

Note: Not total deflection. Only due to K_e , at point i.



Restoring Force

$$M_i := F_{S_i} \cdot [1 - x_i]$$

Moment induced about point 11 due to dynamic loads at point i.

SYCNA

Calculation Sheet

Project Boston Edison Co.

Subject Pump Impact Analysis

System -

Analysis No A

Prepared By M. Senghars

Date 1/14/90

Checked By En. Ge J

Date 1/15/90

Job No 90089

File No 1/F

Sheet No

17

$$\sum_{i=1}^6 M_i = 4858513.4 \quad R := 4.86 \frac{10}{1} \quad R = 9418.6 \quad \text{Reaction at location 1}$$

$$V_1 := R \quad V_i := V_{i-1} - F_s \quad \text{Shear force from location } i \text{ to } i+1$$

$$M_1 := 0 \quad M_i := M_{i-1} + V_{i-1} \frac{10}{10} \quad \text{Moment at location } i$$

$$M_{11} := 0$$

$$f_{b,i} := \frac{M_i}{s} \quad f_{b,11} := 0$$

Bending Stress at location 1

$$i := 1 .. 10$$

i	x
1	0
2	51.6
3	103.2
4	154.8
5	206.4
6	258
7	309.6
8	361.2
9	412.8
10	464.4

v
9418.6
8256.2
6948.4
5453.9
3710.2
1617.8
-997.6
-4484.9
-9715.9
-20177.8

M
0
486000
912018.4
1270557.4
1551977.1
1743424.4
1826904.7
1775426.3
1544002.9
1042662.2

f _b
0
11095.9
20822.3
29000.2
35433.3
39804.2
41710.2
40534.8
35251.7
23005.1



Calculation Sheet

M. Eng. No.

1/10/90

Checked By
Cv. - J-Y

Date

1/15/90

Project Buster Edison Co.

Checked By

Subject Pump Impact Analysis

Cv. - J-Y

System

Date

Analysis No.

1/15/90

Job No.


90089

File No.

1/F

Sheet No.


18



i := 1 .. 11

x := 516

11






Calculation Sheet

Project Boston Edison Co.
Subject Pump Impact Analysis
System -
Analysis No A Rev No C

Prepared By M. Jankowski Date 10/16/90
Checked By ov. J. Date 11/15/90
Job No. 90089 File No. 11F
Sheet No. 19



Bonding Stress
lb/in

Per the above graphs and tables, the maximum predicted stress is at location 7, corresponding to 0.4×516 inches, or 17.2 feet from the impeller end of the casing. Actual failure occurred at approximately 17.4 feet from the end. Agreement is excellent with the predicted results.

Since F_s , the restoring force, is a function of the square root of K_e , then F_s , V (Shear), M , (Moment) and f_b (Bending Stress) are also a function of K_e . K_e is proportional to d , therefore the above parameters are a function of the square root of d , the distance the impeller end of the pump shaft casing fell before striking the ground.

The predicted bending stresses for free fall distances greater than 6 inches are as follows:

$$j := 6 .. 12$$

$$d := j$$



Calculation Sheet

Project Boston Edison Co.
 Subject Pump Impact Analysis
 System _____
 Analysis No A Rev No 0

Prepared By <u>M. Engleman</u>	Date <u>1/16/90</u>
Checked By <u>aw-jay</u>	Date <u>1/15/90</u>
JOB NO <u>90c89</u>	FILE NO <u>1/F</u>
Sheet No <u>20</u>	

$$f := \frac{[d]}{j} \cdot \frac{5}{j} \quad f_b := f \cdot 41710$$

Distance to
Impact (d), inches

Maximum Bending
Stress at location 7

d	j
6	
7	
8	
9	
10	
11	
12	

f _b	j
41710	
45051.9	
48162.6	
51064.1	
53947.4	
56475.6	
59986.0	

See
SHEET
21-23

1
B
RBB
1/19/90
CSD:
aw-jay
LAPTS:
1/19/90




Calculation Sheet		Prepared By <u>L. Howard</u>	Date 1-19-20
Project	<u>BOSTON EDISON CO</u>	Checked By <u>As. Eng.</u>	Date 1-19-20
Subject	<u>PUMP IMPACT ANALYSIS</u>	Job No <u>90089</u>	File No <u>11P</u>
System		Sheet No	
Analysis No	<u>A</u>	Rev No	<u>21</u>

PAGE 14 OF THIS CALCULATION SHOWS
A MODULUS OF ELASTICITY OF $E = 29 \times 10^6$
FOR THIS MATERIAL IT SHOULD BE $E = 15 \times 10^6$
ALSO THE DENSITY CHANGES FROM $w =$
 0.283 lb/in^3 TO 0.276 lb/in^3 (Ref. MIL-H-
HANDBOOK NINTH EDITION, MAT. C95-200 SECUL-
3 FE-9A1). A RATIO WILL BE DETERMINED
USING THESE NEW VALUES TO ACQUIRE
NEW STRESSES

$$F_b \propto \left[\frac{F_c}{K_c} \right]^{1/2} K_c$$

$$F_b \propto \left[\frac{w_n/w_0}{K_c} \right]^{1/2} K_c$$

$$F_b \propto \left[\frac{w_n/w_0}{E_n/E_0} \right]^{1/2} \cdot \frac{E_n}{E_0}$$



Calculation Sheet

Project	BOSTON COISON CO	Prepared By	R. Harrel	Date	1-15-90
Subject	PURP IMPACT ANALYSIS	Checked By	1m. GL	Date	1-15-90
System		Job No.	90089	File No.	11F
Analysis No.	A	Rev No.	1	Sheet No.	22

$$E_n = 15 \times 10^6 \quad E_o = 29 \times 10^6$$


$$w_n = 0.276 \text{ in}^3 \quad w_o = 0.283 \text{ in}^3$$

$$F_b \propto \left[\frac{.276}{.283} \times \frac{15 \times 10^6}{29 \times 10^6} \right]^{1/2}$$

$$F_b \propto \left[\frac{.975}{.517} \right]^{1/2} \cdot .517$$

$$F_b = 0.7100$$

THEREFORE THE STRESS VALUE
NOTED ON PAGE 200 CAN BE MULTI-
PLIED BY THIS ADJUSTED FACTOR



Calculation Sheet

Project BOSTON EDISON CO
Subject PUMP IMPACT ANALYSIS
System _____
Analysis No A Rev. No 1

Prepared By <u>R. Hornal</u>	Date <u>1-19-90</u>
Checked By <u>~</u>	Date <u>1-19-90</u>
Job No <u>90089</u>	File No <u>1/F</u>
Sheet No <u>23</u>	

DISTANCE TO
IMPACT (d), INCHES

d
j

6
7
8
9
10
11
12

MAXIMUM BENDING
STRESS AT LOCATION 'j'

F_b
j

29614
31982
34195
36270
38232
40098
41881

NUCLEAR ORGANIZATION
CONTROLLED DOCUMENT CHANGE NOTICE (CDCN)

RTYPE A2.20

CDCN Log No. _____

MANUAL TITLE: _____
DOCUMENT TITLE: OPERABILITY EVALUATION OF SSW Pump Columns
DOCUMENT NO.: F584C Calc M-410

NEW DOCUMENT RETIRE REVISION SECTION(S)/PROCEDURE(S) AFFECTED
F584C Sec 12, App C

REV. NO./DATE AFTER CHANGE: Rev. 0 / 11/90

NO. OF PAGES ATTACHED: 11

OTHER KNOWN DOCUMENTS AFFECTED SU003RF 89-75, FMR 90-8/NCR 90-247

GENERAL REASON FOR CHANGE

- Change in Work Process Change in Related Document or Procedure
 Error in Previous Revision Editorial Change Only
 Other: SUPPORT JCO NED 90-041

SPECIFIC PURPOSE AND SUMMARY OF CHANGES

DETERMINE OPERABILITY OF SSW PUMPS IN REACTOR
CONSIDERATION AS A RESULT OF TRANSPORTATION DROPP ON
1/11/90. PUMP COL. FOUND CRACKED & HAZARDOUS (AC-642)
PHYSICAL PROB. UNKNOWN. DETERMINING WHETHER REACTOR
PUMP COLUMNS IN SERVICE ARE APPROPRIATE DURING
WORST CASE WORK PROB. (HER EVIDENCE)

Signature of Initiator: Jeff Roberts Dept. Mgr: Administration

Approvals to retire NUORG Procedures:

ONE SD SVPH

Approval to retire Nuclear Operations Procedures:

SD /date

Date Issued by Document Control