

DUKE POWER COMPANY
CRISIS MANAGEMENT
IMPLEMENTING PROCEDURES

March 6, 1990

9003280409 900312
PDR ADOCK 05000413
F PDC

TABLE OF CONTENTS

Volume 2

<u>Tab</u>	<u>Procedure Description</u>
CMIP-8	Oconee Crisis Phone Directory (Rev. 25)
CMIP-9	McGuire/Catawba Crisis Phone Directory (Rev. 32)
CMIP-10	Emergency Classification - Catawba (Rev. 3)
CMIP-11	Emergency Classification - McGuire (Rev. 6)
CMIP-12	Emergency Classification - Oconee (Rev. 6)
CMIP-13	Notifications to States and Counties from the Crisis Management Center (Rev. 19)
CMIP-14	Crisis Management Data Transmittal System Access for Offsite Agencies - (Rev. 1)
CMIP-15	Reserved for future use
CMIP-16	Crisis Management Data Transmittal System Access from the Crisis Management Center - (Rev. 9)
CMIP-17	Public Alerting on Lake Norman (Rev. 6)
CMIP-18	Maintaining Emergency Preparedness (Rev. 3)
CMIP-19	Communications Test for McGuire/Catawba CMC (Rev. 16)
CMIP-20	Communications Test for Oconee CMC (Rev. 10)
CMIP-21	Quarterly Inventory Equipment Check (Rev. 30)
CMIP-22	Telephone Number Updates (Rev. 1)

March 6, 1990

CRISIS MANAGEMENT IMPLEMENTING PROCEDURE

CMIP-10

Classification of Emergency for
Catawba Nuclear Station

Rev. 3
March 6, 1990

R E Harris

Approved By

3/6/90

Date

CMIP-10
CLASSIFICATION OF EMERGENCY FOR
CATAWBA NUCLEAR STATION

1.0 SYMPTOMS

1.1 Notification of Unusual Event

- 1.1.1 Events are in progress or have occurred which indicate a potential degradation of the level of safety of the plant.
- 1.1.2 No releases of radioactive material requiring offsite response or monitoring are expected unless further degradation of safety occurs.

1.2 Alert

- 1.2.1 Events are in progress or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant.
- 1.2.2 Any releases are expected to be limited to small fractions of the EPA Protective Action Guideline exposure levels.

1.3 Site Area Emergency

- 1.3.1 Events are in process or have occurred which involve actual or likely major failures of plant functions needed for protection of the public.
- 1.3.2 Any releases are not expected to exceed EPA Protective Action Guideline exposure levels except near the site boundary.

1.4 General Emergency

- 1.4.1 Events are in process or have occurred which involve actual or imminent substantial core degradation or melting with potential for loss of containment integrity.
- 1.4.2 Releases can be reasonably expected to exceed EPA Protective Action Guideline exposure levels offsite for more than the immediate site area.

2.0 IMMEDIATE ACTIONS

- 2.1 Compare actual plant conditions to the Emergency Action Level(s) listed in Enclosure 4.1 then declare the appropriate Emergency Class as indicated.

If a change in the emergency class is made, perform steps 2.2, 2.3, and 2.4 below.

- 2.2 Instruct the State/County Communicator to notify the state(s) and counties per CMIP-13 of any change in the emergency class. If the emergency class is SITE AREA EMERGENCY or GENERAL EMERGENCY, determine protective action recommendations per CMIP-1 and transmit these recommendations.

NOTE: Notifications to the state(s) and counties must be made within 15 minutes whenever there is a change in the emergency classification.

- 2.3 Announce the change in the emergency class to all CMC personnel and to the Emergency Coordinator at the TSC.

3.0 SUBSEQUENT ACTIONS

- 3.1 To escalate, de-escalate or close out the Emergency, compare plant conditions to the Emergency Action Levels of Enclosure 4.1. Any decision to de-escalate from a General Emergency condition must be discussed with the senior NRC and State representatives.

Notify state(s), counties, and NRC by verbal summary of any reduction or termination in the emergency class followed by a written summary within eight (8) hours.

4.0 ENCLOSURES

- 4.1 Emergency Event List for Emergency Classes

<u>Event No.</u>		<u>Page(s)</u>
4.1.1	Primary Coolant Leak	1-3
4.1.2	Fuel Damage	4-5
4.1.3	Steam System Failure	6-7
4.1.4	High Radiation/Radiological Effluents	8-9
4.1.5	Loss of Shutdown Function	10-13
4.1.6	Loss of Power	14-15
4.1.7	Fires and Security Actions	16-17

4.1.8	Spent Fuel Damage	18-19
4.1.9	Natural Disasters and Other Hazards	20-22
4.1.10	Other Abnormal Plant Conditions	23-27

jh900305.001

CATAWBA NUCL. STATION
EMERGENCY ACTION LEVELS

CMIP-10
Enclosure 4.1
Page 1 of 27

EVENT # 4.1.1 PRIMARY COOLANT LEAK

NOTIFICATION OF UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
<p>1. NC System leakage greater than Tech Spec limits in Modes 1-4.</p> <p>o Greater than 1 gpm unidentified NC System leakage in Modes 1-4</p> <p style="text-align: center;"><u>AND</u></p> <p>Load reduction or plant cooldown initiated in accordance with Tech Spec 3.4.6.2.</p> <p>o Greater than 10 gpm identified NC System leakage in Modes 1-4</p> <p style="text-align: center;"><u>AND</u></p> <p>Load reduction or plant cooldown initiated in accordance with Tech Spec 3.4.6.2.</p> <p>o Greater than 500 gpd primary to secondary leakage in any S/G in Modes 1-4</p> <p style="text-align: center;"><u>AND</u></p> <p>Load reduction or plant cooldown initiated in accordance with Tech Spec 3.4.6.2.</p>	<p>1. NC System leakage greater than 50 gpm in Modes 1-4.</p> <p>o NC System leakage greater than 50 gpm in Modes 1-4</p> <p style="text-align: center;"><u>AND</u></p> <p>NC System subcooling greater than 0°F</p> <p style="text-align: center;"><u>AND</u></p> <p>Leak cannot be isolated within 15 minutes.</p> <p>2. S/G tube leak with loss of offsite power.</p> <p>o S/G tube leak greater than 10 gpm</p> <p style="text-align: center;"><u>AND</u></p> <p>NC System subcooling greater than 0°F</p> <p style="text-align: center;"><u>AND</u></p> <p>Both A and B main bus lines de-energized.</p> <p style="text-align: center;">(Continued)</p>	<p>1. NC System leakage greater than available ECCS capacity.</p> <p>o S/I actuated or required</p> <p style="text-align: center;"><u>AND</u></p> <p>Existing NV, NI and ND flow cannot maintain NC System subcooling greater than 0°F.</p> <p style="text-align: center;">(Continued)</p>	<p>1. Any LOCA with failure of ECCS.</p> <p>o LOCA with failure of both trains of ECCS injection</p> <p style="text-align: center;"><u>AND</u></p> <p>NC System subcooling cannot be maintained greater than 0°F.</p> <p>o LOCA with failure of both trains of ECCS recirculation capability</p> <p style="text-align: center;"><u>AND</u></p> <p>NC System subcooling cannot be maintained greater than 0°F.</p> <p>o LOCA</p> <p style="text-align: center;"><u>AND</u></p> <p>Plant conditions require entry into EP/1(2)/A/5000/2B1, Inadequate Core Cooling.</p> <p style="text-align: center;">(Continued)</p>
(Continued)			

CATAWBA NUCLEAR STATION
EMERGENCY ACTION LEVELS

CMIP-10
Enclosure 4.1
Page 2 of 27

EVENT # 4.1.1 PRIMARY COOLANT LEAK (continued)

NOTIFICATION OF UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
<ul style="list-style-type: none"> o Greater than 1 gpm total primary to secondary leakage in all S/Gs in Modes 1-4 <p style="text-align: center;"><u>AND</u></p> <p>Load reduction or plant cooldown initiated in accordance with Tech Spec 3.4.6.2.</p> <ul style="list-style-type: none"> o Any NC System pressure boundary leakage in Modes 1-4 <p style="text-align: center;"><u>AND</u></p> <p>Load reduction or plant cooldown initiated in accordance with Tech Spec 3.4.6.2.</p> <ul style="list-style-type: none"> o Greater than 40 gpm controlled NC system leakage at 2235 psig in Modes 1-4 <p style="text-align: center;"><u>AND</u></p> <p>Load reduction or plant cooldown initiated in accordance with Tech Spec 3.4.6.2.</p>	<p>3. S/G tube leak with an unisolable steam line break outside Containment.</p> <ul style="list-style-type: none"> o Known S/G tube leak greater than 10 gpm <p style="text-align: center;"><u>AND</u></p> <p>Unisolable steam line break outside Containment</p> <p style="text-align: center;"><u>AND</u></p> <p>NC System subcooling greater than 0°F.</p> <ul style="list-style-type: none"> o Unisolable steam line break outside Containment <p style="text-align: center;"><u>AND</u></p> <p>Field monitoring teams detect activity at the Protected Area fence at greater than or equal to 2 mr/hr whole body.</p> <p style="text-align: center;"><u>END</u></p>	<p>2. S/G tube leak greater than 50 gpm with a steam line break.</p> <ul style="list-style-type: none"> o S/G tube leak greater than 50 gpm <p style="text-align: center;"><u>AND</u></p> <p>Steam line break inside Containment on the ruptured S/G</p> <p style="text-align: center;"><u>AND</u></p> <p>Valid indication on EMP-53A or 53B reading greater than or equal to 290 R/hr.</p> <ul style="list-style-type: none"> o S/G tube leak greater than 50 gpm <p style="text-align: center;"><u>AND</u></p> <p>Unisolable steam line break outside Containment on the ruptured S/G.</p> <p style="text-align: center;"><u>END</u></p>	<p>2. LOCA with initially successful ECCS followed by failure of ECCS heat sink and failure of Containment heat removal.</p> <ul style="list-style-type: none"> o LOCA <p style="text-align: center;"><u>AND</u></p> <p>Loss of recirculation heat sink</p> <p style="text-align: center;"><u>AND</u></p> <p>Loss of Containment spray heat sink.</p> <p style="text-align: center;"><u>END</u></p>

(Continued)

CATAMBA NUCLEAR STATION
EMERGENCY ACTION LEVELS

CMIP-10
Enclosure 4.1
Page 3 of 27

EVENT # 4.1.1 PRIMARY COOLANT LEAK (continued)

GENERAL EMERGENCY

SITE AREA EMERGENCY

ALERT

NOTIFICATION OF
UNUSUAL EVENT

0 Greater than 1 gpm leakage from any NC pressure isolation valve at 2235 psig in Modes 1-4

AMD

Load reduction or plant cooldown initiated in accordance with Tech Spec 3.4.6.2.

2. Unisolable NC System leakage greater than 50 gpm in Modes 5 and 6.

3. Failure of an unisolable PZR PORV or a PZR safety valve to close following a reduction of NC System pressure.

END

CATAWBA NUCLEAR STATION
EMERGENCY ACTION LEVELS

CMIP-10
Enclosure 4.1
Page 4 of 27

EVENT 4.1.2 FUEL DAMAGE

NOTIFICATION OF UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
<p>1. NC System activity greater than Tech Spec limits in Modes 1-5.</p> <p>o Greater than 1.0 microCurie per gram dose equivalent I-131 for more than 48 continuous hours per Chemistry analysis in Modes 1-5</p> <p><u>AND</u></p> <p>Load reduction or plant cooldown initiated in accordance with Tech Spec 3.4.8.</p> <p>o Dose equivalent I-131 in excess of Tech Spec Figure 3.4-1 per Chemistry analysis in Modes 1-5</p> <p><u>AND</u></p> <p>Load reduction or plant cooldown initiated in accordance with Tech Spec 3.4.8.</p> <p>(Continued)</p>	<p>1. Severe loss of fuel cladding.</p> <p>o Valid indication on any Reactor Building EMF reading greater than or equal to 1000 times background value.</p> <p>o Valid indication on EMF-48 reading greater than or equal to 1000 times background value.</p> <p>o Chemistry analysis indicates that primary coolant dose equivalent I-131 concentration is greater than or equal to 300 microCuries per ml.</p> <p>o Chemistry analysis indicates greater than or equal to 5% total fuel clad failures.</p> <p>o Chemistry analysis indicates an increase of greater than 1% fuel failures within 30 minutes.</p>	<p>1. Degraded core with possible loss of coolable geometry.</p> <p>o Plant conditions require entry into EP/1(2)/A/5000/2B2, Degraded Core Cooling.</p> <p>o Containment hydrogen concentration greater than or equal to 1.0%</p> <p><u>AND</u></p> <p>Hydrogen concentration increasing at a rate of greater than or equal to 0.1% per hour.</p> <p>o Valid indication on EMF-53A or 53B reading greater than or equal to 290 R/hr.</p> <p><u>END</u></p>	<p>1. Loss of 2 of 3 fission product barriers with potential for loss of the 3rd barrier. The 3 barriers are the fuel cladding, NC System and Containment.</p> <p>NOTE: To classify at this level, you must satisfy at least one condition from 2 of the 3 categories listed (A, B, C) and have the potential for satisfying at least one condition from the remaining category.</p> <p>A. Loss of fuel cladding barrier.</p> <p>o Chemistry analysis indicates greater than or equal to 20% total fuel clad failure.</p> <p>o Valid indication on EMF-53A or 53B reading greater than or equal to 1100 R/hr.</p>

(Continued)

END

CATAWBA NUCLEAR STATION
EMERGENCY ACTION LEVELS

CMIP-10
Enclosure 4.1
Page 5 of 27

EVENT 4.1.2 FUEL DAMAGE (continued)

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

o Specific activity
greater than 100/E
microCuries per
gram per Chemistry
analysis in Modes 1-5

AND

Load reduction or plant
cooldown initiated in
accordance with Tech
Spec 3.4.8.

END

o Plant conditions
require entry into
EP/1(2)/A/5000/2B1,
Inadequate Core
Cooling.

B. Loss of NC System
barrier.

o NC System leakage
greater than 50 gpm.

C. Loss of Containment
barrier.

o Incomplete Containment
integrity.

o Known Containment leakage
in excess of Tech Specs.

o Containment pressure
greater than or equal
to 60 psig.

o Containment hydrogen
concentration greater
than or equal to 9%.

END

CATAWBA NUCLEAR STATION
EMERGENCY ACTION LEVELS

CNIP-10
Enclosure 4.1
Page 6 of 27

EVENT 4.1.3 STEAM SYSTEM FAILURE

NOTIFICATION OF UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
<p>1. Steam line break which results in rapid depressurization of the secondary side.</p> <p>o Steam line depressurization resulting in Safety Injection or Main Steam Isolation.</p>	<p>1. Unisolable steam line break outside Containment with a S/G tube leak.</p> <p>o Unisolable steam line break outside Containment</p> <p style="text-align: center;"><u>AND</u></p> <p>Known S/G tube leak greater than 10 gpm</p> <p style="text-align: center;"><u>AND</u></p> <p>NC System subcooling greater than 0°F.</p> <p>o Unisolable steam line break outside Containment</p> <p style="text-align: center;"><u>AND</u></p> <p>Field monitoring teams detect activity at the Protected Area fence at greater than or equal to 2 mr/hr whole body.</p>	<p>1. Steam line break with a S/G tube leak greater than 50 gpm.</p> <p>o Steam line break inside Containment on the ruptured S/G</p> <p style="text-align: center;"><u>AND</u></p> <p>S/G tube leak greater than 50 gpm</p> <p style="text-align: center;"><u>AND</u></p> <p>Valid indication on EMF-53A or 53B reading greater than or equal to 290 R/hr.</p> <p>o Unisolable steam line break outside Containment on the ruptured S/G</p> <p style="text-align: center;"><u>AND</u></p> <p>S/G tube leak greater than 50 gpm.</p>	<p>N/A</p>

END

(Continued)

END

CATAMBA NUCLEAR STATION
EMERGENCY ACTION LEVELS

CMIP-10
Enclosure 4.1
Page 7 of 27

EVENT 4.1.3 STEAM SYSTEM FAILURE (Continued)

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

2. Steam line break with
failure of ECCS or
Main Steam Isolation.

o Steam line
depressurization
resulting in Safety
Injection signal

AND

Failure of both trains
of ECCS injection.

o Steam line
depressurization
resulting in Main
Steam Isolation
signal

AND

The failure of two
or more MSIVs to
close results in the
depressurization of
two or more S/Gs.

END

CATAWBA NUCLEAR STATION
EMERGENCY ACT LEVELS

CMIP-10
Enclosure 4.1
Page 8 of 27

EVENT 4.1.4 HIGH RADIATION/RADIOLOGICAL EFFLUENTS

NOTIFICATION OF UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
<p>1. Gaseous or liquid radiological effluents exceed Tech Spec limits.</p> <ul style="list-style-type: none"> o Gaseous radiological effluents exceed Tech Spec limits as determined by Radiation Protection calculations. o Valid indication on EMF-58 reading greater than or equal to 50 times the TRIP 2 setpoint. o Valid TRIP 2 alarm on EMF-49L or EMF-57 <p><u>AND</u></p> <p>Failure of the release path to automatically isolate.</p> <ul style="list-style-type: none"> o Liquid radiological effluents exceed Tech Spec limits as determined by Radiation Protection calculations. 	<p>1. High radiation levels or high airborne contamination.</p> <ul style="list-style-type: none"> o Valid indication on any area EMF reading greater than or equal to 1000 times background value. o Valid indication on EMF-41 reading greater than or equal to 1000 times background value. <p>2. Gaseous or liquid radiological effluents exceed 10 times Tech Spec limits.</p> <ul style="list-style-type: none"> o Valid indication on any of the following effluent monitors reading greater than or equal to 10 times the TRIP 2 setpoint: <ul style="list-style-type: none"> o EMF-35L o EMF-36L o EMF-37. <p>(Continued)</p>	<p>1. Accidental releases of gases.</p> <ul style="list-style-type: none"> o Valid indication on EMF-36L reading greater than or equal to 3.8×10^4 cpm. (See NOTE) o Valid indication on EMF-37 has increased by greater than or equal to 2.4×10^3 cpm over any 1 minute period. Refer to computer points P0129, P0130, P0131, P1822. (See NOTE) o Dose assessment team calculations project a dose rate at the Site Boundary of greater than or equal to 50 mr/hr whole body or 250 mr/hr thyroid. o Field monitoring team measurements determine the dose rate at the Site Boundary is greater than or equal to 50 mr/hr whole body or 250 mr/hr thyroid. 	<p>1. Accidental releases of gases.</p> <ul style="list-style-type: none"> o Valid indication on EMF-36L reading greater than or equal to 7.6×10^5 cpm. o Valid indication on EMF-36H reading greater than or equal to 3.5×10^2 cpm. o Valid indication on EMF-37 has increased by greater than or equal to 4.8×10^4 cpm over any 1 minute period. Refer to computer points P0129, P0130, P0131, P1822. o Dose assessment team calculations or field monitoring team measurements result in a 2 hour integrated dose projection at the Site Boundary of greater than or equal to 1 rem whole body or 5 rem thyroid. <p><u>END</u></p>

END

END

NOTE: This EMF setpoint is calculated based on Stability Class "G" meteorology, and a Unit Vent flowrate of 1.9×10^5 cfm. Calculations by the dose assessment team use actual meteorology and Unit Vent flowrate. Therefore, this EMF setpoint should not be used if dose assessment team calculations are available.

CATAWBA NUCLEAR STATION
EMERGENCY ACTION LEVELS

CMIP-10
Enclosure 4.1
Page 9 of 27

EVENT # 4.1.4 HIGH RADIATION/RADIOLOGICAL EFFLUENTS (continued)

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

o Valid indication on
EMF-58 reading greater
than or equal to 500
times the TRIP 2
setpoint.

o Valid indication on
EMF-49L or EMF-57
reading greater than or
equal to 10 times the
TRIP 2 setpoint

AND

Failure of the release
path to automatically
isolate.

o Radiological effluents
exceed 10 times Tech
Spec limits as
determined by
Radiation Protection
calculations.

END

CATAWBA NUCLEAR STATION
EMERGENCY ACTION LEVELS

CMFP-10
Enclosure 4.1
Page 10 of 27

EVENT 4.1.5 LOSS OF SHUTDOWN FUNCTIONS

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

N/A

1. Complete loss of any function needed to maintain core cooling in Modes 5 and 6.

o Failure of heat sink causes loss of Cold Shutdown conditions in Modes 5 and 6

AND

NC System subcooling cannot be maintained greater than 0°F.

(Continued)

1. Complete loss of any function needed for Hot Shutdown conditions in Modes 1-4.

o Failure of heat sink results in the inability to maintain Hot Shutdown (Mode 4)

AND

NC System subcooling cannot be maintained greater than 0°F.

o Inability to feed S/Gs from any source in Modes 1-3

AND

NC System subcooling cannot be maintained greater than 0°F.

(Continued)

1. Transient initiated by loss of CP and CN Systems followed by failure of heat removal capability for an extended period in Modes 1-4.

o Loss of CM/CF feedwater flow capability in Modes 1-4.

AND

CA flow cannot be established within 30 minutes

AND

NC System feed and bleed flow cannot be established or maintained.

(Continued)

EVENT 4.1.5 LOSS OF SHUTDOWN FUNCTIONS (continued)

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

2. Transient with failure of the Reactor Protection System to automatically initiate and complete a Rx trip which brings the Reactor subcritical (ATWS).

END

2. Transient requiring operation of shutdown systems with failure to trip (power generation continues).

- o Transient with failure of the Reactor Protection System to automatically initiate and complete a Rx trip which brings the Reactor subcritical (ATWS)

AND

Control rods cannot be manually tripped or inserted from the Control Room.

(Continued)

2. Transient requiring a Rx trip with failure to trip and failure of core cooling.

- o Transient with failure of the Reactor Protection System to automatically initiate and complete a Rx trip which brings the Reactor subcritical (ATWS)

AND

Actions taken per EP/1(2)/A/5000/2A1, Nuclear Power Generation/ATWS, fail to bring the Reactor subcritical

AND

Plant conditions require entry into EP/1(2)/A/5000/2B2, Degraded Core Cooling.

(Continued)

CATAWBA NUCLEONIC STATION
EMERGENCY ACTION LEVELS

CMIP-10
Enclosure 4.1
Page 12 of 27

EVENT # 4.1.5 LOSS OF SHUTDOWN FUNCTIONS (continued)

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

3. Inability to maintain Cold Shutdown with loss of Reactor Vessel Coolant Inventory in Modes 5 and 6.

o Failure of heat sink causes loss of Cold Shutdown conditions in Modes 5 and 6

AND

NC System level less than 11% and continues to decrease after initiation of NC System make-up.

o Failure of heat sink causes loss of Cold Shutdown conditions in Modes 5 and 6

AND

Lower Range RVLIS level decreasing after initiation of NC System make-up.

(Continued)

3. Loss of heat sink with subsequent core uncover in Modes 5 and 6.

o Failure of heat sink causes loss of Cold Shutdown conditions in Modes 5 and 6

AND

Lower Range RVLIS level indicates core is uncovered.

o Failure of heat sink causes loss of Cold Shutdown conditions in Modes 5 and 6

AND

Core Exit T/Cs indicate superheat at the core exit.

(Continued)

CATAWBA NUCLEA R TATION
EMERGENCY ACTION LEVELS

CMIP-10
Enclosure 4.1
Page 13 of 27

EVENT # 4.1.5 LOSS OF SHUTDOWN FUNCTIONS (continued)

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

o Failure of heat sink
causes loss of Cold
Shutdown conditions
in Modes 5 and 6

AND

Reliable NC System
level indication
unavailable

AND

Core exit T/Cs or
AP/1(2)/A/5500/19,
Loss of ND, Enclosure
3, indicate boiling
in core

AND

Available NC System
make-up flow is less
than applicable
value given in
AP/1(2)/A/5500/19,
Loss of ND,
Enclosure 4.

END

o Failure of heat sink
causes loss of Cold
Shutdown conditions
in Modes 5 and 6

AND

NC System level below
bottom range of
available level
indicators

AND

Available NC System
make-up flow is less
than applicable
value given in
AP/1(2)/A/5500/19,
Loss of ND,
Enclosure 4

AND

Emergency Coordinator
judgement that core
uncovery is imminent.

END

CATAWBA NUCLEAR STATION
EMERGENCY AC LEVELS

CMIP-10
Enclosure 4.1
Page 18 of 27

EVENT 4.1.6 LOSS OF POWER

NOTIFICATION OF UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
<p>1. Loss of offsite power in Modes 1-6.</p> <p>o Both A and B main bus lines de-energized in Modes 1-6.</p>	<p>1. Loss of offsite power and loss of all onsite AC power for greater than 1 minute but less than or equal to 15 minutes in Modes 1-4.</p> <p>o Both 4160V Essential Buses are de-energized for greater than 1 minute but less than or equal to 15 minutes in Modes 1-4.</p>	<p>1. Loss of offsite power and loss of all onsite AC power for greater than 15 minutes in Modes 1-4.</p> <p>o Both 4160V Essential Buses are de-energized for greater than 15 minutes in Modes 1-4.</p>	<p>1. Loss of offsite power and loss of all onsite AC power with total loss of S/G feed capability in Modes 1-4.</p>
<p>2. Loss of onsite AC power in Modes 1-4.</p> <p>o Both D/Gs are incapable (for greater than 2 hours) of powering the 4160V Essential Buses in Modes 1-4.</p>	<p>2. Loss of offsite power and loss of all onsite AC power for greater than 15 minutes in Modes 5 and 6.</p>	<p>(Continued)</p>	<p><u>AND</u></p> <p>Loss of CM/CF feedwater flow capacity</p>
<p>3. Loss of onsite AC power in Modes 5 and 6.</p> <p>o Both D/Gs are incapable (for greater than 8 hours) of powering the 4160V Essential Buses in Modes 5 and 6.</p>	<p>o Both 4160V Essential Buses are de-energized for greater than 15 minutes in Modes 5 and 6.</p>	<p><u>AND</u></p> <p>CA Flow cannot be established within 30 minutes.</p>	

(Continued)

END

CATAMBA NUCLEAR STATION
EMERGENCY ACTION LEVELS

GMIP-10
Enclosure 4.1
Page 15 of 27

EVENT # 4.1.6 LOSS OF POWER

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

3. Loss of all vital DC power for greater than 1 minute but less than or equal to 15 minutes in Modes 1-4.

o Vital DC Buses EDA, EDD, EDE and EDF de-energized for greater than 1 minute but less than or equal to 15 minutes in Modes 1-4.

2. Loss of all vital DC power for greater than 15 minutes in Modes 1-4.

o Vital DC Buses EDA, EDD, EDE and EDF de-energized for greater than 15 minutes in Modes 1-4.

END

4. Loss of all vital DC power for greater than 15 minutes in Modes 5 and 6.

o Vital DC Buses EDA, EDD, EDE and EDF de-energized for greater than 15 minutes in Modes 5 and 6.

END

EVENT # 4.1.7 FIRES AND SECURITY ACTIONS

NOTIFICATION OF UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
1. Fire within the Plant (see NOTE) that takes more than 10 minutes to extinguish.	1. Fires potentially affecting safety systems needed for current operating mode.	1. Fire compromising the functions of shutdown systems.	1. Any major fire which could cause massive damage to the Unit.
2. Security threat.	o Observation of a fire that could adversely affect safety systems needed for current operating mode.	o Observation of a fire that defeats both trains (or the single operable train) of safety systems needed for current operating mode.	o Fire requiring evacuation of the Control Room
o Discovery of a bomb within the Site Boundary.	o Fire requiring evacuation of the Control Room	o Fire requiring evacuation of the Control Room	<u>AND</u> Control of shutdown systems <u>cannot</u> be established from any plant location.
o Civil disturbance (hostile).	<u>AND</u> Control of shutdown systems has been established or is in the process of being established from the Auxiliary Shutdown Panels.	<u>AND</u> Control of shutdown systems <u>cannot</u> be established from the Auxiliary Shutdown Panels	(Continued)
o Intrusion/attempted intrusion (Protected Area).	(Continued)	<u>AND</u> Control of shutdown systems has been established or in the process of being established from the Standby Shutdown Facility.	
o Hostage situation/extortion.			
o Security threat as determined by Shift Supervisor/Emergency Coordinator and Security.			
<u>END</u>		(Continued)	

NOTE: Plant is defined as Auxiliary Building, Turbine Building, Service Building, Reactor Building, Diesel Generator Rooms, Doghouses, Spent Fuel Building, Standby Shutdown Facility, RN Pumphouse and Monitor Tank Building.

EVENT 4.1.7 FIRES AND SECURITY ACTIONS (continued)

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

2. Ongoing security compromise.

o Adversaries commandeer an area of the Plant but do not control any vital areas.
(See NOTES 1 and 2)

o Discovery of a breached barrier caused by intrusion or sabotage in a vital area.
(See NOTE 2)

o Discovery of a bomb within the Protected Area.

o Ongoing security compromise as determined by Emergency Coordinator and Security.

END

2. Imminent loss of physical control of the Plant.
(See NOTE 1)

o Physical attack on the Plant (see NOTE 1) which leads to the imminent occupancy of the Control Room and Auxiliary Shutdown Panels.

o Discovery of a bomb within a vital area.
(See NOTE 2)

END

2. Loss of physical control of the Plant. (See NOTE 1)

o Physical attack on the Plant (see NOTE 1) has resulted in occupation of the Control Room and Auxiliary Shutdown Panels.

END

NOTE: 1) Plant is defined as Auxiliary Building, Turbine Building, Service Building, Reactor Building, Diesel Generator Rooms, Doghouses, Spent Fuel Building, Standby Shutdown Facility, BN Pumphouse and Monitor Tank Building.

2) For classification purposes, consider the BN Pumphouse as a vital area.

EVENT # 4.1.8 SPENT FUEL DAMAGE

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

N/A

1. Damage to spent fuel with release of radioactivity.

CONTAINMENT

- o Valid TRIP 2 alarm on 1EMF-17 (2EMF-2) (Reactor Bldg Refuel Bridge)

AND

Valid indication on any of the following effluent monitors reading greater than or equal to 10 times the TRIP 2 setpoint:

- o EMF-35L
- o EMF-36L
- o EMF-37.

(Continued)

1. Major damage to spent fuel with release of radioactivity.

CONTAINMENT

- o Valid TRIP 2 alarm on 1EMF-17 (2EMF-2) (Reactor Bldg Refuel Bridge)

AND

Valid indication on EMF-36L reading greater than or equal to 3.8 E4 cpm. (See NOTE)

- o Valid TRIP 2 alarm on 1EMF-17 (2EMF-2) (Reactor Bldg Refuel Bridge)

AND

Dose assessment team calculations project a dose rate at the Site Boundary of greater than or equal to 50 mr/hr whole body or 250 mr/hr thyroid.

(Continued)

NOTE: This EMF setpoint is calculated based on Stability Class "G" meteorology and a Unit Vent flowrate of 1.9 E5 cfm. Calculations by the dose assessment team use actual meteorology and Unit Vent flowrate. Therefore, this EMF setpoint should not be used if dose assessment team calculations are available.

CATAWBA NUCLEAR STATION
EMERGENCY ACTION LEVELS

GMIP-10
Enclosure 4.1
Page 19 of 27

EVENT 4.1.8 SPENT FUEL DAMAGE (continued)

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

SPENT FUEL POOL

- o Valid TRIP 2 alarm on 1EMF-15 (2EMF-4) (Spent Fuel Bldg Refuel Bridge)

AND

Valid indication on any of the following effluent monitors reading greater than or equal to 10 times the TRIP 2 setpoint:

- o EMF-35L
- o EMF-36L
- o EMF-37.

END

SPENT FUEL POOL

- o Valid TRIP 2 alarm on 1EMF-15 (2EMF-4) (Spent Fuel Bldg Refuel Bridge)

AND

Valid indication on EMF-36L reading greater than or equal to 3.8 E4 cpm. (See NOTE)

- o Valid TRIP 2 alarm on 1EMF-15 (2EMF-4) (Spent Fuel Bldg Refuel Bridge)

AND

Dose assessment team calculations project a dose rate at the Site Boundary of greater than or equal to 50 mr/hr whole body or 250 mr/hr thyroid.

END

NOTE: This EMF setpoint is calculated based on Stability Class "G" meteorology and a Unit Vent flowrate of 1.9 E5 cfm. Calculations by the dose assessment team use actual meteorology and Unit Vent flowrate. Therefore, this EMF setpoint should not be used if dose assessment team calculations are available.

CATAWBA NUCLEAR STATION
EMERGENCY ACTION LEVELS

CMIP-10
Enclosure 4.1
Page 20 of 27

EVENT # 4.1.9 NATURAL DISASTERS AND OTHER HAZARDS

NOTIFICATION OF UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
<p>1. Earthquake felt in plant and detected by seismic monitoring instruments.</p> <p>o Valid "Peak Shock Annunciator" alarm.</p> <p>o Valid alarm on "Strong Motion Accelerograph."</p>	<p>1. Earthquake greater than OPE level.</p> <p>o Valid "OBE EXCEEDED" annunciator alarm (IAD-4, B-8).</p>	<p>1. Earthquake greater than SSE level.</p> <p>o Earthquake intensity greater than 0.15g Horizontal or 0.10g Vertical (SSE level).</p>	<p>1. Any major internal or external event (e.g. aircraft impact, earthquakes substantially beyond design basis) which could cause massive damage to the Unit.</p>
	(Continued)	<p>2. Low water level.</p>	<u>END</u>
<p>2. Low water level.</p> <p>o Lake level less than or equal to 557.5 ft</p> <p style="text-align: center;"><u>AND</u></p> <p>SNSWP is available.</p>		<p>o Lake level less than or equal to 557.5 ft</p> <p style="text-align: center;"><u>AND</u></p> <p>SNSWP is not available.</p>	
(Continued)		(Continued)	

EVENT # 4.1.9 NATURAL DISASTERS AND OTHER HAZARDS (continued)

NOTIFICATION OF UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
<p>3. Any tornado/severe weather within the Site Boundary.</p>	<p>2. Damage from tornado, severe weather, missile explosion, aircraft crash or train derailment causing a loss of any function needed for Cold Shutdown conditions in Modes 5 and 6.</p>	<p>3. Damage from tornado, severe weather, missile explosion, aircraft crash, or train derailment causing a loss of any function needed for Hot Shutdown conditions in Modes 1-4.</p>	
<p>o Tornado/severe weather onsite</p>	<p>o Damage to plant equipment causing the inability to maintain Cold Shutdown conditions in Modes 5 and 6</p>	<p>o Damage to plant equipment results in the inability to establish or maintain Hot Shutdown conditions in Modes 1-4</p>	
<p><u>AND</u></p>	<p><u>AND</u></p>	<p><u>AND</u></p>	
<p>Physical damage observed to equipment/structures within the Site Boundary needed for plant operation.</p>	<p>NC System subcooling cannot be maintained greater than 0°F.</p>	<p>NC System subcooling cannot be maintained greater than 0°F.</p>	
<p>4. Aircraft crash.</p>			
<p>o Aircraft crash within the Site Boundary.</p>			
<p>(Continued)</p>	<p>(Continued)</p>	<p>(Continued)</p>	

CATAWBA NUCLEAR STATION
EMERGENCY ACTION LEVELS

CHP-10
Enclosure 4.1
Page 22 of 27

EVENT # 4.1.9 NATURAL DISASTERS AND OTHER HAZARDS (continued)

NOTIFICATION OF UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
5. Train derailment onsite. o Train derailment resulting in physical damage to equipment/structures within the Site Boundary needed for plant operation.	3. Release of toxic or flammable gas in Modes 5 and 6. o Entry of an uncontrolled toxic or flammable gas into any plant area which prevents the operation of systems needed to maintain Cold Shutdown conditions in Modes 5 and 6	4. Release of toxic or flammable gas in Modes 1-4. o Entry of uncontrolled toxic or flammable gas into any plant area which prevents the operation of systems needed to establish or maintain Hot Shutdown conditions in Modes 1-4	
6. Explosion within the Site Boundary. o Explosion within the Site Boundary resulting in physical damage to equipment/structures needed for plant operation or injuries to personnel.	<u>AND</u> NC System subcooling <u>cannot</u> be maintained greater than 0°F.	<u>AND</u> NC system subcooling <u>cannot</u> be maintained greater than 0°F.	
7. Release of toxic or flammable gases. o Release of toxic or flammable gas resulting in personnel injury or evacuation within the Protected Area.	<u>END</u>	<u>END</u>	

END

EVENT § 4.1.10 OTHER ABNORMAL PLANT CONDITIONS

NOTIFICATION OF UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
<p>1. ECCS initiated.</p> <p>o Valid S/I signal verified by redundant indications</p> <p><u>AND</u></p> <p>ECCS injection into the vessel has occurred.</p>	<p>1. Evacuation of Control Room.</p> <p>o Evacuation of the Control Room required</p> <p><u>AND</u></p> <p>Control of shutdown systems has been established or is in the process of being established from the Auxiliary Shutdown Panels.</p>	<p>1. Evacuation of Control Room.</p> <p>o Evacuation of the Control Room required</p> <p><u>AND</u></p> <p>Control of shutdown systems cannot be established from the Auxiliary Shutdown Panels</p>	<p>1. Evacuation of Control Room.</p> <p>o Evacuation of the Control Room required</p> <p><u>AND</u></p> <p>Control of shutdown systems cannot be established from any plant location.</p>
<p>2. Abnormal NC System parameters.</p> <p>o Tech Spec figure 2.1-1 limits exceeded in Modes 1 and 2.</p> <p>o NC System pressure has exceeded 2735 psig in Modes 1-5.</p>	<p>2. Most or all annunciator capability lost in Modes 1-4.</p> <p>o Loss of 50% or more of the Control Room annunciators in Modes 1-4 for greater than 15 minutes.</p>	<p><u>AND</u></p> <p>Control of shutdown systems has been established or is in the process of being established from the Standby Shutdown Facility.</p>	<p>2. Other Unit conditions exist that in the judgement of the Emergency Coordinator create the possibility of a release of large amounts of radioactivity in a short period of time.</p>
<p>(Continued)</p>	<p>3. Other Unit conditions exist that in the judgement of the Emergency Coordinator warrant entry into the Alert classification.</p>	<p>2. Other Unit conditions exist that in the judgement of the Emergency Coordinator warrant declaration of Site Area Emergency.</p>	<p><u>END</u></p>
	<p><u>END</u></p>	<p><u>END</u></p>	

EVENT # 4.1.10 OTHER ABNORMAL PLANT CONDITIONS (continued)

NOTIFICATION OF UNUSUAL EVENT	ALERT	SITE AREA EMERGENCY	GENERAL EMERGENCY
3. Loss of Containment integrity requiring shutdown by Tech Specs in Modes 1-4.			
o Any automatic Containment isolation valve which is open, inoperable and unisolable in Modes 1-4			
<u>AND</u>			
Load reduction or plant cooldown initiated in accordance with Tech Specs 3.6.1.1 and 3.6.3.			
o Both airlock doors of a single airlock are inoperable in Modes 1-4			
<u>AND</u>			
Load reduction or plant cooldown initiated in accordance with Tech Specs 3.6.1.1 and 3.6.1.3.			
o Any Containment penetration fails leak test per Tech Spec in Modes 1-4			
<u>AND</u>			
Load reduction or plant cooldown initiated in accordance with Tech Specs 3.6.1.1 and 3.6.1.2.			

(Continued)

EVENT # 4.1.10 OTHER ABNORMAL PLANT CONDITIONS (continued)

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

4. Loss of ESF or Fire
Protection System function.

- o Both trains of an ESF
function or ESF
actuation system
found inoperable (if
caused by fire, see
Event #4.1.7, under
Alert classification)

AND

Load reduction or plant
cooldown initiated in
accordance with Tech
Specs.

- o Loss of all main Fire
Protection System pumps.

(Continued)

EVENT # 4.1.10 OTHER ABNORMAL PLANT CONDITIONS (continued)

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

5. Significant loss of
assessment or
communication capability.

- o Loss of all onsite
meteorological
instrumentation

AND

Inability to contact the
National Weather Service
for backup source of
meteorological data.

- o Loss of all radio and
telephone communication
capability with all
offsite agencies.

- o Loss of 50% or more of
the Control Room
annunciators in Modes
5 and 6 for greater
than 15 minutes.

(Continued)

EVENT # 4.1.10 OTHER ABNORMAL PLANT CONDITIONS (continued)

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL EMERGENCY

6. Transportation of a contaminated, injured individual from the site to an offsite medical facility.

o Injured contaminated individual is transported offsite with a contamination level of greater than 5000 dpm/100 cm². (See NOTE)

o Internal contamination requiring medical assessment/treatment.

o External exposure requiring medical assessment/treatment.

7. Other Unit conditions exist that in the judgement of the Shift Supervisor/Emergency Coordinator warrant increased awareness of local authorities.

END

NOTE: 5000 dpm/100 cm² corresponds to 150 cpm (above background) beta-gamma as measured with a thin window pancake GM detector at one half inch from the body surface.