



Commonwealth Edison
1400 Opus Place
Downers Grove, Illinois 60515

March 21, 1990

Dr. Thomas E. Murley, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Byron Station Unit 1
DC Battery 111
Operability Calculations
NRC Docket No. 50-454

Dear Dr. Murley:

Dr. S. Saba of your Electrical Systems Branch has requested a copy of calculations verifying the operability of the Unit 1 DC Battery 111 with only 57 of its 58 cells functional. A copy of the Architect Engineer Calculations and Byron Onsite Review notes are attached and fulfills this request.

Please address any questions that you or your staff may have concerning this response to this office.

Respectfully,

A handwritten signature in black ink, appearing to read "T. K. Schuster".
T. K. Schuster
Nuclear Licensing Administrator

Attachment

cc: Dr. S. Saba - NRR
P. C. Shemanski - NRR
Resident Inspector - Byron

0811T/TSK:wj

9003300078 900321
PDR ADDCK 05000454
P PDC

floor 11 Add: S. Saba 1/1 Ltr end

This On Site Review is being written to address the operability of the 111 Battery with only 57 cells. To maintain a bus voltage of 105 VDC an individual cell voltage of 1.84 is required. Sargent and Lundy performed a calculation to verify for an individual cell voltage of 1.84 that a NCX-1200 battery would meet the operability requirements(This calculation is attached). Some questions with the calculation are addressed in this On Site Review.

- 1) In the calculation a correction factor for temperature was used for 69 F. Technical Specification 4.B.2.1.2-b.3 defines 60 F as the minimum electrolyte temperature. With 60 F as the minimum temperature the correction factor per IEEE 450 would have been 1.11. With the correction factor for 60 F the calculation at the bottom of page 3 of 6 of the attached S&L letter is:

$$4.5 * 1.11 * 1.15 * 1.25 = 7.18$$

Since the NCX-1200 battery has 8 positive plates This calculation proves the battery voltage would remain above 105 during the load profile.

- 2) With the temperature correction factor for 60 F the calculation with the battery crosstied(page 4 of 6 of the S&L letter) is:

$$5.8 * 1.11 * 1.25 = 8.04$$

Since the NCX-1200 battery has only 8 positive plates the battery would not maintain the bus voltage greater than 105 VDC with the crosstie breakers closed. To insure this does not occur the Crosstie breakers will be taken OOS. The Crosstie will only be used if the actual electrolyte temperature is greater than 65 F. With the correction factor for 65 F:

$$5.8 * 1.08 * 1.25 = 7.83$$

The NCX-1200 battery would maintain 105 VDC during the load profile with the battery crosstied above 65 F.

- 3) The calculation in the S&L letter are not based on the maximum load profile in the UFSAR. S&L used the load profile reflected in the DC ELMS program. The values in the DC ELMS program reflects actual plant load. The DC ELMS program is a documented program of actual plant loads.

A concern was brought up as to would the battery meet the load profile defined in the UFSAR. The following calculation assumed 1.84 volts per cell and 60 F electrolyte temperature. The design margin correction factor was not used in this calculation since the DC ELMS program shows that BUS 111 is below the UFSAR load profile.

BATTERY 111 LOAD PROFILE WITHOUT CROSSTIE

60 F cell voltage 1.84

LOAD	CHANGE IN LOAD	AMPS/POS	POSITIVE PLATES
617		111	5.56
		TOTAL	5.56
517		79.4	7.77
354	-263	79.9	-3.29
		TOTAL	4.48
617		43	14.35
354	-263	43.5	-6.04
152	-202	50	-4.04
		TOTAL	4.27
617		28	22.04
354	-263	28	-9.39
152	-202	30.5	-6.62
55	-97	43	-2.26
		TOTAL	3.77

5.56(positive plates) * 1.11(temperature correction for 60 F) * 1.25(aging factor for 80% minimum capacity) = 7.71(positive plates)

Since the NCX-1200 has 8 positive plates battery 111 would maintain the bus voltage above 105 VDC with 57 cells using the UFSAR load profile without the battery crosstied.

This On Site review finds that the 111 Battery is operable with 57 cells.

Client	Commonwealth Edison Co.	
Project	Byron Station Unit I	
Proj. No.	B226-03	Equip. No. 1Dc01E

Prepared by	B.A.Kutchik	Date 5-4-89
Reviewed by	A.G.Runde	Date 6-27-89
Approved by	D.R.Galvin	Date 6-27-89

Revision Summary

Rev 0 First Issue by B.A. Kutchik p1-6

SYSTEM:DC

SUBSYSTEM:N/A

COMPONENT NUMBER:1Dc01E

Purpose: The purpose of this calculation is to ensure Battery 1Dc01E has sufficient capacity to supply its loads when operating with 57 cells instead of 58 cells.

References:

- 1) ELMS- DC, Byron Unit 1, File# 1Dc01E.E01
- 2) Byron /Braidwood Calculation 19-D-B, Rev. OTD5R2
- 3) Gould Inc. Curves TC-107011 + TC-107628+TC107172
- 4) Battery Testing & Surveillance Guidelines, Byron/Bdwg, July 23, 1987
- 5) IEEE-450, 1987
- 6) Byron Station Technical Specifications 3/4.8.2, 3.8.2.1c+ 4.P.D.13

Conclusion: Based upon the worksheets in this calculation, for both operating scenarios, ~~saf~~ Battery 1Dc01E has sufficient capacity to ~~saf~~ operate with 57 cells.

This Calculation will be accurate for the loading as of 5-4-89.

→ 7) Telephone Conversation Memos by B.A. Kutchik
to P Kajmo of GNB 6-9-89
to E. Widmer of GNB 6-15-89
(Attachments A+B)

Review Method

This calculation has been reviewed by a detailed review of the original calculation. Andrew J Runde 6/27/89

Calc. For		Calc. No. 14-1, 15
<input checked="" type="checkbox"/> Safety-Related		Rev. C Date
		Page 2 of 6
Client	Prepared by	Date
Project	Reviewed by	Date
Proj. No. 8226-03 Equip. No.	Approved by	Date

Battery 1D201E has two operating modes

- ① Normal - loads as tabulated in ELMS-DC
- ② Crosstie - loads as tabulated in ELMS-DC plus 63A.
(Ref. 296)

To maintain a minimum operating voltage of 105Vdc & operate with 57 cells the final volts per cell is required to be 1.84.

$$57 \times 1.84 = 104.9 \text{ V}$$

Pages 3+4 of this calc provide the sizing worksheets for both loading scenarios.

Pages 5+6 provide the ELMS-DC load data for both loading scenarios. Note: the 63 A was added to the load data in ELMS to provide a consistent presentation.

The 175 vpc - 1/minute rate for the NCR-1200 is 1360A. This value has been obtained from GNB. (Ref. 7) ~~Excluded~~
To obtain readings for 1 hour or less GNB recommends the use of their curve TC-10762B (published for that purpose) with the 1 minute rates published in their table. (Ref. 7).

Pg 30+10
E326-03

Normal Operation

CELL SIZING WORKSHEET

(For Ref. See ESC-291)

Project Bryant - 1DX515 Date 5-4-89 Page 3Lowest Expected Minimum Cell Voltage / 104 Cell Min Govt Cell Type NCK-1200 Sized By 84K
Electrolyte Temp °F 69

(1) Period	(2) Load (amperes)	(3) Change in Load (amperes)	(4) Duration of Period (minutes)	(5) Time to End of Section (minutes)	(6) Capacity at T Min Rate (6A) Amps/Pos (R _T) or (6B) K Factor (K _T)	(7) Required Section Size (3) (6A) + Positive Plates or (3) x (6B) = Rated Amp Hr	
						(3) Pos Values	(3) Neg Values

Section 1 - First Period Only - If A2 is greater than A1 go to Section 2

1	A1-499.1	A1-0.4991	M1-1	T-M1-1	Sec 1 Total	4.5	***
---	----------	-----------	------	--------	-------------	-----	-----

Section 2 - First Two Periods Only - If A3 is greater than A2 go to Section 3

1	A1-499.1	A1-0.4991	M1-1	T-M1-M2-2	79.4	6.09	
2	A2-31.7	A2-A1-31.7	M2-2	T-M2-2	71.9	5.35	
					Sec Sub Tot	6.23	1.22
					2 Total	5.44	

Section 3 - First Three Periods Only - If A4 is greater than A3 go to Section 4

1	A1-499.1	A1-0.4991	M1-1	T-M1-M2-M3-3	7.3	11.61	
2	A2-31.7	A2-A1-31.7	M2-2	T-M2-M3-2	4.2	-4.31	
3	A3-2.7	A3-A2-2.7	M3-2	T-M3-2	5.6	-3.42	
					Sec Sub Tot	11.61	-7.74
					3 Total	3.45	

Section 4 - First Four Periods Only - If A5 is greater than A4 go to Section 5

1	A1-499.1	A1-0.4991	M1-1	T-M1-M2-M3-M4-4	28	17.83	
2	A2-31.7	A2-A1-31.7	M2-2	T-M2-M3-M4-2	2.5	-5.99	
3	A3-2.7	A3-A2-2.7	M3-2	T-M3-M4-2	5.5	-1.52	
4	A4-0.7	A4-A3-0.7	M4-1	T-M4-1	0.5		
					Sec Sub Tot	17.83	-7.27
					4 Total	3.56	

Section 5 - First Five Periods Only - If A6 is greater than A5 go to Section 6

1	A1-499.1	A1-0.4991	M1-1	T-M1-M2-M3-M4-M5-5	5.5	5.5	
2	A2-31.7	A2-A1-31.7	M2-2	T-M2-M3-M4-M5-2	2.5	-5.99	
3	A3-2.7	A3-A2-2.7	M3-2	T-M3-M4-M5-2	5.5	-1.52	
4	A4-0.7	A4-A3-0.7	M4-1	T-M4-M5-1	0.5		
5	A5-0.1	A5-A4-0.1	M5-1	T-M5-1	0.1		
6	A6-0.05	A6-A5-0.05	M6-1	T-M6-1	0.05		
					Sec Sub Tot	5.5	
					5 Total	5.5	

Section 6 - First Six Periods Only - If A7 is greater than A6 go to Section 7

1	A1-499.1	A1-0.4991	M1-1	T-M1-M2-M3-M4-M5-M6-6	5.5	5.5	
2	A2-31.7	A2-A1-31.7	M2-2	T-M2-M3-M4-M5-M6-2	2.5	-5.99	
3	A3-2.7	A3-A2-2.7	M3-2	T-M3-M4-M5-M6-2	5.5	-1.52	
4	A4-0.7	A4-A3-0.7	M4-1	T-M4-M5-M6-1	0.5		
5	A5-0.1	A5-A4-0.1	M5-1	T-M5-M6-1	0.1		
6	A6-0.05	A6-A5-0.05	M6-1	T-M6-1	0.05		
					Sec Sub Tot	5.5	
					6 Total	5.5	

Section 7 - First Seven Periods Only - If A8 is greater than A7 go to Section 8

1	A1-499.1	A1-0.4991	M1-1	T-M1-M2-M3-M4-M5-M6-M7-7	5.5	5.5	
2	A2-31.7	A2-A1-31.7	M2-2	T-M2-M3-M4-M5-M6-M7-2	2.5	-5.99	
3	A3-2.7	A3-A2-2.7	M3-2	T-M3-M4-M5-M6-M7-2	5.5	-1.52	
4	A4-0.7	A4-A3-0.7	M4-1	T-M4-M5-M6-M7-1	0.5		
5	A5-0.1	A5-A4-0.1	M5-1	T-M5-M6-M7-1	0.1		
6	A6-0.05	A6-A5-0.05	M6-1	T-M6-M7-1	0.05		
7	A7-0.02	A7-A6-0.02	M7-1	T-M7-1	0.02		
					Sec Sub Tot	5.5	
					7 Total	5.5	

Random Equipment Load Only (if needed)

R	AR+	AR 0+	MR+	T-MR+			***
---	-----	-------	-----	-------	--	--	-----

Maximum Section Size (8) 4.5 + Random Section Size (9) .110 = Uncorrected Size (10) 4.5
 US (11) 4.5 + Temp Corr (12) .105 + Design Marg (13) .15 x Aging Factor (14) 1.05 x (15) 0.79

When the cell size (15) is greater than a standard cell size, the next larger cell is required.

Required cell size (16) 7 (A) - Positive Plates(B) - Ampere Hours Therefore cell (17) NCA is required
/200

Rev

SARGENT & LUNDY
ENGINEERS

E.I.C.

N.Y. 100-1

Date 4-26-63

R206-03

Private

CELL SIZING WORKSHEET
(For Ref. See ESC-291)

Project Bryer DC CIE

Date 5-4-69 Page 4

Lowest Exported Minimum Cell Min. Charge Cell Type AGCF-1000 Sized By BAK
Electrolyte Temp °F 64 Cell Voltage 18.4

(1)	(2)	(3)	(4)	(5)	(6)	(7)	
						Capacity at T Min Rate (RA) Amps/Pos (R _T) or (BFR) Factor (K _T)	Required Section Size (3) (6A) = Positive Plates or (3) (6B) = Rated Amp. Hrs Pos Values Neg Values
Period	Load (amperes)	Change in Load (amperes)	Duration of Period (minutes)	Time to End of Section (minutes)			

Section 1 - First Period Only - If A1 is greater than A1 go to Section 2

1	A1-S ₁ -1	A1-0-S ₁ -1(M ₁)	/	T-M ₁ -1	/	5.06	***
					Sec 1 Total	5.06	***

Section 2 - First Two Periods Only - If A3 is greater than A2 go to Section 3

1	A1-S ₂ -1	A1-0-S ₂ -1(M ₁)	/	T-M ₁ -M ₂ -3	79.4	2.08	
2	A2-S ₂ -5	A2-A1-S ₂ -5(M ₂)	/	T-M ₂ -5	29.5	-2.45	
					Sec Sub Tot	2.52	-2.45

2 Total 47.3

Section 3 - First Three Periods Only - If A4 is greater than A3 go to Section 4

1	A1-S ₃ -1	A1-0-S ₃ -1(M ₁)	/	T-M ₁ -M ₂ -M ₃ -28	4.3	13.7	
2	A2-S ₃ -5	A2-A1-S ₃ -5(M ₂)	/	T-M ₂ -5	-1.2	-3.4	
3	A3-S ₃ -5	A3-A2-S ₃ -5(M ₃)	/	T-M ₃ -5	-2	-3.4	
					Sec Sub Tot	13.7	-7.8

3 Total 5.11 ***

Section 4 - First Four Periods Only - If A5 is greater than A4 go to Section 5

1	A1-S ₄ -1	A1-0-S ₄ -1(M ₁)	/	T-M ₁ -M ₂ -M ₃ -M ₄ -28	5.7	20.07	-6.7
2	A2-S ₄ -5	A2-A1-S ₄ -5(M ₂)	39	T-M ₂ -5-M ₃ -M ₄ -28	5.5	-5.11	
3	A3-S ₄ -5	A3-A2-S ₄ -5(M ₃)	36	T-M ₃ -5-M ₄ -28	5.5	-1.58	
4	A4-S ₄ -5	A4-A3-S ₄ -5(M ₄)	36	T-M ₄ -28	4.3	-1.58	

4 Total 36.67 -14.42

5 Total 5.0

Section 5 - First Five Periods Only - If A6 is greater than A5 go to Section 6

1	A1	A1-0	M ₁	T-M ₁ -M ₂			
2	A2	A2-A1	M ₂	T-M ₂	M ₂		
3	A3	A3-A2	M ₃	T-M ₃ -M ₁ -M ₂			
4	A4	A4-A3	M ₄	T-M ₄ -M ₁ -M ₂ -M ₃			
5	A5	A5-A4	M ₅	T-M ₅ -M ₁ -M ₂ -M ₃ -M ₄			
6	A6	A6-A5	M ₆	T-M ₆ -M ₁ -M ₂ -M ₃ -M ₄ -M ₅			

6 Total 5.0 ***

Section 6 - First Six Periods Only - If A7 is greater than A6 go to Section 7

1	A1	A1-0	M ₁	T-M ₁ -M ₂			
2	A2	A2-A1	M ₂	T-M ₂	M ₂		
3	A3	A3-A2	M ₃	T-M ₃	M ₃		
4	A4	A4-A3	M ₄	T-M ₄	M ₄		
5	A5	A5-A4	M ₅	T-M ₅	M ₅		
6	A6	A6-A5	M ₆	T-M ₆	M ₆		

6 Total 5.0 ***

Section 7 - First Seven Periods Only - If A8 is greater than A7 go to Section 8

1	A1	A1-0	M ₁	T-M ₁ -M ₂			
2	A2	A2-A1	M ₂	T-M ₂	M ₂		
3	A3	A3-A2	M ₃	T-M ₃	M ₃		
4	A4	A4-A3	M ₄	T-M ₄	M ₄		
5	A5	A5-A4	M ₅	T-M ₅	M ₅		
6	A6	A6-A5	M ₆	T-M ₆	M ₆		
7	A7	A7-A6	M ₇	T-M ₇			

7 Total 5.0 ***

Random Equipment Load Only (if needed)

R	AR+	AR-0	MR+	T-MR-			***
---	-----	------	-----	-------	--	--	-----

Maximum Section Base (4) 5.0 + Random Section Size (5) 0.0 = Uncorrected Base (UB) (10) 5.0UB (11) 5.0 x Temp Corr (12) 1.0 x Design Margin (13) 1.0 x Aging Factor (14) 1.25 x (15) 2.50

When the cell size (16) is greater than a standard cell size, the next larger cell is required.

(A) - Positive Plates

Required cell size (16) 5.0 ^{is acceptable} (B) - Ampere Hours Therefore cell (17) 5.0 ^{is required}

SARGENT & LUNDY -- ELM3-DC VER 1.20
BATTERY SIZING CALCULATION

Work sheet output using IEEE Std 485 worksheet format

UTILITY : COMMONWEALTH EDISON
STATION : BYRON

PROJECT NO. ~~1000~~
UNIT 1

Calc 14-D15
Rev 0
Pg. Seite
8206-03

	1	2	3	4	5	6	7	
PER- IOD	LOAD IN AMPERES	CHANGE IN LOAD	DURATION OF PERIOD	TIME TO END OF SECTION	MIN RATE	MIN RATE	SIZE (3)/(6)	
10D					R(T)AMP/POS	R(T)AMP/POS	POS. PLATES	
LOWEST EXPECTED ELECTROLYTE TEMPERATURE EG. Degrees F	MIN CELL VOLT:	CELL MFG:	CELL TYPE:	SIZED BY:				
TEMPERATURE EG. Degrees F	1.81 Voc	GNB (GLOB.D)	NCX					
1 A 1= 499.1 A 1- Ø = 499.1 M1= 1 T=100 1=100 2= 30 R(T)= 85.0 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	
1 A 1= 499.1 A 1- Ø = 499.1 M1= 1 T=100 1=100 2= 30 R(T)= 85.0 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	T=100 1=100 2= 29 R(T)= 86.3 3.892	
2 A 1= 499.1 A1- Ø = 499.1 M1= 1 T=100 1=100 2= 30 R(T)= 85.0 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	
3 A 1= 499.1 A1- Ø = 499.1 M1= 1 T=100 1=100 2= 30 R(T)= 85.0 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	
3 A 1= 499.1 A1- Ø = 499.1 M1= 1 T=100 1=100 2= 30 R(T)= 85.0 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	
4 A 1= 499.1 A1- Ø = 499.1 M1= 1 T=100 1=100 2= 30 R(T)= 85.0 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	
4 A 1= 499.1 A1- Ø = 499.1 M1= 1 T=100 1=100 2= 30 R(T)= 85.0 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	A 2= 311.5 A 2-A 1= -187.6 M 2= 29 T=100 1=100 2= 29 R(T)= 86.3 3.892	
MAXIMUM SECTION SIZE = UNDERRATED SIZE 3.90								
US X TEMP. CORR. X DESIGN MARGIN X BEARING FACTOR = MINIMUM REQUIRED SIZE								
3.90 X 1.05 X 1.15 X 1.25 X 5.87								
MINIMUM REQUIRED BATTERY SIZE ACTUAL BATTERY SIZE REMAINING MARGIN								
6 POSITIVE PLATES 6 POSITIVE PLATES 36.2 %								

MAXIMUM SECTION SIZE = UNDERRATED SIZE 3.90

US X TEMP. CORR. X DESIGN MARGIN X BEARING FACTOR = MINIMUM REQUIRED SIZE
3.90 X 1.05 X 1.15 X 1.25 X 5.87

MINIMUM REQUIRED BATTERY SIZE ACTUAL BATTERY SIZE REMAINING MARGIN
6 POSITIVE PLATES 36.2 %

Normal Operation

SARGENT & LUNDY -- ELMS-DC VER 1.20
BATTERY SIZING CALCULATION

Work sheet output using IEEE std 485 Worksheet format

UTILITY : COMMONWEALTH EDISON
STATION : BYRON

PROJECT NO. 7944-30
UNIT 1

BATTERY NAME : 111 1DC@IE

DATE : BAK

PAGE : 1 OF 1

PERIOD	LOAD IN AMPERES	CHANGE IN LOAD	DURATION OF PERIOD	TIME TO END OF SECTION	T MIN RATE R(T) AMP/POS	SIZE (3) / (6) POS. PLATES
--------	-----------------	----------------	--------------------	------------------------	-------------------------	----------------------------

LOWEST EXPECTED ELECTROLYTE TEMPERATURE 69. Degrees F MIN CELL VOLT: 1.81 Voc CELL MFG: GNB (GOULD) CELL TYPE: NCK SIZED BY:

1 A 1= 562.1 A 1- 0 = 562.1 M1= 1 T=M 1+..+M 2= 30	R(T)= 128.0	4.392
	TOTAL =	4.392
2 A 1= 562.1 A1- 0 = 562.1 M1= 1 T=M 1+..+M 2= 30	R(T)= 85.0	6.613
A 2= 374.5 A 2-A 1= -187.6 M 2= 29 T=M 2+..+M 2= 29	R(T)= 86.3	-2.175
	TOTAL =	4.438
3 A 1= 562.1 A1- 0 = 562.1 M1= 1 T=M 1+..+M 3=120	R(T)= 46.0	12.220
A 2= 374.5 A 2-A 1= -187.6 M 2= 29 T=M 2+..+M 3=119	R(T)= 46.0	-4.059
A 3= 191.7 A 3-A 2= -182.7 M 3= 90 T=M 3+..+M 3= 90	R(T)= 52.0	-3.448
	TOTAL =	4.714
4 A 1= 562.1 A1- 0 = 562.1 M1= 1 T=M 1+..+M 4=240	R(T)= 29.0	18.384
A 2= 374.5 A 2-A 1= -187.6 M 2= 29 T=M 2+..+M 4=239	R(T)= 29.1	-0.445
A 3= 191.7 A 3-A 2= -182.7 M 3= 90 T=M 3+..+M 4=210	R(T)= 32.5	-5.523
A 4= 123.7 A 4-A 3= -68.0 M 4=120 T=M 4+..+M 4=120	R(T)= 46.0	-1.478
	TOTAL =	5.836

MAXIMUM SECTION SIZE = UNCORRECTED SIZE (US)
5.84 * 5.84

US X TEMP. CORR. X DESIGN MARGIN X AGING FACTOR = MINIMUM REQUIRED SIZE
5.84 X 1.05 X 1.00 X 1.25 = 7.65

MINIMUM REQUIRED BATTERY SIZE 8 POSITIVE PLATES	ACTUAL BATTERY SIZE 8 POSITIVE PLATES	REMAINING MARGIN
--	--	------------------

INFORMATION ONLY

Calc 19-D-15

Rev 0

Pg 6 of 6

8226-U3

Crossline Operation

JUN 27 1989

SARGENT & LUNDY
ENGINEERS

TRANSMITTAL OF QA RECORDS

To: QA RECORDS SECTION, Rm. 31V 33From D. P. GALANISDivision EPEDProject No. 4391 Date 6-27-89

Routing

Name	Room No.
D.J.GRANDYS	ZSP49

Transmittal herewith are QA records in the quantities indicated below:

8
(Pages)CALC # 19 D-15
REV. O Hard Copy Records

S&L Aperture

Microfiche

Jackets

(FOR QAD USE ONLY)

8

If project number above is non-billable or closed,
charge this transaction to 8236-D3.

NOTE: Each record shall be identified by project number, name or acronym of the division responsible for the record, file index number, title, date (approval date or date of issue). The system, subsystem, and component number, if applicable, and the safety-related identification, if required, shall also be identified.

(FOR QAD USE ONLY)

- Attached records have been microfilmed, indexed, and stored.
- Transmitted quantity not received as indicated.
- Transmitted records not properly identified.
- Transmitted records not legible for filming.
- Transmitted records not silver halide.
- Records scheduled for processing.
- Other:

Correct and Resubmit

Signature A. Liff
(QAD Records Section)Date JUN 27 1989

SARGENT & LUNDY

MEMORANDUM OF
TELEPHONE CONVERSATION

August 1989

To: Carol H. Rude

Date: 6-9-89

Time: 3:00

Person Called: Paul Kajiwara of GNB
(Name) (Company)

Person Calling: Barb Kutchik of S&L
(Name) (Company)

Project: Byron / Bradwood Project No. B226-03

Subject Discussed: NC-X - 1200 Battery

Summary of Discussion, Decisions and Commitments:

GNB Drawing TC-107172 indicates the I_{max} rate to 1.75V pc for the subject battery to be 1360A. The catalog data indicates 1306A.

Paul informed me that 1306A is a typo, 1360 A is the correct value.

cc: B.G. Treece

A. Runde

Barb Kutchik
Signature

File: 7A

PAGE 1 OF 1

Memorandum of Telephone Conversation

SARGENT & LUNDY

Date 6-15-89 Time 11:30

Person Called Everett Widner	Company GNB (215) 750-2748
Person Calling Barbara Kutchik	Company S&L (312) 269-7018
Project Byron & Braidwood	Project No. 8226-03

Subject Discussed
Battery Type NCX-1200 Characteristic Curves TC-107011

Summary of Discussion Decisions and Commitments

I asked Mr. Widner if he would explain why the two curves do not provide the same values for areas in which they overlap (i.e., below a 1 hour duration).

He stated that curve TC-107628 was developed using a pilot cell, whereas the curve is utilized for the entire NCX line, and therefore, inaccuracies can be expected. In part due to the effects of intercell resistances at the higher discharge currents (lower time durations).

In addition, the TC-107628 curve was developed to enable GNB battery users to obtain intermediate discharge currents (e.g., a 1/8 minute rate or 6 minute rate). Since this curve is based upon percent of the 1 minute rate to 1.75vpc, GNB recommends that the 1 minute rate be obtained from their published tables and not be extracted from the curves. Again, at high discharge rates, various resistances can significantly affect the data.

Finally, curve TC-107011 also utilized a pilot cell, although the curve is for both the NAX and NCX cell lines, and the same explanations apply.

:scr

cc A. Runde


File 7A

B. A. Kutchik
Signature

B. A. Kutchik

SL-F713 10 84-F3

ATTACHMENT A, PAGE 2 of 6
 BATTERY TESTING & SURVEILLANCE
 GUIDELINES, PROJECT NO. 7500-94
 Date: 7-22-87
 TC - 1070II



ATTACHMENT A, PAGE 1 of 6

BATTERY TESTING & SURVEILLANCE
GUIDELINES, PROJECT NO. 7500-94

Date: 7-23-87

TC-107268

TO 175 VPC

% OF 1 MINUTE RATE

10 175 VPC

10 175 VPC