

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: U.S. Nuclear Regulatory Commission
Advisory Committee On Reactor Safeguards

Title: SUBCOMMITTEE MEETING ON ADVANCED
PRESSURIZED WATER REACTORS

Docket No.

LOCATION: Bethesda, Maryland

DATE: Tuesday, April 3, 1990

PAGES: 1. - 217

**ACRS Office Copy - Retain
for the Life of the Committee**

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950

9004050034 900403
PDR ACRS
T-1791 FDC

1
2
3
4 PUBLIC NOTICE BY THE
5 UNITED STATES NUCLEAR REGULATORY COMMISSION'S
6 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
7

8 DATE: Tuesday, April 3, 1990
9
10
11
12

13 The contents of this transcript of the
14 proceedings of the United States Nuclear Regulatory
15 Commission's Advisory Committee on Reactor Safeguards,
16 (date) Tuesday, April 3, 1990,

17 as reported herein, are a record of the discussions recorded at
18 the meeting held on the above date.

19 This transcript has not been reviewed, corrected
20 or edited, and it may contain inaccuracies.
21
22
23
24
25

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 ***

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5
6 Subcommittee Meeting on Advanced

7 Pressurized Water Reactors

8
9 Conference Room P-110

10 7920 Norfolk Avenue

11 Bethesda, Maryland

12
13 Tuesday, April 3, 1990

14
15 The above-entitled proceedings commenced at 8:30
16 o'clock a.m., pursuant to notice, J. Carroll,
17 committee chairman, presiding.

18
19 PRESENT FOR THE ACRS SUBCOMMITTEE:

20 I. Catton	R. Singh
21 C. Michelson	C. Miller
22 D. Ward	S. Ritterbusch
23 J. Wylie	E. Kennedy
24 M. El-Zeftaway	R. Matzie

1 PARTICIPANTS:

2 R. Turk

3 W. Fox

4 K. Scarola

5 R. Jaquith

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

P R O C E E D I N G S

[8:30 a.m.]

MR. CARROLL: Good morning. The meeting will now come to order. This is a meeting of the Advisory Committee on Reactor Safeguards, Subcommittee on Advance Pressurized Water Reactors.

I'm J. Carroll, Subcommittee chairman. The other ACRS members in attendance, on my right, Charlie Wylie, on my left, Carl Michelson, Ivan Catton, and Dave Ward.

The purpose of this meeting is to review the licensing review basis document developed by combustion engineering for the System 80 + Standard Design.

Med El Zeftaway is the cognizant ACRS staff member for this meeting. The rules for participation in today's meeting have been announced as part of the notice of this meeting, previously published in the Federal Register of March 15, 1990.

A transcript of the meeting is being kept and will be available as stated in the Federal Register notice. It is requested that each speaker first identify himself or herself and speak with sufficient clarity and volume so that he or she can be readily heard.

We have received no written comments or requests for oral statements from members of the public for this meeting.

1 As you can see from the revised agenda before you,
2 today's meeting is basically to review the Combustion
3 licensing review basis document. We have another meeting on
4 this same general subject scheduled for April 26th where
5 both General Electric and Combustion will be in to talk more
6 about licensing review basis documents.

7 The point being, the Commission has asked ACRS in
8 their SECY 89-311 to review both of these documents and
9 provide them with comments and in particular, to look at the
10 two documents side by side and determine whether the
11 approach taken is "consistent."

12 It is probably worthwhile for the committee
13 members as we go through today to take a look at 89-311
14 because it does outline other things in this general area
15 that the Commission has asked us to look at. And it's part
16 of Med's mailing of March 20th.

17 Do any members of the subcommittee have any
18 comments they'd like to make at this time? So, Carl, I
19 guess you and I since you have ABWR, and I kind of co-chair
20 the 26th meeting and find out whether consistency exists.

21 Okay. With that, we'll proceed with the staff's
22 presentation.

23 [Slide.]

24 MR. MICHELSON: Perhaps before the staff tells
25 about the details of this or maybe you're going to tell us.

1 I'm still a little puzzled as to whether or not these
2 licensing review basis documents are going to be approved by
3 the staff or used for information only or just what will be
4 their status once one finally agrees as to what the
5 licensing basis is.

6 MR. SINGH: I think the final decision will be
7 with the Commission. We are in the process of preparing a
8 Commission paper.

9 MR. MICHELSON: What is your recommendation as to
10 how they be treated?

11 MR. SINGH: Right.

12 MR. MICHELSON: Well, I asked a question. I say,
13 what will be your recommendation?

14 MR. SINGH: With regard to the LRB?

15 MR. MICHELSON: Yes.

16 MR. SINGH: We are going to recommend the
17 Commission to improve the LRB with certain comments.

18 MR. MICHELSON: So, it will become part of the
19 certification docket then?

20 MR. SINGH: Yes, sir.

21 MR. MICHELSON: It will become a part of the
22 commitments?

23 MR. SINGH: Yes, sir.

24 MR. MICHELSON: Okay. That isn't presently the
25 status as I understand it, the ABWR licensing basis

1 agreement.

2 MR. SINGH: Well, you know, ABWR, LRB was issued
3 way back before the Commission guidance stance, as you know.

4 MR. MICHELSON: So, we'll go back, I guess, and as
5 far as you know, we'll go back and also make that document a
6 part of the docket?

7 MR. SINGH: We have not decided to do that.

8 MR. MICHELSON: You haven't decided yet?

9 MR. SINGH: No, no. We have not been given the
10 specific direction by the Commission what to do with it,
11 ABWR LRB.

12 MR. MICHELSON: Okay.

13 MR. SINGH: We haven't told what to do about the
14 LRB.

15 MR. MICHELSON: It's one thing to comment on a
16 document if it becomes a part of the requirements. It's
17 another if it's just an information-type document.

18 MR. CARROLL: Well, maybe it would be useful to
19 the subcommittee to hear from you, sort of a history of
20 LRB's or how did this all come to be? I guess, my
21 understanding is, it's kind of an ad hoc document. You
22 can't go to a NUREG someplace and find out what the content
23 and format of a acceptable LRB is. It's kind of an evolving
24 thing. Is that a fair characterization?

25 MR. SINGH: I don't know all of the history behind

1 the LRB. I do know some things though. I think the idea
2 was to propose or discuss with the staff way back in 1986
3 time frame, you know, between General Electric and the
4 staff. And it basically evolved through the years.

5 I have been project manager on System 80+ for the
6 last 10 months. The first LRB with commitment to do a --
7 was submitted to the staff in March of last year.

8 And we have used that a couple of times in
9 discussions on a number of occasions. And then in the
10 meantime, we had specific guidance from the Commission what
11 to do in the LRB document. And that is where I was going to
12 start my presentation.

13 After the Commission guidance came in December
14 SRM's, December 15, 1989, SRM's, we went over the Commission
15 guidance. -- provided revised input on January 22, 1990 and
16 I believe you all have copies of that.

17 MR. CARROLL: Now, which staff requirements?

18 MR. SINGH: December 15, 1989.

19 MR. CARROLL: 1989?

20 MR. SINGH: Yes, sir.

21 MR. MICHELSON: I assume that's a SECY 89-311?

22 MR. SINGH: Right.

23 MR. CARROLL: Well, that doesn't tell me much. I
24 mean it starts from the premise that something called a
25 licensing review basis document exists. What was the

1 guidance as to what belongs in it?

2 MR. SINGH: Yeah, the guidance from the Commission
3 was that LRB document ought to have two things. One is,
4 they ought to cover all of the policy issues involving that
5 design and the Commission will make decisions for them
6 before the final LRB is issued. That's one.

7 The second thing is they ought to have a -- with
8 every -- these two major points were made in the SRM and
9 they went back and put those things into the LRB, the
10 proposed LRB document and presented it to us in January.

11 MR. MICHELSON: Now, when you say you look at, I
12 think you said, compare it with the EPRI requirements?

13 MR. SINGH: Yes.

14 MR. MICHELSON: When you do that, that means the
15 entire lightwater requirements document, all the chapters?
16 Is that right.

17 MR. SINGH: That's my understanding of the
18 Commission guidance.

19 MR. MICHELSON: Okay.

20 Thank you.

21 MR. SINGH: So we have the revised input from CE,
22 the staff review is virtually complete. We have drafted a
23 Commission Paper.

24 MR. CARROLL: Let me go back. Revised input. I
25 guess you alluded to the fact that Combustion had submitted

1 something earlier that was also called a Licensing Review
2 Basis Document?

3 MR. SINGH: Yes.

4 MR. CARROLL: And it was a commitment to do what?

5 MR. SINGH: In general, earlier versions of the
6 LRB document contained a commitment of what the scope of the
7 design will be, what are the major technical issues involved
8 and what is proposed revisions regarding those issues.

9 MR. CATTO : Okay. So that was the earlier
10 versions of this. The revision you received on 1/22/90 was
11 all of that plus the points that the Commission had made
12 about comparison with EPRI requirements, and so forth.

13 MR. SINGH: And policy issues.

14 MR. CARROLL: Okay.

15 MR. SINGH: That is exactly what the revised
16 policy input is.

17 MR. CARROLL: Okay. But I am correct in saying
18 there is no document I can go to if I want to get into the
19 business of designing a reactor for certification on my
20 kitchen table, I can't go to a document and it will tell me
21 what you expect to see in a Licensing Review Basis Document.

22 MR. SINGH: No. I don't know of any. Like I say,
23 this idea of Licensing Review Basis Document has evolved
24 over the years and I do not know exactly how it started out.

25 MR. CARROLL: Okay.

1 MR. SINGH: So, the staff review is virtually
2 complete. We have prepared a Commission Paper which is in
3 concurrence at this moment. That paper is going to go to
4 the Commission soon and to the ACRS. We plan to meet with
5 you again, and the Commission, followed by guidance from the
6 Commission and then we will issue the final LRB document.
7 We expect sometime this summer, if not sooner, to issue the
8 final LRB document.

9 MR. CARROLL: Now, is there an intention on the
10 part of the staff, once you have been through one of these,
11 this one in particular, to provide some guidance for future
12 Licensing Review Basis Documents? For example, for the
13 passive plants or whatever?

14 MR. SINGH: There is another one -- as a matter of
15 fact, the Commission had asked us to propose how to
16 streamline the process for the review and approval of the
17 LRB document as well as applications for design
18 certifications. And we are going to present a paper to the
19 Commission. That paper has been drafted and is going to go
20 to the Commission on the 14th of this month, which would
21 have a process, measured steps for reviewing and approving
22 an LRB document, for example, for passive plants and it
23 would have some major steps that the staff is going to
24 follow in reviewing the design certification application.
25 So, you would see those things in that part of the

1 Commission Paper. We will be providing copies to you, of
2 course.

3 MR. MICHELSON: So we can expect to see that
4 document before the 14th of this month?

5 MR. SINGH: No, not before the 14th. It is due to
6 the EDO on the 14th.

7 MR. MICHELSON: We will see it when it goes to the
8 Commission, of course.

9 MR. SINGH: Of course, yes. And there is a
10 Commission meeting, as you know, on the 27th of this month
11 and those aspects are expected to done.

12 MR. CARROLL: Does that suggest, Carl, that we
13 might want to think about waiting until we get that to have
14 our joint meeting?

15 MR. MICHELSON: Well, yes. I didn't realize they
16 were putting together such a document, of course.

17 MR. SINGH: You may have seen SECY 90-065.

18 MR. MICHELSON: No. What's the subject?

19 MR. SINGH: SECY 90-065 had the proposed process
20 and a schedule for the review of ABWR.

21 MR. MICHELSON: I have seen that already, I'm
22 quite sure. That's the one with a very busy one-page chart
23 of where everything goes.

24 MR. SINGH: Right.

25 MR. MICHELSON: Now that really is --

1 MR. SINGH: In that paper, we made a commitment
2 that since the process looks like it's going to delay all
3 the reviews, we offered to streamline the process and still
4 meet the Commission's objectives. We said that in that
5 paper.

6 MR. MICHELSON: By that you mean you are going to
7 stay on the original schedules if you streamline that
8 process? Is that what you are suggesting?

9 MR. SINGH: We are trying to be close --

10 MR. MICHELSON: The original schedule for ABWR
11 being the end of this year, completion.

12 MR. SINGH: Right. But, you know, a lot of other
13 things have happened.

14 MR. MICHELSON: Well, I think the staff has been
15 blaming the process for the delay when in reality that's not
16 where the problem really is. I hope that's taken care of
17 because at the rate we are going -- we haven't even gotten
18 all of Module 1 done, and between now and December you are
19 not going to get through all the rest of that on ABWR. I
20 don't care what kind of funny drawing you make of the
21 process. So it's unrealistic to think that the process is
22 the problem. The problem is just getting the review work
23 done.

24 MR. SINGH: Like I said, a streamlined process
25 with a better estimate of the schedules and review are going

1 to be coming in the Commission Paper this month.

2 MR. MICHELSON: Now, you are going to the
3 Commission, then, on the 27th to discuss this new paper --

4 MR. SINGH: Plus the 15 issues.

5 MR. MICHELSON: -- and I would say yes, in all
6 likelihood we ought to wait until after that's available and
7 make it a part of our meeting. We only need about a half a
8 day on the comparison of the two and the other half of the
9 day can be spent looking at the final -- what was thought to
10 be the final process, and so forth. I assume the Commission
11 might want our comments on it anyway.

12 MR. SINGH: Yes.

13 MR. MICHELSON: So, let's reschedule our meeting
14 until such time as this paper is available, assuming it is
15 in the near-term. I mean, it really is that imminent?

16 MR. SINGH: The Mission Director has to be given
17 the paper ten days before they meet with us on April 27th.

18 MR. MICHELSON: Okay.

19 MR. SINGH: That's how the date came about.

20 MR. CARROLL: And this goes to the EDO on the --

21 MR. SINGH: Fourteenth.

22 MR. CARROLL: And he, presumably, is going to have
23 it off his desk and on the way to the Commission by the --

24 MR. WARD: Well, when are you going to get the
25 paper?

1 MR. MICHELSON: I hope on the 14th. If it gets to
2 us on the 14th, that should be enough time.

3 MR. CARROLL: Do we want to see what comments the
4 Commission has?

5 MR. MICHELSON: It is going to get a briefing that
6 day.

7 MR. CARROLL: It sounds like tight timing to me.

8 MR. WARD: If you really don't get it on that day,
9 about the 14th, then it is a problem.

10 MR. SINGH: Thank you.

11 [Slide.]

12 MR. KENNEDY: Good morning, gentlemen. My name is
13 Ernie Kennedy. I'm here from Combustion Engineering. I'm
14 the Manager of Nuclear Systems Licensing. Let point out
15 that today is the first time we've been to talk to you as
16 ABB Combustion Engineering, Nuclear Power. As most of you
17 may know, Combustion Engineering was acquired by Boveri last
18 January. Our designation now as ABB Combustion Nuclear
19 Power, Combustion Engineering Incorporated still exists as a
20 U.S. Corporation and it is under that name that we are
21 applying for design certification.

22 You'll begin to see the ABB logo on our
23 presentations from here on out as we adopt the corporate
24 identity. That is something new for you. In general, we
25 would like to structure the agenda today a little

1 differently from what's in front of you. We're certainly
2 very flexible.

3 I would like to very briefly introduce you to the
4 LRB and perhaps add some light to the questions you've been
5 asking on the history of the LRB and how we got to where we
6 are today.

7 MR. MICHELSON: Excuse me. Before we get into
8 that, as long as you've put in a little pitch for your new
9 affiliation, maybe you could explain to me to what extent
10 the System 80 Plus might be able to take advantage of the
11 expertise provided by this new affiliation. In other words,
12 how will the foreign expertise be brought in, if at all,
13 into System 80 Plus?

14 MR. KENNEDY: Well, the first large advantage to
15 us is, last year, we committed to certify an entire plant,
16 not simply the nuclear steam supply system as we did on
17 System 80. The biggest advantage to us right now of being
18 part of the ABB corporate family is that ABB is very active
19 in turbine generators, balance of plant, architect
20 engineering services for the rest of the plant.

21 It gives us an in-house capability to provide that
22 extended scope. It also provides us with large corporate
23 resources in research and development. The ABB group
24 believes in basic research and development and has a very
25 large program. Is there anything that you'd like to add to

1 that?

2 [No response.]

3 MR. KENNEDY: Basically, those are the two points.

4 MR. MICHELSON: Well, really, though, as far as
5 the Nuclear Island portion of that, I guess it would be the
6 same as if the affiliation hadn't existed. There won't be
7 any additional real engineering thought going into System 80
8 Plus from your foreign affiliate.

9 MR. KENNEDY: From the Nuclear Island, the content
10 will still be largely combustion engineering content. ABB's
11 expertise in that area is in boiling water reactors, large,
12 and there's not a whole lot of overlap there, so it will be
13 largely combustion engineering content.

14 MR. MICHELSON: Thank you.

15 MR. KENNEDY: On the agenda today, the LRB, as
16 will see, discusses a number of technical issues as well as
17 policy and process issues. In order to put those in
18 perspective, we are going to walk you through an overview of
19 the design and talk about those issues in the context of the
20 design. We'd like to leave this meeting not only with you
21 having an understanding of the LRB, but some general
22 understanding of the design.

23 We, of course, will be expecting to come back to
24 this Committee several times in the course of the review and
25 talk about the design in much greater detail. Today, we'll

1 simply try to give you a high level overview. Let me also
2 point out that Ed Sharer, our director of nuclear licensing,
3 whom you may remember from some years back, was hoping to
4 make it to the meeting today, but a group of ABB management
5 showed up at our offices this morning, and he's unable to
6 make it today. He does send his apologies for not being
7 here today.

8 [Slide.]

9 MR. KENNEDY: Again, our objectives, very briefly,
10 are to obtain your comments from this meeting and any later
11 meetings on our LRB and to review the System 80 Plus design
12 features with you. A little history of the LRB, to go to
13 your question:

14 We first proposed our LRB back in July of 1987.
15 That LRB went through several revisions before the issuance
16 of Part 52, the Standardization and Certification Rule.
17 This really was a break point in how our LRB was structured.
18 Before this, our LRB discussed largely the process for
19 certification and a number of policy issues.

20 Part 52 settled that. Part 52 defined the process
21 and settled some policy issues; for example, prior to this
22 point we were still trying to certify the nuclear steam
23 supply system. Part 52 says you can only certify an
24 essentially complete plant. That settled the issue.

25 We revised our LRB after the issuance of Part 52

1 to incorporate the Part 52 requirements. We took out a lot
2 of the procedural steps that used to be in our LRB because
3 they were covered by Part 52. We committed to the complete
4 plant and there were several revisions in this timeframe.

5 As Robbie Singh pointed out, there were two staff
6 requirements memoranda in December of 1989 where the
7 Commission said they would like to see comparisons of the
8 EPRI requirements. They would like to see some policy
9 issues. We have revised our LRB after the staff
10 requirements memoranda, the latest revision in January of
11 1990, and that's the version that we are discussing here
12 today. So, yes, it has evolved and it has changed. Those
13 are really the two milestones that have driven us.

14 MR. CARROLL: This is probably an inappropriate
15 question, but do you have any sense as to how close your LRB
16 is to the GE one?

17 MR. KENNEDY: We started out being very practical.
18 We took the GE LRB and almost xeroxed it.

19 MR. CARROLL: Which was about a year earlier?

20 MR. KENNEDY: Yes. Since that time, mainly in the
21 area of technical issues, issues which the staff in a number
22 of forms has asked us to address in the LRB, we have added
23 issues to the LRB. Also, the General Electric LRB was back
24 in this timeframe before Part 52. It does discuss process.
25 We don't need to discuss that anymore; we can simply

1 reference Part 52.

2 MR. CARROLL: They have not done what you have
3 done with the advent of Part 52.

4 MR. KENNEDY: Not to my knowledge.

5 MR. CARROLL: We'll get to that one.

6 MR. KENNEDY: Since our's has not been approved,
7 we've been revising it. I don't believe General Electric
8 has revised their's, once it was approved. There are a
9 number of other documents, I think, that document staff
10 agreements, but they did not revise their LRB.

11 MR. MICHELSON: Now, when you say their's was
12 approved, I think you're using that term rather loosely.

13 MR. KENNEDY: Yes.

14 MR. MICHELSON: Okay, it's not in any sense a
15 formal approval.

16 MR. KENNEDY: I believe -- I may be speaking out
17 of turn here, but I believe there was one letter, but as far
18 as any legal standing of the LRB, I'm not aware of any.

19 MR. MICHELSON: I'm quoting from the August 7th
20 letter from Murley to General Electric which was the so-
21 called approval. It says, "The licensing review basis
22 represents our understanding of certain approaches which GE
23 proposed and committed to follow in the ABWR design and
24 license application design in order to permit the review to
25 proceed efficiently until final Commission positions and

1 staff requirements are defined and implemented."

2 In other words, it's a gentleman's agreement that
3 you're heading in the right direction.

4 MR. KENNEDY: That is my understanding.

5 MR. MICHELSON: That's about all it appeared to
6 be. Since then, of course, we're going to have some new
7 thoughts about what these are, but at that time, it was not
8 approved in the sense of regulatory approvals.

9 [Slide.]

10 MR. KENNEDY: I understand. That brings us to
11 today. Given Part 52, what do we see as the purpose of the
12 LRB? Well, we believe it serves three primary roles right
13 now. One is to implement Part 52 -- not to duplicate it,
14 but to implement the Part 52 process; to define a schedule
15 for both the submittal of our application and the staff
16 review so that we can work to a common schedule. Thirdly,
17 to identify important issues that we in the staff need to
18 address during the technical review of the application.

19 Those, right now, are the functions we see being
20 served by our LRB.

21 [Slide.]

22 MR. KENNEDY: This is a slide, a very busy slide
23 right here which the staff has shown to the ACRS on a number
24 of occasions. This is the staff flow chart for design
25 certification. What I wanted to point out is that in the

1 lefthand side here in the discussion of the LRB, we had
2 hoped to be at this point, ACRS Review of the LRB, after
3 completing staff review.

4 The staff still has our LRB under review, so we're
5 not quite there yet, but we thought it was still worthwhile
6 to come talk to the ACRS because, although we don't have the
7 staff review completed, I think I can say that I don't know
8 of any substantive disagreements that we have with the staff
9 that can't be resolved between us. I believe we're very
10 close.

11 MR. MICHELSON: Could we just interrupt a moment
12 and ask the staff when they think their review will be
13 completed?

14 MR. SINGH: The review of the LRB document is
15 virtually complete. It is going -- we have drafted a
16 recommendation paper.

17 MR. MICHELSON: Is that the same Commission paper
18 we talked about a little earlier?

19 MR. SINGH: Right.

20 MR. MICHELSON: Okay, it will be in there?

21 MR. SINGH: I'm sorry. I talked about several
22 Commission papers. There is a Commission paper --

23 MR. MICHELSON: The one that's going to be out on
24 April 14th?

25 MR. SINGH: No, it's not the same Commission

1 paper.

2 MR. MICHELSON: You mean then, even if we hold a
3 meeting on the 27th, we still don't have the staff's
4 position on the LRB?

5 MR. SINGH: We may not.

6 MR. MICHELSON: I don't think we would want to
7 meet until we do.

8 MR. CARROLL: You're talking about 9016?

9 MR. SINGH: EPRI 27.

10 MR. MICHELSON: I assume from what I just heard
11 that the staff is going to prepare some kind of an approval
12 letter for the CE's proposed LRB; is that right?

13 MR. SINGH: Right.

14 MR. MICHELSON: It's that letter that I would like
15 to think that we had before we discuss the differences
16 between these two.

17 MR. CARROLL: Let me see if I can say it for you:
18 I think what he's saying, Carl, is that until the process of
19 getting back Commission views on 9016 is complete, they're
20 not going to be able to complete their letter on Combustion
21 LRB; is that right?

22 MR. SINGH: That's right, because many of the
23 issues are common.

24 MR. MICHELSON: Yes, that's true. I'm asking the
25 question, though; until we do have that letter, do we want

1 to have a Subcommittee meeting? You know the Subcommittee
2 meeting is coming up shortly and it's not clear that even on
3 the 14th of April that that letter will yet be available.

4 MR. SINGH: I can't give you a date when the
5 Commission letter will go to the Commission.

6 MR. MICHELSON: We don't want to look at it but
7 once, and we'd like to know, so I guess we just have to
8 postpone that meeting until later.

9 MR. CARROLL: We're in that loop also because the
10 Commission has asked us to comment on 9016 and we haven't
11 sent our comments in yet.

12 MR. MICHELSON: Our's are getting close to
13 completion, though, at least most of the items.

14 MR. CARROLL: I hope.

15 [Slide.]

16 MR. KENNEDY: Let me, in very general terms, talk
17 about what's in our LRB. First, our LRB describes the scope
18 of the System 80 Plus design. You'll hear a little bit more
19 about that later, but it is a complete plan. The LRB then
20 discusses the schedule that we are working for to achieve
21 design certification.

22 The milestones are for us to complete our
23 application -- to complete the modules of our application by
24 the end of this year. We are shooting for final design
25 approval by December of '91 which is consistent with the

1 schedule of the staff requirements memorandum and we're
2 targeting for design certification a year after that at the
3 end of 1992.

4 [Slide.]

5 MR. KENNEDY: Jus to remind you of an acronym here
6 that we have been using, our application, the safety
7 analysis report that we refer to is CESSAR-DC, the
8 Combustion Engineering Standard Safety Analysis Report
9 Design Certification. CESSAR-F was the document which you
10 approved, or which the NRC approved for our System 80
11 design. We're referring to this one as CESSAR-DC.

12 MR. CARROLL: You're going to have to get clever
13 and somehow or other work Asea Brown Boveri into all of
14 that, too.

15 MR. KENNEDY: We really haven't quite figured out
16 how to do that. It gets somewhat unwieldy.

17 MR. MICHELSON: Just to be sure I understood what
18 you just said, the only document you want to certify is
19 actually CESSAR-DC and not anything earlier?

20 MR. KENNEDY: Correct.

21 [Slide.]

22 MR. KENNEDY: What we have done is, we have been
23 submitting portions of our application in modules. These
24 modules; what we did is, we took our existing System 80
25 document, our CESSAR-F and we began to amend it as we

1 incorporated design changes. So, the document has been
2 essentially under continuous revision. We began this in
3 November 1987 with the first submittal, and as you can see,
4 we continued that through the end of 1989.

5 I would point out that in March of 1989, you begin
6 to see us expanding into areas which were not part of
7 CESSAR-F. We began to implement the entire plant approach
8 in our March 1989 submittal. You begin to see a balance of
9 plant systems containment buildings. In December of 1989,
10 we began to submit our PRA methodology and our Level 1 PRA
11 results and also we begin to include our resolution, our
12 technical resolution to the USIs and GSIs, the Generic
13 Safety Issues and Unresolved Safety Issues.

14 MR. MICHELSON: Excuse me. What's a Sabotage
15 Projection Program?

16 MR. KENNEDY: That should be protection.

17 MR. MICHELSON: I thought maybe you had something
18 else in mind.

19 [Slide.]

20 MR. KENNEDY: We have three remaining submittals
21 scheduled. This month, we will be supplying an additional
22 input to our USI/GSI resolutions and will be submitting our
23 ECCS and Containment Analysis descriptions and results. In
24 August of this year, we will complete the safety analyses;
25 we will complete the Level 3 PRA and our severe accident

1 analyses, seismic methods and complete the building layouts
2 for the plant.

3 Then at the end of this year, December of 1990, we
4 expect to send in the rest of the material, including the
5 technical specifications, the inspections tests and analyses
6 that are required by Part 52 and the Maintenance and
7 Reliability guidelines which the staff has requested as a
8 part of the certification application. We hope to finish
9 those by the end of the month.

10 MR. CARROLL: Are those guidelines part of Part
11 52?

12 MR. KENNEDY: I don't believe maintenance and
13 reliability guidelines are mentioned specifically in Part
14 52.

15 MR. CARROLL: But the staff just thinks this is a
16 good idea?

17 MR. SINGH: Excuse me; let me clarify that for
18 you. Commission sent an SRM back, I believe, in July August
19 timeframe last year with respect to ABWR. Commission wanted
20 to know when the staff expects the maintenance and
21 reliability criteria document from GE, okay? Maintenance
22 and reliability program, reliability issue and design
23 issues; they are mentioned in Part 52.

24 But it doesn't say like it's shown in the slide,
25 but the -- obviously the Commission intended to have some of

1 these, and it is said in the SRL.

2 MR. CARROLL: All right. On the issue of USIs and
3 GSIs, what's your understanding of what you have to commit
4 to? I read it somewhere on the plane yesterday. Does it
5 exist?

6 MR. KENNEDY: The words, I believe -- I think I
7 can quote them relatively accurately -- is to provide a
8 technical resolution to all of the unresolved safety issues
9 and to the median and high priority generic safety issues as
10 documented in NUREG 0933, six months before the date of the
11 application.

12 MR. CARROLL: Now, the date of the application is
13 what?

14 MR. KENNEDY: We sent in an application for design
15 certification, a formal letter, in March of 1989. The staff
16 still has not officially set up a docket number for me. I'd
17 have to ask the lawyers whether or not that counts as a date
18 of application, but that's beside the point.

19 We are using Supplement 9 to NUREG 933 which is
20 after that date. Supplement 10 has been issued. We are
21 looking at that to see if there are any substantial changes,
22 but our submittals were made to Supplement 9 of NUREG 933
23 and there is one supplement after that that is on the
24 street.

25 MR. CARROLL: I have one -- that the staff keeps

1 telling us that they're going to come and talk to us about
2 and they never come, is on the CE PORV issue.

3 Now, is that -- since that hasn't been resolved,
4 you're not going to be committing to that?

5 MR. KENNEDY: No, we will address all of them,
6 particularly those that have not been resolved by the staff.
7 Part 52 requires us to propose a resolution. So, for those
8 even which are unresolved as far as the staff status, we
9 will be proposing what we think is an acceptable resolution
10 for the System 80+ design.

11 MR. CARROLL: Okay.

12 MR. MICHELSON: Well, then you leave me with a
13 little bit of confusion then. What does it have to do with
14 the date of the application?

15 MR. KENNEDY: That is simply what is written into
16 Part 52 as a benchmark for this list that you have to
17 address.

18 MR. MICHELSON: Well, later on we'll get back with
19 the staff on why GE has committed to the FDA date for the
20 resolution of these issues and not to the application date.

21 MR. SINGH: Let me make a comment about the date
22 of application. We have recently gotten guidance from our
23 lawyers on what is the date of application as referred to in
24 Part 52.

25 Now, our lawyers have told us the date of the

1 application is when all the submittals are in. In other
2 words, not when an applicant sends a letter of intent to
3 apply for certification, but, rather all the submittals are
4 in.

5 MR. MICHELSON: That would be sometime during 1990
6 then?

7 MR. SINGH: Right.

8 MR. MICHELSON: Okay. Now, --

9 MR. SINGH: That is the guidance.

10 MR. MICHELSON: At least that will be close.

11 MR. SINGH: Yes.

12 MR. CATTON: Could you get me -- send the PORV.

13 MR. KENNEDY: We will be discussing that in our
14 technical presentation. The answer is, we have a safety
15 depressurization system that Mr. Turk will be talking about.

16 MR. CATTON: Okay.

17 [Slide.]

18 MR. KENNEDY: Very quickly, graphically, this
19 simply shows the schedule in graphical form, FDA at the end
20 of '91, design certification at the end of '92.

21 MR. MICHELSON: Back on your previous slide in
22 December of '89, you indicated a PRA methodology in level 1.
23 That PRA I guess was submitted?

24 MR. KENNEDY: Yes.

25 MR. MICHELSON: Does that include external events?

1 When will the external events portion be submitted?

2 MR. JACQUITH: My name is Bob Jacquith from
3 Combustion and we will be submitting the level 3 PRA in
4 August is the schedule and that includes external events.

5 MR. MICHELSON: And that will be a level 3?

6 MR. JACQUITH: Right.

7 [Slide.]

8 MR. KENNEDY: To continue again briefly with
9 what's in the LRB, there is a section in the LRB that
10 discusses severe accident issues, how we're going to resolve
11 USI's and GSI's, how we're going to conduct the PRA, and a
12 number of severe accident performance goals. Mr. Jacquith
13 will be discussing this today as part of his presentation.

14 [Slide.]

15 MR. KENNEDY: The LRB also contains a discussion
16 of a number of other issues. These issues come from a
17 number of sources from letters we've received from the
18 staff, from meetings we've had with the staff, of issues
19 they would like for us to address in the LRB.

20 Without going through this list in detail, let me
21 point out that there is another list that's been discussed
22 recently, the so-called 15 technical issues. Of these 15
23 technical issues which are being discussed currently, 13 of
24 them are presently discussed in our LRB.

25 The reason the other two aren't discussed in our

1 LRB, is we weren't smart enough to anticipate those two.
2 There is no reason we could not discuss them in our LRB if
3 the staff thought it was appropriate for us.

4 But, in our January, 1990 version, we simply have
5 no discussion on two of these issues.

6 [Slide.]

7 MR. KENNEDY: Now, what we would like to do today
8 since these issues are of current interest, as we go through
9 today's agenda, we are going to, at the appropriate point in
10 the presentation when we're talking about a design feature,
11 discuss each of these 15 technical issues in the context of
12 the design.

13 So, as we go through today, you will see in our
14 presentation, each of these 15 technical issues.

15 MR. CARROLL: Do you think 15 is the right number?
16 What would you add to the list?

17 MR. KENNEDY: Well, it's interesting, as part of
18 our LRB back in January, the staff requirements memorandum,
19 we were asked to identify what we thought potential issues
20 were. We came up with a shorter list.

21 Frankly, we think there are some things on that 15
22 issue list that don't really involve policy questions. So,
23 I think we've come up with a shorter list. This is the list
24 we came up with.

25 MR. MICHELSON: And what would you define as

1 policy matter? You know, that's apparently how you
2 differentiated why some of them don't belong on the list.
3 What were you using as a definition?

4 MR. KENNEDY: I would say we're not using anything
5 cast in stone. What we have been using is an issue which we
6 believe is a policy issue of sufficient merit that the
7 Commission needs to give the staff guidance because it goes
8 well beyond current regulations and current regulatory
9 practice.

10 MR. MICHELSON: Now, well beyond means that some
11 of the others could go beyond but it isn't a policy issue?

12 MR. KENNEDY: There are some issues which could go
13 beyond current staff requirements but are within the range,
14 I would say, of the interpretation of the requirements.
15 It's a gray area as to what's a policy issue and what's not.

16 MR. MICHELSON: So, those that are gray don't need
17 to be policy issues. If they're black and white, clearly
18 then they're policy issues.

19 MR. KENNEDY: If they are grey, we would prefer
20 to, first of all, negotiate with the staff to see whether or
21 not we can reach an appropriate resolution with the staff
22 before we say it requires a Commission decision.

23 We might be able to reach a perfectly agreeable
24 resolution with the staff.

25 MR. CARROLL: And "we" could even be broader.

1 "WC" could be the industry?

2 MR. KENNEDY: That's true.

3 MR. CARROLL: We, as you were using in the context
4 of Combustion.

5 MR. KENNEDY: We could be, for example, in the
6 EPRI requirement document. There are a number of issues
7 that are being pursued on the EPRI requirements document
8 which I think might be satisfactorily resolved there and we
9 would simply adopt a resolution.

10 MR. CARROLL: Do we have a copy of that?

11 MR. KENNEDY: It is in the LRB. If you have our
12 LRB, it's one of the sections right up front in the LRB, the
13 list of policy issues which we were asked to identify.

14 MR. MICHELSON: Let me ask you. In appendix A to
15 the LRB is where you discusses differences with the EPRI
16 document.

17 MR. KENNEDY: Yes.

18 MR. MICHELSON: Am I to conclude that those are
19 the only differences?

20 MR. KENNEDY: We will be going through that list
21 as part of our presentation today.

22 MR. MICHELSON: Was that the intent -- unless
23 listed in appendix A, you were in agreement with the
24 requirements document?

25 MR. KENNEDY: Yes.

1 MR. MICHELSON: Okay. Thank you.

2 MR. CARROLL: Page three, Dave.

3 MR. KENNEDY: And I can get you a copy of the
4 slide if you'd like it, but, it should be brought out at the
5 LRB.

6 MR. CARROLL: We have it.

7 MR. KENNEDY: That was the completion of my
8 introduction, gentlemen. If you don't have any questions, I
9 would like to turn the floor over to Dr. Regis Matzie to
10 give you an overview of our design program.

11 MR. MICHELSON: Before you leave, though, let me
12 ask you something that bothers me, and I don't know -- maybe
13 you're going to get into it in great length later or maybe
14 not -- and that's this question of the completeness of
15 design that you're presenting.

16 Were you planning on talking about it anymore than
17 you might have mentioned already?

18 MR. KENNEDY: You mean level of detail in the
19 design?

20 MR. MICHELSON: For instance.

21 MR. KENNEDY: Or the completeness of the scope of
22 the design?

23 MR. MICHELSON: Well, no. It's the completeness
24 of design identified in the standardization policy statement
25 and so forth.

1 MR. KENNEDY: If I could, then, I would like to
2 come back to that issue at the conclusion of our technical
3 presentations. I will address that.

4 MR. MICHELSON: Okay. What constitutes an
5 essentially complete design is the question, because that's
6 what we are, presumably, certifying.

7 MR. KENNEDY: Okay. I will address that issue at
8 the closing of the meeting.

9 MR. MICHELSON: Okay. That will be great. Thank
10 you.

11 MR. CARROLL: Let me point out to the Subcommittee
12 that, I guess, Combustion would like to complete the meeting
13 by 2 o'clock today. Is that right?

14 MR. KENNEDY: If possible, we would like to try to
15 catch a 3:15 flight, if that's agreeable. If that's not
16 agreeable, we can make other arrangements.

17 MR. CARROLL: So far, you're 11 minutes ahead of
18 schedule.

19 [Slide.]

20 MR. MATZIE: My name is Regis Matzie. I'm the
21 Director of Advanced Water Reactor Projects, and I'll give
22 you a programmatic overview of the System 80+ design
23 certification program. I'll be followed by a series of
24 presentations on the technical details of the design.

25 [Slide.]

1 MR. MATZIE: The objectives of our System 80+
2 program are rather broad and generally encompass what are
3 viewed as some of the requirements for future plants:
4 enhanced safety, increased margin, improved operability and
5 maintainability, reduced cost, and the use of proven
6 technology. And we're doing this to obtain NRC
7 certification to, number one, reduce licensing risk to a
8 prospective customer, and finally, then, the result of that,
9 possibly, is to retain nuclear as a viable option for future
10 capacity additions in the United States.

11 [Slide.]

12 MR. MATZIE: The program that we have been
13 involved with is not only a Combustion Engineering program
14 but a rather broad industry program, and at the start of
15 that program, in terms of what a future plant should be, is
16 the EPRI ALWR requirements document. Combustion
17 Engineering, teamed with Duke Power Company, has been a key
18 player in the development of the requirements in the EPRI
19 program since 1986. We have been a partner with Duke to
20 develop those requirements, and we have continued to work
21 with Duke to develop the balance-of-plant aspects of the
22 System 80+ design.

23 In addition to the EPRI requirements, we have been
24 involved rather heavily in a number of other programs, as
25 you can see here, all of which provide input to our design,

1 and that input is collected and documented in our CESSAR-DC,
2 under the sponsorship of a Department of Energy program
3 called the DOE ALWR Design Verification Program, and that
4 leads, then, to the submittals that Mr. Kennedy spoke of
5 earlier to the NRC and, hopefully, on schedule, the
6 certification of the System 80+ design.

7 [Slide.]

8 MR. MATZIE: The approach that we have taken to
9 develop System 80+ is to start with our rather successful
10 System 80 design, which had final design approval in CESSAR-
11 F for the NSSS, and as a starting point, we have taken the
12 Duke Cherokee/Perkins balance of plant as the reference from
13 which we would then incorporate changes to upgrade and
14 update the design to conform to the EPRI ALWR requirements
15 for evolutionary plants, the NRC required changes and,
16 mostly notably, in the area of severe accidents, and
17 operational feedback from our own units and, particularly,
18 Palo Verde -- the startup and operation of Palo Verde.

19 MR. MICHELSON: How does the Cherokee differ from
20 the Yellow Creek? Are they same vintage?

21 MR. MATZIE: They are basically the same vintage.

22 MR. MICHELSON: Is Cherokee a later one or an
23 earlier one?

24 MR. MATZIE: I think Cherokee probably had more
25 design completion on some of the balance-of-plant aspects,

1 but they're the same vintage, same timeframe.

2 MR. MICHELSON: Okay.

3 MR. MATZIE: These potential changes, then -- and
4 there's a whole set of these, obviously -- we assess with
5 respect to safety, performance, operability,
6 maintainability, and cost, and we use probabilistic risk
7 assessment and cost-benefit techniques to help us decide
8 which changes to incorporate into the System 80+ design.

9 MR. MICHELSON: Excuse me. Was Cherokee a
10 spherical containment, also?

11 MR. MATZIE: Yes.

12 MR. MICHELSON: Thank you.

13 MR. MATZIE: Those that we then select have been
14 documented and submitted to the NRC as part of the CESSAR-
15 DC.

16 [Slide.]

17 MR. MATZIE: The System 80 design was a major part
18 of a nuclear power plant but not a complete plant. It was
19 basically the nuclear steam supply system, as defined here.

20 [Slide.]

21 MR. MATZIE: We have, as discussed earlier,
22 expanded the scope of the design to an essentially complete
23 nuclear power plant, and the categories of systems that we
24 are now including in the design and design certification are
25 shown here. Everything required by 10 CFR, Part 52, and

1 that which the staff will need to review the design under
2 the standard review plan is included.

3 [Slide.]

4 MR. MATZIE: Of course, Part 52 recognizes that
5 certain site-specific features should be addressed only by
6 presentation of the conceptual design level. To this end,
7 conceptual design descriptions and interface requirements
8 are being provided in CESSAR-DC for the following systems
9 and structures, consistent with the requirements of 10 CFR,
10 Part 52.

11 MR. WYLIE: Excuse me. You don't list the turbine
12 generator building. Is that not included?

13 MR. MATZIE: The turbine generator building is
14 included in the System 80+ design.

15 MR. WYLIE: Thank you. And the auxiliary
16 building.

17 MR. MATZIE: That's correct.

18 A very high level comparison of System 80+ to
19 System 80 is shown on the next two slides.

20 MR. MICHELSON: Before you get to that, let me
21 ask: On the portable and sanitary water, why isn't that
22 detailed in the auxiliary building, control building, places
23 like that, where it could be a potential threat to safety-
24 related equipment? Why can't you detail the sewer
25 arrangement, the drinking-water arrangements, and so forth

1 in the reactor building?

2 MR. MATZIE: From a practical standpoint, systems
3 like that have not been included from a cost perspective.

4 MR. MICHELSON: They're trivial systems,
5 virtually, compared with everything else you are doing, and
6 they could be a potential threat if done improperly. You
7 can write all kinds of interface requirements, but an
8 inexperienced designer may not interpret them properly. The
9 staff will never see or review them until that cooling water
10 line over the control building going to a cooler in the
11 corner leaks one day and drips on the control panel. Then
12 everybody will be aware of it.

13 So, within sensitive areas, I don't know why you
14 aren't considering such things as the drinking water in the
15 design. There aren't going to be many of these. It's
16 almost trivial. But why do we leave out something like
17 that?

18 MR. MATZIE: When we were trying to settle the
19 scope of what we were including and what we were not, that
20 fell on one side of the fence. We'll take it under
21 advisement.

22 MR. MICHELSON: The sanitary water -- heck,
23 sanitary drains can back up and so forth. I don't know what
24 the interface -- you know, the interaction might be with
25 safety-related equipment and not knowing what the

1 arrangement is, and probably never knowing, it's not clear
2 to me how you do a safety analysis of these kinds of non-
3 safety systems.

4 MR. CATTON: You mean you don't think it turns up
5 in the PRA?

6 MR. MICHELSON: No. You know it isn't going to
7 turn up in the PRA. It isn't going to turn up anywhere,
8 including in nobody's mind, if it's never been detailed
9 until the day that Podunk Electric buys it and, apparently,
10 goes in and puts the sewers into this nuclear island and
11 then the water coolers, which it will stick in the control
12 room, right over the control panel, for all I know.

13 It's so trivial. It seems like you ought not to
14 leave it out.

15 MR. WYLIE: Is someone going to discuss the
16 offsite power systems interfaces further?

17 MR. MATZIE: Yes.

18 [Slide.]

19 MR. MATZIE: A very high level comparison of
20 System 80+ and System 80 is shown on the next two slides.
21 The details of this will be discussed subsequently by the
22 other speakers. I wanted to give you a feel early-on for
23 the kinds of things that we have done without going through
24 the details at this point in time.

25 In the reactor area, the principal objective was

1 to maintain a proven design and to meet utility performance
2 requirements.

3 There are relatively few changes to the design and
4 one example of such a change is the fact that we have
5 included part strength or weak or grey -- whatever the
6 terminology you want to use -- control rods for some of the
7 rods to enhance load following capability, which will likely
8 be a requirement in the future as utility capacity in the
9 nuclear area gets to be a higher percentage.

10 In the reactor coolant system area, the principal
11 objective was to improve plant margins and some of the
12 examples of this are shown for changes from System 80 in
13 terms of temperatures, system volumes and materials and
14 these will be discussed in detail later.

15 The safeguard systems, a principal objective was
16 to reduce the core melt frequency to meet a goal that we
17 have established which is in agreement with the general
18 industry goal and I'll show you that in a minute.

19 We have therefore redesigned the safeguard systems
20 to be essentially in compliance with the current EPRI/ALWR
21 requirements for evolutionary plants and as was already
22 mentioned, we have added a safety depressurization system
23 which will be described later.

24 [Slide.]

25 MR. MATZIE: In the auxiliary systems, principally

1 the CVCS, we have taken the objective of simplification and
2 the major simplification and result of that has been to
3 design a non-safety CVCS. There is no safety function of
4 the CVCS as it is currently designed.

5 The containment design principal objective was to
6 address severe accidents and meet utility maintenance
7 requirements. That has resulted in the use of a dual
8 spherical steel containment that will be described to you.

9 In the instrumentation and control area our
10 objective was to provide state-of-the-art human factors
11 engineered instrumentation and control systems and control
12 room and that has resulted in an advanced control complex
13 that we call NUPLEX 80+, again which will be described.

14 In the electrical distribution and support system
15 area, improved reliability consistent with the safeguards
16 systems improvements, greater redundancy and greater
17 diversity are the types of changes we have implemented
18 there.

19 [Slide.]

20 MR. MATZIE: The next two slides will give you a
21 very broad overview of improvements in the areas of cost and
22 operation. We have looked at the construction schedule with
23 the changes we have made and it is a significant improvement
24 over the average experience in the United States, very
25 consistent with the best experience in the U.S. and

1 experience overseas in terms of that schedule.

2 Similarly, with respect to plant costs, we have
3 good confidence that we can meet these objectives in an
4 environment where the design is prelicensed and there's a
5 significant level of detail completed prior to start of
6 construction.

7 MR. WYLIE: The capital costs doesn't include the
8 cost of money during construction?

9 MR. MATZIE: That's correct. That was the
10 overnight capital costs.

11 [Slide.]

12 MR. MATZIE: In the area of improved operation, we
13 are designing the plant for a 60 year design life, for a
14 high availability, for a relatively short outage time, for
15 significant reduction in unplanned scrams or plant trips,
16 for a low personnel exposure and for improved
17 maintainability.

18 MR. WARD: Regis, when you talk about a sixty year
19 design life, is there anything explicitly different that's
20 been done than if it you had specified a forty year design
21 life, let's say?

22 MR. MATZIE: In terms of the way the plant was
23 designed, let me give you the basic overview of that issue
24 and the issue is anything that we do not have high
25 confidence from the standpoint of design criteria that can

1 meet sixty year lifetime we have specifically ensured that
2 that is easily replaceable.

3 As an example, despite the fact that we have
4 improved the design of steam generators substantially in
5 this design which will be described, we have gone through
6 and made sure that the steam generators can be replaced in
7 one piece without cutting containment.

8 We have looked at the ability to handle and move
9 those generators out of containment. That's an example.

10 Basically besides structures --

11 MR. CARROLL: But you have really hopefully taken
12 care of the problems that require replacement.

13 MR. MATZIE: That's correct. In addition to
14 design improvements we have made that accommodation and that
15 is true of all the major pieces of equipment with the
16 exception of the reactor pressure vessel which we do not
17 believe will need replacement and which we did not make
18 provisions to replace and --

19 MR. WARD: What provisions for annealing?

20 MR. MATZIE: We have not made any specific
21 provisions for annealing. We don't believe it will be
22 necessary and the design aspects of the reactor vessel will
23 be covered to show how we can get a sixty year life.

24 MR. MICHELSON: On your NUPLEX 80+, is that in any
25 power plant operating today?

J

1 MR. MATZIE: No, it is not. There are bits and
2 pieces of the design that are going into some replacement,
3 power plants and new units under construction in Korea, but
4 those are bits and pieces and not the whole thing.

5 MR. MICHELSON: So we really don't have much
6 operating experience yet with the instrumentation and
7 control system that will control this generation reactor.

8 MR. MATZIE: In terms of the type of equipment I
9 think that is true.

10 MR. MICHELSON: So we are speculating a little bit
11 on how many unplanned trips we might get from it and all the
12 other good things -- we are thinking it is a highly reliable
13 system not subject to environmental influences that might
14 generate spurious scrams or things of that sort but we don't
15 really -- do you have test data to back it up, its
16 susceptibility, its vibration sensitivity, its humidity
17 sensitivity, all this sort of thing?

18 MR. MATZIE: We do have test data and you can ask
19 those questions of Mr. Scarola when he presents the
20 material.

21 MR. MICHELSON: Because you're going to a new
22 technology and yet you are predicting extremely low
23 unplanned trips and its very high availability.

24 MR. MATZIE: That's correct.

25 MR. WYLIE: Is there somewhere where you are going

1 to go into detail as to what you have done to try to
2 accomplish the goals you have set forth, such as unplanned
3 trips?

4 MR. MATZIE: Yes.

5 MR. CARROLL: What is your definition of refueling
6 time?

7 MR. MATZIE: The definition of refueling time is
8 off-line to back on-line in terms of breaker closure,
9 opening and closing.

10 MR. CARROLL: So it isn't just refueling, it's a
11 refueling and maintenance?

12 MR. MATZIE: That's correct, that's correct.

13 MR. CARROLL: And your fuel cycle is how long?

14 MR. MATZIE: The fuel cycle that we are showing in
15 the licensing documentation is 18 months fuel cycle. As
16 with a number of our reactors the capability for 24 month
17 cycles has been looked at and we have the capability for 24
18 month cycles. That tends to be a option that the utility
19 will select from the standpoint of its own grid structure
20 and the replacement power, whether he is anywhere from a
21 year to two years.

22 MR. CARROLL: So the outage time information you
23 have there is on the basis of an 18 month fuel cycle?

24 MR. MATZIE: That's correct.

25 MR. CARROLL: So in other words you're going to

1 have 30 days down, 45 -- so you're saying -- let's see, oh,
2 okay. Never mind. I got it.

3 [Slide.]

4 MR. MATZIE: The safety goal that we have chosen
5 for the System 80+ design is consistent with those safety
6 goals that you have probably seen quite a bit of recently.
7 In particular they are the ones adopted in the EPRI/ALWR
8 program, a core damage frequency of less than 10 to the
9 minus 5 events per reactor year and a severe accident
10 release goal of 10 to the minus 6 events per year for an
11 occurrence of doses greater than 25 rem at the site
12 boundary.

13 MR. MICHELSON: Is that at half-mile or at the
14 site boundary?

15 MR. MATZIE: Pardon?

16 MR. MICHELSON: At a half-mile or the site
17 boundary?

18 MR. MATZIE: That's synonymous in this
19 terminology.

20 MR. MICHELSON: You mean the site will
21 automatically have a boundary out a half-mile from the
22 plant?

23 MR. MATZIE: That is approximately.

24 MR. MICHELSON: Is that the assumption?

25 MR. MATZIE: That's approximately where the site

1 boundary would be.

2 MR. MICHELSON: Okay.

3 MR. MATZIE: It's obviously site-specific.

4 MR. MICHELSON: But in calculating it is a half-
5 mile?

6 MR. MATZIE: That's correct.

7 I am only going to discuss the differences from
8 the EPRI requirements in terms of these global statements.
9 There is a detailed accounting in a subsequent presentation
10 of what the major differences between System 80+ and the
11 EPRI requirements are as per our Licensing Review Basis
12 Document tabulation.

13 I can say that we have a very high degree of
14 compliance with the EPRI requirements and I can say further
15 that, in terms of performance and safety-related
16 requirements that are included in the EPRI requirements, we
17 are at essentially at 100% agreement. There are a number of
18 specific requirements that we are in disagreement with and
19 those will be articulated to you by a subsequent speaker.

20 Although there is a list in the LRB at this point
21 in time, there is obviously potential for changes. No. 1,
22 the EPRI requirements document for evolutionary plants is
23 currently under review by the staff and as comments come
24 back those requirements end up changing.

25 Similarly, we have not completed our design and

1 there may be changes to the design even after our last
2 submittal, based on interactions with the NRC staff. So,
3 although the differences may be a different list finally,
4 the snapshot you see in the LRB is where we are today in
5 terms of conformance to EPRI requirements.

6 That really concludes my presentation. Are there
7 any questions from a programmatic standpoint before Mr. Rick
8 Turk goes through the start of the detail portions of the
9 presentation?

10 MR. MICHELSON: I don't have a question for you,
11 but I have a question for our subcommittee chairman and that
12 is when we have our next meeting in which we compare these
13 two documents, meaning the System 80 and the ABWR, I assume
14 at that time Combustion will come back to answer detailed
15 questions on the Licensing Basis Agreement so we don't have
16 to spend today getting into a lot of that detail, rather, do
17 it next time.

18 MR. CARROLL: Well, I think what you say is true,
19 but to the extent there are questions, I think we ought to
20 get them out on the table.

21 MR. MICHELSON: But not necessarily expecting the
22 answers today. We will expect the answers next time.

23 MR. CARROLL: Right.

24 MR. MICHELSON: Okay. Because otherwise it's hard
25 to write a letter at this time without knowing where we're

1 at.

2 MR. CARROLL: Right.

3 MR. MICHELSON: OKay.

4 [Slide]

5 MR. TURK: My name is Rick Turk. I am the Project
6 Manager for System 80+ Development.

7 What we would like to do over the next couple of
8 hours is go back through this overview that Dr. Matzie put
9 up related to the changes from System 80 to System 80+, show
10 you specifically what those changes were and then relate
11 them to some of the policy issues that were discussed
12 earlier and mentioned in regard to the LRB. So, we will
13 essentially start with the reactor, look at the fluid
14 systems, Mr. Scarola will then talk about the electrical and
15 INC systems, Bill Fox from Duke Engineering Services will
16 talk about the containment and balance of the plant, and
17 then we will finish up with Bob Jaquith from our PRA group
18 talking about the safety significance in PRA space.

19 MR. MICHELSON: Before you get into that, let me
20 ask the previous speaker one more question on the overview.
21 The Licensing Basis Agreement talked about, of course,
22 providing amendment sheets to CESSAR-F, and so forth. Is
23 that going to all be amended, now, to indicate that you, in
24 reality, are going to submit a final CESSAR-DC, which is
25 self-contained and complete?

1 MR. KENNEDY: Let me answer that. This is Ernie
2 Kennedy.

3 By the time we finish the amendment process, every
4 page in the document will have been amended and it will be a
5 complete new document at the end of the process.

6 MR. MICHELSON: Well, let me ask, as we proceed
7 with the review, now, over the next several months, are we
8 going to have in front of us CESSAR-DC to review for the
9 particular sections under consideration, or are we still
10 going to have to go back to the old CESSAR-F?

11 MR. KENNEDY: You should have all of the CESSAR-DC
12 amendments in front of you. The volume should be complete
13 with all the submittals we have submitted.

14 MR. MICHELSON: Okay. So the discussion in here
15 about being amendment sheets and being identified and marked
16 where they are and all that, is no longer relevant?

17 MR. KENNEDY: If you go to your CESSAR-DC binders,
18 you will find printed pages there. You will see amendment
19 bars in the margin to show when we amended it. But it
20 should be, more or less, a complete document. When we
21 finish, the whole thing will have been amended. You will
22 have a complete self-consistent document.

23 MR. MICHELSON: So we really don't have to ever
24 refer CESSAR-F. It's all CESSAR-DC we are going to look at.

25 MR. KENNEDY: Correct.

1 MR. MICHELSON: Okay.

2 MR. KENNEDY: The old material that is there, we
3 will hope would provide a frame of reference for those
4 portions of the design which were not changed. But the more
5 we have gotten into it, we realized we have got to change
6 the entire document.

7 [Slide]

8 MR. TURK: We will, however, continue to talk
9 today primarily in terms of those features that have changed
10 in that those are the features that are probably of the most
11 interest.

12 I would like to start with the reactor where, as
13 we said, we have changed relatively little. We want to
14 maintain what we feel is a very proven design, that is, the
15 Palo Verde design, making some performance changes.

16 [Slide]

17 MR. TURK: This cutaway or cross-section of the
18 reactor vessel highlights those changes. As was mentioned,
19 we have added additional control and drive mechanisms for
20 additional control elements and we will show those changes
21 in the core scheme in a couple minutes.

22 One addition that we will talk about in the
23 safeguard systems is the addition of a direct vessel
24 Injection Nozzle 4, the safety injection system. We will
25 see that we have lowered the reactor coolant hot leg

1 temperature, primarily, in order to again provide additional
2 margin from our operating conditions to our thermal limits.
3 That's also reflected in the core.

4 We will see that our vessel material and
5 construction method has changed going from a rolled plate
6 construction used at Palo Verde to a ring forged
7 construction which, by the way, has been incorporated in the
8 2825 megawatt version of System 80 that is currently under
9 construction in Korea.

10 MR. MICHELSON: Roughly, where are the welds for
11 the ring forging?

12 MR. TURK: Roughly, they are right below the
13 nozzle area in here to the lower head here, a ring
14 containing the nozzles.

15 MR. MICHELSON: Well, the main ones of concern, of
16 course, are around the core anyway.

17 MR. TURK: That's right. To keep them out of the
18 core area.

19 MR. CARROLL: So this is a complete ring forging,
20 no horizontal or vertical welding.

21 MR. TURK: That's right.

22 Let me just ahead just a slide, as long as we are
23 on the subject.

24 [Slide]

25 MR. TURK: You can see, basically, a comparison

1 between the exploded view of the System 80 Palo Verde
2 construction versus the ring forge construction that we are
3 using for System 80+. That eliminates about 135 feet of
4 linear weld. It takes it out of the beltline region, for
5 one thing, and also reduces it in total as far as ISI
6 inspection.

7 MR. CARROLL: Now, the ring labeled lower shell is
8 the one you were describing being in the core region.

9 MR. TURK: Right.

10 MR. CARROLL: Okay.

11 [Slide]

12 MR. TURK: Now, as far as the actual core design,
13 it's virtually unchanged from Palo Verde. The same --

14 MR. CARROLL: Going back to the vessel, I do have
15 -- Paul Schuman, our metallurgical witch doctor was unable
16 to be here, but he left us some questions.

17 He says, I was once told by CE that System 80 had
18 a 40 year fluence of 4 times 10 to the minus 19th greater
19 than one MEV, which is quite high.

20 Is that a fair statement?

21 MR. TURK: I believe that was. Our 60-year
22 fluence for System 80+ is 6 times 10 to the minus 19th,
23 slightly higher.

24 The changes we have made relative to the 60-year
25 life are, first of all, with regard to materials. We have

1 gone from the 533 plate material to the 508 material, 508
2 for forging with much lower copper/nickel content. We have
3 taken our initial RTNDT from -- I believe, on Palo Verde
4 Unit 1 we had one plate that was plus 40 degrees Fahrenheit.
5 We are going to spec System 80+ ring forgings at a minus 20
6 degrees Fahrenheit.

7 MR. WARD: I am puzzled by the difference between
8 the end of life fluence in the System 80 versus the 80+. It
9 seems to amount to the same thing. Are you talking about
10 fluence in the weld, in the worst weld? Is that what you
11 are talking about?

12 MR. TURK: Yes. Regis, do you want to elaborate
13 on that a little bit?

14 MR. WARD: I mean, because the 80 has a weld in
15 the, you know, right in the middle of the core. And you
16 seem to have gotten away with that. I am surprised that the
17 fluence isn't much lower in the System 80+.

18 MR. MATZIE: This is Regis Matzie.

19 The fluence that we are talking about is the peak
20 fluence in the beltline region that is on the vessel inner
21 wall.

22 MR. WARD: Okay. But there is no weld there.

23 MR. MATZIE: That's correct. But in the modern
24 vessels, the weld material has been as good, if not better,
25 than some of the plate material. So, it really ends up

1 being the ring forging metallurgical properties that dictate
2 the shift now.

3 MR. MICHELSON: Well, just for the skeptics, what
4 is the fluence at the weld?

5 MR. TURK: I don't know what it would be.

6 MR. MATZIE: I'm not sure. You would have to look
7 how it lines up to the peak fluence around the core
8 azimuthally.

9 MR. MICHELSON: So you don't have a number on the
10 maximum weld fluence.

11 MR. MATZIE: Not in front of me, no, I don't.

12 MR. TURK: We can find that out.

13 MR. CARROLL: Yes. On Paul's list, I guess the
14 only question you haven't answered at this point is, what is
15 the maximum percent sulphur for the reactor pressure vessel?

16 The same that it meets ASME specs isn't an
17 acceptable answer. It's either .04 or .015.

18 MR. TURK: It's .015.

19 MR. CARROLL: All right. We've answered Paul's
20 question.

21 MR. TURK: The other point I was making with that
22 slide was the fact that the essential array of fuel elements
23 is the same. It's 241 array. It's the same fuel elements
24 used in Palo Verde.

25 But as mentioned, we did --

1 MR. WARD: Leave that out for a minute. I've got
2 a couple of questions. Well, unless you're going to come
3 back to it.

4 MR. TURK: No, go ahead.

5 MR. WARD: Let's see, you said you have a reduced
6 hot -- temperature.

7 MR. TURK: Correct.

8 MR. WARD: Is the thermal rating lower than Palo
9 Verde then?

10 MR. TURK: No, the thermal rating is the same.

11 MR. WARD: How did you manage that?

12 MR. TURK: By lowering steam pressure associated
13 with the unit, there is some increase in steam flow then.
14 But we're essentially operating at a lower temperature.

15 MR. TURK: A lower steam --

16 MR. WARD: Right.

17 MR. TURK: So the power density is identical with
18 Palo Verde?

19 MR. WARD: That's correct.

20 MR. TURK: But the gray rods are different. Are
21 you going to talk about the gray rods any place?

22 MR. WARD: I will --

23 MR. TURK: To ATWS?

24 MR. WARD: Not in relation to that. I will show
25 you where they fit in and at that point, maybe I'll have

1 Regis comment a little bit more on the details since he was
2 a little closer to that design than I was.

3 [Slide.]

4 MR. TURK: In terms of what it does relative to
5 the difference between normal operating conditions and
6 thermal limits, we've lowered the temperature. Palo Verde,
7 for instance, had a th of 621. We've lowered this now to
8 615 degrees.

9 MR. CARROLL: And what however is not as low as
10 the EPRI requirements document?

11 MR. TURK: That's correct. The EPRI requirements
12 document which first of all were predicated on a 1,000
13 megawatt electric plant asked for 600 degrees. That is an
14 exception we've taken with EPRI. It's based on two things.

15 One, that we did not see any significant benefit
16 in terms of predicted material performance in the generators
17 with that extra 15 degrees reduction.

18 Second of all, at 3,800 megawatts, the size of the
19 steam generator necessary to maintain the thermal rating
20 with those transfer temperatures become prohibitively large.

21 So, we say like today, a 615 temperature --

22 MR. CARROLL: It isn't prohibitive if you have to
23 change out steam generators three or four times of the life
24 of the plant.

25 MR. TURK: Well, that was the basis for the first

1 reason I said that we could not identify any advantage
2 relative to the material performance going from 615 to 600.

3 MR. CARROLL: If you had an EPRI hat on up here,
4 how would you argue the other side of it? Why did they pick
5 600?

6 MR. TURK: I often think because it has two zeroes
7 and it's a nice round number, but, I'm not so sure.

8 MR. CARROLL: I guess I'm coming from experience
9 with Westinghouse. But, on the Westinghouse generators, I
10 sure think you ought to get down to 600.

11 MR. MATZIE: Yes, this is Regis Matzie. The data
12 base in terms of tubing material in the generators that had
13 most of the failures that were in the evaluation as part of
14 the EPRI Program, the material was different than what
15 Combustion Engineering has traditionally specked out.

16 And we have not had the types of problems that the
17 data showed that if you reduced temperature you got out of.
18 We have not had those problems and therefore we said that
19 that did not influence our design.

20 Furthermore, we're changing the tubing material to
21 an improved corrosion resistant material. I think the belt
22 and suspenders approach to this issue was overdone.

23 MR. CARROLL: So you think EPRI was dealing with
24 the Westinghouse problem?

25 MR. MATZIE: Primarily from the standpoint of the

1 data that they were using to evaluate the issue.

2 MR. CARROLL: Okay. That's fair.

3 MR. WARD: Why did you reduce hot leg to the
4 extent you did?

5 MR. TURK: Primarily the benefit we see in reduced
6 hot leg temperature is the thermal margin benefit, the
7 operating farther away from the thermal limits. The 621
8 was, you know, a number that came out of the megawatt race
9 when System 80 was being designed, trying to push the
10 designs to their absolute limit.

11 And one of the philosophies of EPRI's program and
12 our program is that it's to drop back a little bit and not
13 press the designs quite as hard.

14 MR. MATZIE: Regis Matzie again. Another reason
15 for that is, the plant has been designed for a two-year fuel
16 cycle. And if you'll look at the fuel managements that you
17 would want to implement, you can get to fuel burnups in the
18 55,000 megawatt day per ton burnup range.

19 And the reduction in hot leg temperature allows us
20 to go to higher burnups on the fuel without getting
21 increased water site corrosion of the cladding.

22 MR. MICHELSON: One question yet. On the vessel,
23 was this a Palo Verde vessel?

24 MR. TURK: In dimensions, yes.

25 MR. MICHELSON: Now, my vague recollection is that

1 Westinghouse has elongated their vessel significantly in
2 part to provide for better coverage of the field for certain
3 of the accidents.

4 MR. CARROLL: That's correct.

5 MR. MICHELSON: And does CE think that sort of
6 action is not necessary for future plants?

7 [Slide.]

8 MR. TURK: We made a significant change in our
9 Palo Verde vessel. Our Palo Verde vessel is significantly
10 different than the previous vessels for instance at San
11 Onofre, Waterford, St. Lucie, okay? To some degree we think
12 that Westinghouse was playing a little bit of catchup.

13 MR. MICHELSON: Well, what difference now was the
14 significant difference?

15 MR. TURK: Well, the significant difference was in
16 the, actually, in the structure of the upper head and guide
17 tube and the arrangement with the fingers for the control
18 element.

19 So, you would see in San Onofre, the core being
20 much higher in the unit and the nodule --

21 MR. MICHELSON: Higher than is shown there, you
22 mean?

23 MR. TURK: Okay.

24 MR. MICHELSON: Higher than shown on this drawing?

25 MR. TURK: Yes. Yes.

1 MR. MICHELSON: I don't see how it could be much
2 higher but I admit it could be another foot maybe.

3 MR. TURK: No, no, because the nozzles were also
4 higher.

5 MR. MICHELSON: Okay.

6 MR. TURK: I don't have it with me.

7 MR. MICHELSON: It is a different vessel.

8 MR. TURK: It is an improvement that we made at
9 the Palo Verde level.

10 MR. MICHELSON: What was the clearance between top
11 of core and bottom ID of the exit nozzle?

12 MR. TURK: I don't recall that offhand.

13 MR. MICHELSON: And how has that changed from the
14 older vintage to Palo Verde and on to this one? That's what
15 counts in terms of where the water is going to be during an
16 accident.

17 MR. TURK: Yes. The reasons for the changes
18 weren't exactly those particular reasons.

19 MR. MICHELSON: Yes, they weren't driven for that
20 reason.

21 MR. TURK: No, they were mechanical reasons.

22 MR. MICHELSON: Well, it would appear of course
23 that it is a nice conservative thing to have a little deeper

24 MR. TURK: We'll show you a little later in the
25 presentation the results and comparisons of line break

1 analysis for Palo Verde relative to System 80+ and the
2 changes that have been made and how that meets the EPRI
3 goal, for instance, of maintaining core covering for breaks
4 in excess of six inches in diameter.

5 MR. MICHELSON: What break size did you finally
6 end up with as not uncovering the core?

7 MR. TURK: I think when we get there, I think it's
8 10 inches.

9 MR. MICHELSON: All right. You'll get to it
10 later?

11 MR. TURK: Which of course corresponds to our
12 larger --

13 [Slide.]

14 MR. TURK: There are other margin aspects that go
15 along with the reduced hot leg temperature. With the lower
16 core temperatures, because of the higher density, we get a
17 higher mass flow density which also gains in thermal margin.
18 There are a combination of uncertainty changes we're making
19 in our core monitoring systems which will improve our
20 margin.

21 MR. CARROLL: That's not anything physical you're
22 doing?

23 MR. TURK: No, that's -- but it determines the
24 room the operator has in operating prior to initiating an
25 alarm condition. At the same time, it helps with the CPCs

1 being the trip producer, the issue of reducing our
2 unanticipated trips by providing more maneuvering room.

3 MR. CARROLL: So the way you get this four percent
4 gain is by sharpening your pencil, so to speak, in terms of
5 uncertainties and evaluating those parameters.

6 MR. WARD: I guess I don't see what you're adding
7 up there. The two percent for higher core flow; how is that
8 different? Why are you adding that to the three percent
9 above it?

10 MR. TURK: Well, the 3 percent is coming strictly
11 from operating at a lower temperature relative to starting
12 condition and the limit. The 2 percent is the power
13 equivalent then of operating at a higher mass flow rate at
14 that temperature.

15 MR. MATZIE: This is DNBR over power margin.

16 MR. WARD: You're talking about margin to DNB?

17 MR. MATZIE: That's correct.

18 MR. WARD: Some of it is from temperature and some
19 of it is from velocity.

20 MR. MATZIE: Right, which has traditionally been
21 limiting in our CE plans.

22 MR. MICHELSON: How much higher velocity are we
23 talking about?

24 MR. WARD: Two percent, it looks like.

25 MR. MICHELSON: I didn't know that was necessarily

1 the increase in velocity.

2 MR. MATZIE: For that particular parameter, it's
3 one for one, essentially.

4 MR. MICHELSON: Okay, now, is this higher than was
5 used at Palo Verde?

6 MR. MATZIE: In terms of mass flow velocity, it's
7 2 percent higher.

8 MR. WARD: Now, at Palo Verde you got some
9 surprises from high flow problems, vibration problems and so
10 forth, as I recall. Is that worked out here?

11 MR. TURK: It's worked out in terms of mechanical
12 changes that have been incorporated into the design. The
13 basic fixes from Palo Verde have been incorporated into the
14 design and designed for these flow rates.

15 MR. MICHELSON: Hopefully, Palo Verde was designed
16 for its flow rate, too, but you've got a surprise. But now
17 you think you understand it.

18 MR. TURK: That's exactly right. Of course, at
19 Palo Verde, we were going to, like I said before, a
20 completely new design, whereas this is the same basic design
21 being changed slightly.

22 MR. MICHELSON: Will the core test be -- a core
23 internal test be required for certification? I'm asking
24 staff. Do you know yet?

25 MR. SINGH: I don't think I have an answer to

1 that.

2 MR. CARROLL: What do you mean by that, Carl?

3 MR. MICHELSON: Well, generally, if you can point
4 out somebody else who has done the same test already, then
5 you don't have to go and do a core internal vibration
6 monitoring test. I just wondered if 2 percent more -- I
7 don't know; did Palo Verde do one?

8 MR. TURK: Yes, they did do one and we would not
9 anticipate doing one.

10 MR. MICHELSON: So the 2 percent more doesn't
11 necessarily mean you've got to do it over.

12 MR. CATTON: How do you make that decision? What
13 percent leads you into a new core vibration regime? You
14 didn't anticipate the Palo Verde problems. Do you think
15 there may be some lurking out here?

16 MR. TURK: I think the question of determining it
17 would be based upon looking at the range of parameters that
18 were done in the analysis and the test program at Palo Verde
19 and whether or not that's easily and acceptably extrapolated
20 at this range.

21 MR. CATTON: If you don't plan on doing it, I have
22 to assume that somebody's gone through that exercise. It
23 must be documented somewhere.

24 MR. TURK: I would have to go back and talk to the
25 core designers and the vessel designers. Lyle, do you want

1 to address that?

2 MR. GERDES: Lyle Gerdes, CE. The comprehensive
3 vibration assessment program that was run on Arizona
4 initially still did not pick up the problems at that --
5 within the internals. It was only after operation that they
6 went back and retested, because the instrumentation was not
7 at the proper locations.

8 I might add also that it was not in regions of
9 safety problems. The small changes that were made from the
10 Arizona to the System 80 Plus can easily be shown by
11 analysis that there will be little or no difference. One of
12 the main purposes of the comprehensive vibration assessment
13 program is to verify your analysis techniques.

14 The analysis techniques that are being used for
15 System 80 Plus are identical to those that were used for
16 Arizona.

17 MR. CATTON: Does that mean it's not documented?
18 I just asked if it was documented.

19 MR. GERDES: The analyses will be documented. The
20 analyses are not completed yet for the internals.

21 MR. CATTON: If you didn't anticipate the problems
22 on PV, what leads you to believe there won't be any problems
23 on the new vehicle?

24 MR. GERDES: Because the analysis techniques are
25 the same and there are very few differences structurally.

1 MR. CATTON: If the analysis techniques are the
2 same and you missed it one time, why aren't you going to
3 miss it again. I mean, what have you done differently?

4 MR. TURK: I think the answer is that we really
5 haven't done anything differently.

6 MR. CATTON: Is it identical?

7 MR. TURK: Well, Palo Verde certainly runs in this
8 regime as it transits up in temperature. In other words,
9 we're talking about coming down in temperature 15 degrees
10 which puts the pump operating --

11 MR. WARD: I guess they're saying they reduce the
12 specific things that troubled them at Palo Verde.

13 MR. CATTON: But now they've reduced the
14 temperature which increases the density a little bit.
15 They've increased the velocity a little bit, and all these
16 things kind of lead in the wrong direction. What makes you
17 believe that with this change, you're still all right?

18 MR. TURK: We've changed the steady state
19 operating point, but this is still a portion on the map of
20 parameters that Palo Verde operates in. They have to
21 transit through this.

22 MR. CARROLL: But vibration often tends to be a
23 fatigue problem and cycles accumulate at the normal
24 operating point.

25 MR. CATTON: I just think that, considering the

1 fact that there were problems before, that somehow this
2 ought to be addressed and put to bed. Maybe it's easy to
3 do. If it is easy to do, then it shouldn't be much of a
4 chore.

5 MR. CARROLL: Didn't somebody say you have
6 different internals than Palo Verde?

7 MR. TURK: No, exactly the same internals. I said
8 Palo Verde was a change from San Onofre and Waterford.
9 These are exactly the same, including the fixes that were
10 made to Palo Verde.

11 [Slide.]

12 MR. TURK: The only change is the change to the
13 control alternate assembly design where we have kept the 48
14 B-4C full strength, 12-finger shutdown rods, however, have
15 taken the four finger control elements and reduced them in
16 number to 20 and changed the material to silver Indium
17 Cadmium to increase the lifetime, and then added 13 part
18 length rods, while deleting -- I'm sorry -- adding 25 part
19 strength rods, Inconel rods while deleting the 13 part
20 length four finger rods that were included in the original
21 System 80 design for a net increase of 4 control element
22 assemblies with now a 20 year lifetime versus the 10 year
23 lifetime.

24 MR. CARROLL: Having said all that, translate it
25 into terms of what it does to the hydraulics of the core.

1 MR. TURK: I don't think it really has any effect
2 on the hydraulics of the core.

3 MR. MATZIE: It really doesn't have any effect.
4 If you look at the design, with that center Calandria region
5 -- I don't know if you want to put it back up -- which was
6 the major design change for System 80 relative to previous
7 plans, there's an individual shroud for every control rod
8 finger location. We don't use all the locations on System
9 80. We're using a few more of those locations on System 80
10 Plus.

11 That section where he's pointing now, the
12 Calandria region, that's where the flow turns and goes out
13 of the nozzles. All those tubes are already there for not
14 only the additional rods we've added, but other rods that
15 in a future design actually could be added.

16 MR. CARROLL: I guess where Ivan and I are is,
17 we'd like at some future time to be more comfortable with
18 the idea that the operating point changes 2 percent in flow
19 and this won't do anything bad from an internal vibration
20 point of view.

21 MR. WARD: All the problems here weren't internal.
22 I mean, there was a pump problem, for example, as I recall.
23 Are you using the same pumps as you did at Palo Verde?

24 MR. TURK: Yes, and we'll get into the reactor
25 coolant system next. There were some design changes to the

1 pumps that were made and some materials changes that I can
2 address.

3 MR. CATTON: There were problems at Palo Verde and
4 I'd like to be comforted a little bit, considering that
5 there were those problems. How much margin do you have in
6 the flow vibration, particularly if the design is so
7 similar. What have you done, and what's the rationalization
8 to lead you to believe that you have this kind of margin?

9 MR. TURK: We can address that in more depth than
10 we have here.

11 MR. CATTON: The pumps were part of the problem,
12 as I remember. So, it's sort of the whole flow loop that
13 I'd like to see addressed at one time, not start separating
14 out different pieces.

15 MR. KENNEDY: This is Ernie Kennedy. If it's
16 acceptable to the subcommittee, at one of our future
17 meetings, we will put that on the agenda and discuss the
18 Palo Verde problems, walk through how we've changed the
19 designed and what confirmatory work we have done. I will
20 have the appropriate people here to do that.

21 MR. CARROLL: All right. We'd be delighted to see
22 that.

23 MR. KENNEDY: We'd be happy to do that on one of
24 our future meetings.

25 MR. CARROLL: Okay. Moving on.

1 MR. WARD: Let me ask about ATWS now. I don't
2 know if this change in the control elements or at least the
3 -- has that changed the ATWS picture at all? As I
4 understand it, the Palo Verde type design doesn't have the
5 ability to ride out the worst ATWS scenarios, and that's the
6 same with the System 80+?

7 MR. TURK: You may have more background than I do.

8 MR. MATZIE: Let me make a few comments. The
9 issues with ATWS are typically related to the moderator
10 temperature coefficient value because that's a negative
11 feedback without control rods, obviously, and the volumetric
12 sizes to accommodate expansion of the RCS.

13 We have two things in this design. One is the
14 minimum allowable moderator temperature coefficient, which,
15 you know, is negative any time above 50 percent power, and I
16 believe we'll have at least a .5 at full power, .5 times
17 ten-to-the-minus four moderator temperature coefficient.
18 We've also, and Rick will get to that, we've increased the
19 size of the pressurizer, which allows you the volumetric
20 expansion and less pressure increase during an ATWS.

21 MR. WARD: Okay. What about the relief from the
22 pressurizer? Is that significantly -- I guess you've added
23 this, you know, depressurization system, but I don't know if
24 that --

25 MR. TURK: It really has no ATWS mitigation bases.

1 MR. WARD: Okay. It doesn't add significantly to
2 the overall capacity?

3 MR. TURK: Yes. One thing I would say about the
4 ATWS as an issue, you know, first of all the analyses were
5 done many years ago, the ones before the staff and the one
6 that you're speaking of. The resolution then moved to some
7 hardware changes in the trip system and the alternate
8 protection system, which we'll show in the I&C section how
9 we've incorporated it. At that point, the analysis really
10 stopped until we started looking at it again for System 80+.
11 That analysis work hasn't been completed yet because the
12 issue resolution is really in the hardware realm. But with
13 improvements in analysis techniques, our indication is that
14 the predicted ATWS performance is probably a lot better than
15 was predicted a few years ago. But that's basically
16 analysis techniques.

17 MR. WARD: Okay. Well, the hardware change has
18 been accepted as a -- certainly helps with the ATWS
19 situation by some likes. It isn't the total answer. Will
20 we at some point hear more detail about what a fresh ATWS
21 analysis looks like?

22 MR. TURK: We can do that, yes.

23 MR. WARD: I'd like to hear that at a future
24 meeting.

25 MR. CARROLL: At a future meeting, yes.

1 One of our members, and I guess I share his view
2 is that -- Bill Kerr believes that PWRs can make the ATWS a
3 non-problem by proper field design in terms of moderated
4 temperature coefficient, and he thinks that's a lot cleaner
5 way to solve the problem than the hardware changes, which
6 you really can't -- you're down in a reliability area where
7 it's very hard to really say that it's that reliable or an
8 order of magnitude on either side.

9 MR. TURK: We will talk later on as far as the
10 hardware, but I think we would like to come back and show
11 you the analysis results later on.

12 [Slide.]

13 MR. TURK: What I'd like to do now is move on to
14 the -- and we've kind of migrated into that area, but move
15 on to the reactor coolant system where our main focus was
16 really one of changing margins, adding margin -- in this
17 case, I mean margin in terms of this larger system that is
18 challenged last. This is kind of a summary of some of these
19 changes.

20 MR. CARROLL: This is a fairly lengthy section,
21 isn't it?

22 MR. TURK: Say again?

23 MR. CARROLL: I say this is a fairly lengthy
24 section on the coolant system?

25 MR. TURK: Yes.

1 MR. CARROLL: Okay. Why don't we take a break
2 until 10:35.

3 [Recess.]

4 MR. CARROLL: Let's reconvene.

5 MR. TURK: I wanted to move on now to the reactor
6 coolant system and address essentially the sizing changes
7 that have been made and a few other changes. They are
8 summarized on this slide in terms of larger pressurizer.
9 I'll spend a little bit more time in a minute talking about
10 steam generator and the impact of the lower hot leg
11 temperature, the changes in steam generator relative to flow
12 also.

13 But first, with regard to the pressurizer, the
14 larger pressurizer is a significant performance impact.

15 [Slide.]

16 MR. TURK: If you look here, for instance, at a
17 reactor trip and pressurizer level following that trip, you
18 see that on the standard System 80, essentially we come
19 relatively close to the top of the heater's level now with
20 significant margin to the top of the heaters.

21 [Slide.]

22 MR. TURK: Likewise, pressure shows significant
23 margin above the pressure set point for safety injection
24 actuation.

25 [Slide.]

1 MR. TURK: On the over-pressure size side, the
2 loss of condenser vacuum, which now analyses show
3 challenging primary safety valves as a design bases, we no
4 longer challenge primary safety valves on the loss of
5 condenser vacuum.

6 MR. CARROLL: That's the worst abnormal transient
7 that --

8 MR. TURK: Over-pressure transient -- the only
9 worse case is the -- no. That is really virtually identical
10 to the isolation of the steam stops. They're functionally
11 identical. We've had one isolation of feed stops at St.
12 Lucie which did lift safety valves so that would no longer
13 happen. Yes, that is the worst case.

14 MR. CARROLL: While we're talking about
15 pressurizers, do you have a surge line stratification
16 problem, or have had, and if so, have you dealt with that?

17 MR. TURK: The surge line stratification will be
18 addressed in the routing of the surge line, which is going
19 on as far as the actual routing in the containment design.
20 Lyle, do you want to add anything to that?

21 MR. GERDES: Lyle Gerdes. I have nothing really
22 to add to that, Rick, other than the fact that it is being
23 addressed in the design and the layout of the surge line.
24 So, it's being explicitly addressed in the design process.

25 MR. CARROLL: And you have had some indication of

1 problems in past designs?

2 MR. TURK: There has been indication, very layout
3 dependent indication, in some of the operating plants. I
4 know Calvert Cliffs made some measurements of
5 stratification.

6 MR. CARROLL: Okay. And how about the Calvert
7 Cliffs --

8 MR. CATTON: Heater. Well --

9 MR. CARROLL: -- heater problem. That's been
10 dealt with?

11 MR. TURK: That work is ongoing and we will be
12 incorporating the work that results in the System 80+
13 design, probably in terms of both material changes and a
14 change in the actual well design. I don't have any other
15 details on that. I don't know if anybody else does. That's
16 an ongoing issue that's working right now.

17 [Slide.]

18 MR. TURK: This figure kind of summarizes the
19 changes in the steam generator. The steam generator for the
20 EPRI requirements and in dealing with the lower TH, the
21 lower steam pressure, we've taken steam pressure now from
22 1070 to 1000 pounds; as I mentioned, hot leg pressure from
23 621 to 615. That's essentially increased or increased the
24 required heat transfer area from 124,000 square feet to
25 146,000 square feet.

1 The number of tubes has increased from around
2 11,000 to 12,000. That's been accomplished basically in an
3 overall increase in the height of the unit of about five
4 feet. The average tube length has increased from 57 feet to
5 60 feet.

6 The overall downcomer volume has been increased by
7 lowering the conical section of the generator somewhat,
8 increasing the upper dome section. So we have about 25
9 percent more liquid volume in the downcomer to boil off in
10 terms of decay heat removal margin prior to the introduction
11 of emergency feedwater.

12 MR. WARD: So the increase in the number of tubes
13 doesn't require a bigger diameter vessel, just a taller one?

14 MR. TURK: A taller vessel, yes.

15 MR. MICHELSON: What do you know about the
16 potential vibration problems for this generator since you've
17 lengthened the tubes and changed the flows, apparently
18 redesigned a flow distribution and so forth?

19 MR. TURK: Based upon essentially the same
20 geometries as the previous units and analyses -- do you have
21 anything, Regis?

22 MR. MATZIE: Yes. Regis Matzie. Let me answer
23 that. The vibration problems were detected and temporarily
24 designed, in-place design change occurred at Palo Verde.
25 Subsequent to that, we are redoing the design of the inlet

1 flow area in that distribution of economizer flow.

2 That design is going into our Korea units, and
3 we've got a testing program for that design to verify that
4 localized flow vibration problem that we did detect at Palo
5 Verde will not happen in the future.

6 MR. MICHELSON: Was any of the vibration problem
7 related to things happening in the upper part of the
8 generator along the, you know, where the tube bends are?

9 MR. MATZIE: No, it was not.

10 MR. MICHELSON: It was all down at the base?

11 MR. MATZIE: That's correct.

12 MR. TURK: Well, it was a separate issue with the
13 bat wings. We have incorporated it because it -- it's on
14 the slide. You can see here that we're talking about a new
15 bend support.

16 MR. MICHELSON: Yes. I thought you had problems
17 up there. And you're now going to lengthen the tubes
18 another five feet roughly, is that right?

19 MR. TURK: That's correct.

20 MR. MICHELSON: And you think that you won't
21 introduce any -- well, what kind of testing will you do to
22 verify this doesn't introduce any vibration problems?

23 MR. TURK: There is currently no plan to do any
24 testing.

25 MR. MICHELSON: You're just going to build it?

1 MR. MATZIE: The testing that's going to go on is
2 primarily in the economizer region where we're making a
3 design change and incorporating that into our currently
4 under construction unit.

5 MR. MICHELSON: Okay. What other changes to the
6 steam generator are there, if any, from the vintage used at,
7 say, Palo Verde?

8 MR. TURK: Most of the others are indicated here.
9 We are changing the dryer design from the CE Chevron dryers
10 to a slightly different configuration from Peerless. We've
11 increased manways sizes from 16 inches to 21 inches for
12 access. We've reoriented the primary manways on the lower
13 shell to provide a more direct access, directly up, making
14 it easier to get in and out.

15 We have added a recirculation nozzle to allow for
16 generator recirculation in a cold wet lab condition. I thin
17 those are the most significant of the changes, and I
18 mentioned a few of the others.

19 MR. CARROLL: What's a "permanently marked
20 tubesheet," lower lefthand corner.

21 MR. TURK: Yes, I see that. I'm not really sure.
22 Regis, do you have that --

23 MR. MATZIE: Regis Matzie. That's for
24 identification of tubes for inspection. I guess one other
25 thing -- I don't know if you mentioned it, Rick -- Inconel

1 690 tubing is going to this generator.

2 MR. TURK: Yes.

3 MR. CARROLL: So, what? Next to each tube, I have
4 some indication of --

5 MR. MATZIE: That's my understanding, yes.

6 MR. CARROLL: Of what? The tube number and --
7 okay.

8 Now, you do depart from the EPRI requirement
9 document in that they are advocating handholds at each
10 support plate, and you're only going to have them down at
11 the bottom?

12 MR. TURK: That is one of the departures, yes.
13 Again, because we really have not identified the advantage
14 of the hold -- I don't believe the EPRI requirement was for
15 each and every support plate, but I don't have that in front
16 of me.

17 I think one thing to point out is that some of the
18 EPRI requirements that are not -- are still under review, as
19 Regis indicated before, still looking at some of the EPRI
20 requirements in terms of the design. I think that that
21 actual requirement did come up after we had gone through
22 most of the work on the steam generator. I don't really
23 have anything else to say on that.

24 [Slide.]

25 MR. TURK: While we're discussing the reactor

1 coolant loop, one of the issues that has been of interest is
2 the issue of mid-loop operation, operating in the partial
3 drain situation work on the loop.

4 This is an area where we have worked with the EPRI
5 requirements. The staff has reviewed the EPRI requirements
6 and their draft SER makes some particular comments. Our
7 design basis has been to minimize the probability of losing
8 decay heat removal during mid-loop operation.

9 And to do that with specific design features, this
10 issue on operating plant is being addressed primarily
11 through changes in procedure.

12 Amongst those features are the installation of a
13 dedicated permanent safety grade level indication to be used
14 during shutdown to provide level detection all the way to
15 the bottom of the hot leg, to provide that indication in the
16 control room available to the operator.

17 The layout of System 80+ is very favorable in
18 comparison to many of the operating plants that have had
19 problems in this area in that first of all, the hot leg is a
20 42 inch hot leg versus a 30 inch hot leg in many four-loop
21 plants.

22 The section piping is oriented vertically directly
23 off the bottom of the hot leg to give maximum benefit of the
24 available height of water. The RHR pump or shutdown cooling
25 pump as you'll see when we look at some of the plant

1 arrangements is located in the subsphere region below the
2 spherical containment providing a maximum in net positive
3 suction head.

4 We'll see in a few minutes that the redesign of
5 the safety injection system allows for one of four high
6 pressure injection pumps could be made available
7 procedurally to supply makeup to the system if needed.

8 We have eliminated the shutdown cooling system
9 auto closure interlock from the design by providing adequate
10 over pressure protection in the RHR system. We are, and
11 this is where I alluded to the draft SER from the staff, in
12 conjunction with EPRI considering whether requirements are
13 necessary to provide a design change in the RHR nozzle off
14 the hot leg to decrease vortexing. This would essentially
15 be an increase in diameter going down into the RHR suction
16 line.

17 And then as I mentioned, the operating plants
18 through our owner's group are coming up with many
19 operationally oriented, tech spec, oriented changes in this
20 area and those of course would also be incorporated into the
21 System 80+ design.

22 MR. MICHELSON: You said something about the staff
23 safety evaluation.

24 MR. TURK: The EPRI requirements document as each
25 go and the staff then returns with a draft safety evaluation

1 report.

2 MR. MICHELSON: And it's on the EPRI document that
3 you're referring to?

4 MR. TURK: Correct, yes.

5 MR. MICHELSON: Okay. Thank you.

6 MR. TURK: We are of course paying attention in
7 that most of our design changes are encompassed in the EPRI
8 requirements.

9 MR. MICHELSON: On your slide that talks about
10 level detections at the bottom of a hot leg, aren't you
11 providing full vessel range level detections?

12 MR. TURK: We are providing full vessel range
13 protection. I need to check very quickly whether that was a
14 misprint as far as the off line system. In other words,
15 we'll have two vessel level systems.

16 We'll have the on line system which is the heated
17 Junction thermal couple which provides a stagger through the
18 upper region and the off line system. And I believe that
19 was a misprint that it goes all the way to the vessel but I
20 don't have the material to check that with me.

21 MR. MICHELSON: Maybe somebody else can confirm.
22 But, you think it really is to the bottom of the vessel and
23 not just to the bottom of the hot leg. It clearly covers to
24 the bottom of the hot leg but it goes further?

25 MR. TURK: Right.

1 MR. WARD: Could you let us know?

2 MR. TURK: We can check that, yes.

3 MR. CATTON: There were some difficulties, at
4 least I recollect, at least with the heated junction thermal
5 couple design early on. Have these been addressed? I'm not
6 even sure I recollect what they were.

7 MR. TURK: I'm not aware of that. I know of no
8 current problem with the heated junction thermal couple.

9 MR. CATTON: To get good response time, the power
10 to them had to be cranked up or something?

11 MR. TURK: I don't recall that.

12 MR. CATTON: Is there anywhere I could find out
13 what the heated junction thermal couples in the new system
14 look like relative to the old and maybe get some background
15 information on the difficulties that came up? EPRI was
16 involved in it. There were some concerns about the design
17 and the efficacy of the whole process for measuring levels.

18 MR. TURK: Okay. I really am not aware of that.
19 We can check into it.

20 MR. KENNEDY: Let me, if I could, address that
21 generally. This is Ernie Kennedy. There was back at the
22 time we were designing and backfitting the heated junction
23 thermal couple in operating plants. There was first of all,
24 a large school of thought by some plant owners that no level
25 detection at all was required and there was that series of

1 arguments.

2 On our particular heated junction thermal couple,
3 there were a number of technical concerns with the separator
4 tube where we separate the air and the water into an
5 equivalent collapsed level and whether or not there was
6 adequate supporting test data on that.

7 I believe that was all satisfactorily resolved
8 through a combination of testing and that each plant, the
9 heated junction thermal couple separator tube was divided
10 into appropriate segments consistent with the geometry of
11 the upper head.

12 So, for example, in some plants there is not one
13 continuous measurement of level from the top of the head
14 down to the bottom of the heated junction thermal couple,
15 but, it is segmented because the upper head region is
16 segmented.

17 And I believe that issue was resolved
18 satisfactorily and the test results from the operating plant
19 shows it works appropriately.

20 Since the units have gone into operation, there
21 have been some problems with the materials of some of the
22 heater wires themselves. We've had burnout problems and
23 failures of individual of the sensors.

24 That is now being fixed. There is a change both
25 to the material and I believe the manufacturing process and

1 I believe we've qualified an alternate vendor and we are now
2 supplying replacements that address those material problems.

3 Those are all the problems that I'm aware of.

4 MR. CATTON: I'd like to see somewhere where these
5 lessons are all brought to bear on what you're going to do
6 in the new plant.

7 MR. KENNEDY: Okay. I think that fits into your
8 Palo Verde discussion. As I listen here, you are asking for
9 us to tell you how we have incorporated operating experience
10 into this design in a rather broad context. I kind of get
11 that tone from the Subcommittee.

12 MR. CATTON: I think he was. I'm more narrow in
13 my view.

14 MR. KENNEDY: Okay. We'd be more than happy. If
15 you like to pick a list of specific items, then we'd be
16 happy to discuss those.

17 MR. MICHELSON: While you were out, they also
18 discussed the steam generator which is about five feet
19 taller than the old one. It has some modifications to help
20 take care of, again, some of the Palo Verde problems, steam
21 generator vibration, tube vibration.

22 MR. CATTON: It sounds to me like there's another
23 topic for future discussion.

24 MR. KENNEDY: I added that to my list to talk
25 about at our Palo Verde meeting as I was listening to you.

1 MR. CATTON: The steam generator is a different
2 beast. At least you're dealing with single phase flow
3 vibration in the core. When you're in the steam generator,
4 it's two-phased and you get into this fluid -- instability
5 that Westinghouse is talking. There's just all kinds of
6 things.

7 I don't think the analytical tools are really
8 there. I want to see you how you can culminate this.

9 MR. KENNEDY: Okay. As we go through today's
10 meeting, please, bring up these areas and I'll add them to
11 the list to discuss.

12 MR. CATTON: Maybe it might be a good idea at the
13 end for them to show us a list to make sure that you've got
14 all of them.

15 MR. KENNEDY: Okay. Yes.

16 MR. CARROLL: I would mention to Combustion that
17 ACRS has something called, an adopted plant program and Hal
18 Lewis has adopted Palo Verde and -- and I have an interest
19 in Palo Verde. Three of us are going to visit Palo Verde on
20 the 20th of April. I believe that's the tentative plan.
21 So, we're going to come back real smart about Palo Verde
22 here.

23 MR. CATTON: That's a rather big assumption you're
24 making.

25 MR. WARD: To go back just a minute to mid-loop.

1 Since you have responsibility, you know, the whole plant
2 design, under what conditions is mid-loop operation? I
3 mean, is mid-loop operation ever necessary? Is it necessary
4 to have the containment open for some operations where it
5 would be in mid-loop? Has there been any thought to the
6 relationship of mid-loop operation and whether or not
7 containment is open?

8 MR. TURK: I think the answer is, no, in the sense
9 that dictating that kind of requirement on top of a
10 maintenance outage like that, I think would severely impact
11 the kind of goals that we're trying to reach in terms of
12 availability and ongoing evolution.

13 MR. CARROLL: Put that issue on your list too
14 because I don't think that's true. I think with nozzle
15 dams, you don't really have an outage impact.

16 But, I think Dave and I both have some very long-
17 standing concerns about going into mid-loop without having
18 containment integrity.

19 [Slide.]

20 MR. TURK: Mid-loop kind of sets the stage for
21 then proceeding onto the next area where you have really
22 made the most substantial changes to the design, and that's
23 in the safeguards systems area.

24 MR. MICHELSON: Before you get to that, what are
25 inlet and outlet pipe sizes?

1 MR. TURK: 42 inch hot leg and a 30 inch cold leg,
2 four cold leg nozzles, two hot leg nozzles.

3 MR. MICHELSON: Thank you.

4 MS. TURK: Those safeguard systems, and I might
5 say this was done very very closely with the EPRI
6 requirements and the EPRI requirements in this area are
7 probably also the most significant changes or the
8 significant aspects in the EPRI requirements and this is the
9 area where we did just recently receive the staff's SER on
10 those EPRI requirements. But specifically we've gone to a
11 four-mechanic train safety injection system with -- set down
12 cooling and containment sprays essentially being separated
13 from the safety injection system. We no longer ask dual
14 service of our low pressure pumps to be both an injection
15 pump and a RHR pump.

16 We have added as we have mentioned earlier the
17 safety depressurization system to provide essentially a feed
18 and bleed capability, and one of the key differences in
19 implementing this feed and bleed system is the incorporation
20 of an in-containment refueling water storage tank which
21 provides an in-containment receptacle for the bleed process
22 and it also provides a suction source for the safety
23 injection system that does not require a recirculation
24 actuation signal. You're essentially always in
25 recirculation as opposed to initially taking suction outside

1 and having to switch over.

2 [Slide.]

3 To go into those in a little bit more depth and in
4 the interest of time I'm going to skip over the word slides
5 and look at those as we look at the system diagrams, but the
6 safety injection system as I mentioned is four mechanical
7 train divided into quadrants. You'll see when we look at
8 the containment layouts that this fits very nicely with the
9 subsphere region and the overall layout of the plant in
10 terms of separation. We now inject directly into the vessel
11 -- this feature essentially comes into play in terms of the
12 sizing of the system and not having to postulate that during
13 the design base line break that all of one train of
14 injection is lost out of that break, that then allows us to
15 go with the four pumps which are essentially the same pumps
16 we're using now in Palo Verde to provide sufficient flow for
17 all the design base accidents without the need to credit
18 automatic injection of the low pressure pump. We've
19 maintained the four safety injection tanks inside
20 containment to provide fluid on actuation, the in-
21 containment refueling water storage tank is shown here again
22 providing, as I mentioned, the suction for injection without
23 the need to switch from an external tank to recirculation.

24 What does that do for performance?

25 MR. MICHELSON: Excuse, is suction, pumps one and

1 three, intricately tied, is that correct? There's a line
2 there.

3 MR. TURK: Yes, that is correct.

4 MR. MICHELSON: There is common suction for those
5 two and then there are two over, two more on the other side.

6 MR. TURK: Correct.

7 MR. MICHELSON: Certainly they aren't four
8 independent drains with a common suction, if I'm reading the
9 drawing correctly.

10 MR. TURK: You are reading the drawing correct,
11 whether the sketch is correct --

12 MR. MICHELSON: Well, I'm reading the sketch.

13 MR. TURK: Yes, I understand that. Bob Jacquith,
14 do you remember the correct assumption in the PRA in the
15 diagram? I don't believe that cross connect needs to be
16 there.

17 MR. JACQUITH: In the PRA it was assumed that the
18 cross connect is not there and the last I recall about a
19 month ago there was a little bit of debate back and forth
20 between designers as to whether it was going to be there or
21 not.

22 MR. MICHELSON: So, you don't know yet?

23 MR. JACQUITH: Right.

24 MR. TURK: That's the answer, and we'll confirm
25 the correct configuration. It can be confirmed from the

1 actual PNID.

2 MR. MICHELSON: Now, to return to the refueling
3 water storage, is that for test purposes only?

4 MR. TURK: That is correct. It provides a full
5 flow test capability.

6 MR. MICHELSON: Well, the valve there is showing
7 normally open.

8 MR. TURK: That's the mini-re-circuit through the
9 orifice, the normal --

10 MR. MICHELSON: But at any rate again it's not an
11 independent drain because it's got a common discharge back
12 of the tank and if that valve spuriously opens during a need
13 for the systems both pumps are lost, unless there are more
14 valves than appear on the sketch.

15 MR. TURK: There are more valves, but I'm not --

16 MR. MICHELSON: The return --

17 MR. TURK: The return --

18 MR. MICHELSON: No, no, back down below, that guy.

19 MR. TURK: Yes, well, this guy is normally
20 accepting the return through the orifice mini-flow research
21 which have to be on for normal operation.

22 MR. MICHELSON: Well, that's still a substantial
23 flow, the minimum flow requirements --

24 MR. TURK: Are designed to accepted --

25 MR. MICHELSON: Well, maybe what's puzzling me, I

1 thought that you were going to build in a full flow test
2 capability.

3 MR. TURK: There is, the full flow test capability
4 is established by opening the bypass valves around the
5 orifices.

6 MR. MICHELSON: And those are intended to be
7 manual.

8 MR. TURK: That's correct.

9 MR. MICHELSON: So, the mini-flow is only a few
10 hundred gallons a minute, maybe even less than that.

11 MR. TURK: It's less than that.

12 MR. MICHELSON: But at any rate there will be a
13 partial loss of flow if you spuriously open the return line.

14 MR. TURK: This line is normally open and
15 recircuit normally -- is normally accountable for. In other
16 words, when the pump, the pump is speced, it is speced for
17 its design flow plus recircuit.

18 MR. MICHELSON: Are you saying then during an
19 accident that it is normally recirculation, recirculating a
20 portion of its flow?

21 MR. TURK: Correct, because during the accident
22 procedures you may wish to throttle down procedurally later
23 in the accident.

24 MR. MICHELSON: So, it's already accounted in the
25 design.

1 MR. TURK: Yes, now this is a sketch and not all
2 valves are shown, so in terms of doing any scenario
3 postulation would look at the actual PNID that's in the
4 FSAR.

5 MR. WYLIE: These are four 50 percent --

6 MR. TURK: These are four 100 percent.

7 MR. MICHELSON: But they're not independent
8 because again if they're -- if the problem of the valve
9 spuriously closes you've lost minimum flow protection for
10 two out of the four trains, by that sketch at least.

11 MR. TURK: I'm not, say it again --

12 MR. MICHELSON: If you're minimum -- if your valve
13 spuriously closes on the return line, it removes minimum
14 flow protection from two out of the four trains, now that's
15 hardly independent.

16 MR. TURK: That's correct. I also said they're
17 mechanical in that two pumps are essentially supplied from
18 the same diesel generator, they're not four diesel generator
19 trains either, so we have a two-division system.

20 MR. MICHELSON: Okay, it's a two train system.

21 MR. TURK: It is a two train --

22 MR. CARROLL: It could take the power off.

23 MR. MICHELSON. Yes.

24 MR. WYLIE: I guess somebody's going to over what
25 you do when you take one diesel out of service.

1 MR. TURK: Yes, we will cover that from an
2 electrical standpoint. The answer is per the EPRI
3 requirement we have included an alternate AC power source.

4 MR. WYLIE: You would fire that up.

5 MR. TURK: That would be -- that's correct.

6 MR. MICHELSON: This is two train electrical as I
7 understand it.

8 MR. TURK: Two train electrical with a -- we'll
9 get into that a little later in the afternoon with an
10 alternate AC source that has the capability of picking up
11 one train.

12 [Slide.]

13 The question was asked earlier about the
14 capability to handle a given break diameter, this shows a
15 comparison of the system 80+ versus system 80. System 80,
16 if you remember, had only two high-pressure injection pumps
17 in each train. We now have -- has one in each train, two
18 total, we now have four, two in each train. This analysis
19 assumes the loss of the diesel generator, in other words,
20 single-failure analysis shows that for the 10-inch diameter
21 cold leg break, previously we were showing --

22 MR. MICHELSON: Well, the largest cold leg break,
23 though, can be thirty inches.

24 MR. TURK: The double ended rupture, yes, the 10-
25 inch size is the largest line that we have coming off

1 the -- that's the RHR line I believe.

2 MR. CARROLL: Now, okay, so smaller -- how about
3 hot leg breaks?

4 MR. TURK: In terms of performance?

5 MR. CARROLL: Yes.

6 MR. TURK: Again, we have a larger flow capacity
7 available at higher pressures, so our system is now much
8 more attuned to the small break. The hot leg performance
9 would be -- the large break hot leg performance would be
10 essentially the same.

11 MR. CARROLL: There are no lines coming off the
12 hot leg is what you're saying.

13 MR. TURK: The only one would be the surge line to
14 the pressurizer.

15 MR. CARROLL: Right, how big is that?

16 MR. TURK: That's either a 10-inch or 12-inch
17 line, and I believe that's -- because that's a -- I believe
18 it's a nominally 12-inch schedule 160 line which I'm not
19 sure what it is in terms of actual diameter, internal
20 diameter, it's significantly less than 12 inches.

21 MR. CARROLL: But you can handle that break also
22 without uncovering --

23 MR. TURK: No, I don't believe so, I don't believe
24 the double ended of the search line, we don't have a LOCA
25 analyst with us, but we can answer that.

1 MR. MICHELSON: What accounted for the improvement
2 on system 80+.

3 MR. TURK: The improvement is essentially the
4 increased high-pressure injection capacity, four pumps
5 instead of two pumps, and the injection directly to
6 the vessel where there's no flow loss, minimum flow loss
7 to --

8 MR. CARROLL: Plus bigger pressurizers.

9 MR. TURK: Bigger pressurizer, yes, that factors
10 in also that more -- there's more -- the larger inventory on
11 the secondary side of the steam generator also helps in that
12 it takes up some of the heat.

13 MR. MICHELSON: In doing the analysis, did you
14 assume single failure?

15 MR. TURK: Yes.

16 MR. MICHELSON: And assumed the single failure is
17 the electrical supply to two of those four HPI pumps, since
18 it's a common electrical source.

19 MR. TURK: Right.

20 MR. MICHELSON: Then you're down to two pump
21 operation, is this drawing the two pump operation?

22 MR. TURK: Yes it is.

23 MR. CARROLL: What happens if one of those two
24 pumps happen to be out for maintenance.

25 MR. TURK: Yes. That is true.

1 MR. WYLIE: It would if you assumed one diesel
2 generator.

3 MR. TURK: As far as that scenario being treated,
4 that scenario would be treated in our PRA, and I don't
5 believe it would be a core melt scenario. I believe that
6 one pump, although it may result in core uncover, is not
7 treated. Bob, do you remember how that case is analyzed in
8 the PRA?

9 MR. JACQUITH: One pump is sufficient.

10 MR. TURK: So one pump from a PRA standpoint is
11 sufficient to prevent. What do you use as the criteria?

12 MR. JACQUITH: It keeps the core below 2200
13 degrees.

14 MR. MICHELSON: I am still puzzled by the figure.
15 If the figure for System 80, how many pumps was operating
16 when you made that calculation?

17 MR. TURK: Only one pump.

18 MR. MICHELSON: Is that a one-pump figure?

19 MR. TURK: That is correct.

20 MR. CATTON: Are these calculations done using
21 best estimate?

22 MR. TURK: These calculations, no, these are
23 calculations using the LOCA codes. These are the design
24 basis calculations. These are the Chapter 6, Chapter 15.

25 MR. CATTON: I hear you. Are you guys going to

1 enter the real world of best estimate calculations, or stay
2 with the fiction of Appendix K?

3 MR. TURK: The calculations that Bob Jacquith just
4 talked about, as far as analyzing for our PRA response, what
5 we get with one pump, is all based on best estimate
6 calculations.

7 MR. CATTON: Has your best estimate code been
8 qualified?

9 MR. JACQUITH: Our best estimate code has not been
10 qualified.

11 MR. CATTON: Is it being qualified?

12 MR. JACQUITH: It is not being qualified. It was
13 not quite correct that we are relying solely on it. We are
14 relying on the, primarily on the safety codes. We are using
15 the best estimate codes where we see that it is needed, in
16 order to do scoping and --

17 MR. CATTON: I think you misunderstood me, or at
18 least misunderstood my concern. My concern is that we are
19 entering a new world and we are proposing a new reactor
20 called System 80-plus, yet you are using tools that are
21 antiquated. It seems to me that that is kind of silly.
22 Shouldn't you be using best estimate in the new world,
23 completely? We now have the best estimate tools. NRC has
24 promulgated a new rule that allows you to use best estimate.
25 You don't have to work in this world of fiction. Why do you

1 do it?

2 MR. TURK: I think the answer to that, relative to
3 the Chapter 15 analysis, was one of being able to show,
4 using the old tools, that we meet the requirements, and not
5 having the need.

6 MR. CATTON: Why not show that you meet them with
7 new tools?

8 MR. TURK: Ernie?

9 MR. KENNEDY: I think I understand the question,
10 let me see if I can address it. This is Ernie Kennedy
11 again.

12 MR. CATTON: It is a simple question.

13 MR. KENNEDY: We have not yet taken advantage of
14 the revision to Appendix K that allows us to update our
15 models. One reason of that is, to be perfectly frank with
16 you, largely commercial. None of our current operating
17 customers have expressed an interest in asking us to go do
18 that work for them, to present the model to the NRC and get
19 it approved. So from a licensing point of view, we have a
20 best estimate model. It is not going anywhere right now.
21 Your question on System 80-plus is a good one, why we are
22 not at least pursuing that on System 80-plus, as far as
23 applying that new model. And I will go back and look into
24 that one.

25 MR. CATTON: I think Westinghouse is pursuing it

1 because their system has a lot of margin. Your not pursuing
2 it sort of leads me to believe you don't have very much
3 margin. And you certainly wouldn't want to leave me with
4 that fiction, would you?

5 MR. KENNEDY: We would not want to leave you with
6 that impression.

7 MR. CATTON: Good.

8 MR. CARROLL: So that is on our list of topics for
9 a future meeting.

10 MR. MICHELSON: Let me clear up one more point on
11 System 80. What was the HPI pump size for System 80,
12 roughly?

13 MR. TURK: I don't recall the rated gallons per
14 minute.

15 MR. MICHELSON: Well, let me ask, is it the same
16 pump for System 80-plus?

17 MR. TURK: It is the same pump. Only 4 instead of
18 2.

19 MR. MICHELSON: When I look at your previous
20 slide, I still have a great deal of difficulty wondering
21 why, if the principal is just one extra pump pumping during
22 those about 60, 70 seconds, how you can make up all that
23 volume difference identified by that curve, I don't know.
24 There's got to be something else. It hardly whimpered with
25 two pumps, and it dumped way down to the 12-foot level with

1 one pump, but recovered immediately at 100 seconds.

2 MR. TURK: The pressurizer was a factor.

3 MR. CATTON: It could be that in the two-phase
4 mixture it is 99 percent void, Carl; then it would do that.

5 MR. MICHELSON: If it was void enough, and that is
6 the two-phase mixture, all right, if it were void enough --

7 MR. CATTON: And this curve just really isn't
8 adequate to tell you what is going on.

9 MR. MICHELSON: Yes. I guess maybe that is it.
10 I'll take their word for it for the moment.

11 MR. CATTON: You get really nothing from this
12 curve.

13 MR. MICHELSON: Yes. It left me a little cold.

14 MR. CATTON: If you don't have the void fraction
15 distribution, then you have no idea what the heat transfer
16 capability of a two-phase mixture is. So this curve really
17 tells us nothing.

18 MR. MICHELSON: I want to make sure the pumps are
19 essentially the same pumps.

20 MR. CARROLL: What does two-phase mixture height
21 mean?

22 MR. CATTON: Typically it is a 99 percent cutoff.

23 MR. CARROLL: I guess that is the question in my
24 mind.

25 MR. MICHELSON: But they are both two-phase

1 mixture curves, of course. Yet in one case it hardly
2 changed, and in other case it bottomed out.

3 MR. CATTON: But again, you know, if it is just a
4 few percent moisture, it is not a big difference on that
5 curve.

6 MR. CARROLL: What does it mean; what is the
7 definition of --

8 MR. TURK: I don't have the actual definition with
9 me. But we can get that.

10 MR. MICHELSON: Those pumps, I don't think, are
11 that big. But you weren't able to tell me the EPM rating
12 and pressure or something.

13 MR. CATTON: You really need to have a better
14 picture, and you need to have other information, void
15 fraction distribution, all sorts of things, in order to make
16 an assessment of coolability of the core. You can't, from
17 this diagram by itself. But that is going to be part of the
18 future topic, right?

19 MR. CARROLL: I believe they got it all.

20 [Slide.]

21 MR. TURK: The major differences in the shutdown
22 cooling and containment spray system, again based upon the
23 EPRI requirements, are, first of all, the incorporation of a
24 second heat exchanger, a dedicated containment spray heat
25 exchanger. Whereas on System 80, the heat exchanger was

1 shared between the two systems, the two loops are
2 essentially again from the incontainment refueling water
3 storage tank through the containment spray heat exchanger,
4 through back and into the spray headers in the containment,
5 or the shutdown cooling loop as we mentioned, off the bottom
6 of the hot leg cooling and back into the reactor vessel.

7 The most significant change here, though, is
8 probably not in configuration, but in upgrade of the overall
9 system design pressure. That is, the portion of the system
10 outside containment, outside the third isolation valve, has
11 been upgraded to a 900-pound design pressure, which is
12 sufficient to ensure that even pressurized as high as 2,500
13 pounds, we would not expect failure of the system.

14 MR. MICHELSON: Those systems are cross-tied. Is
15 the other one rated for the 2,500-pound also?

16 MR. TURK: Yes, they are both rated for that.

17 MR. MICHELSON: The fact is, there must be some
18 isolation valves, but you just didn't show them going back
19 through the containment, in the suction for the containment
20 spray.

21 MR. TURK: Yes. There would be a similar
22 isolation.

23 MR. MICHELSON: Both systems are 2,500-pound
24 system, then?

25 MR. TURK: Both systems are 900-pound systems,

1 when looked at in terms of ultimate failure.

2 MR. MICHELSON: Now, you think ultimate failure
3 includes the seals on the pumps, things of that sort?

4 MR. TURK: It would not prevent seal leakage to
5 some degree.

6 MR. MICHELSON: How large a leak do you expect
7 from a containment spray pump when it is pressurized to four
8 times design, well over four times the design of the seal?

9 MR. TURK: We do not have that figure yet.

10 MR. MICHELSON: Those will be 900-pound seals?

11 MR. TURK: Yes.

12 MR. CARROLL: How about the tubes and the heat
13 exchangers?

14 MR. TURK: The heat exchanger will be designed for
15 900 pounds.

16 MR. MICHELSON: There isn't the same margin in the
17 tubes as there is in the pipe, so they will burst first.

18 MR. TURK: Bill, do you have any information on
19 that from Tom or not?

20 MR. FOX: No.

21 MR. TURK: Okay.

22 MR. CARROLL: I guess the Staff keeps telling us
23 about designing these systems to accommodate primary system
24 pressure. But we never seem to get very good answers about
25 some of the things like seals, and heat exchangers.

1 MR. TURK: We will provide information on seals
2 and heat exchangers.

3 MR. CARROLL: And are their gasketed joints in the
4 system, and things like that.

5 MR. MICHELSON: Valve bonnets?

6 MR. CARROLL: It's not too tough to design to get
7 that rating on the piping, but there is a lot more to these
8 systems than just piping.

9 MR. MICHELSON: The piping is probably the
10 strongest thing in there and the most over-designed. But
11 the valve bonnets and molding and so forth are not
12 necessarily designed anywhere near those kind of allowances.
13 The valve body is, but not necessarily the molding.

14 [Slide.]

15 MR. TURK: The other safeguard system that was
16 mentioned earlier and that is new to the System 80 is the
17 safety depressurization system.

18 It's being added really for several different
19 functions. The one of most note I think is the function of
20 a safety grade method to depressurize the reactor coolant
21 system when there is no heat removal from the steam
22 generators and that is accomplished by two trains of valving
23 off the pressurizer that looks configuration-wise as a PORV
24 configuration may be, the difference being as they are not
25 pilot operated or power operated relief valves but rather

1 the manual valves.

2 MR. CATTON: What is the size of the lines?

3 MR. TURK: The lines are I believe 10 by 6, 10
4 inch inlet, 6 inch outlet, but I would have to check that,
5 and then the second one would be a 6 by 6.

6 MR. MICHELSON: I suspect it is 6 inches into the
7 valves and 10 inches out, isn't it?

8 MR. TURK: Oh, you're correct.

9 MR. MICHELSON: It's got to be or should be.

10 MR. TURK: Six inch inlet, 10 inch outlet.

11 MR. MICHELSON: What kind of valve will you use to
12 take that kind of a pressure drop?

13 MR. TURK: These will essentially be block valves,
14 the same valves that would be used for PORV block valves.

15 MR. MICHELSON: That's just the gate valves used
16 in that case.

17 MR. TURK: Right.

18 MR. MICHELSON: And you are going to use gates
19 here but you are not going to throttle with them, just going
20 once wide open and leave it there?

21 MR. TURK: We provide a small vent capability up
22 through the gas vent system.

23 MR. MICHELSON: Are you intending to throttle with
24 these depressurization valves?

25 MR. TURK: We have not identified a throttling

1 need nor is there a throttling design basis. This is a
2 depressurization.

3 We did at one time have a design based on an
4 upstream throttle valve that if we identified a design basis
5 requirement that required a throttling capability we would
6 use but the basic design function now is twofold.

7 One is in the case of loss of all heat removal to
8 the steam generators, which is essentially a feed-and-bleed
9 operation and establishing makeup through the high pressure
10 injection system.

11 The other is in a severe accident scenario, also
12 opening the valves to allow the plant to depressurize.

13 MR. WARD: When you say feed-and-bleed and supply
14 through the high pressure injection system but you're really
15 just opening up these, what are they, six inch valves wide,
16 with no provision for controlling flow, so you've been
17 calling it feed-and-bleed. It's really not. It's
18 depressurization.

19 Then why -- I mean what does the transient look
20 like? Do you need the high pressure injection then?

21 MR. TURK: Yes.

22 MR. WARD: Okay. The pressure doesn't come down
23 to the point where the low pressure injection pumps will
24 handle it?

25 MR. TURK: There are no low pressure injection

1 pumps.

2 MR. WARD: Okay.

3 MR. TURK: There are no low pressure injection
4 pumps.

5 MR. CARROLL: Now how do you deal with steam
6 generator tube ruptures when you are trying to equalize
7 pressure between primary and secondary?

8 MR. TURK: When heat removal conditions are
9 maintained on the secondary side, okay, and it's a matter of
10 just venting the depressurizer in order to reduce plant
11 pressure, overpressure, where we would normally use main
12 sprays if reactor coolant pumps are available which are not
13 safety grade or then go to auxiliary spray which is also a
14 non-safety system.

15 If neither of those are available, then we have a
16 small vent line of approximately one inch, again safety
17 grade, that allows us to vent off the pressurizer, to back
18 up the aux spray capability and bleed down pressurizer
19 pressure while removing heat through the steam generators.

20 MR. CARROLL: And that gets you down to an
21 equalized condition quickly enough to avoid serious offsite
22 doses?

23 MR. TURK: Yes.

24 MR. MICHELSON: That's a one inch pipe?

25 MR. TURK: It is a one inch line, yes.

1 This system normally exists. The other system,
2 the other function of this system is to bleed non-
3 condensible gases off the top of the pressurizer and off the
4 top of the upper head.

5 You can see in the upper head arrangements it is
6 orificed because the only function there being the non-
7 condensible gases. Unorificed the one inch line is shown to
8 be sufficient to bleed down pressurizer pressure as long as
9 heat removal can cool the system as well and you are cooling
10 down as well.

11 All you have to do is relieve the saturated
12 conditions in the pressurizer.

13 MR. MICHELSON: Okay. At some point I think I
14 would like to be led through the various steam generator
15 tube rupture scenarios to be satisfied --

16 MR. TURK: Yes, we can do that.

17 MR. MICHELSON: But you're within the capability
18 of the reactor drain tank during that bleed down?

19 MR. TURK: Yes. The reactor drain tank then also
20 overflows or actually rupture disks to the in-containment
21 refueling water storage.

22 MR. MICHELSON: Then you are not within the
23 capability of it, so you rupture a disk and flow over.

24 MR. TURK: No. I do not know that we rupture a
25 disk for that scenario. I am just saying that the physical

1 design of the ruptured disk is there. Whether it ruptures
2 or not depends upon the length of the bleed and that drain
3 tank is the tank that now takes the safety valve flow-down
4 so my guess is that for any tube rupture scenario you would
5 not rupture the rupture disk.

6 MR. MICHELSON: Using the same size drain tank
7 yet, for this new arrangement?

8 MR. TURK: Yes.

9 MR. CATTON: Where does the relief from the steam
10 generators go?

11 MR. TURK: The safety valves, steam generator
12 safety valves?

13 MR. CATTON: Right.

14 MR. TURK: To atmosphere.

15 MR. CARROLL: Okay. They are on the steam line.
16 You don't dump it --

17 MR. TURK: They are outside.

18 MR. WARD: I'm sorry, I may have missed it but in
19 handling the steam generator tube rupture, do you expect
20 that the auxiliary spray will be able to -- I mean is this
21 the primary approach?

22 MR. TURK: This is the backup.

23 MR. WARD: It's the backup.

24 MR. TURK: But it is the safety grade method.

25 One of the basic design changes in compliance with

1 the EPRI requirements is to go with a non-safety grade
2 chemical volume control system, which is where the auxiliary
3 spray is normally supplied from.

4 If you remember, one of the issues on Palo Verde
5 was the issue of establishing that function as a safety
6 grade function within this non-safety system so the
7 conclusion we reached was that that system would be a non-
8 safety system and this is the analyzed system for safety
9 grade.

10 In the normal occurrence of a tube rupture, 99
11 percent of the time the operator is going to have his main
12 sprays available to him with reactor coolant pumps running.

13 Even if he doesn't have reactor coolant pumps, he
14 will probably have the aux spray even if he has lost off-
15 site power because you'll see we have this gas turbine that
16 we mentioned earlier which is capable of supplying the
17 charging pumps for aux spray.

18 This then becomes the final line in the tertiary
19 depressurization.

20 MR. WARD: Okay. So main spray is off the reactor
21 coolant pumps. RH spray is off the charging pumps. Neither
22 of those are safety-grade.

23 MR. TURK: Correct.

24 MR. WARD: But this is a safety grade system?

25 MR. TURK: That's correct.

1 MR. WARD: Okay.

2 MR. MICHELSON: The big valves to depressurize
3 with are manually only operated? By that I mean remote
4 manual?

5 MR. TURK: Remote manual only, yes.

6 MR. MICHELSON: Are they on different divisions,
7 is that the idea or something?

8 MR. TURK: Yes.

9 MR. MICHELSON: With the three and the four?

10 MR. TURK: Right.

11 MR. MICHELSON: So there is no spurious opening of
12 both of them --

13 MR. TURK: Right.

14 MR. MICHELSON: -- because this is a very large
15 hole in the pressurizer compared with spurious opening of a
16 relief valve which is about a one inch or so port. This is
17 a six inch hole.

18 MR. TURK: The capacity of these valves is
19 virtually identical to the capacity of a PORV that would be
20 needed to provide any kind of feed-and-bleed capability.

21 MR. MICHELSON: You mean this is equivalent to a
22 one inch port PORV?

23 MR. TURK: No, a one inch PORV would not provide
24 you a feed-and-bleed cooling capability.

25 MR. MICHELSON: No, it doesn't say that. I

1 thought you meant compared with more normal PORVs which are
2 about an inch and a half.

3 MR. TURK: No, I guess I was referring to, for
4 instance, the PORVs that were supplied to provide a feed-
5 and-bleed cooling capability as opposed to an overpressure
6 protection capability.

7 MR. MICHELSON: I was just trying to think in
8 terms of the kind of depressurization rate you get from a
9 six inch gate valve. That depends almost entirely on what
10 kind of sparger you have put in the refueling water storage
11 tank as to what the ultimate capacity is but it's very hard
12 so that depressurizes very fast.

13 MR. TURK: Like a stuck open safety valve.

14 MR. MICHELSON: I think it's even bigger than
15 that. The safeties don't have as big a port as those gates.

16 MR. TURK: Well, the sizing on the valve is
17 essentially the same as a safety valve.

18 MR. MICHELSON: Well, safety valves, those are not
19 more than three inch ports at best, are they?

20 How big a safety valve are you putting in? Let's
21 settle it that way.

22 MR. TURK: I think the 410s --

23 MR. MICHELSON: What's the port size?

24 MR. TURK: I don't know that dimension offhand but
25 we can provide that.

1 MR. MICHELSON: But the gate valve is a six inch
2 hole.

3 MR. TURK: Yes. I may have misspoken on the two
4 gate valves.

5 We may have decided on the upstream globe valve
6 and we can verify that and get back to you.

7 MR. MICHELSON: That would make a lot of
8 difference, of course. Yes.

9 MR. WARD: We should hear more about that.

10 MR. MICHELSON: Yes, I think we need to hear a lot
11 more about that.

12 MR. CARROLL: Do you intend to test these valves
13 to prove that the motor operators will close them under
14 maximum flow conditions?

15 MR. TURK: We have not addressed the actual -- are
16 you talking about a preoperational test, or are you talking
17 about in-service testing or both?

18 MR. CARROLL: Or a prototype test.

19 MR. WARD: Design verification, really.

20 MR. TURK: It would be a function of whether or
21 not the actual valves we choose were tested as part of the
22 EPRI valve test program back a few years ago. I think the
23 requirements -- in meeting those requirements, if the valves
24 have not been previously covered by that EPRI valve test
25 program, they would have to be --

1 MR. MICHELSON: We know a lot more about it than
2 we did then, and you'll find that there's a lot more that
3 has to be done, even if that EPRI work were to be repeated.
4 It just was the start of the motor operated valve problems,
5 as you probably are well aware.

6 You never told me that you really had to reclose
7 those valves. You told me the idea was to open them once
8 and dump it.

9 MR. TURK: That's correct.

10 MR. MICHELSON: I assume that's two lines that
11 will be opening to dump at the same time; is that correct?

12 MR. TURK: How the operator would address that in
13 procedure; I don't think we've got to the point of writing
14 the procedure. Whether he would be told to open one; verify
15 it's flow and if he didn't get it open, open the other.
16 They are redundant in function.

17 MR. MICHELSON: I was trying to get your intent
18 mainly. It would probably be just one at a time.

19 MR. TURK: I believe so. They are sized
20 redundantly. Each one is sufficient.

21 MR. MICHELSON: But no intention to reclose them?

22 MR. TURK: Certainly there's an intention to
23 reclose them. They are not --

24 MR. MICHELSON: There is no need to reclose them.

25 MR. TURK: That's correct.

1 MR. MICHELSON: You do the analysis as if there
2 was a one -- then you don't worry about reclosure, but
3 that's an awful fast depressurization.

4 MR. CARROLL: Does one control switch open both
5 valves in series?

6 MR. TURK: Ken?

7 MR. SCAROLA: They are separate -- Ken Scarola; I
8 am supervisor of I&C. They are four channel valves where we
9 have an A, C, B and D. There are four separate switches on
10 each one of those valves.

11 MR. WARD: Now, if those valves are -- you say
12 they have the same flow capacity -- or the system does -- as
13 the safety valve has --

14 MR. TURK: Right.

15 MR. WARD: That means they do -- it seems to me
16 they would contribute significantly to an ATWS scenario.

17 MR. TURK: If you could open them fast enough.

18 MR. WARD: All right.

19 [Slide.]

20 MR. TURK: The other system that we have taken
21 from the balance of plant and added as a dedicated
22 engineering safeguard system is the emergency feedwater
23 system. We have a separate emergency feedwater system and
24 startup feedwater system.

25 The emergency feedwater system is dedicated only

1 to emergency functions. It's a four pump system that
2 consists of one motor and one turbine driven pump per train.

3 MR. MICHELSON: Excuse me. Before you go to that,
4 I have one more question on your safety valve arrangement.
5 You show a common discharge header. Is it really common, or
6 each safety valve has its own header, or each one of these
7 depressurization valves?

8 MR. TURK: It will probably be a separate header
9 for the safety valves and a separate one for the
10 depressurization valves.

11 MR. MICHELSON: But all the safety valves would be
12 on one, hopefully very large, header so it doesn't affect
13 the setpoint.

14 MR. TURK: That's correct, and that's the way it
15 is at Palo Verde.

16 MR. MICHELSON: But a separate header for the gate
17 valves?

18 MR. TURK: Yes.

19 MR. MICHELSON: Okay, thank you.

20 [Slide.]

21 MR. TURK: The emergency feedwater system, as I
22 said, a four pump system and a turbine motor for each steam
23 generator. One other key feature that we have eliminated is
24 that on the current systems, there's a relatively convoluted
25 isolation logic that measures steam pressure and it tries to

1 identify a good generator or a bad generator and
2 appropriately isolate.

3 We have eliminated that logic by installing flow
4 limiting cavitating venturis and appropriately designing
5 both the containment and the reactor coolant system to
6 accept the flow from the system to, for instance, a broken
7 steam generator and then rely on manual isolation after 30
8 minutes, as opposed to trying to concoct an automatic
9 isolation system.

10 MR. CARROLL: I worry about cavitating venturis
11 for some reason. Do you intend to do some testing?

12 MR. TURK: We're using essentially the San Onofre
13 emergency feedwater system. We backfed -- Combustion
14 Engineering, working with San Onofre cavitating venturis to
15 that design for essentially the same function.

16 The flow rates here are actually a little less.

17 MR. CARROLL: Have you actually determined that
18 the thing doesn't tear itself up?

19 MR. TURK: It's been operating for -- that was
20 about five or six years ago that we made that installation.
21 I don't have any data in front of me or performance, but
22 that is our basis for the design. We can provide some
23 additional information.

24 MR. CARROLL: Your situation is different than
25 Westinghouse where they're using, because you're just

1 dealing with one steam generator.

2 MR. TURK: What is the concern in the other
3 design?

4 MR. CARROLL: That if this thing breaks piping
5 because it vibrates so badly, you'd end up blowing down two
6 steam generators.

7 [Slide.]

8 MR. TURK: Several issues associated with the
9 safeguard systems, we'll go through and try to indicate our
10 approach. One of the key issues -- and we've alluded to it
11 a couple of times today - is the in-service testing of --

12 MR. MICHELSON: Excuse me. Before you get to
13 that, I guess you're not -- are you going to discuss any
14 further the cross tying of the emergency feedwater system?
15 I thought that that was kind of an issue also.

16 MR. TURK: There is a cross tie shown here,
17 isolated, and essentially, it provides the capability to
18 address those multiple failure scenarios; in other words,
19 scenarios beyond the design bases, where for some reason
20 this may not be the generator that needs to be supplied and
21 that we have multiple failures in the train aligned to the
22 good steam generator, affectively allows any pump to feed
23 any steam generator, or any pump to feed each steam
24 generator.

25 It was added to our design and it shows up as an

1 exception to the EPRI requirements, only because the EPRI
2 requirements are based on a four steam generator system.
3 From a PRA standpoint, we show a clear advantage. We've
4 talked about it with EPRI and they've agreed -- at least I
5 believe they agree -- that for a two steam generator system,
6 that is the correct flexibility.

7 MR. MICHELSON: They are providing four
8 independent feedwater systems then; one to each generator in
9 the EPRI case?

10 MR. TURK: The EPRI case is looking at four steam
11 generators.

12 MR. MICHELSON: Feedwater to each of them
13 independently?

14 MR. TURK: No, it's not independent. Two steam
15 generators -- any -- one pump can feed either of two steam
16 generators, so it's not a total separation; it's a geometry
17 factor that is affected by one steam generator versus two.

18 MR. MICHELSON: Okay, thank you.

19 MR. TURK: Our approach relative to in-service
20 testing pumps and valves, we've seen for some of the major
21 cases, the major pumps, we have designed in full-flow test
22 capability. We are complying with the EPRI requirements.

23 We are using the documented test program at Palo
24 Verde for which an SER has been issued, and are establishing
25 a goal of trying to address by design any exceptions that

1 Palo Verde had to take in their establishment after the fact
2 of a test program.

3 MR. MICHELSON: How do you test your safety
4 injection pumps to full flow?

5 MR. TURK: They can be recircled to the in-
6 containment refueling water storage tank.

7 MR. MICHELSON: You kind of assured me a little
8 earlier that that was just a mini flow line. The bypass --

9 MR. TURK: The bypass --

10 MR. MICHELSON: That's a big pipe, but it may even
11 flow normally.

12 MR. TURK: Yes.

13 MR. MICHELSON: Okay. So, the bypasses are
14 cranked open to do it?

15 MR. TURK: Yes.

16 MR. MICHELSON: Okay. Good. How big a pipe,
17 then, is that?

18 MR. TURK: I don't have that size off-hand.

19 MR. MICHELSON: Okay. It's got to be large.

20 MR. TURK: Yes. Really, probably the correct way
21 to show that is to show the valve in line and the orifice as
22 a bypass, if you want to be --

23 MR. MICHELSON: Because that's the norm.

24 MR. TURK: You know, that would make it a little
25 diagrammatically correct.

1 Okay. This is really something that at the phase
2 of development we're in, we're really just entering into in
3 terms of the details on a per-valve basis.

4 MR. MICHELSON: Now, you're acquainted with
5 Generic Letter 89-10, I'm sure.

6 MR. TURK: Yes.

7 MR. MICHELSON: And I assume that anything done
8 for this plant will certainly meet the requirements at least
9 as proscribed there?

10 MR. TURK: Right. What we're saying is that we're
11 starting with the known response on the System 80 design
12 which is largely consistent, and then we want to go in and
13 address the exceptions that had to be taken.

14 MR. CARROLL: Check valve testing is also emerging
15 as a big issue that ought to be factored in.

16 MR. TURK: Yes.

17 MR. CATTON: Are you participating with NIC, the
18 Nuclear Industry Check-valve Program?

19 MR. TURK: On the service side of our
20 organization, there is participation, and then the feedback
21 comes from the service side of our organization through the
22 system. So the answer is yes.

23 MR. CATTON: Okay.

24 MR. CARROLL: There are probably a lot of things
25 one can do at the design stage to make testing of check

1 valves more easy.

2 [Slide.]

3 MR. TURK: Source term. Source term again is an
4 issue on the EPRI requirement document, one that both EPRI
5 and the staff I know have talked to the committee about it
6 on several occasions.

7 Our approach right now, primarily based upon what
8 we have heard and been told by the staff as far as what they
9 see as the relative timing necessary for approval, is to use
10 currently approved methodology -- that is the TID -- for our
11 design base analysis, that is the Chapter 6, Chapter 15
12 analysis in the SAR, meeting the requirements of 10CFR 100.

13 We are using, in our severe accident evaluations
14 for the PRA, a more realistic source term.

15 MR. CATTON: Did you develop --

16 MR. TURK: That discussion is ongoing and is
17 related to the discussions with EPRI on the subject.

18 MR. CATTON: Did you develop your own method of
19 doing a more realistic source term calculation, or are you
20 just going to use what EPRI advises?

21 MR. TURK: I think the actual source terms comes
22 about in using the MAPP code. In other words, we're using
23 -- Regis, do you want to respond?

24 MR. MATZIE: Yes. Regis Matzie. We're using MAPP
25 code as it's being modified to support advanced lightwater

1 reactors, and that, I think is consistent with the EPRI
2 source term direction. So, we're in line, I think, with the
3 industry with respect to a more realistic source term for
4 beyond design basis events that are accidents.

5 MR. CATTON: When I read through some of the paper
6 that came before this meeting, there was discussion of
7 something called MAPP-3B and MAPP-DOE. What's what? What
8 are these codes? Where do they come from. I know what the
9 MAPP code is, but what does the 3B mean?

10 MR. MATZIE: Regis Matzie again. MAPP-3B is, I
11 think, the latest version of the MAPP code that is under
12 extensive V&V, verification and validation, through EPRI,
13 and is probably going to be used in the IPEs by the
14 operating reactors.

15 The MAPP-DOE is a version that has had some
16 modifications to incorporate the features being added to
17 ALWRs. As an example, to get an IRWST, I believe, into the
18 coding arrangement of the containment and other features
19 like that, there needed to be software changes to MAPP.

20 MR. CATTON: Does the DOE mean that DOE paid for
21 it?

22 MR. MATZIE: That's correct. DOE is sponsoring
23 the advanced reactor severe accident program, and that's
24 what that means.

25 MR. CATTON: Okay. Thank you.

1 [Slide.]

2 MR. TURK: Some of the remaining issues -- we have
3 already touched on the issue of the intersystem LOCA where
4 our primary concern has been to shut down cooling system and
5 increasing the design pressure to 900 pounds, which we
6 mentioned.

7 We have extended the Class I portion of the system
8 out one more valve. Rather than two-valve isolation, we're
9 going with three-valve isolation within the Class I portion
10 of the system.

11 MR. MICHELSON: Does that mean two outside and one
12 inside normally or --

13 MR. TURK: Yes.

14 MR. MICHELSON: -- is it normally two inside?

15 MR. TURK: I hesitate to look at the sketch to
16 answer that, but I believe that's correct: two outside, one
17 inside.

18 MR. MICHELSON: Or is it just a mixed bag?

19 MR. TURK: I don't think it's an absolute in all
20 cases, but for most cases, it is; it's two outside, one
21 inside.

22 MR. MICHELSON: Okay. Thank you.

23 MR. TURK: There are other aspects that we're
24 applying on all systems in one way or another. In other
25 words, that the system ultimate at rupture strength is equal

1 to the pressure, and if it's not, that we can show that the
2 charging pumps can make up the lost inventory, for instance
3 in the sampling system; that the system break would actually
4 occur inside containment and not result in --

5 MR. CARROLL: Notice you're saying system piping.
6 That's where we have a problem.

7 MR. TURK: I understand your concern from before
8 as far as seals and valve caps and --

9 MR. MICHELSON: And instruments and things like
10 that.

11 MR. TURK: Again, this is the key, I think, to the
12 acceptability or non-acceptability of those kinds of
13 performances, and we --

14 MR. MICHELSON: Keeping in mind the real concern
15 is that these breaks will occur in what otherwise might be
16 designed only for mild environments and whatever because
17 this was never an anticipated rupture mode even because of
18 the unusual way in which high pressure is gotten back into a
19 water system or whatever. So, even if the pipe doesn't
20 rupture, blowing out seals that have a few hundred gallons a
21 minute flow out of them could be catastrophic to the
22 environment that sensitive equipment might be located in.
23 We just don't know because we don't know where the break is,
24 we don't know what all's happening.

25 MR. CARROLL: This is from a systems interaction

1 point of view. Flooding or spraying water on other
2 equipment.

3 MR. MICHELSON: Right. And the environmental
4 qualification --

5 MR. CATTON: In high pressures like that, if that
6 jet hit something or the spray hit something, it'll rip it
7 right off the wall. It's a little bit more than just the
8 normal kind of environmental damage.

9 MR. MICHELSON: Yes. We never postulated leaks
10 from high pressure. We postulate leaks from low pressure in
11 some of these compartments and designed for that, but not
12 high pressure leaks, and they behave quite differently. The
13 energy, the temperature and the pressure of the fluid coming
14 out is quite different, besides the size of the hole, which
15 is no longer a leakage crack. It's now a big rupture.

16 MR. CATTON: This ought to be a topic for the
17 future meetings as well, I think, peeking into this a little
18 bit.

19 MR. MICHELSON: Well, I think the main thing we're
20 waiting for is the staff position on interfacing system
21 LOCA, which is going to come out one of these days.

22 MR. CARROLL: Yes. This is one of the 15 issues
23 on 90-16 that we're looking at also.

24 MR. CATTON: It's more than just a leak. The
25 interfacing system LOCA I don't think really addresses these

1 questions. So, we ought not let the new plants get away
2 with it.

3 [Slide.]

4 MR. TURK: The last fluid system that I'd like to
5 address is the non-safety chemical volume control system,
6 which I mentioned the major change is taking that to a non-
7 safety system which allows it to be simplified.

8 The other major change we have is going from the
9 positive displacement charging pumps that we have used in
10 the past and have had maintenance problems to centrifugal
11 pumps, and moving the letdown heat exchanger onto the high
12 pressure side of letdown so we're letting down cooler water
13 and moving the heat exchanger itself inside the shield
14 building.

15 MR. MICHELSON: Before we leave interfacing system
16 LOCA, there is one other thing one has to be very careful
17 about, and that is heat exchanger tubing. The tubing may be
18 the weak point, and it ruptures. Everything else holds on
19 in that 900-pound system you put in. However, the rupture
20 in the tubing pressure or overpressurizes the shield side
21 water system, which may only be a couple-hundred-pound
22 design, and now you're talking about ruptures I don't know
23 where the weak point then moves to, and that's where the
24 water starts popping out. This all has to be a part of
25 interfacing system LOCA consideration. So we will chase the

1 thing on out to the end.

2 The pipe is probably too strong. Unfortunately,
3 the rupture will be where you least expect it, ultimately.

4 MR. CATTON: Maybe they need a fuse.

5 MR. MICHELSON: You need a fuse. Precisely. You
6 need a rupture disk.

7 MR. TURK: I would like to turn the attention now
8 to the electrical systems and the I&C systems. Ken Scarola,
9 our supervisor of I&C design. Let me ask the committee if
10 you'd like to break at this point?

11 MR. CARROLL: Yes. How long is this presentation?

12 MR. KENNEDY: About a half hour.

13 MR. CARROLL: All right. It sounds like we ought
14 to break for lunch. It also looks like we have reached,
15 what, about the 10:50 point in the schedule you guys had set
16 out. I guess it appears to me that two o'clock is not
17 realistic, at least with presenters this afternoon. So, I
18 would suggest you do something about your plane reservation.

19 MR. KENNEDY: We'll do that.

20 MR. MICHELSON: The NUPLEX system is going to take
21 a lot of discussion.

22 MR. KENNEDY: Let me just remark ahead on the
23 NUPLEX. We would fully anticipate that we could do that in
24 an all-day meeting on NUPLEX 80 advanced control rooms, so I
25 fully expect that in the review of the design, we would come

1 back in to give you an all-day presentation on that. Today
2 is just, if you will, to orient you. But it's an
3 interesting subject.

4 MR. MICHELSON: Well, what we're trying to do is
5 understand everything enough to talk about this licensing
6 basis agreement and whether the right things are in there.

7 MR. KENNEDY: Correct.

8 MR. MICHELSON: That's why we need a little of a
9 feel for this as we go along.

10 MR. CARROLL: In addition to that, ACRS has
11 established a new subcommittee chaired by Dr. Lewis which is
12 going to go into all the potential foibles of computer-based
13 control systems.

14 MR. KENNEDY: We understand.

15 MR. CARROLL: Okay. We'll reconvene at one
16 o'clock.

17 [Whereupon, at 12:00 p.m., the hearing recessed
18 for lunch, to reconvene this same day at 1:00 p.m.]

19

20

21

22

23

24

25

1 AFTERNOON SESSION

2 [1:05 p.m]

3 MR. CARROLL: Okay. Shall we continue?

4 [Slide.]

5 MR. SCAROLA: It seems like the I&C people are
6 always the ones who are forced to keep everybody awake right
7 after lunch, but I will do my best. That is, if I don't
8 fall over the cord.

9 I am supervisor of Advanced Instrumentation. My
10 name is Ken Scarola, and I will be speaking about the
11 control complex for System 80+, as well as the electrical
12 distribution. Since I don't have slides that really address
13 the concern that was voiced this morning about the advanced
14 technology, let me tell you something about what we're doing
15 there.

16 First of all, the control complex for System 80+
17 is referred to as the Nuplex 80+ Advanced Control Complex.
18 And we use the term "advanced" because the application of
19 human factors engineering, as well as computer technology,
20 far and away exceeds anything that you've seen in any
21 existing operating reactors. On the other side, all of the
22 hardware that is in Nuplex 80+ who exists right now. You
23 can walk into places, you can see it, you can feel it, you
24 can touch it, and at CE, we have extensive mock-up
25 facilities, development facilities, where all of that

1 hardware exists.

2 From an overall qualification point of view, we
3 are going through extensive rigorous qualification that
4 includes seismic testing -- the electromagnetic interference
5 testing -- we are meeting the licensing criteria for things
6 like environmental testing for environmental qualification.
7 So, in summary, the hardware is all proven technology; it
8 exists right now by make and model number. You can walk
9 into places and you can touch it, and we are basically going
10 through the application of that technology in a nuclear
11 power plant program right now.

12 MR. CARROLL: Everybody always says they're really
13 doing a first-rate job on human factors engineering. Tell
14 me how you're doing this.

15 MR. SCAROLA: Okay, let me address that, though,
16 as we go through the presentation.

17 MR. CARROLL: Okay.

18 [Slide.]

19 MR. SCAROLA: Now, what I'd like to do since
20 there's not a lot of time, though I will overview the design
21 bases of Nuplex 80+, I will go through an overview of what
22 the scope is of the overall design, then we will hit
23 specifically human factors, then I will go into the handful
24 of identified issues that we have on the agenda.

25 So, first of all the design basis. There are four

1 major design bases and they're listed here, and I will
2 highlight some of the important areas underneath each one of
3 them. First of all, we are meeting all of the existing
4 regulatory and the industry criteria, and I focus on human
5 factors engineering because that is a major focus of our
6 entire design effort, as well as fire protection and
7 sabotage, and I have slides that will address each one of
8 those.

9 Second two will improve plant safety. Before, you
10 heard basically about the four train-engineered safety
11 feature systems that we have. We also, inside the
12 protection system itself, the I&C systems, we have gone to
13 fully automatic testing. And that does not mean simply that
14 the hardware is verified. It also means that the software
15 trip paths are continuously exercised.

16 The next one in the overall design bases is
17 improved plant availability. You know, we talked this
18 morning about, how do we achieve less than one reactor trip
19 a year. The things we're doing in the I&C area are not the
20 only contributors for that, but they are major contributors.
21 One is, we're using fault tolerant systems. Basically, all
22 of the systems in the I&C area have built-in redundancy such
23 that they can tolerate failures in hardware. They
24 automatically switch over and there is basically no impact
25 on the plant. We also look at the process of the plant

1 itself, and as we approach limiting conditions, we do
2 initiate automatic control actions and thereby avoid trips.
3 This is basically an extension of features such as reactive
4 power cutback that we're now using at the Palo Verde.

5 Lastly is a thrust on improving the overall cost
6 effectiveness of the I&C packages for nuclear power plants,
7 and we look at all phases, all of the phases of those costs.
8 That's through the design phase, through construction, as
9 well as operations and maintenance. I will address all of
10 these issues to some level as we go through this.

11 MR. WARD: I have a question, before you -- the
12 term, "accident management" has become sort of a code, set
13 of code words for activities to address or improve
14 procedures for following accidents, possible accidents,
15 beyond the usual, tradition design basis regions, in regions
16 where there might be more failing than were counted on,
17 where there might actually be core damage. Does your design
18 think about this accident management space at all?

19 MR. SCAROLA: Yes it does. We have in CE plants
20 what we call the "optimal recovery procedures," and then we
21 have "functional recovery procedures." The optimals --

22 MR. WARD: Yeah, but are those extended into, I
23 guess you've had those for some time.

24 MR. SCAROLA: Yes, and they are extended into the
25 man-machine interface design, and I will show you a little

1 bit of that later.

2 MR. WARD: But are they extended into what are
3 called severe accident space, rather than the more
4 traditional EOP space.

5 MR. SCAROLA: Only from the standpoint that the
6 functional recovery that will handle those types of things;
7 not beyond that, no. I think that we will address severe
8 accidents later and, you know, maybe we can elaborate more
9 on that.

10 MR. KENNEDY: Let me, could, if I can, make a
11 comment on that. This is Ernie Kennedy. Right now, our
12 procedural guidelines, which we prepare generically for our
13 plant owners, are being looked at for operating plants for
14 accident management considerations. We would expect, toward
15 the end of our system 80+ design effort, that we are going
16 to have to go back and revise our emergency procedure
17 guidelines to coincide, first of all, with the System 80+
18 design, and at that point we would pick up in those
19 emergency procedure guidelines the accident management work
20 that's being developed for operating plants that extends
21 into the severe accident regime.

22 MR. WARD: Okay, do you think there might be, that
23 sounds like a program that's appropriate for an existing
24 plant, but what about this plant of the future that for the
25 design isn't complete. Is there going to be anything in the

1 design to address that area?

2 MR. MATZIE: This is Regis Matzie. We have made a
3 number of design changes to the plant to mitigate the
4 consequences of a severe accident. The design changes we've
5 made to the systems that we've already described and will
6 continue to describe, but try to reduce the core melt
7 probability and, in addition to that, we have made changes,
8 as an example, to the containment to reduce the
9 consequences. So, the answer is the design has been
10 addressed from that standpoint --

11 MR. CARROLL: Well, I think what you're saying,
12 Dave --

13 MR. WARD: But has the man machine interface that
14 might present some different sorts of problems been
15 addressed?

16 MR. CARROLL: For example, I think, Dave, what
17 you're saying is if you, in fact, had these accident
18 management procedures in place right now, it might influence
19 additional instrumentation or ways of displaying it, or
20 whatever.

21 MR. WARD: Yeah. You're providing for, let's be
22 gross about it, for core on the floor. Is the operator
23 going to have any information telling him what the situation
24 is -- is there core on the floor, or does he just throw up
25 his hands, or what?

1 MR. SCAROLA: Oh, I think right now, at this point
2 in time, we would have to say that the man-machine interface
3 designs do not specifically define the instrumentation that
4 would be required for those scenarios. That will be
5 occurring in a later part of the design effort. We have not
6 looked at the severe accident scenarios with regard to the
7 man-machine interface design changes or the design additions
8 that may be required. I think that one of the things that
9 we have going for us here is that a flexibility toward the
10 introduction of specific displays or the alarms for those
11 scenarios are very simple to add in a later stage of the
12 design, although at this point in time, I have to be honest;
13 they are not in there.

14 MR. CARROLL: Is there room to add them. That's
15 been the historic problem.

16 MR. SCAROLA: I think when you'll see this design,
17 you'll see that there is more than sufficient room in the
18 control room to add them. It's not a space consideration,
19 as it is in existing plants. It's basically a depth
20 consideration in the information displays, and we'll show
21 that. This is a highly dynamic control room, as opposed to
22 a control room that has fixed displays for every piece of
23 information.

24 MR. CARROLL: Let me back up. Okay. You've got V
25 and V down there as an item and you're going to meet all

1 current and regulatory and industry requirements. I guess I
2 have some apprehensions that current isn't probably good
3 enough as we move off into the world of computer-based
4 control and safety systems.

5 MR. SCAROLA: Okay. One thing I can point out
6 there is that CE has been supplying computer-based systems
7 for more than 15 years now in the safety area. And we have
8 basically incorporated all of the lessons learned throughout
9 that time period into the V and V program.

10 So CF's V and V program goes far beyond what the
11 industry now requires in Reg Guide 1.152 for example. So,
12 there's a lot more in our program.

13 MR. CARROLL: But is that good enough as we give
14 these systems more responsibility? I guess I think to the
15 Canadians who are still struggling with whether they can
16 really rely at Darlington on the new computer-based safety
17 system.

18 MR. SCAROLA: I understand your concern. We
19 addressed V and V as one part of an overall system
20 reliability program. We will talk about a diversity as well
21 and overall systems qualification.

22 I think all of these have to be looked at
23 synergistically and not just V and V by itself.

24 MR. CARROLL: Okay. Well, I don't think today is
25 the day we spend hours on the subject, but, I think it is a

1 subject that the Committee is going to want to hear about
2 eventually.

3 MR. SCAROLA: Okay.

4 [Slide.]

5 MR. SCAROLA: This slide is a block diagram
6 overview of the entire scope of the NUPLEX 80+ Advance
7 control complex. At the very top of the picture is the main
8 control room and I will be showing you more information on
9 that.

10 There's a separate remote shutdown room and then
11 over here we have the technical support center. Those are
12 basically the man/machine interface areas.

13 Now, behind that, there a number of systems that
14 support those man/machine interfaces. The first level here
15 are the display systems. This system here that we call the
16 data processing system which is a redundant super mini-
17 computer based system that is responsible for all of the CRT
18 based information inside the control room.

19 There is a diverse and completely separate system
20 that is responsible for the spatially dedicated display
21 inside the control room. Those are things like the meters,
22 the alarm tiles, things that we have retained from the
23 existing control room design because they're good. And I
24 will be showing you those later.

25 The next level down are the control and protection

1 systems. On the left hand side of the drawing are the
2 protection systems and you can see that they are multi-
3 channel four-train systems and on the right hand side, are
4 the fault tolerant control systems.

5 Further down in the system are the interfaces or
6 the fingers into the plant.

7 MR. MICHELSON: Excuse me. Where did we leave the
8 control room area now in this drawing?

9 MR. SCAROLA: Okay. We have left the control room
10 area and I'll show this on a later slide, as soon as you get
11 down below this line. All of this equipment is located in
12 the I and C equipment room from here to here.

13 MR. MICHELSON: Okay.

14 MR. SCAROLA: And there are five I and C equipment
15 rooms, four channels for safety and one for non-safety. And
16 then from here out, we are basically out into the plant.
17 And these boxes that you see on the bottom are what we call
18 remote field multiplexers.

19 MR. MICHELSON: They're out in the various
20 locations in the plant.

21 MR. SCAROLA: They're out in the reactor building,
22 turbine building. There are none inside the containment but
23 they are basically in the locations of all of the mechanical
24 equipment.

25 The intent of these is basically to meet the

1 design basis that I had identified earlier and that is lower
2 cost.

3 MR. MICHELSON: You drew lines from there on in to
4 what I guess, what's the significance of that dotted area
5 down at the bottom?

6 MR. SCAROLA: This is basically showing the inside
7 containment building.

8 MR. MICHELSON: Well, certainly --

9 MR. SCAROLA: There is not multiplexing internal
10 to the containment. You wire everything out.

11 MR. MICHELSON: But there must be a lot of
12 multiplexing coming from outside the containment but outside
13 also of the I and C equipment room.

14 MR. SCAROLA: Okay. Yes, that's my point. This
15 line is the end of the I and C equipment room.

16 MR. MICHELSON: Yes.

17 MR. SCAROLA: Everything that's above here is in
18 the I and C equipment room and everything that's lower than
19 here is in the plant.

20 MR. MICHELSON: Those multiplexers are looking at
21 information coming from outside of containment as well as
22 inside containment?

23 MR. SCAROLA: Both.

24 MR. MICHELSON: Okay. It wasn't clear from that
25 drawing that that was the case.

1 MR. SCAROLA: I'm sorry.

2 MR. CARROLL: What's your problem with
3 multiplexing from inside?

4 MR. SCAROLA: There are a number of things. One
5 is the maintenance access concern. One is the radiation
6 hardening, the accident environment. We just decided not
7 really to go that step for this advanced program.

8 We are going that step for some of the other
9 programs we're working on with DOE but not this particular
10 one.

11 MR. MICHELSON: Now, could you tell us just
12 briefly how you handle it, starting with a given instrument,
13 like a pressure sensor, where do you start in with solid
14 state transmission to the multiplexer or do you?

15 MR. SCAROLA: It depends on the specific
16 transmitter. For example, if the transmitter is required in
17 a single system, then the multiplexing occurs right in the
18 four to 20 milliamp control loop or the instrumentations.
19 The multiplexer is located as near to that sensor as we
20 possibly can.

21 MR. MICHELSON: But the sensor, let's say, is
22 inside containment.

23 MR. SCAROLA: Okay. So we route the wires, three
24 wires inside the containment, through the containment
25 penetration and then the multiplexer sits right in the

1 containment penetration area.

2 MR. MICHELSON: That's the point at which you do -

3 MR. SCAROLA: There we do an A to D conversion, an
4 analog to digital conversion and then the signal that goes
5 from the multiplexer back into the intelligent processor is
6 basically a digitized signal of the analog value.

7 MR. WYLIE: Is any of this fiber optic?

8 MR. SCAROLA: Yes. I will show you that after.
9 We're using fiber optics in all places where we require
10 electrical isolation.

11 MR. WARD: Do you have reason to expect
12 maintenance, reliability problems with these A to D and
13 multiplexer units?

14 MR. SCAROLA: No, we don't.

15 MR. WARD: You said you didn't put them in
16 containment for that reason.

17 MR. SCAROLA: Basically, for the access into the
18 containment. The MTBF numbers that we are looking at for
19 all of this equipment is around 10 years. Those are mean
20 time between failure numbers.

21 Most of the equipment, as I said, has fault
22 tolerance. There are situations where there is no fault
23 tolerance in the equipment itself where we have multiple
24 safety channels because that in itself is the fault
25 tolerance.

1 The MTFR, the mean time for repair is on the order
2 of 30 minutes. But it was simply the access inside the
3 containment at power for repair that we thought was a
4 limiting condition.

5 MR. MICHELSON: How many multiplexers are we
6 really talking about? This is just a figure that shows
7 nine, but, how many multiplexing cabinets do you expect or
8 locations?

9 MR. SCAROLA: Okay. There are roughly 100 of them
10 in the plant.

11 MR. MICHELSON: Spread around? I'm talking about
12 outside of the I and C equipment room.

13 MR. SCAROLA: On one side of the sphere for the
14 containment in the reactor area, in the shadow areas where
15 we have aux equipment, on the other side of the sphere.
16 Inside the turbine building. Inside what we call the aux
17 control building.

18 MR. MICHELSON: There's quite a number of them?

19 MR. SCAROLA: Yes, there's quite a number of them.

20 MR. MICHELSON: Now, what kind of environmental
21 qualification is this equipment? In other words, what is
22 its fault tolerance for high temperature, high humidity,
23 whatever?

24 MR. SCAROLA: Okay. All of the equipment that
25 we're using is 60 degree C equipment or 104 degree F.

1 MR. MICHELSON: Does that mean 140 ambient in the
2 air that's used to cool the equipment?

3 MR. SCAROLA: No. It means that the maximum
4 outside air temperature is 104 degrees F.

5 MR. MICHELSON: So, you're rating only up to 104
6 F?

7 MR. SCAROLA: For the outside air. And the reason
8 for that is, we have to take a heat rise to go inside the
9 closure and we have to take the --

10 MR. MICHELSON: So, 104 is not really very high.
11 What do you now about power blackouts or other situations
12 wherein the room areas get warm or a small pipe breaks or
13 whatever? How does this equipment behave when the ambient
14 air gets over 104 degrees?

15 MR. SCAROLA: Well, certainly nothing is going to
16 fail instantly. So, the equipment behaves is it basically
17 gets an extremely shorter life.

18 MR. MICHELSON: That's true for a few degrees
19 above this. But, let's go up to 130 right away. Do you
20 think that none of this will drift or change state?

21 MR. SCAROLA: Yes, it will.

22 MR. MICHELSON: Okay.

23 MR. SCAROLA: And we accommodate that in the
24 single failure analysis in that the locations for the
25 equipment are basically subject to the same single failure

1 criteria of HVAC, ambience fires et cetera that we would
2 apply to any four-channel safety --

3 MR. MICHELSON: That single failure analysis is
4 one failure at a time. Is that right?

5 MR. SCAROLA: One train at a time, yes.

6 MR. MICHELSON: Well, one failure, I think would
7 do it in doing single failure analysis and it might result
8 in a train going out or whatever it causes it to go out.

9 But this can be multi-channel because this can be
10 high temperature in large areas containing both trains of
11 equipment and so forth unless you've got some special
12 provisions to prevent it.

13 MR. WYLIE: I think that this whole area is one
14 that we're probably going to spend a day on.

15 MR. MICHELSON: I just want to see roughly where
16 they're at.

17 MR. SCAROLA: I think basically the approach we're
18 taking is, we're maintaining segregation of the I and C
19 equipment by trains. So, we our limiting case is loss of an
20 entire train.

21 MR. MICHELSON: But of course, common cause events
22 like station blackout and so forth, it's going to start
23 warming up more than one train.

24 MR. SCAROLA: Let me address station blackout at a
25 later slide.

1 MR. MICHELSON: Okay. Now, the 104 degree max
2 design of course, you can certainly get equipment that will
3 handle more than that. Apparently you had reasons to select
4 that particular number. Not all vendors of these systems
5 are selecting that same number. Some are going much higher.

6 So, the closer that is to normal room
7 temperatures, the more sensitive the problem becomes. And
8 the 104 is not far from what some of these areas see
9 routinely particularly in the summer time in the south.

10 So, I think this will be an area we'll pursue very
11 hard later on if you're going to design for 104 cooling air
12 inlet.

13 MR. SCAROLA: In the room.

14 MR. MICHELSON: Yes.

15 MR. SCAROLA: Right. Okay.

16 [Slide.]

17 MR. SCAROLA: That was an overview of the control
18 complex itself. Let me talk a little bit about the approach
19 that we have taken to the design of the man-machine
20 interfaces.

21 First, we established a multidiscipline design
22 team. And that consisted of human factors specialists,
23 reactor operators, nuclear system engineers, as well as I&C
24 engineers. People who are designing the information for the
25 control room or reactor operators.

1 MR. CARROLL: These are utility reactor operators?

2 MR. SCAROLA: Past utility licensed operators,
3 people that now work for Combustion Engineering but in the
4 past have held operating licenses for utilities.

5 MR. CARROLL: Is the same true of the I&C
6 engineers? Is there any utility flavor there?

7 MR. SCAROLA: Well, there is utility flavor in
8 that we interact with Duke Power on everything that we do.
9 So there is a utility influence in the design. They are
10 part of the design team.

11 MR. CARROLL: Because in my experience, I think
12 vendor I&C engineers and utility I&C engineers often have
13 different perspectives on these issues.

14 MR. SCAROLA: We often clash. There is no doubt
15 about it.

16 MR. CARROLL: Okay.

17 MR. SCAROLA: But I think what we have ended up
18 with is a design that is basically meeting all the
19 requirements for both sides.

20 Okay. That team does a system analysis as well as
21 we do an independent analysis by separate design team that
22 establishes the functional requirements for the information
23 and controls in the control room. We basically look at the
24 systems, we look at the operating procedures, and we see
25 this is the information the operator has to have. That is

1 often referred to as function task analysis. And that is
2 part of the overall design process. A later part of the
3 design process is the validation through mockups, actual
4 full-size control panels, the operating displays, et cetera,
5 where we go through walkthroughs of all the information
6 displays along with the procedures. So that is roughly the
7 process.

8 [Slide.]

9 MR. SCAROLA: Now, I have a few 35-millimeters
10 here that are in your handouts, in black and white. Let me
11 switch on the projector.

12 Okay. This is a picture of the control room
13 itself. Now, let me go through it in part. this is what we
14 call the controlling workspace. This is basically where the
15 operators are going to run the plant. And we have designed
16 this in a segregated manner basically to keep non-operating
17 personnel out of the controlling workspace. There is a
18 master control console where one man can run the plant
19 through all normal plant excursions. But the work space is
20 large enough to accommodate six people for any sort of
21 abnormal events.

22 In those six people, we include a control room
23 supervisor that would be resident at the supervisor console,
24 as well as a shift technical advisor.

25 In the front of the control room is a large screen

1 overview display that I will be showing you more on after.
2 In the back of the control room are the offices for the
3 operating staff, auxiliary reactor operators when they are
4 not at the controls, the control room supervisor, and behind
5 this wall, there is an office for the shift supervisor.

6 All of this, including the offices, is a secured
7 area.

8 This second floor that you see over here is what
9 we call a technical support center. That is a separate
10 security zone. It allows people to come in and get freer
11 access, visibility into the control room so they can view
12 what is happening. We intend that this would be used, not
13 only for the accident conditions of the plant but also as a
14 visitor's gallery. And that is why we made this a separate
15 security zone.

16 MR. CARROLL: What is the glass security between
17 it and the control room?

18 MR. SCAROLA: The glass is fully bulletproof as
19 well as the floor is as well.

20 MR. CARROLL: Nothing is fully bulletproof.

21 MR. SCAROLA: Well, it meets the bulletproof
22 criteria that have been established.

23 MR. CARROLL: Okay.

24 MR. SCAROLA: Let's put it that way.

25 In all of the offices as well as the TSC and

1 throughout the control room, you can see that these small
2 boxes are CRT displays. They are basically windows that go
3 into the plant computer that allow the personnel in any
4 location to have full access into the entire plant database.

5 We also support through CRT information the
6 emergency offsite facility where again there are CRTs
7 located for access into the plant.

8 What we have done here as compared to a nuclear
9 power plant control room that is in operation now is, we
10 have retained those features of that design that are good.
11 There are certain spatially-dedicated aspects of existing
12 control rooms that are very good.

13 We have also looked at those and said we have a
14 tendency to overload the operator with information, and
15 therefore we have reduced the amount of information that we
16 have spatially dedicated.

17 I have slides on --

18 MR. CARROLL: Now, your tree over in the corner
19 there is to combat the greenhouse effect to keep the
20 temperature down?

21 MR. SCAROLA: That is an artist's --

22 MR. WARD: Let me ask you a couple questions. I
23 think that is beautiful.

24 MR. SCAROLA: We have a similar comment.

25 MR. WARD: I think that is beautiful. I like it,

1 that tree. In Belgium they have fish bowls, or fish tanks.

2 Is there something called an SPDS or is that an
3 antiquated concept?

4 MR. SCAROLA: It is basically a function that
5 exists, but not as a dedicated piece of hardware. The SPDS
6 function is integrated because there is a human factors
7 philosophy that we have that says that an operator uses
8 daily what he is going to use during an accident. So there
9 is nothing here that he uses only for accidents. It is an
10 integrated part of the design.

11 MR. WARD And is NRC staff happy with that?

12 MR. SCAROLA: We don't know that.

13 MR. SINGH: We haven't looked at that yet.

14 MR. CARROLL: You get one vote from me. I think
15 that is good philosophy.

16 MR. WARD: What sort of guidelines do you have for
17 this review? Do you expect to see SPDSes in plants? Or is
18 that strictly a backfit?

19 MR. SINGH: We are going to visit facilities later
20 on this month to get a little better understanding. The
21 human factors people are developing some criteria, or
22 guidelines, on what we will be looking at.

23 MR. WARD: Okay.

24 MR. SINGH: But we don't have anything on paper
25 yet.

1 MR. SCAROLA: There are no functions of existing
2 SPDS systems that are not found inside this control room.
3 The only difference is the operator uses the media that he
4 uses for an SPDS-type display all the time, and he uses what
5 we call a function-based operating approach, all the time in
6 this plant, not simply for handling accident recovery. We
7 use critical functions day to day. And I will be showing
8 you a display on that.

9 MR. WARD: But I think your first statement, there
10 is no function that is not available here, could be said for
11 plants before the SPDS era, too. That was the point of the
12 SPDS, if there was one, that it concentrated them somewhat.

13 MR. SCAROLA: Okay. We are doing that as well.

14 MR. WARD: Okay. What would you do in a multi-
15 unit plant?

16 MR. SCAROLA: Separate control room.

17 MR. WARD: No connection at all?

18 MR. SCAROLA: Right. For a light water plant.
19 There are some advanced designs that we are looking at
20 multi-unit. But for the light waters, there are separate
21 control rooms.

22 MR. MICHELSON: Let me make sure I understood what
23 you were showing us up here correctly. Are you saying that
24 that is a visitor's gallery shown on the left there?

25 MR. SCAROLA: It is defined as the technical

1 support center fulfilling the requirement of NUREG 0696.

2 MR. MICHELSON: Well, that is not a visitor's
3 gallery, of course.

4 MR. SCAROLA: I'm sorry?

5 MR. MICHELSON: That is not a visitor's gallery.

6 MR. WARD: That's just for visitors like ACRS
7 members. Not school kids.

8 MR. MICHELSON: Certainly not the public.

9 MR. SCAROLA: No. We would anticipate that you
10 would bring visitors in there, because visitors frequently
11 visit power plants, and right now they come into the control
12 room and they are basically somewhat of a disturbance.

13 MR. MICHELSON: I thought that they weren't even
14 allowed in control rooms.

15 MR. CARROLL: We are talking about the difference
16 between general public and --

17 MR. MICHELSON: You don't allow the general public
18 in the control room.

19 MR. SCAROLA: These are VIP-types, this is not
20 open to the public. I'm sorry.

21 MR. WARD: Not ACRS members.

22 [Laughter.]

23 MR. MICHELSON: Okay. That is not a visitors'
24 gallery, then; that is part of the technical support center.

25 MR. SCAROLA: Thank you. I pointed out the large

1 screen overview. That is what we call the integrated
2 process status overview display. And I will show you what
3 that looks like.

4 [Slide.]

5 MR. SCAROLA: This is basically a simplified
6 graphic presentation that presents the highest level of
7 information in the plant in a very simplified manner. The
8 design basis for the display is, very simply, critical
9 functions, those functions important to power production
10 when you are producing power, and those functions that are
11 important to safety when you are recovering from a reactor
12 trip.

13 All of the critical function identifiers are on
14 here and all of the system representations are laid out to
15 support those critical functions.

16 Very simply, we look at all of the system
17 parameters. There are about 10,000 points that are looked
18 at in defining this display. These red symbols are
19 basically that a system is on, and the green, which is
20 washed out somewhat in this picture, is that a system is
21 off. All of the yellow indicators are that systems have
22 alarm conditions.

23 MR. MICHELSON: What kind of display is this?

24 MR. SCAROLA: We are using multiple video
25 projectors. The video technology for the flexibility and

1 the multiple units so we can basically gain adequate
2 brightness.

3 Simple display symbols such as the down arrow, the
4 minus sign, the indicator here that you have are a higher
5 level than normal, are all things that are processed by the
6 computer and then basically put up on the display to
7 simplify the operator's overview comprehension of the plant.

8 The intent of this entire display is such that,
9 number one, when an operator is lost in the details of
10 diagnostics he does not lose the big picture.

11 Secondly, it's to give the entire staff one common
12 mental model of the plant status.

13 MR. MICHELSON: Will this be seismically
14 qualified?

15 MR. SCAROLA: No. This display is not seismically
16 qualified.

17 MR. MICHELSON: So something I can write off
18 without being needed for accident response?

19 MR. SCAROLA: Not being fully credited for
20 accident response --

21 MR. MICHELSON: Not being credited at all, I
22 assume, at least for anything you might get into in
23 conjunction with a seismic event.

24 MR. SCAROLA: To the extent that the SPDS is, this
25 is at existing plants so it means the same criteria.

1 MR. MICHELSON: Oh, yes, but SPDS doesn't -- isn't
2 required to go through your emergency procedures.

3 MR. SCAROLA: Right, and this is not required.

4 MR. MICHELSON: So this is something that I can
5 write off? I don't need it at all?

6 MR. SCAROLA: Yes, absolutely. It is not
7 required.

8 MR. MICHELSON: You get into these fundamental
9 arguments of course after you build these highly
10 sophisticated crutches and then you take them away from the
11 operator, how well can he do without them?

12 MR. SCAROLA: I think that's an important point.
13 That's one of the reasons why when we look at what we have
14 retained as fully qualified instrumentation I think you'll
15 see that there is more than adequate information there for
16 the operator to use.

17 MR. MICHELSON: Well, it's not a question of the
18 amount of information but rather the manner in which it is
19 projected to the operator.

20 MR. SCAROLA: Let me get right into that.

21 MR. WARD: Could you just say briefly though why?
22 Is it really impossible to make that sort of a display, the
23 whole system seismically qualified, whatever that means?

24 MR. SCAROLA: Well, there are two aspects to it.
25 One is, yes, you can make it seismically

1 qualified.

2 The second aspect is there's a lot of data
3 processing behind that and the data processing is basically
4 a software task and to the extent that you would want to
5 apply V and V to highly sophisticated software, yes, it can
6 be made that way but it may not really be cost effective.

7 MR. WARD: It sounds like it is more of an issue
8 of putting it through the QA ringer than it is structurally
9 designing it to be seismically resistant.

10 MR. SCAROLA: It's a lot of things.

11 It's deterministic, performance. It's the sort of
12 machine that is needed for the calculations. It's not a
13 simple thing to say that that is going to meet all of the
14 same criteria that you would meet inside class system.

15 MR. MICHELSON: How is software affected by a
16 seismic event?

17 MR. SCAROLA: No, it's not.

18 MR. MICHELSON: If the hardware and all of the
19 rest of the hardware better be good because it is the same
20 hardware that's giving you the good information.

21 MR. WARD: That's why I say, it's more
22 administrative or QA problem.

23 MR. MICHELSON: Everything up to the screen I
24 think is safety grade, I would think -- isn't it?

25 MR. SCAROLA: No. The instrumentation is safety

1 grade where it is required to be safety grade but then you
2 have to take the information into computers, process the
3 data, and then display the data.

4 From the points you process the data that is not
5 safety grade at this point.

6 MR. MICHELSON: Now the hard stuff that the
7 operator has access to that you tell me is all he really
8 needs, that is all safety grade?

9 MR. SCAROLA: Yes. Let me go to that.

10 MR. MICHELSON: Okay.

11 MR. CARROLL: Is this consistent with your
12 philosophy that the stuff he uses every day ought to be the
13 stuff he has available and uses under accident conditions?

14 MR. SCAROLA: Yes. It is.

15 MR. CARROLL: Including a seismically induced
16 accident?

17 MR. SCAROLA: I am not saying that everything that
18 the operator has at his disposal will be at his disposal
19 during an accident. That's not what I am saying.

20 It is exactly the opposite. I am saying the
21 things that he needs during an accident he will use every
22 day. It is a different situation.

23 I cannot design a control room where he uses
24 everything and that's also available during an accident
25 because it makes a very expensive control room design but it

1 does work the other way around.

2 My next slide --

3 MR. WARD: Well, I didn't want to take a lot more
4 time but this is -- if we are serious about where the
5 threats are, at some plants, at some sites there are claims
6 that a large seismic event is a major risk contributor --
7 you know, some numbers -- I don't know whether to believe
8 them or not but some numbers show more than half of the
9 risk. This is for the other half, I guess.

10 MR. SCAROLA: On my next slide I am going to show
11 you --

12 MR. MICHELSON: The question is, what do you do?
13 What do you do in a PRA with the human factors aspects of a
14 PRA for the events wherein this good stuff is not available
15 and he has to fall back on his fundamental instrumentation?

16 It certainly must change slightly the efficiency
17 of the operation.

18 MR. CATTON: Increase the human factors error.

19 MR. MICHELSON: It's got to.

20 MR. CATTON: I wouldn't think it would decrease
21 it. If it's a good system they ought to decrease it
22 relative to what they use.

23 MR. MATZIE: This is Regis Matzie speaking. The
24 other equipment is not backup. You've got the idea this is
25 the stuff they normally use only and the other stuff is all

1 backup.

2 As Ken gets into this you'll see they use both
3 types of instrumentation continuously in their processing
4 and that other type of instrumentation which he is going to
5 describe has got all the standard parameters he needs to run
6 the plant.

7 MR. MICHELSON: And those read off onto the main
8 control panels?

9 MR. CARROLL: I guess this all started talking
10 about SPDS. It looks to me like this integrated process
11 status has a lot of the elements of a good SPDS in it.

12 Do the other instruments -- are they grouped and
13 displayed so that there is one good place to look, and he is
14 going to tell us that?

15 MR. SCAROLA: I think the answer is yes. I don't
16 know -- okay.

17 Let me get into the design of the actual control
18 panels and in my next slide I have photographs of this
19 specific panel, which is the reactor coolant system panel.

20 [Slide.]

21 MR. SCAROLA: Now this panel is representative of
22 all of the panels inside the control room.

23 On the panel there is a CRT that is basically the
24 window into the data processing of the plant through the
25 plant computer. Those are in essence 19 inch CRT displays

1 that present a pictorial representation of the plant.

2 We also have spatially dedicated alarm tiles as
3 well as spatially dedicated indicators. They are done on a
4 very limited sense. There are very few of them as compared
5 to existing control rooms and they are selected by the human
6 factors specialists as those few instruments that are
7 indicative of system performance, so again we go back to the
8 critical function concept -- what are the few instruments
9 you need to really indicate that the system is meeting its
10 performance criteria?

11 MR. MICHELSON: Which readouts on that panel are
12 seismically qualified?

13 MR. SCAROLA: This one, the alarm tiles and all of
14 the indicators that you see over here.

15 MR. MICHELSON: But not the CRT?

16 MR. SCAROLA: Not the CRT display. The operator
17 is going to use the CRT display as well as the indicators
18 and the alarm tiles all of the time. For a seismic event he
19 will be left with the alarm tiles and the indicators.

20 MR. MICHELSON: So you are using seismically
21 qualified alarm systems then?

22 MR. SCAROLA: Yes, seismically qualified alarm as
23 well as display systems, and they are fully qualified
24 through all the software pedigrees.

25 [Slide.]

1 MR. SCAROLA: Now I have pictures of each one of
2 those in somewhat more details.

3 These are the alarm tiles. This is -- it
4 replicates what you would normally expect to see inside a
5 control room -- spatially dedicated alarm tile for the major
6 alarm areas.

7 The major difference is we have large groupings of
8 alarms into functionally related groups so behind this tile
9 there would be roughly eight to a dozen alarms that are all
10 related to that specific area.

11 The alarm tile itself is dynamic in that right now
12 it is showing through the box outline of what we call
13 Priority 2 conditions. If there is a Priority 1 condition
14 it goes to a full yellow display.

15 When the operator want to acknowledge that alarm
16 he simply sticks his finger right on the tile.

17 [Slide.]

18 MR. SCAROLA: What he gets is again the
19 representation of the tile, a listing of those things that
20 are in alarm that he has acknowledged and those alarms that
21 have cleared that he has now acknowledged.

22 If he wants to go further, he can simply make
23 another touch.

24 [Slide.]

25 MR. SCAROLA: He gets a full listing of all of the

1 alarms related to that tile.

2 MR. MICHELSON: That is only if the CRT is
3 working.

4 MR. SCAROLA: No. This is functional all the time.
5 In fact this is --

6 MR. MICHELSON: Where is this reading out on that
7 other picture?

8 MR. SCAROLA: It's this panel right here.

9 MR. MICHELSON: Yes?

10 MR. SCAROLA: Okay, now what we have done is those
11 slides that I showed you are these exact tiles.

12 MR. MICHELSON: Yes, yes.

13 MR. SCAROLA: And these are showing Priority 1
14 conditions in alarm and the lower ones are showing Priority
15 2 conditions but the tiles are dynamic.

16 MR. MICHELSON: Where is all this printout on the
17 next slide showing up?

18 MR. SCAROLA: When the operator makes a touch,
19 this screen now becomes the printout screen.

20 MR. MICHELSON: Oh, that's an LED type readout.

21 MR. SCAROLA: It is electro-luminescent
22 technology, which is a phosphor-based black panel screen.

23 MR. MICHELSON: That's what I wasn't -- didn't
24 realize.

25 MR. CARROLL: So while he is getting smart about

1 what the one tile is saying, what is going on with the
2 others?

3 MR. SCAROLA: Okay. What is happening on the main
4 page is reflected here at all times in that this box, the
5 alarm status box, is saying this is the activity on the main
6 page and that box is going to show him his highest priority
7 condition on the main page and we have a list of how
8 priorities go.

9 Priority 1, not acknowledged; Priority 2, not
10 acknowledged; Priority 3 -- et cetera.

11 The operator can return to the main page anytime.

12 He also in NUPLEX 80 there are only momentary
13 audibles. A momentary audible comes in, beeps, says there
14 is a new alarm.

15 If he has not done the acknowledgement within a
16 minute, he gets a second tone that is a reminder, again
17 momentary, okay?

18 So there is the flashing as well as the audible
19 reminder that he has alarms.

20 The big screen we had, the big screen gives him a
21 summary of the plant locations that have all the priority
22 one conditions, okay, so he can see on the big screen as
23 well as anyplace on any CRT that he has alarms going on. He
24 doesn't lose any information.

25 [Slide.]

1 MR. WARD: Back to seismic again, some of these
2 displays and instrumentations are apparently seismically
3 qualified, but most risk analysis show that, you know, the
4 risk from -- the risk there is from earthquakes is at ground
5 accelerations in excess of the SSE and that in fact if you
6 look at hazard curves, hazard curves per -- a lot of actual
7 sites, you get numbers, you know, maybe twice or more of the
8 SSE, you get return periods certainly with the ten to the
9 minus, you know, a 100,000 years which is one of your design
10 bases. Seismic PRAs generally show that good old piping is
11 okay and a lot of other structures and pieces of equipment
12 can at least survive up at accelerations in excess of the
13 SSE. What about this stuff, what do you know about these
14 instruments in the control systems.

15 MR. SCAROLA: The only thing I can tell you is
16 what we have tested. All of these devices have been tested
17 up to 25gs, that was the envelope that we looked for, we
18 actually had over testing that went to 30gs by error just
19 because we lost control of the table, but this stuff is very
20 survivable.

21 MR. CARROLL: The temperature got above 104
22 degrees.

23 MR. MICHELSON: What is the power supply for a
24 typical screen like we've been discussing?

25 MR. SCAROLA: Okay, depending upon the arrangement

1 or with the particular one you're looking at, these are
2 powered from the battery buses, the vital buses in the
3 plant.

4 MR. MICHELSON: Now, some of the information is
5 coming in through multiplexers to this device?

6 MR. SCAROLA: Correct, yes.

7 MR. MICHELSON: And the amount -- a certain amount
8 of that information is coming from non-seismic, and 1E
9 devices into the multiplexers and there the isolation is
10 occurring, is that right?

11 MR. SCAROLA: Let me show you and I think I can
12 elaborate a little bit on that.

13 MR. MICHELSON: All right.

14 MR. SCAROLA: Okay, these are the indicators. Let
15 me go back here for one second, the indicators that are on
16 the panel are down here, and let me show you what we're
17 doing with indication. For all of the indicators we display
18 what we call the process representation value, that's not a
19 value from any specific sensor, but rather a computerized
20 composite of a validated process representation value from
21 all senses, so here we're looking at the hot leg RCS
22 temperature, and on the 565 cold leg RCS temperatures. We
23 have in the cold legs about 32 sensors, safety and non-
24 safety, in the hot leg we have about 18 sensors, and we look
25 at them, in the microprocessor, and we display what's called

1 valid information, which is basically we look for sensor
2 deviations, we throw out the bad ones. The operator can
3 make a touch on this screen and he get to a second page
4 where now he can make a touch on any particular sensor
5 instrument tag number and he can get the read-out of that
6 sensor.

7 [Slide.]

8 So, in essence what we're doing is we're looking
9 at those non-safety sensors, we're looking at the safety
10 sensors, and we are doing composite validations. The word
11 PAMI here says not only is the data valid and that it meets
12 all the acceptance criteria, but it also is within the
13 tolerant of the Reg. Guide 197 sensors which are the fully
14 qualified ones for the first accident environment.

15 MR. CARROLL: Where does PAMI come from?

16 MR. SCAROLA: Post Accident Monitoring

17 Instrumentation, that's the term.

18 [Slide.]

19 So, we look at all of the sensors. Now, from here
20 the operator can display any individual sensor, or he can
21 return back to this display where we normally show an analog
22 indication of the value of historical data trends that
23 basically replaces the near-term usage of strip chart
24 recorders, that is the real time usage. The historic usage
25 of strip charts is inside the plant computer on optical

1 disks, which is a permanent storage medium.

2 MR. MICHELSON: Will this be a safety grade
3 computer now?

4 MR. SCAROLA: Yes.

5 MR. MICHELSON: Okay.

6 MR. SCAROLA: This is.

7 MR. MICHELSON: No, I'm talking about the process
8 computer, you said you stored --

9 MR. SCAROLA: The one for the CRT displays is not
10 a safety grade computer, that's where we draw the
11 distinction.

12 MR. MICHELSON: No, but the historical data, you
13 have said this is the display, but you're storing everything
14 else in a computer.

15 MR. SCAROLA: Yes, that is non-safety grade.

16 MR. MICHELSON: That's a non-safety grade
17 computer, so that's all lost under certain kinds of
18 circumstances, like loss of power supply or whatever.

19 MR. SCAROLA: We're maintaining the real time
20 information. Well, when you say it's lost, no, I don't want
21 to say that. You never lose the data you have recorded
22 because it goes onto the optical disks which is a permanent
23 media, but from the point that you lose the computer, from
24 there forward you will no longer retain historical data.

25 MR. MICHELSON: You no longer have it.

1 MR. CATTON: On your optical disk, if I attempt to
2 restore on top of information that's already there, what
3 happens?

4 MR. SCAROLA: Oh, if you attempt to rewrite, no,
5 they're write once disks. You write once.

6 MR. CATTON: I hear you, but what if you write
7 twice.

8 MR. SCAROLA: I'll look into it, I don't have the
9 answer.

10 MR. CATTON: You know, I guess --

11 MR. SCAROLA: I don't think you can --

12 MR. CATTON: The reason I asked this is that I
13 have a fancy hard disk in my computer that you're not
14 supposed to do that to --

15 MR. SCAROLA: Yes.

16 MR. CATTON: -- but I had a program for backup
17 that didn't know it, and now I don't have anything on my
18 hard disk.

19 MR. SCAROLA: I think it's a valid question.

20 MR. CARROLL: We should point out that Dr. Catton
21 is a klutz when it comes to mechanical things.

22 MR. CATTON: My son says the problem is I don't
23 read any of the instructions and I don't even read the
24 screen.

25 MR. MICHELSON: Let me go back a minute to the

1 plant process computer. For present day plants is non-
2 safety grade, generally, and not necessarily on good power
3 supply, often out for maintenance, whatever, it's just not
4 treated well because people don't seem to worry about it, so
5 when an event comes along it turns out almost whenever you
6 want it it's not there. Should this be the way we do future
7 plants?

8 MR. SCAROLA: That's not the way we're doing this
9 design. We have --

10 MR. MICHELSON: Maybe I misunderstood then.

11 MR. SCAROLA: We have a computer system that is a
12 100 percent redundant. It has a segmented architecture as
13 well that allows you to take pieces of it out for
14 maintenance and leave the rest of it in operation. If you
15 look inside the control room picture there are about fifteen
16 CRT displays inside the control room. So, there is a
17 significant emphasis on the reliability of that plant
18 computer.

19 MR. MICHELSON: Now, this is the plant process
20 computer, the one that present day plants call non-safety?

21 MR. SCAROLA: Yes, it is a non-safety piece of
22 gear, but we're not designing it to the same criteria.

23 MR. MICHELSON: Okay, how do you power it?

24 MR. SCAROLA: You power it off of battery bus,
25 separate battery busses, there's a fully redundant computer

1 system, we have a x-channel and a y-channnel, those are the
2 non-safety designations, the x-power supply is independent
3 of the y-power supply, and the x-computer is independent of
4 the y-computer.

5 MR. MICHELSON: Are they both in the same cabinet
6 then ultimately?

7 MR. SCAROLA: No, they're not in the same cabinet,
8 they are in the same room, but the room is HVAC.

9 MR. MICHELSON: Okay, so, on a case of a power
10 blackout even, are these battery backups coming from the
11 qualified part of the system, qualified batteries or non-
12 qualified.

13 MR. CATTON: Or does the computer have its own?

14 MR. MICHELSON: This computer does not have its
15 own battery sources, no, it relies on the safety instrument
16 battery buses.

17 MR. MICHELSON: It is using the station battery
18 then, not the vital batteries.

19 MR. SCAROLA: It uses the non-vital instrument
20 battery, right, and those batteries get recharged during a
21 blackout from the gas turban generator.

22 MR. CATTON: Do these computers have an internal
23 interrogation to see that they're upgrading properly?

24 MR. SCAROLA: Yes, not only that.

25 MR. CATTON: Is it automatic?

1 MR. SCAROLA: Yes, it's completely automatic. The
2 other thing I'll point out is that this computer is doing
3 its own dataprocessing, single validation alarm processing,
4 etc., it's also continuously looking at the same
5 calculations that are being performed by these computers,
6 and then that main computer will enunciate that there are
7 discrepancies if they exist, and the logic that goes into
8 that is basically designed to tolerate a little bit of
9 skewing and time because they will not be updating exactly
10 simultaneously.

11 MR. MICHELSON: Let me pursue the battery a little
12 further. Now, these are non-vital, it means it's non-1E
13 battery banks that they're using, is that correct?

14 MR. SCAROLA: For the CRT, no --

15 MR. MICHELSON: So, therefore it's non-seismic and
16 so forth, not necessarily physically separated from the fire
17 viewpoint and sort of thing either since they're not in the
18 set that you normally talk about for separation.

19 MR. SCAROLA: Not physically separated from each
20 other, but definitely physically separated from the class 1E
21 batteries.

22 MR. MICHELSON: Oh, yes, I hope so.

23 [Slide.]

24 MR. SCAROLA: The intent of the design, if I go
25 back and look at the panel, is that the operator has all of

1 this information both qualified and non-qualified at his
2 disposal all the time and he will actually be using it all
3 on a day to day basis. He'll be using his specially
4 dedicated information very frequently because that's the
5 simplest for him to access. The alarms are easy to get to,
6 he looks up and he sees the indicator, he will be relying on
7 those.

8 During an accident the operator will use whatever
9 is in front of him. If the CRTs are working he will use
10 them, but the indicators are the ones that are fully
11 qualified and he will be familiar with them because he uses
12 them every day.

13 That's basically the difference between the
14 philosophy for this control room and the philosophy that we
15 have inside existing control rooms where we have dedicated
16 backup instrumentation that the operator really doesn't use
17 on a day to day basis.

18 [Slide.]

19 MR. SCAROLA: Let me just show you the CRT
20 displays, and I don't think I'm going to be able to show you
21 much. There are --

22 MR. MICHELSON: Let me get a clarification on that
23 panel again. If I've got a four-train system, do I have
24 four separate tiles, one for each of the trains?

25 MR. SCAROLA: No. Let me show you. These are

1 multi-channel sensors that are being looked at
2 simultaneously by both computers, one computer that's
3 operating the electro-luminescence displays, the second
4 computer that's operating the CRT displays. All safety
5 channels and non-safety channels are looked at together, and
6 then the displays are completely independent and redundant.

7 MR. SCAROLA: Well, how about the electro-
8 luminescent panels? How many of those are there -- one for
9 each train, or --

10 MR. SCAROLA: For this particular parameter, which
11 is RCS hot leg temperature --

12 MR. MICHELSON: Well, let's talk about safety.

13 MR. SCAROLA: Okay.

14 MR. MICHELSON: Things where you're monitoring
15 safety situations.

16 MR. SCAROLA: There is a small set of parameters
17 defined by Reg Guide 197 as Category I Parameters. For
18 those, there is a second set of dedicated displays that look
19 exactly like this that simply continuously display that
20 handful of Reg Guide 197 Category I Parameters.

21 MR. MICHELSON: Is that on this same panel?

22 MR. SCAROLA: No. If I go back to the control
23 room, it's in the back. It's in one of the auxiliary panels
24 on the back left-side of the control room. It's what we
25 call the safety monitoring panel.

1 MR. MICHELSON: You have to walk over there to
2 look at it? Is that it?

3 [Slide.]

4 MR. SCAROLA: In the event that all of this
5 information fails, the CRT fails --

6 MR. MICHELSON: Well, I'm just going to let the
7 electro-luminescent panel fail, which I assume there are
8 failure modes for it.

9 MR. SCAROLA: Okay. If the electro-luminescent
10 panel fails, then the same exact information is accessible
11 on the CRT from that exact panel.

12 MR. MICHELSON: Well, I don't know that. It
13 depends on where the power is coming -- and that's a non-
14 qualified CRT, so I don't know where its power is coming
15 from.

16 MR. SCAROLA: I agree if they both fail, the third
17 source is in the back of the control room.

18 MR. MICHELSON: So, I suspect there are single
19 failures for which both the CRT goes and one of the panels?

20 MR. SCAROLA: No.

21 MR. MICHELSON: No?

22 MR. SCAROLA: No. No single failures. They are
23 completely independent. All of the instrumentation that
24 feeds --

25 MR. MICHELSON: They're powered from yet another

1 source somehow?

2 MR. SCAROLA: Yes.

3 MR. MICHELSON: Okay.

4 MR. SCAROLA: These are powered by the vital
5 batteries; these are powered by non-vital batteries.

6 MR. MICHELSON: Okay. Okay. So it would only be
7 -- okay. Okay. But if it were, then there is this back-up
8 for these few essential parameters?

9 MR. SCAROLA: Yes.

10 MR. MICHELSON: Is it located facing the operator,
11 or is it on the back-side of a panel?

12 [Slide.]

13 MR. SCAROLA: No, it faces the operator. Let me
14 get back to a picture so I can show it to you.

15 MR. MICHELSON: Okay. I'll take your word for it.
16 That's okay. I take your word for it.

17 MR. SCAROLA: It's inside the horseshoe.

18 MR. MICHELSON: Okay, it's within the horseshoe.

19 MR. SCAROLA: Yes.

20 MR. MICHELSON: All right. Thank you.

21 MR. SCAROLA: Okay. So that CRT display that I
22 was showing, which I don't think I'll be able to show
23 because it's so dim, is a function-based CRT display. That
24 one was designed to maintain the inventory control function.
25 On that display, it's got --

1 MR. MICHELSON: That's this one?

2 MR. SCAROLA: Yes. It's got a minimum set of
3 parameters that are indicative of the performance of that
4 critical or the status of that function.

5 In addition, there are all of the systems, or what
6 we call success paths, that are used in maintaining that
7 critical function. There is one of those for the nine
8 safety functions, and we've got those same nine as well as
9 an additional three power production functions, and there
10 are displays for each one of those.

11 Now, in addition, the operator can page down and
12 get CRT mimic displays of every fluid system in the plant.
13 So if, for example, the inventory control is supported by
14 safety injection, he can page down and get a mimic of the
15 safety injection system and get detailed status of every
16 pump valve and instrument in that system.

17 MR. MICHELSON: Now, this control panel, this
18 NUPLEX control panel, which you showed me some of the
19 electro-luminescent panels also, there are control functions
20 performed from there, and I guess that's all the little
21 back-lit push-buttons at the bottom or something?

22 MR. SCAROLA: Yes. We have the philosophy to
23 separate monitoring from controls. So all of the controls
24 are on the desk section. There are two types.

25 MR. MICHELSON: But they are all at that location.

1 MR. SCAROLA: Yes. We use electro-luminescent
2 again for the soft controls that you see there, which are
3 the process loop continuous controls, what we used to call
4 PID controllers, proportional integral derivative
5 controllers, and the push-buttons are for the on/off,
6 open/close functions.

7 MR. MICHELSON: Now, if I have a four-train
8 system, then I have four electro-luminescent panels across?

9 MR. SCAROLA: Yes.

10 MR. MICHELSON: And there's a set of controls
11 associated with each of those down on the desk?

12 MR. SCAROLA: Yes. We are maintaining electrical
13 independence of all the channels inside the control room.

14 MR. MICHELSON: And there is some physical
15 separation within the cabinet, or is that a requirement?

16 MR. SCAROLA: Physical separation to accommodate
17 the voltage levels that we have, which are all low-voltage
18 signals inside the panel. We are taking credit for the
19 remote shutdown panel, which I'll show in the next set of
20 slides, for catastrophic events such as fires.

21 MR. MICHELSON: Now, there's got to be some fair
22 amount of power cabling within that cabinet, right, for that
23 CRT and so forth?

24 MR. SCAROLA: When you say "power," you mean
25 voltage level, that type of power?

1 MR. MICHELSON: Yes, and 15, 20, 30 amps circuit,
2 that sort of power. Those CRTs are big and they require a
3 fair --

4 MR. SCAROLA: Yes.

5 MR. MICHELSON: So you have an energetic source in
6 there to ignite a fire within that cabinet?

7 MR. SCAROLA: Yes, that is true.

8 [Slide.]

9 MR. SCAROLA: Let me show you the physical
10 separation and isolation that we have in the entire control
11 complex. We talked extensively about the main control room
12 and the technical support center. Supporting that, we have
13 the computer room, we have the remote shutdown room, four
14 safety-related equipment rooms, and one non-safety related
15 equipment rooms.

16 All of these rooms are physically separated with
17 fire barriers and separate security, and all of the data
18 communication between the room is fiber optic interfaces.

19 MR. CARROLL: What's the fire barrier?

20 MR. SCAROLA: Three-hour fire barriers. What is
21 it physically?

22 MR. CARROLL: Okay. So your use of the word "fire
23 barrier" means the classical three-hour fire barrier?

24 MR. SCAROLA: Yes. Three-hour fire barriers.
25 That's what we're using.

1 MR. MICHELSON: Three-hour fire doors and the
2 works? All the electrical penetrations, as required, will
3 be three-hour?

4 MR. SCAROLA: Certainly in the safety area. I
5 would have to look a little bit more closely in the non-
6 safety area.

7 MR. MICHELSON: Wait a minute. We're just trying
8 to understand what you're trying to tell us. You know, say
9 it right whatever it is.

10 MR. SCAROLA: Well, you're asking a level of
11 detail that I don't --

12 MR. MICHELSON: When you say it's a three-hour
13 barrier, do you mean three-hour electrical penetrations as
14 well as ventilation penetrations and doors, the whole works?
15 Is that what you mean, or do you just mean the wall is
16 three-hours?

17 MR. SCAROLA: That's the intent. Whether or not
18 that is fully carried through in the design, I have to look
19 at it in more detail.

20 MR. MICHELSON: Okay. Because there may be a one-
21 hour door on a three-hour wall, for instance.

22 MR. SCAROLA: Right. I would hope not. I hope
23 not.

24 MR. MICHELSON: Well, it's not uncommon. People
25 put concrete in for other reasons.

1 MR. CARROLL: Yes. There is also the issue of
2 heat going through a three-hour barrier and effecting what's
3 on the other side, and smoke and things like that.

4 MR. MICHELSON: We haven't gotten into the
5 ventilation system at all. He didn't say they're going to
6 ventilate all those from --

7 MR. SCAROLA: We talked earlier about the
8 importance of verification and validation -- excuse me.

9 MR. KENNEDY: If I could, Mr. Chairman, we've got
10 about 35 minutes left. How would you like to split the
11 remaining time. Would you like to continue this discussion?
12 I'm just looking a little -- we have some severe accident
13 discussion and we have our PRA discussion. If you're
14 interested, we can try to squeeze it in. If not, we can
15 continue with the remaining time on I&C.

16 MR. MICHELSON: We have to hear the others, too.

17 MR. WYLIE: I don't know that we're going to gain
18 a great deal by continuing with the I&C because we're going
19 to have -- I mean, that's a lot of detail, it looks like to
20 me.

21 MR. KENNEDY: I think we're going to spend some
22 more time on this in the future, but I don't want to cut you
23 off too soon if this is really of value to you.

24 MR. CARROLL: Well, I guess I agree with Charlie.
25 Just to get a flavor of the whole thing, is there a couple

1 of minutes you want to summarize in, and then we'll pick up
2 the severe accidents, or tell us what you're going to talk
3 about next time or something?

4 MR. SCAROLA: The only issues that we have not
5 addressed, the ATWS issue, and I can say that we are meeting
6 the criteria and we have extensive diversity in the design;
7 and the other one is the station blackout criteria, and
8 there, we talked already about the alternate AC source,
9 which is a gas turbine generator.

10 MR. CARROLL: Yes. We're generally familiar with
11 that.

12 MR. SCAROLA: So, I think that's it. We're all
13 set.

14 MR. CARROLL: Okay. Be ready for some good V&V
15 questions next time.

16 MR. SCAROLA: Thank you very much.

17 MR. TURK: I might point out that we do have
18 working mark-ups of this material in Windsor, the panels
19 that he showed in the 35 millimeter slides, and the staff
20 will be visiting to look at that material, and certainly, if
21 subcommittee members had occasion to be in Windsor and would
22 like to see that, that could be arranged.

23 MR. CARROLL: Just one free comment. Don't make
24 them white. They get too dirty in a control room.

25 [Slide.]

1 MR. TURK: I think 35 minutes for today is briefly
2 acquaints you with the containment design, especially with
3 regard to severe accident features, then Bob Jacquith will
4 give a short run-down on the PRA results today, and then
5 Ernie can summarize quickly.

6 [Slide.]

7 MR. TURK: As was pointed out earlier, the base
8 design that we're using is the Cherokee/Perkins containment
9 design, which is a steel spherical containment, not unlike
10 the Yellow Creek containment. We spent a lot of time in
11 that decision working with EPRI, as you may be aware. The
12 EPRI base design is also a steel containment, but in a
13 cylindrical geometry. Our feelings were that the increased
14 access and maintenance room at the operating floor and
15 several other reasons led us to that preference.

16 MR. CARROLL: I think most of us have heard a
17 presentation on the containment.

18 MR. TURK: All right. That is true. That was
19 part of the containment presentation. So, let me focus,
20 then on severe accident-related features of that containment
21 design.

22 [Slide.]

23 MR. TURK: They are basically inherent, first of
24 all, in the large free-volume of the sphere, and the overall
25 openness and venting of the sphere region. If you look at a

1 cross-section of the containment and the structural walls
2 within it, you can see that it's a relatively open
3 containment that allows for fairly free natural circulation
4 throughout the sphere. You can all see here the in-
5 containment refueling water storage tank.

6 MR. CARROLL: Is it intended to use igniters
7 anywhere in this containment?

8 MR. TURK: The current design would show that for
9 the NRC criteria of, right now, 100 percent of the clad
10 mixture and the 10 percent detonability limit, we would need
11 igniters in the containment. Moving with, the EPRI criteria
12 would be such that 75 percent and 13 percent would allow not
13 using igniters.

14 MR. CARROLL: Well, you would probably need them
15 in things like the refueling water storage tank, don't you?

16 MR. TURK: In the vent area, yes. The vents for
17 in-containment refueling water storage tank.

18 MR. CATTON: Do you make any assumptions regarding
19 where the hydrogen is, or do you assume that it's fully
20 mixed throughout the volumes?

21 MR. TURK: Depending upon the event, yes, there
22 are assumptions. It was pointed out, in a vent that
23 resulted in the discharge to the in-containment refueling
24 water storage tank, prior to any failure, the hydrogen would
25 be generated in the tank, released as the coolant was

1 released. I don't know; can you speak to the assumptions as
2 far as the map code in hydrogen generation --

3 MR. CATTON: You don't have to. I know what the
4 map code does. The assumption that the hydrogen is mixed
5 within the volumes is not correct. You certainly are going
6 to have stratification of hydrogen in your containment, and
7 I think somehow you're going to have to come to grips with
8 that.

9 MR. MATZIE: This is Regis Matzie again. There
10 was a special study of the hydrogen mixing issue by the
11 advanced reactor/severe accident program, probably now on
12 the order of a year, year and a half ago, for this
13 particular design. And. that study showed very good mixing
14 within the major part of the containment, but that there was
15 high concentrations in the area of the IRWST for those
16 scenarios where you were venting into the IRWST, such as
17 station black out. There is very good natural circulation,
18 very open containment, so we would expect with the lower
19 limits with the EPRI program has proposed, that overall
20 containment would not need igniters, but there would be some
21 requirement for localized igniters in the areas where the
22 stuff would be concentrating because of the scenario.

23 MR. CATTON: Are you familiar with the study that
24 was done for NRC by the National Academy?

25 MR. MATZIE: I personally am not.

1 MR. CATTON: It's interesting. It was a very good
2 study, yet nobody seems to know about its existence. In any
3 event, one of the first things that they note is that when
4 you release a mixture of hydrogen and steam, hydrogen will
5 stratify. It's not "it might" or "it could;" it will.
6 Second, there is experimental data available through the HDR
7 containment in Germany, which you guys probably know about,
8 where they have measured significant stratification. Now, I
9 know that NRC talks about it being mixed, and I have read
10 what Fauske & Associates did for EPRI, but somehow they're
11 avoiding the fact that the stuff's going to stratify. When
12 it stratifies, it escapes very strongly.

13 They had circumstances where the hot
14 air/steam/helium mixtures in the HDR facility got into the
15 top of the building and it was days -- you could walk and
16 reach up and stick your hand into the region where it was
17 extremely hot, and yet you were comfortable down below. And
18 that's how strong the stratification was. I just don't see
19 anybody dealing with it and NRC not requiring it. And I'm
20 gonna harass you forever about the stratification, unless
21 there's something that really demonstrates it won't occur,
22 some reason for it not occurring. I'm familiar with some of
23 the testing that was done early on by EPRI, but it was in
24 the kinds of chambers where you would expect there to be
25 mixing. If you say you're always going to have your sprays

1 on, sprays will keep it mixed, but by itself, it ain't gonna
2 be mixed. You agree with that, don't you?

3 MR. CARROLL: I believe I do, Dr. Catton. I think
4 somebody's hiding their head in the sand on some of this
5 hydrogen issue myself.

6 MR. CATTON: Too many things have blown up. Not
7 in the nuclear business.

8 MR. CARROLL: Including a couple of utility
9 generators that have had hydrogen leaks that I've been
10 familiar with.

11 MR. CATTON: Buoyancy driven flows are, generate
12 very strong stratified flows. There is an example at Edison
13 where they had, it was just the insulation was off a pipe
14 and the heated plume went all the way up 20 or 30 feet
15 without mixing with the surrounding air and cooked the cable
16 tray. Any of the kinds of calculations that you guys might
17 do would not show that.

18 MR. TURK: I think to quickly go through these
19 prior to presenting the PRA results, the other aspects of
20 the containment design that you may recall from having seen
21 it before is the fact that the cavity design is such that a
22 large floor area is provided to facilitate coolability.
23 Again, we've used the guidelines that have been developed
24 during the ALWR program of about .02 meters per megawatt.
25 There's a flood capability from the in-containment refueling

1 water storage tank to that cavity for coolability and
2 there's also --

3 MR. CARROLL: How does that work? Does it flood
4 it before the core's on the floor, or floods it after, or
5 thermal fuses?

6 MR. TURK: The design we're working on, it is in
7 the state of work, would allow for operator decision. It
8 would not be an automatic flooding system. That's
9 consistent with the current EPRI requirements. It is an
10 issue as part of the DSER on the EPRI Chapter 5. So I think
11 that is an open design issue right now.

12 MR. CATTON: Does this mean that you're going to
13 let EPRI make the decision for you?

14 MR. TURK: No, I didn't mean that, but it means
15 that we will be working with EPRI on the decision. We are
16 part of the EPRI program. We are a contractor to EPRI on
17 the EPRI program. So, we have been, I think, relatively
18 successful in the EPRI program of reaching consensus
19 decisions on most things; there have been a few exceptions
20 where we have --

21 MR. CATTON: Well, there's the consensus on the
22 hydrogen that I think the consensus is not right. And I'm a
23 little concerned about this water, when you're going to put
24 the water, because if you put it after, there's some
25 question about the formation of crusting and everything else

1 so that the water really doesn't do you any good. If you
2 put the water before, can you stand the rapid steam
3 generation, the rapid pressurization and maybe even the
4 possibility of having steam explosions that might do some
5 damage, not that the damage would be --

6 MR. TURK: And a factor in that is whether or not
7 sprays are available in the containment when that's going
8 on.

9 MR. CATTON: Right, so there's a whole lot of
10 factors. There's the wind.

11 MR. TURK: Which leads us to the accident
12 mitigation question that Mr. Ward brought up earlier, that
13 this is an issue of, and as I say, the current design bases
14 is that it's an issue of a vent condition that will probably
15 have to be evaluated, and we're talking in terms of
16 providing a capability that has to be directed.

17 MR. CATTON: Having, essentially, a steel sphere,
18 are you concerned about the problem the Mark 1 has, the Mark
19 1 reactor, Mark 1 containment?

20 MR. TURK: The problem being?

21 MR. CATTON: The problem being that the molten
22 core hits the liner.

23 MR. TURK: Bill, do you want to address? I'll put
24 the picture up here for you to speak to.

25 MR. CATTON: I'm not familiar with layout in the

1 building and where it is.

2 MR. TURK: This is the cavity area that we're
3 talking about, and this being the floor area.

4 MR. CATTON: What is the blue?

5 MR. TURK: The blue is concrete. Okay, Bill?

6 MR. FOX: My name's Bill Fox, with Duke, working
7 with CE on this design. The blue area shown is inside
8 containment concrete. The cavity that's on the picture
9 there is where the core would be disbursed into. As shown,
10 going up the right hand side in the very laborious fashion,
11 a vent path for the pressurized release. Also, on the right
12 side just above the bottom of the cavity there is what we
13 call a core debris chamber that entrains heavy core material
14 back down into the bottom of the reactor vessel cavity while
15 allowing the hot gases to go out. Once it releases out of
16 the reactor cavity itself, it then goes into open
17 containment and the crane wall is completely circumferential
18 around the cavity and the steam generators which will,
19 again, provide a separate protected area from containment
20 contact.

21 MR. CATTON: All those surfaces are concrete?

22 MR. FOX: That is correct. Or, lined concrete
23 with stainless steel. And the bottom, I believe, is 5 feet
24 below the vessel of concrete cover before it gets to the
25 containment, which is continuous through, and sandwiched in

1 between the interior and exterior concrete.

2 MR. CATTON: What corrosion --

3 MR. FOX: With stainless steel plates, it's not a
4 concern.

5 MR. CARROLL: You're thinking of the outside
6 surface of the containment shell?

7 MR. CATTON: Yes. The containment shell is
8 sandwiched in concrete.

9 MR. CARROLL: That's not a problem if you build it
10 right. It's just looking at all your fancy arrows that one
11 would almost assume that you knew what you were doing. The
12 flow processes are very complicated.

13 MR. CARROLL: What he's accomplishing is, he's
14 going to burn a vent in the top of the containment valve
15 there.

16 MR. CATTON: At the tip of that arrow is where all
17 of the hydrogen is going to be. You ought to think about
18 that.

19 MR. TURK: I think the only remaining feature is
20 the depressurization system which we did talk about earlier.
21 So I'd like Bob Jacquith to just go through quickly the DRA
22 results we have to date.

23 MR. CATTON: Is this anything like that Italian
24 guy, Petrangeli's super system saver? Or are you familiar
25 with that?

1 MR. CARROLL: Suppose the O2, -- I always get the
2 units mixed up, meters squared per megawatt thermal isn't
3 enough, do you have room?

4 MR. MATZIE: Regis Matzie. This was an integrated
5 effort and that was an extension of the cavity quite a bit
6 to get that floor area. It would be very difficult to get a
7 substantially greater amount if that criteria was not
8 acceptable.

9 MR. CATTON: I think that criteria leads to 30
10 centimeter deep pool of molten whatever on the floor.

11 MR. FOX: Phil Fox again with Duke. I believe the
12 criteria for this particular design allows for a nine inch
13 bed of core material with this particular surface area we
14 allotted for.

15 MR. CATTON: What are you going to do if the
16 criteria is not acceptable?

17 MR. CARROLL: Go to a cylindrical.

18 MR. CATTON: The criteria basically says that it's
19 coolable, that you can flush it.

20 MR. FOX: We would have to go back and revisit
21 that. It took a tremendous amount of iteration to get there
22 and relaying all the requirements and coupling them together
23 with all the accident issues to come up with that design.
24 If that criteria is not accepted, we would have to go back
25 and revisit and see what we can come up with.

1 [Slide.]

2 MR. JACQUITH: My name is Bob Jacquith and I'm
3 supervisor of the reliability and risk assessment group.
4 And I'm going to try to do the short version here.

5 We are still working on our PRA, the objectives of
6 which were to comply with the severe accident policy
7 statement to provide a level 3 PRA for a System 80+. As a
8 part of that, we are demonstrating compliance with a 10 to
9 minus five core belt objective, 10 to minus six large
10 release objective, and demonstrate adequate containment
11 performance reliability.

12 And moreover, as a part of the design process, PRA
13 integrated pretty much into the design process.

14 [Slide.]

15 MR. JACQUITH: The approach that we used was to
16 perform a baseline PRA per system 80. That was the CESSAR
17 System 80 design. This being an evolutionary design, the
18 design evolved from System 80 and the PRA did also in lock
19 step with the PRA.

20 And again the design changes were evaluated using
21 PRA and the ultimate product here for the PRA will be a
22 level 3 PRA.

23 [Slide.]

24 MR. JACQUITH: Where we are as far as internal
25 events goes for the PRA is that we have calculated that the

1 core melt frequency is less than 10 to minus six for
2 internal events and you can see here that we are dominated
3 really by three things.

4 The vessel rupture which we consider to be
5 conservatively large. We have just not worked to cut that
6 down at all. ATWS is still an important contributor.

7 MR. CATTON: What did you do with the human
8 factors in this? It's not in?

9 MR. JACQUITH: Pardon me? We modeled the human
10 interaction the same --

11 MR. CATTON: Traditional approach. Seven times 10
12 to the minus seven is a pretty low number.

13 MR. JACQUITH: This is for internal events only.
14 It is a very low number. That's right.

15 MR. CATTON: It's one of the lowest I think I've
16 seen. It borders on the unbelievable.

17 MR. CARROLL: How about Seal LUCA? Why is that
18 not a problem?

19 MR. JACQUITH: Seal LUCA --

20 MR. CARROLL: Is it encompassed by the small LUCA?

21 MR. JACQUITH: It is encompassed in the station
22 blackout analysis.

23 MR. CARROLL: In the station blackout. Do you
24 have a separate source of power for the seals, for seal
25 cooling?

1 MR. JACQUITH: No, we don't, but, we've got an
2 auxiliary AC power supply. I want to go on a little bit.

3 MR. MICHELSON: Let me ask, why is the vessel
4 rupture a higher probability than a pipe break, even a small
5 pipe break?

6 MR. CARROLL: A small LUCA doesn't lead to core
7 damage.

8 MR. MICHELSON: These are just frequency of
9 occurrence?

10 MR. CARROLL: No, no.

11 MR. JACQUITH: This is core damage, excuse me.
12 This is core damage.

13 MR. MICHELSON: This is a core damage. All right.
14 That could be right.

15 [Slide.]

16 MR. CATTON: Have you defended these numbers in
17 front of the staff yet?

18 MR. JACQUITH: We have presented the Level I.

19 MR. CATTON: Those are the numbers you have up
20 here?

21 MR. JACQUITH: Pardon me?

22 MR. CARROLL: The numbers you had. You have new
23 numbers now. Do you believe them?

24 MR. SINGH: We just received the submittal a
25 couple of months ago, and we just started looking at it.

1 MR. CATTON: I'd be very interesting in hearing
2 what you have to say about numbers like ten-to-the-minus-
3 ten.

4 MR. SINGH: Yes. Of course.

5 MR. MATZIE: Regis Matzie. I guess I should point
6 out that we had the baseline System 80 PRA submitted quite a
7 while ago, and it was reviewed I guess by Brookhaven
8 National Laboratory in addition to the staff, and have fed
9 back all their feedback in terms of the methodology and the
10 results and incorporated it into the System 80+ PRA.

11 So, there has been a lot of scrutiny on methods
12 and on approaches for the System 80 calculated numbers, and
13 we have incorporated that into the System 80 plus.

14 MR. CATTON: I don't think people ever really
15 questioned the methods used in PRA. The bottom line, if you
16 put in the same numbers, you usually get the same answer.
17 What people question is the numbers you put into it, and
18 when you get numbers like ten-to-the-minus-ten, where in the
19 hell did you get the input to get a number that's ten-to-
20 the-minus-ten. I just don't believe it. It's too small
21 unless there's something really unique about your system.

22 We're going to have some interesting explorations,
23 I think, in the future with you guys.

24 MR. MICHELSON: These are interesting.

25 MR. CARROLL: They do not include the traditional

1 sabotage or cognitive human error kind of stuff.

2 MR. JACQUITH: Excuse me?

3 MR. CARROLL: These numbers on the previous slide
4 do not include sabotage or cognitive human error?

5 MR. JACQUITH: That's correct. Well, they do not
6 include errors of commission, correct.

7 When we include the external events of seismic
8 events and tornadoes, our core melt frequency is one-point-
9 six times ten-to-the-minus six.

10 MR. CATTON: I haven't seen fire yet. I think
11 that's supposed to be an external event.

12 MR. JACQUITH: Well, there is a footnote here that
13 we have not explicitly modeled fire or flood --

14 MR. MICHELSON: Yet.

15 MR. JACQUITH: -- and that --

16 MR. CATTON: He didn't say yet; he just said he
17 didn't do it.

18 MR. MICHELSON: Well, I assume you're going to do
19 it.

20 MR. JACQUITH: We provided a position paper to the
21 staff about a year and a half ago. Based on the fact that
22 the new design requirements with regard to fire and flood
23 are much more severe than they were ten years ago, and the
24 specifics of our design, which are very unusual isolation
25 between the quadrants under the containment, so that it was

1 justified, we feel, that the frequency is so low that it
2 need not be specifically --

3 MR. MICHELSON: I thought the licensing basis
4 agreement said you were going to do it, but maybe I didn't
5 read it carefully.

6 MR. CARROLL: Can we get a copy of the position
7 paper? Can somebody send it to Med?

8 MR. JACQUITH: Yes.

9 MR. CARROLL: On both issues, because both of them
10 are of interest to us.

11 MR. JACQUITH: Okay.

12 MR. CATTON: Is the heating ventilation system
13 separate for each of these quadrants?

14 MR. JACQUITH: Yes, it is.

15 MR. CATTON: So you have four of them, four
16 independent systems?

17 MR. JACQUITH: There are certainly two independent
18 systems, and each of the -- the answer is yes, there are
19 four.

20 MR. MICHELSON: And there is no common building
21 ventilation that, for normal operation, ties the two
22 together? That's really what he's asking, I think.

23 MR. CATTON: Yes. I think so, too.

24 MR. MICHELSON: Some people have come up with
25 that. Some said, "No. We're going to keep ventilation

1 totally separated, even the normal ventilation." You
2 haven't said that either way yet.

3 MR. JACQUITH: I'm pretty sure that --

4 MR. KENNEDY: That's correct, we have not set it
5 either way yet.

6 MR. MICHELSON: That issue is where you start
7 worrying, then, about heat and smoke from fire going through
8 the back way and heating up other rooms. There are a whole
9 lot of issues that really haven't been addressed here at all
10 yet, but we'll get to them.

11 MR. CATTON: Are you going to write that down on
12 your list?

13 MR. MICHELSON: Well, certainly fire will be
14 addressed. But I thought it was, and I'm just trying to
15 find again in here why I got misled.

16 MR. CARROLL: Yes. I came away with the same
17 impression you did.

18 MR. MICHELSON: Yes. I must have got misled when
19 I read it, or I was sleeping probably.

20 MR. EL-ZEFTAWAY: Page 31.

21 MR. MICHELSON: Thirty-one.

22 [Slide.]

23 MR. JACQUITH: Additionally with regard to
24 containment performance, one of the staff's issues is
25 containment performance, and we are attempting to

1 demonstrate the ruggedness of the containment design by
2 predicting the reliability for severe accident sequences.
3 The notion here is that the frequency of large releases
4 ought to be on the order of attempt or less of the core melt
5 frequency.

6 That is a goal that we probably can meet. Whether
7 that's the right thing to do or not isn't quite decided yet.
8 We aren't quite far enough along.

9 MR. CARROLL: What are the arguments pro and con
10 since we're also wrestling with this question?

11 MR. JACQUITH: Well, one argument is, as you've
12 already pointed out, our core melt frequency is very low,
13 and there is a requirement -- you know, the inverse of the
14 requirement is that the core melt frequency has to be at
15 least ten times higher than large-release frequency, and we
16 could cause that to happen, but we probably shouldn't.

17 There are some decisions to be made with regard to
18 diverse containment heat removal capability. That is an
19 issue that we're still wrestling with. Whether that's
20 required or not -- it might be required in order to meet
21 that ten-percent requirement, whereas to meet the ten-to-
22 the-minus-six requirement, it probably is not required.

23 MR. CARROLL: If, instead of the tenth, you did
24 your "or," what deterministic analysis do you think would be
25 appropriate?

1 MR. JACQUITH: Well, we've already demonstrated, I
2 believe, two things. One is that within the PRA, 97 percent
3 of the core damage sequences, the containment holds together
4 for at least 24 hours, okay. That's one.

5 MR. CARROLL: And why is 24 hours good enough?

6 MR. JACQUITH: I'm not saying it is. I just said
7 that's a fact.

8 There's another. The NRC has proposed a
9 requirement or a sort of a proof of principle here, maybe,
10 that Level C stresses not be violated for 24 hours, and I
11 believe that we're on the edge of demonstrating that right
12 now.

13 MR. MATZIE: This is Regis Matzie. That alternate
14 or "or" category of potential criteria was listed in the
15 EPRI Chapter 5 draft SER from the staff, and we have been
16 looking at whether that would be an acceptable alternative
17 to the conditional failure probability. It looks as if that
18 could be achieved, too.

19 MR. CARROLL: One in ten bothers me from the point
20 of view that we're discouraging people from doing the right
21 thing. If you think you got it bad, think of the poor high-
22 temperature gas cool guys.

23 MR. MICHELSON: Let me point out why I got misled
24 on fire, and I think I haven't -- I think you have not
25 stated it correctly, or whoever wrote the licensing basis

1 agreement.

2 On page 20, you talk about the PRA, and there it
3 says that the System 80 probabilistic risk assessment will be
4 a Level III PRA which addresses both internal and external
5 initiators of accident sequences which lead to core damage.

6 Now, you did take one exception further down the
7 paragraph. You said sabotage would not be addressed.
8 Nowhere did you take exception to fire not being addressed.

9 MR. MATZIE: In the middle of the paragraph, it
10 says "External events [seismic events and tornado strikes
11 only]."

12 MR. MICHELSON: Well, that's relative to the
13 bounding plant site characteristics. On a site, sure, you
14 worry about seismic and tornado and not fire, but on the
15 plant itself, when you do the PRA, you worry about fire. I
16 read that as something you did with the site only.

17 MR. JACQUITH: The fact is that we really did
18 consider fire and flood and tsunami and sand slides and --

19 MR. MICHELSON: We're just interested in internal
20 fires now.

21 MR. JACQUITH: No, I understand that.

22 MR. MICHELSON: Okay.

23 MR. JACQUITH: But you mentioned there, you quoted
24 chapter and verse, that we were considering a whole bunch of
25 external events. Well, we did consider them and we wrote a

1 position paper that basically put some of them to rest.

2 MR. MICHELSON: I guess you should have taken fire
3 as an exception, then, because you did take sabotage as an
4 exception.

5 MR. KENNEDY: This is Ernie Kennedy. I agree I
6 think we should clarify the LRB.

7 MR. MICHELSON: Yes.

8 MR. KENNEDY: Our intent was that fires would not
9 be there, and if this is misleading, we ought to fix it.

10 MR. MICHELSON: Well, it sure doesn't say that
11 fires aren't there because that's not a part of the bounding
12 -- the bounding plant site characteristics -- sure, that's a
13 different issue. That's external fires.

14 MR. CATTON: Did the NRC staff accept your
15 position paper?

16 MR. SINGH: No, the staff has not accepted what is
17 written in the LRB, and you will be seeing our comments.

18 MR. MICHELSON: I have not heard the staff ever
19 say they can eliminate fire from a PRA yet.

20 MR. SINGH: That's right.

21 MR. CARROLL: What do we do for the last two
22 minutes?

23 [Slide.]

24 MR. JACQUITH: Let me show one last slide here,
25 which is the kind of improvements that we got going from

1 system 80 to system 80+, and you can see that we've picked
2 up two orders of magnitude of improvement, there are five
3 slides in your handout that maybe you'll get a chance to
4 look at on your own, and that basically identifies the
5 features that make each one of these things go down, okay.

6 MR. CATTON: Somehow those things are incredible,
7 you go from ten to the minus five to two times ten to the
8 minus eight on transients.

9 MR. JACQUITH: Right.

10 MR. CATTON: That's going to be very difficult
11 to --

12 MR. JACQUITH: No, I understand, I wish though
13 that we had more time.

14 MR. CATTON: Well, we will, we will.

15 MR. JACQUITH: We really did overwhelm these
16 problems with four trains of this, four trains of that,
17 extra electricity, you know, all sorts of improvements,
18 and --

19 MR. CATTON: But there's a bottom line on every
20 one of the numbers there which is the human --

21 MR. CARROLL: Or the common mode failure kills
22 you.

23 MR. JACQUITH: We've had common mode failure in
24 the human model --

25 MR. CATTON: We are going to be very interested in

1 seeing how you did that.

2 MR. MICHELSON: In the external event of fire it
3 may kill you, too, because if we believe other people have
4 studied it, it's about half the total contribution, and it's
5 not even in here. So, you know --

6 MR. CATTON: I am just trying to sensitize you a
7 little bit as to what it will be like next time.

8 MR. CARROLL: Yes, you didn't even have the mean
9 guys here today.

10 MR. MICHELSON: We are just the good guys.
11 I think at the next meeting we're going to discuss what
12 completeness of design means also, because we will have to
13 prepare some recommendations to the Commission after our
14 next meeting and that's one of the issues I think the
15 commissioners had better face up to.

16 MR. KENNEDY: Let me, if I could, just make two
17 very brief closing comments. I put this slide up earlier on
18 the purpose of the LRB. One comment I would like to make on
19 this last bullet, as evidenced by today's meeting our LRB
20 discussed a number of issues for which there's a potential
21 for a lot of dialogue with both the ACRS and the staff. Our
22 purpose in the LRB is to identify those issues and we
23 believe they'll be resolved as part of the review of the
24 application. We think if we use the LRB to resolve the
25 issues then the approval of the LRB may be concurrent with

1 the end of the review. So, we try to avoid trying to use
2 the LRB specifically to resolve the issues, because we don't
3 think we get there from here. We'd like to do that on the
4 application.

5 MR. MICHELSON: Are you suggesting the LRB be
6 approved at the end of the game instead of the beginning?

7 MR. KENNEDY: No, I'm suggesting it be approved at
8 the beginning, but to do that you probably can't resolve the
9 issue in the LRB. You have to identify it there, and the
10 resolution comes as part of the technical review of the
11 application.

12 MR. MICHELSON: What good is an LRB approval then
13 if we leave all the really important things out because they
14 haven't been resolved?

15 MR. CARROLL: It's the road map as to where you're
16 going that you've agreed to up front. It's agreed that
17 you've agreed that fire is a potential issue, Combustion's
18 position is this, the staff has to come back and take a
19 position.

20 MR. MICHELSON: Yes, I guess if you want to
21 tabulate issue its purpose could be useful.

22 MR. CATTON: If it's for a road map it's clearly
23 going to mark the points that you have to get over.

24 MR. MICHELSON: But having approved such a
25 document and having found out later you left some things off

1 the road map, what does the approval mean?

2 MR. CATTON: Your last point is that the above is
3 not all inclusive.

4 MR. MICHELSON: Okay, then you're all right,
5 that's a very good insulator.

6 MR. CATTON: I don't think approval has any
7 meaning.

8 MR. MICHELSON: No, and I'm wondering if whether
9 we'll even do it.

10 [Slide.]

11 MR. KENNEDY: I would also like to respond very
12 briefly, I did say the end of the meeting I would talk a
13 little bit about essentially complete plant. Let me do that
14 very briefly and I'm sure we'll have to continue this
15 discussion later.

16 MR. MICHELSON: Is this the slide we have?

17 MR. KENNEDY: No, this is backup slide, but this
18 is quote from part 52, so it's nothing magic. The level of
19 detail or essentially complete plant to us has two
20 dimensions. First, the scope of the plant. I think we've
21 made a pretty clear commitment that the scope of system 80+
22 is going to be a complete plant, and we heard some comments
23 today that perhaps service water, portable water, to some
24 extent should come within that definition. I think we can
25 talk about that, but there's no doubt we've committed to the

1 essentially complete as far as scope of plant.

2 With regard to level of detail, this slide is
3 nothing more than a quote from part 52 on what part 52 says
4 about the level of detail. The only point I want --

5 MR. MICHELSON: Which part of part 52 are you
6 quoting from?

7 MR. KENNEDY: 52.47[a][2] I believe.

8 MR. CARROLL: You have seen those words before,
9 Carl, we've had a lot of debate about them.

10 MR. MICHELSON: I just want to --

11 MR. KENNEDY: They're in 5247 somewhere.

12 MR. MICHELSON: Yes.

13 MR. KENNEDY: The point I wanted to make about
14 this is the way the rule is constructed it distinguishes
15 between the material which is presented to the staff and
16 that which is made available for audit by the staff. It is
17 our intention to present CESSAR-DC, all of the information
18 that the staff will need to close out its safety review.
19 Essentially that means since the staff used the application
20 to the standard review plan, we have to present in the
21 application the information necessary for the staff to make
22 that review or make its finding. So, CESSAR-DC is going to
23 look very much like what you're used to seeing in a FSAR,
24 absent if you will procurement level and as-built data which
25 obviously won't be in there to the extent it's in somebody's

1 FSAR.

2 MR. CARROLL: But will it be available for audit?

3 MR. KENNEDY: That's what I wanted to come to.

4 Because this is an evolutionary plant design, we are
5 fortunate in that much of the detailed design information in
6 a lot of areas already exists in our files. For example,
7 Rick Turk pointed out that within the reactor we have
8 retained a lot of our previous design. All of that design
9 information down to the equipment specs, performance specs,
10 is there, is available for audit. So, we are fortunate that
11 that information exists.

12 In areas where we have changed the design we are
13 developing the information down to whatever level it's going
14 to take to support the staff and we expect that to be a
15 rather iterative effect, it will depend, I think, on the
16 importance of that particular component, or the importance
17 of that particular system to safety, and the information
18 that we've got. We intend to develop that information to
19 whatever level of detail it takes.

20 MR. MICHELSON: Will that be at the level that the
21 regulation talks about when it says an essentially complete
22 means of being able to write your procurement spec from it
23 and so forth?

24 MR. KENNEDY: Yes, but it would be the information
25 you would need to include in the procurement spec to specify

1 the functional and performance requirements of that system
2 for its safety functions. Now, what you might not find, and
3 I say might not because some of it is there, what you might
4 not find is some of our, if you will, commercial
5 requirements which we would impose on that component.

6 MR. MICHELSON: Well, you don't find a boiler
7 plate, no.

8 MR. KENNEDY: That's right, you wouldn't
9 necessarily find that boiler plate. Now, in those areas
10 where we have already developed you find that to. We
11 wouldn't create a new document.

12 That, in a nutshell, is a brief discussion of the
13 level of detail and I think it deserves some further
14 discussion.

15 MR. CARROLL: ACRS had a lot of trouble with this
16 language when part 52 was going through, and, you know, my
17 problem is that I can take something that I've labelled
18 procurements and I can buy a quality piece of hardware or
19 I can buy a piece of junk, and I'm worried about a whole
20 string of plants having that range of options on hardware.

21 MR. KENNEDY: Okay, we --

22 MR. MICHELSON: First of all, of course, there
23 must be enough information with which to write a procurement
24 spec and that's, I think you've agreed that amount of
25 information will be there, and do you agree that that's the

1 criteria one should look at in terms of judging the
2 completeness of design then? Is there enough there to go
3 out and buy the component?

4 Also, is there enough information to go out and
5 construct the plant? That's the way it was defined
6 originally, and I think that's the way EPRI is still
7 defining it. Essentially complete and ready for design and
8 construction.

9 MR. KENNEDY: Let me draw a distinction --

10 MR. MICHELSON: No, no, no, pardon me.
11 Procurement and construction.

12 MR. MATZIE: Let me tell you my opinion. Regis
13 Matzie. You certainly could not construct a plant based on
14 the level of detail. You've got to do design detail for the
15 items -- the construction level of detail has got to be
16 still done for any of these plants that you're thinking of
17 certifying. We don't think that's anywhere near the level
18 of detail needed to certify the safety of the design, and
19 you've got to have all the minute details to let a craftsman
20 go do the construction. That's not needed to determine
21 safety. There's one level above that, and that's -- we're
22 all struggling with defining what that level is.

23 MR. MICHELSON: Yes. Do you need to know where
24 the piping is, where the cable trays are to define safety,
25 for instance?

1 MR. MATZIE: Certainly major allocations of space
2 for important systems, I think that's the answer, for
3 separation, sabotage, fire protection, all the kinds of
4 things you've talked about, sort of, today, the issues
5 you're going to ask to look into in more detail.11. But, you
6 know the specific location of a pipe hanger, no. I mean,
7 you don't need to know that.

8 MR. MICHELSON: You need to know where all these
9 multi-plexars are located, for instance, around the plant,
10 and where its wiring or its cabling goes from there to the
11 main control room or to the instrument room or wherever.
12 You need to know that in order to do a fire analysis.

13 MR. MATZIE: I think, in general, that's correct.

14 MR. MICHELSON: Okay. We're perhaps together.

15 MR. CARROLL: Okay. So, in order to let these
16 guys go catch their airplane, you'll send Med your list and
17 we'll look it over for completeness?

18 MR. KENNEDY: Yes. What we would like to do, I
19 suppose, is we would kind of like to work with the committee
20 and the staff to work out, if you will, a series of meetings
21 so we can discuss like topics in a meeting and have the
22 appropriate people here, and kind of look a little bit to
23 the future as far as you'd like to look ahead.

24 MR. CARROLL: Okay. Well, Med would be the focal
25 point on that.

1 MR. KENNEDY: Okay.

2 MR. CARROLL: We've established the same kind of
3 relationship with GE and Westinghouse, so there's no reason
4 we can't with you guys.

5 MR. KENNEDY: Well, it's good to be here today.

6 MR. CARROLL: All right. I will say that I
7 thought the presentations today were very first-rate, and we
8 learned a lot.

9 MR. KENNEDY: Thank you.

10 MR. CARROLL: Does anybody have anything else to
11 say as they're walking out the door?

12 [Laughter.]

13 MR. MICHELSON: Let's talk about the next meeting,
14 but we can do that off the record.

15 MR. CARROLL: All right. Adjourned.

16 [Whereupon, at 2:57 p.m., the hearing adjourned.]

17

18

19

20

21

22

23

24

25

REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

in the matter of:

NAME OF PROCEEDING: Subcommittee Meeting on Advanced
Pressurized Water Reactors

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, Maryland

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

Marilynn Nations

Marilynn Nations
Official Reporter
Ann Riley & Associates, Ltd.

SYSTEM 80+ LRB DOCUMENT

MILESTONES

SCHEDULES

o REVISED INPUT FROM CE

1/22/90

o STAFF REVIEW

IN PROGRESS

o RECOMMENDATIONS TO ACRS/COMMISSION
- COMMISSION PAPER

IN PREPARATION

o ACRS MEETING

TBD

o COMMISSION MEETING

TBD

o COMMISSION APPROVAL

TBD

o ISSUE FINAL LRB DOCUMENT

TBD

System 80+TM Standard Design Licensing Review Basis Document

**Presentation To The
ACRS Advanced PWR Subcommittee**

April 3, 1990

ABB Combustion Engineering Nuclear Power

SYSTEM 80+TM

E.H. KENNEDY,
MANAGER
NUCLEAR SYSTEMS LICENSING

AGENDA

- o INTRODUCTION TO LRB E. H. KENNEDY
- o SYSTEM 80+ PROGRAM OVERVIEW R. A. MATZIE
- o SYSTEM 80+ DESIGN & PRA:
 - R. S. TURK,
 - W. A. FOX,
 - K. SCAROLA
 - R. E. JAQUITH
- TECHNICAL ISSUES
DISCUSSED IN LRB
- COMPARISON TO SYSTEM 80
- o SUMMARY & CONCLUSIONS E. H. KENNEDY

PURPOSE OF MEETING

- O ACRS SUBCOMMITTEE COMMENTS ON SYSTEM 80+
 LICENSING REVIEW BASIS DOCUMENT (LRB)**
- O REVIEW SYSTEM 80+ DESIGN FEATURES**


HISTORY OF LRB

- 0 FIRST PROPOSED LRB: JULY 1987
- 0 SEVERAL REVISIONS
 - 0 ISSUANCE OF 10 CFR 52: APRIL 1989
- 0 REVISED LRB. AUGUST 1989
 - 0 STAFF REQUIREMENTS MEMORANDUM: DEC. 1989
- 0 CURRENTLY PROPOSED LRB: JANUARY 1990

PURPOSE OF LRB

- O IMPLEMENT PART 52 PROCESS**
- O DEFINE SCHEDULE FOR SUBMITTAL/NRC REVIEW**
- O IDENTIFY IMPORTANT ISSUES TO BE ADDRESSED DURING REVIEW OF APPLICATION.**

DESIGN CERTIFICATION



CONTENT OF LRB

0 SCOPE OF SYSTEM 80+ DESIGN

- COMPLETE PLANT

0 SCHEDULE FOR APPLICATION/REVIEW

- | | | |
|---|----------------------|-------|
| - | COMPLETE APPLICATION | 12/90 |
| - | FDA | 12/91 |
| - | DC | 12/92 |

SYSTEM 80+ APPLICATION FOR
DESIGN CERTIFICATION

"CESSAR-DC"

COMBUSTION ENGINEERING STANDARD SAFETY
ANALYSIS REPORT - DESIGN CERTIFICATION


CESSAR-DC SUBMITTALS NOW COMPLETED:

- | | | |
|----------------|---|--------------------------------|
| NOVEMBER 1987 | - | GENERAL DESCRIPTION |
| | - | POWER CONVERSION SYSTEM |
| APRIL 1988 | - | REACTOR CORE & COOLANT SYSTEM |
| | - | CHEMICAL AND VOLUME CONTROL |
| | - | PROCESS SAMPLING |
| JUNE 1988 | - | SHUTDOWN COOLING |
| | - | SAFETY INJECTION |
| | - | EMERGENCY FEEDWATER |
| SEPTEMBER 1988 | - | SITE ENVELOPE |
| | - | SAFETY DEPRESSURIZATION |
| | - | EMERGENCY FEEDWATER |
| MARCH 1989 | - | LEAK-BEFORE-BREAK |
| | - | BALANCE OF PLANT SYSTEMS |
| | - | ELECTRICAL POWER DISTRIBUTION |
| | - | REACTOR PROTECTION SYSTEM |
| | - | FUEL HANDLING SYSTEM |
| | - | RADWASTE SYSTEM |
| | - | BUILDING AND SITE ARRANGEMENTS |
| | - | CONTAINMENT SYSTEMS |
| | - | SABOTAGE PROJECTION PROGRAM |
| DECEMBER 1989 | - | UPDATE FUEL METHODOLOGY |
| | - | DESCRIPTIONS |
| | - | RESOLUTION OF 64 USIs/GSIs |
| | - | PRA METHODOLOGY & LEVEL 1 |

REMAINING CESSAR-DC SUBMITTALS:

- | | | |
|----------------------|---|--|
| APRIL 1990 | - | USI/GSI RESOLUTIONS (20) |
| | - | ECCS AND CONTAINMENT ANALYSES |
| AUGUST 1990 | - | SAFETY ANALYSES |
| | - | PRA AND SEVERE ACCIDENT RESULTS |
| | - | SEISMIC METHODS |
| | - | BUILDING LAYOUTS |
| DECEMBER 1990 | - | SEISMIC RESULTS |
| | - | TECHNICAL SPECIFICATIONS |
| | - | INSPECTIONS, TESTS, ANALYSES |
| | - | MAINTENANCE AND RELIABILITY |
| | | GUIDELINES |
| | - | REMAINING USIs/GSIs |

System 80+ Design Certification in the U.S. NRC Review Schedule



CONTENT OF LRB . . .

0 SEVERE ACCIDENT ISSUES:

- USIs/GSIs
- PRA
- SEVERE ACCIDENT PERFORMANCE GOALS
 - CORE DAMAGE
 - LARGE RELEASE
 - CONTAINMENT PERFORMANCE

CONTENT OF LRB . . .

0 OTHER SPECIFIC ISSUES:

- COMPARISON WITH EPRI REQUIREMENTS
- PHYSICAL SECURITY AND SABOTAGE
- SITE ENVELOPE
- COMPLETENESS OF DESIGN DOCUMENTATION
- QUALITY ASSURANCE
- MAINTENANCE, SURVEILLANCE & RELIABILITY
- SAFETY GOAL POLICY STATEMENT
- 60-YEAR LIFE
- FIRE PROTECTION
- STATION BLACKOUT
- LEAK-BEFORE-BREAK
- SOURCE TERMS
- OBE/SSE
- CONTAINMENT LEAK RATE
- HYDROGEN GENERATION
- CONTAINMENT VENTS
- MID-LOOP OPERATION
- INTERFACING SYSTEM LOCA
- ATWS
- ELECTRICAL SYSTEM DESIGN
- DEGRADED CORE BEHAVIOR

15 "TECHNICAL" ISSUES

- *1. PUBLIC SAFETY GOALS
- *2. SOURCE TERMS
- *3. ATWS
- *4. MID-LOOP OPERATION
- *5. STATION BLACKOUT
- *6. FIRE PROTECTION
- *7. INTERSYSTEM LOCA
- *8. HYDROGEN GENERATION AND CONTROL
- *9. CORE-CONCRETE INTERACTION
- *10. HIGH-PRESSURE CORE MELT EJECTION
- *11. CONTAINMENT PERFORMANCE
- *12. "ABWR" CONTAINMENT VENT
- 13. EQUIPMENT SURVIVABILITY
- *14. OBE/SSE
- 15. IST FOR PUMPS AND VALVES

* CURRENTLY ADDRESSED IN LRB

DETAILED AGENDA

9:00 - 9:30 INTRODUCTION E. H. KENNEDY

- PURPOSE OF MEETING
- HISTORY OF LRB
- CONTENTS OF LRB

9:30 - 9:50 PROGRAM OVERVIEW R. A. MATZIE

- DESIGN PROCESS
- PARTICIPANTS
- DESIGN OBJECTIVES
- DESIGN SCOPE

**9:50 - 10:40 SYSTEM 80+ DESIGN R. S. TURK
(AND COMPARISON TO SYSTEM 80)**

- RV, FUEL, INTERNALS
- REACTOR COOLANT SYSTEM
 - MID-LOOP
- SAFEGUARDS
 - IST PUMPS/VALVES
 - SOURCE TERMS
- AUXILIARY SYSTEMS
 - INTERSYSTEM LOCA
- COMPARISON TO EPRI REQUIREMENTS

10:40 - 10:50 BREAK

10:50 - 11:20 INSTRUMENTATION AND ELECTRICAL SYSTEMS K. SCAROLA

- ATWS
- STATION BLACKOUT

11:20 - 11:50 SYSTEM 80+ CONTAINMENT Wm. A. Fox

- FIRE PROTECTION
- OBE/SSE

11:50 - 12:20 SEVERE ACCIDENT FEATURES R. S. TURK

- H₂ CONTROL
- CORE/CONCRETE INTERACTION
- HIGH PRESSURE CORE MELT EJECTION
- "ABWR" VENT
- EQUIPMENT SURVIVABILITY

12:20 - 12:50 PRA R. E. JAQUITH

- OBJECTIVES
- STATUS
- SAFETY GOALS
- CONTAINMENT PERFORMANCE
- RESULTS (LEVEL I)

12:50 - 1:00 SUMMARY AND CONCLUSIONS E. H. KENNEDY

R. A. MATZIE,


DIRECTOR

ADVANCED WATER REACTOR PROJECTS

SYSTEM 80+ PROGRAM OBJECTIVES

- 0 DEVELOP AN ADVANCED PWR DESIGN WITH:
 - ENHANCED SAFETY
 - INCREASED MARGINS
 - IMPROVED OPERABILITY AND MAINTAINABILITY
 - REDUCED COST
 - PROVEN TECHNOLOGY
- 0 OBTAIN NRC CERTIFICATION OF THE ADVANCED DESIGN TO:
 - REDUCE LICENSING RISK
 - RETAIN NUCLEAR AS A VIABLE OPTION

C-E EVOLUTIONARY ALWR PROGRAM



**APPROACH FOR DEVELOPING
SYSTEM 80+ STANDARD DESIGN**

- 0 START WITH CURRENT SYSTEM 80 (CESSAR-F) AND DUKE POWER'S CHEROKEE/PERKINS BOP**
- 0 CONSIDER CHANGES DUE TO**
 - EPRI ALWR REQUIREMENTS**
 - NRC MANDATED CHANGES (PRIMARILY TO ADDRESS SEVERE ACCIDENTS)**
 - C-E DESIRED CHANGES (AS A RESULT OF OPERATIONAL FEEDBACK)**
- 0 ASSESS IMPACT OF CHANGES ON**
 - SAFETY**
 - PERFORMANCE**
 - OPERABILITY**
 - MAINTAINABILITY**
 - COST**
- 0 INCORPORATE CHANGES USING**
 - PRA**
 - COST/BENEFIT**
- 0 REVISE STANDARD DESIGN (SYSTEM 80+/CESSAR-DC)**

SYSTEM 80 IS A MAJOR PORTION OF A NUCLEAR PLANT

- o NSSS
- o PLANT PROTECTION AND MONITORING SYSTEMS
- o SUPPLEMENTARY PROTECTION SYSTEM
- o SHUTDOWN COOLING SYSTEM
- o SAFETY INJECTION SYSTEM
- o CHEMICAL AND VOLUME CONTROL SYSTEM
- o WATER CHEMISTRY
- o FUEL HANDLING SYSTEM

**SYSTEM 80+ IS A COMPLETE
NUCLEAR POWER PLANT**

- 0 REACTOR SYSTEMS**
- 0 SAFEGUARDS SYSTEMS**
- 0 STEAM AND POWER CONVERSION SYSTEMS**
- 0 TURBINE GENERATOR SYSTEMS**
- 0 WASTE MANAGEMENT SYSTEMS**
- 0 ONSITE POWER SYSTEM**
- 0 CONTAINMENT STRUCTURE AND SUPPORT SYSTEMS**
- 0 COOLING WATER SYSTEMS**
- 0 SUPPORT SYSTEMS**
- 0 CONTROL BUILDINGS**
- 0 OTHER BUILDINGS (FUEL, DIESEL GENERATOR, ETC.)**

**STRUCTURES
SYSTEMS, AND COMPONENTS
FOR WHICH A CONCEPTUAL
DESIGN WILL BE PROVIDED**

- 0 OFFSITE POWER SYSTEMS**
- 0 TRAINING AND SUPPORT FACILITIES**
- 0 HEAT SINKS AND INTAKE STRUCTURES**
- 0 POTABLE AND SANITARY WATER**

SYSTEM 80+ ASSURED CONSTRUCTABILITY & COSTS

0 CONSTRUCTION SCHEDULE:

- 48 MONTHS (FIRST CONCRETE TO FUEL LOAD)
- 6 MONTHS (START-UP)

0 PLANT COSTS:

- CAPITAL <\$1150/KWE
- FUEL <0.8¢/KWH
- O&M <1.2¢/KWH
- TOTAL LIFE CYCLE COSTS <5.8 ¢/KWH

0 CONFIDENCE IN SCHEDULE AND COSTS IS VERY HIGH, SINCE EXISTING CONSTRUCTION TECHNIQUES ARE USED AND DESIGN DETAILS ARE ALREADY KNOWN

**SYSTEM 80+
IMPROVED OPERATION**

- O 60-YEAR DESIGN LIFE**
- O AVAILABILITY >87%**
- O OUTAGE TIME**
 - <30 DAYS/YEAR**
 - INCLUDING REFUELING TIME, <50 DAYS/FUEL CYCLE**
- O UNPLANNED TRIPS <1/YR**
- O PERSONNEL EXPOSURE <100 MAN-REM/YR**
- O IMPROVEMENT MAINTAINABILITY:**
 - SELF-TESTING FEATURES**
 - REDUCED ISI**
 - INCREASED WORK SPACE**
 - SEPARATION OF SAFETY/NON-SAFETY SYSTEMS**

SYSTEM 80+ SAFETY GOALS

- 0 CORE DAMAGE FREQUENCY $<10^{-5}$ EVENTS/YR
- 0 SEVERE ACCIDENT RELEASE $<10^{-6}$ EVENTS/YR FOR
OCCURRENCE OF DOSES GREATER THAN 25 REM AT SITE
BOUNDARY

SYSTEM 80+/SYSTEM 80 DESIGN COMPARISON**SYSTEM 80⁺™****AREA****DESIGN OBJECTIVES****CHANGES FROM SYSTEM 80****REACTOR**

- MAINTAIN PROVEN DESIGN
- MEET UTILITY PERFORMANCE NEEDS

- VERY FEW CHANGES
- PART-STRENGTH RODS FOR LOAD FOLLOW

REACTOR COOLANT SYSTEM**IMPROVE PLANT MARGINS**

- LOWER OPERATING TEMPERATURES
- INCREASED SYSTEM VOLUMES
- IMPROVED MATERIALS

SAFEGUARDS SYSTEMS**REDUCE CORE MELT FREQUENCY**

- REDESIGN IN VERY CLOSE CONFORMANCE WITH EPRI ALWR REQUIREMENTS
- ADDED SAFETY DEPRESSURIZATION SYSTEM

SYSTEM 80+/SYSTEM 80 DESIGN COMPARISON . . .**SYSTEM 80+™**

<u>AREA</u>	<u>DESIGN OBJECTIVES</u>	<u>CHANGES FROM SYSTEM 80</u>
AUXILIARY SYSTEMS	SIMPLIFICATION	Non-safety CVCS
CONTAINMENT	- ADDRESS SEVERE ACCIDENTS MEET UTILITY MAINTENANCE NEEDS	USE DUAL, SPHERICAL STEEL DESIGN
INSTRUMENTATION AND CONTROL	PROVIDE STATE OF THE ART, HUMAN FACTORS ENGINEERED CONTROL COMPLEX	NUPLEX 80+
ELECTRICAL DISTRIBUTION AND SUPPORT SYSTEMS	IMPROVE RELIABILITY CONSISTENT WITH SAFEGUARDS SYSTEMS	GREATER REDUNDANCE AND DIVERSITY

DIFFERENCES FROM EPRI DESIGN REQUIREMENTS

- 0 DEGREE OF COMPLIANCE IS HIGH (>95%)
- 0 DIFFERENCES RELATED TO PLANT PERFORMANCE, NOT REGULATORY REQUIREMENTS.
- 0 LIST OF DIFFERENCES MAY CHANGE DUE TO COMPLETION OF:
 - EPRI ALWR DESIGN REQUIREMENTS
 - SYSTEM 80+ DESIGN

SPECIFIC DIFFERENCES FROM EPRI
ALWR DESIGN REQUIREMENTS

- 0 HOT LEG TEMPERATURE, 615°F (S-80+) vs. 600°F
- 0 SG SUPPORTS, SKIRT (S-80+) vs. PEDESTAL OR OPEN FRAME
- 0 SG HANDHOLES, BOTTOM TUBESHEET (S-80+) vs. EVERY TUBE SUPPORT ELEVATION
- 0 CEA ANTI-EJECTION LATCHES, SYSTEM 80+ DOES NOT INCLUDE THEM.
- 0 EFW CROSS-CONNECT, SYSTEM 80+ HAS A NORMALLY-CLOSED CROSS-CONNECT
- 0 FW ISOLATION VALVES, REDUNDANT (S-80+) vs. FWIV & CONTROL VALVE
- 0 MAIN FW PUMPS, TURBINE-DRIVEN (S-80+) vs. MOTOR-DRIVEN
- 0 MAIN STEAM ISOLATION, NOT INITIATED FOR S-80+ ON PRESSURE RATE-OF-CHANGE
- 0 CABLE FAILURE DETECT/REPAIR CRITERION MAY NOT BE MET

**SPECIFIC DIFFERENCES FROM EPRI
ALWR DESIGN REQUIREMENTS . . .**

- 0 SOME PVC AND NEOPRENE INSULATION MAY BE USED
- 0 ALTERNATE AC SOURCE WILL NOT MEET IEEE 387 (DGs)
- 0 SYSTEM 80+ RETAINS THE RVLMS
- 0 DIESELS WILL NOT BE AUTOMATICALLY LOADED WITHOUT TG TRIP
- 0 DUAL CONTAINMENT, SPHERICAL (S-80+) VS. CYLINDRICAL
- 0 NSSS OFFSET IN CONTAINMENT, NO OFFSET (S-80+) VS. 15-20 FOOT OFFSET
- 0 EQUIPMENT HATCH, OPERATING FLOOR LEVEL (S-80+) VS. GRADE LEVEL

R. S. TURK,
PROJECT MANAGER
SYSTEM 80+ DEVELOPMENT


SYSTEM 80+ DESIGN FEATURES


0 REACTOR*

- INCREASED OVERPOWER MARGIN
- MANEUVERING CONTROL WITHOUT SOLUBLE BORON
- RING FORGED REACTOR VESSEL
- LONG-LIFE CONTROL RODS

* DESIGN CHANGES ARE RELATIVE TO SYSTEM 80

System 80+ Reactor Enhancements





SYSTEM 80+™

REACTOR CORE CROSS SECTION
241 FUEL ASSEMBLIES

Figure

4.1-2

DESIGN CHANGES TO INCREASE THERMAL MARGIN

<u>CHANGE</u>	<u>APPROX. GAIN</u>
LOWER COOLANT TEMPERATURE (°F)	3%
HIGHER CORE FLOW RATE (2%)	2%
COLSS/CPC IMPROVEMENTS	4%
ADVANCED INTEGRAL B.P. (OPTIONAL)	2%
	<hr/> 9-11%


NET THERMAL MARGIN FOR SYSTEM 80+ (TYPICAL)

INITIAL CORE	18 - 20%
RELOAD CORES	15 - 17%

CONTROL ELEMENT ASSEMBLY DESIGN CHANGE COMPARISON

<u>CEA TYPE</u>	<u>SYSTEM 80</u>		<u>SYSTEM 80+</u>	
	<u>NUMBER</u>	<u>ABSORBER</u>	<u>NUMBER</u>	<u>ABSORBER</u>
FULL STRENGTH (12-FINGER)	48	B ₄ C	48	B ₄ C
FULL STRENGTH (4-FINGER)	28	B ₄ C	20	AG-IN-CD
PART-LENGTH (4-FINGER)	13	B ₄ C	--	--
PART-STRENGTH (4-FINGER)	--	---	25	INCONEL
TOTAL	<u>89</u>	<u>10-YEAR LIFE</u>	<u>93</u>	<u>20-YEAR LIFE</u>

SYSTEM 80 REACTOR VESSEL COMPARISON




SYSTEM 80+ DESIGN FEATURES...

○ REACTOR COOLANT SYSTEM:


- 33% LARGER PRESSURIZER
- 10% SG TUBE PLUGGING MARGIN AND 10% MORE HEAT TRANSFER AREA
- 25% LARGER SECONDARY INVENTORY
- MORE CORROSION RESISTANT SG TUBES (INCONEL 690)
- SG DESIGNED FOR EASE OF MAINTENANCE (LARGER MANWAYS)
- 6°F LOWER HOT LEG TEMPERATURE (T_H)
- REDUCED VIBRATION IN SG ECONOMIZER REGION
- LOWERED FW DISTRIBUTION RING
- IMPROVED STEAM DRYERS
- SECONDARY SIDE PRESSURE REDUCED 70 PSIA TO 1000 PSIA

REACTOR & TURBINE TRIP




SYSTEM 80+

REACTOR & TURBINE TRIP




SYSTEM 80+



SYSTEM 80+

SYSTEM 80+ STEAM GENERATOR ENHANCEMENTS



SYSTEM 30+ DESIGN FEATURES...


0 SAFEGUARD SYSTEMS:


- FOUR-TRAIN SAFETY INJECTION SYSTEM,
- SHUTDOWN COOLING AND CONTAINMENT SPRAY SYSTEMS
- SAFETY DEPRESSURIZATION SYSTEM
- IN-CONTAINMENT REFUELING WATER STORAGE TANK
- FOUR-TRAIN EMERGENCY FEEDWATER SYSTEM

SYSTEM 80+ DESIGN FEATURES...

- **SAFETY INJECTION SYSTEM:**
 - SEGREGATED SYSTEM INTO QUADRANTS
 - INJECT DIRECTLY INTO REACTOR VESSEL
 - FOUR 100% CAPACITY PUMPS (HIGH PRESSURE)
 - ELIMINATION OF NEED FOR LOW PRESSURE PUMPS
 - SUCTION FROM IRWST (ELIMINATION OF SWITCHOVER FROM EXTERNAL WATER SUPPLY)
 - ON-LINE FULL FLOW TEST CAPABILITY
 - PERFORMS BORON INJECTION ACCIDENT MITIGATION FUNCTION

ENGINEERED SAFETY FEATURES SYSTEM (Safety Injection System)





SMALL BREAK LOSS OF COOLANT ACCIDENT
(SYSTEM 80 vs SYSTEM 80+)


SYSTEM 80+ DESIGN FEATURES...

- SHUTDOWN COOLING AND CONTAINMENT SPRAY SYSTEMS:
 - INCREASED PRESSURE (900 PSIA) OF SHUTDOWN COOLING SYSTEM
 - INDEPENDENT BUT INTERCHANGEABLE SHUTDOWN COOLING AND CONTAINMENT SPRAY
 - ON-LINE FULL-FLOW TEST CAPABILITY
 - HIGHER CAPACITY CONTAINMENT SPRAY

INTERSYSTEM LOCA (ISSUE 7)

- o DESIGN BASES: MINIMIZE PROBABILITY OF INTERSYSTEM LOCA
- o KEY DESIGN FEATURES:
 - ELIMINATION OF LOW PRESSURE SAFETY INJECTION
 - SCS DESIGN PRESSURE INCREASED TO 900 PSIA
 - TRIPLE PRESSURE ISOLATION VALVES (PIV) (I.E., CHECK VALVES OR MOV'S) FOR SCS
 - FOR SIS, CVCS AND SAMPLING SYSTEM; ONE OR MORE OF THE FOLLOWING APPLY:
 - ...SYSTEM PIPING ULTIMATE RUPTURE STRENGTH IS EQUAL TO NORMAL RCS PRESSURE,
 - ...CHARGING PUMPS CAN MAKEUP LOST INVENTORY,
 - ...BREAK IS ASSUMED TO OCCUR INSIDE CONTAINMENT,
 - ...FLOW PATH CONTAINS NORMALLY OPEN VALVES WHICH CAN ISOLATE THE BREAK.
 - MEAN FREQUENCY OF ISI IS $3.0E-9$ EVENTS PER YEAR.

ENGINEERED SAFETY FEATURES SYSTEM (Shutdown Cooling & Containment Spray System)



MID-LOOP OPERATION (ISSUE 4)

- o DESIGN BASIS: MINIMIZE THE PROBABILITY OF LOSING DECAY HEAT REMOVAL CAPABILITY DURING MID-LOOP OPERATION.
- o DESIGN FEATURES:
 - DEDICATED, PERMANENT, SAFETY GRADE INSTRUMENTATION
 - LEVEL DETECTION TO BOTTOM OF HL
 - CORE EXIT TEMPERATURE AVAILABLE DURING SHUTDOWN
 - FAVORABLE RCS LAYOUT
 - SUCTION PIPING CONNECTED TO BOTTOM OF HL
 - SUCTION PIPING ORIENTED VERTICALLY
 - SCS PUMP LOCATED IN SUBSPHERE
 - ONE OF FOUR HPSI PUMPS CAN BE AVAILABLE
 - SCS AUTO CLOSURE LOGIC REMOVED
 - CONSIDERING DESIGN CHANGE TO DECREASE VORTEXING (VORTEX BREAKER)
 - OPERATIONAL GUIDELINES WILL ADDRESS MID-LOOP OPERATION (E.G., PRESSURIZER MANWAY VENT)

INSERVICE TESTING OF PUMPS AND VALVES (ISSUE 15)

o DESIGN BASES:

- EPRI ALWR REQUIREMENTS
- 10 CFR 50.55,
- NRC GENERIC LETTERS 89-04 AND 89-10,
- ASME CODE, SECTION XI.

o DESIGN FEATURES;

- FULL FLOW TEST CAPABILITY FOR SCS PUMPS.
- COMPLIANCE WITH EPRI ALWR REQUIREMENTS ON SAFETY-RELATED PUMP AND VALVE TESTING.
- TESTING OF SAFETY-RELATED PUMPS AND VALVES UNDER DESIGN CONDITIONS.
- ADDRESS ANY EXCEPTIONS OF PVNGS PROGRAM
- ALARMS FOR LEAKAGE INTO (OVER-PRESSURIZATION) OF LOW-PRESSURE SYSTEMS.

SOURCE TERMS (ISSUE 2)

o DESIGN BASIS:

- MEET CURRENT NRC REGULATIONS AND GUIDANCE
- IMPLEMENT EPRI ALWR REQUIREMENTS TO EXTENT PRACTICABLE


o DESIGN APPROACH:

- CURRENTLY APPROVED METHODOLOGY (TID 14844, REG. GUIDES, SRP) IS BEING USED FOR THE DESIGN BASIS SAFETY ANALYSIS. REQUIREMENTS OF 10 CFR 100 WILL BE MET.
- A MORE REALISTIC SOURCE TERM WILL BE USED FOR SEVERE ACCIDENT EVALUATIONS. SPECIFIC REVISIONS TO BE FINALIZED DURING NRC STAFF REVIEW. [A REDUCTION IN THE EPZ BASED ON MORE REALISTIC SOURCE TERMS IS OUTSIDE THE SCOPE OF OUR DESIGN CERTIFICATION PROGRAM.]


- **SAFETY DEPRESSURIZATION SYSTEM:**

- **SAFETY GRADE VENTING OF
NON-CONDENSIBLE GASES FROM
PRESSURIZER AND REACTOR VESSEL**
- **SAFETY GRADE RCS DEPRESSURIZATION AND
COOLDOWN IF NORMAL PRESSURIZER SPRAYS
ARE NOT AVAILABLE**
- **RCS DEPRESSURIZATION TO INITIATE
BLEED AND FEED FLOW IN UNLIKELY EVENT
OF TOTAL LOSS OF FEEDWATER FLOW**
- **RCS DEPRESSURIZATION DURING A SEVERE
ACCIDENT SCENARIO**
- **MANUAL CONTROL FROM THE CONTROL ROOM**

SAFETY DEPRESSURIZATION AND VENT SYSTEM



- **EMERGENCY FEEDWATER SYSTEM FEATURES:**
 - **DEDICATED SAFETY SYSTEM (NO OPERATING FUNCTIONS FOR NORMAL PLANT OPERATION)**
 - **FOUR-TRAIN SYSTEM:**
 - FOR EACH STEAM GENERATOR;**
 - A. **ONE 100% CAPACITY MOTOR-DRIVEN PUMP TRAIN**
 - B. **ONE 100% CAPACITY TURBINE-DRIVEN PUMP TRAIN**
 - C. **ONE EMERGENCY FEEDWATER STORAGE TANK**
 - D. **ONE CAVITATING VENTURI**
 - **FOUR-CHANNEL CONTROL SCHEME TO PRECLUDE INADVERTENT ACTUATION DUE TO SINGLE FAILURE**
 - **MANUAL CROSS CONNECTION CAPABILITY BETWEEN TRAINS**



EMERGENCY FEEDWATER SYSTEM

SYSTEM 80+ DESIGN FEATURES...

0 AUXILIARY SYSTEM DESIGN:

- NON-SAFETY GRADE CHEMICAL AND VOLUME CONTROL SYSTEM
- SIMPLIFIED RCS CHARGING AND AUXILIARY SPRAY PIPING
- HIGHER LETDOWN EXCHANGER DESIGN PRESSURE
- LETDOWN FLOW VALVE WITH FIXED ORIFICE
- CENTRIFUGAL CHARGING PUMPS
- ELIMINATION OF EXTENSIVE HEAT TRACING

WM. A. Fox, III

DUKE ENGINEERING SERVICES, INC.

SYSTEM 80+TM

SYSTEM 80+ CONTAINMENT

CONTAINMENT SELECTION PROCESS:

- o SPHERICAL STEEL CONTAINMENT VESSEL (SSCV)

CONTAINMENT DESCRIPTION:

- o TECHNICAL DATA
- o SECTIONS & PLANS

CONTAINMENT FEATURES:

- o IRWST
- o SEVERE ACCIDENTS

"TECHNICAL" ISSUES:

- o FIRE PROTECTION
- o SEISMIC DESIGN

SYSTEM 80+ CONTAINMENT...

CONTAINMENT SELECTION PROCESS:

- o REVIEWED DECISION FOR SELECTION OF P-81 CONTAINMENT
- o DEVELOPED INDEPENDENT CONSIDERATIONS AND CONCERNS FOR CONTAINMENT TYPE SELECTION
 - DESIGN
 - CONSTRUCTION
 - OPERATION, MAINTENANCE AND TESTING
 - DESIGN BASIS EVENTS & SEVERE ACCIDENT
- o CLOSELY FOLLOWED WORK ON DOE DESIGN FOR CONSTRUCTABILITY PROGRAM (INDEPENDENT FROM SYSTEM 80+)
 - COMPARATIVE CONSTRUCTABILITY EVALUATIONS OF 4 DIFFERENT PWR CONTAINMENT TYPES
- o FACTORS FOR SELECTION OF SSCV

SYSTEM 80+ CONTAINMENT...


FACTORS FOR SELECTION OF SSCV:

- o SPHERE IS TECHNICALLY SUPERIOR HOWEVER LACKS U.S. EXPERIENCE
- o ECONOMICALLY COMPETITIVE WHEN CONSIDERING:
 - OPERABILITY/MAINTAINABILITY
 - RELIABILITY/AVAILABILITY
 - SAFETY MARGINS AND ACCIDENT RECOVERABILITY
 - CONSTRUCTION IMPACT COSTS
 - INVESTMENT PROTECTION (MINIMIZE VULNERABILITY)
- o MEETS EPRI ALWR FUNCTIONAL REQUIREMENTS
- o BENEFITS

SYSTEM 80+ DESIGN CONTAINMENT...

- 0 **LARGE, STEEL SPHERICAL CONTAINMENT:**
 - **DUAL CONTAINMENT**
 - **200 FT. DIAMETER**
 - **INCREASED SPACE FOR MAINTENANCE & ACCESS**
 - **DESIGNED TO MITIGATE SEVERE CORE DAMAGE**
 - **SHADOW AREA HOUSES SAFEGUARD SYSTEMS**

Containment Building — Elevation View




TECHNICAL DATA**CONTAINMENT:**


CONTAINMENT TYPE	STEEL SPHERE
STEEL TYPE	SA-537 CL. 2
INTERNAL DIAMETER	200 FEET
WALL THICKNESS	1.75 IN.
FREE VOLUME	3.4×10^6 CU. FT.
DESIGN PRESSURE	49 PSIG

SHIELD BUILDING:


TYPE	CONCRETE
INTERNAL DIAMETER	210 FEET
WALL THICKNESS	3 FEET



SECTION VIEW 0 - 180
SYSTEM 80+



SECTION VIEW 90 - 270
SYSTEM 80+



**BASEMAT PLAN SUBSPHERE
SYSTEM 80+**

SYSTEM 80+ CONTAINMENT...

0 IN-CONTAINMENT REFUELING WATER STORAGE TANK (IRWST)


- STRUCTURAL CHARACTERISTICS

- TOROIDAL, USING CONTAINMENT INTERNAL STRUCTURE AS BOUNDARY
- LOCATED LOW IN CONTAINMENT FOR OPTIMAL SPACE UTILIZATION AND IMPROVED WATER RETURN PATH

- FUNCTIONAL CHARACTERISTICS

- CAPACITY IN EXCESS OF 500,000 GALLONS
- PROVIDE WATER FOR EMERGENCY CORE COOLING AND REFUELING
- PROVIDE ENERGY SINK FOR SAFETY DEPRESSURIZATION SYSTEM
- ELIMINATES NEED FOR RECIRCULATION MODE OF EMERGENCY CORE COOLING
- PROVIDE SOURCE OF WATER FOR REACTOR CAVITY FLOODING
- SCRUBS RADIOACTIVE MATERIAL FROM DISCHARGE OF PRESSURIZER SAFETY VALVES AND SAFETY DEPRESSURIZATION SYSTEM

Nuplex 80 + CRT Displays



Integrated Process Status Overview Display



Second Level Critical Function Display




Third Level Diagnostic Display




Third Level Success Path Display

Nuplex 80 + Control Panel



Combustion Engineering, Inc.
1000 Prospect Hill Road
Windsor, Connecticut 06095




**IRWST PLAN
SYSTEM 80+**


SYSTEM 80+ CONTAINMENT...

DESIGN CHARACTERISTICS FOR SEVERE ACCIDENTS:


- o LARGE REACTOR VESSEL CAVITY FLOOR AREA FOR DEBRIS COOLABILITY
- o ABILITY TO FLOOD CAVITY FROM IRWST FOR DEBRIS QUENCHING
- o FEATURES TO RETAIN CORE DEBRIS IN REACTOR VESSEL CAVITY TO MINIMIZE DIRECT CONTAINMENT HEATING (TWICE CORE VOLUME)
- o LABORIOUS BUT OPEN AND FREE EXITWAY OUT OF REACTOR VESSEL CAVITY
- o VENT PATHS TO FACILITATE CONTAINMENT ATMOSPHERE MIXING AND HYDROGEN DILUTION




SECTION



**IN CONTAINMENT REFUELING
WATER STORAGE TANK**



SEVERE ACCIDENT MITIGATION



POST-ACCIDENT VENTILATION

FIRE PROTECTION (ISSUE 6):**o APPROACH:**

- FIRES ARE ADDRESSED SEPARATELY FROM THE DESIGN BASIS AND SEVERE ACCIDENT ANALYSES
- FIRE ANALYSIS WILL INCLUDE PREVENTION, DETECTION, SUPPRESSION AND CONTAINMENT FEATURES
- ACCEPTANCE CRITERIA:
 - SAFE SHUTDOWN CAN BE ACHIEVED ASSUMING ALL EQUIPMENT ON ANY ONE FIRE AREA IS RENDERED INOPERABLE AND RE-ENTRY FOR OPERATOR ACTION IS NOT POSSIBLE. THE CONTROL ROOM IS EXCLUDED, PROVIDED THAT AN INDEPENDENT, ALTERNATE SHUTDOWN CAPABILITY IS PROVIDED.
 - PROTECTION MUST BE PROVIDED FOR REDUNDANT SHUTDOWN SYSTEMS IN CONTAINMENT TO ENSURE TO EXTENT PRACTICAL THAT ONE DIVISION WILL REMAIN FREE OF DAMAGE.
 - SMOKE, HOT GASES, AND FIRE SUPPRESSANT WILL NOT MIGRATE TO OTHER AREAS TO ADVERSELY AFFECT SHUTDOWN CAPABILITY.

FIRE PROTECTION . . .

o DESIGN FEATURES:

- PLANT ARRANGEMENTS PROVIDE FOR PHYSICAL SEPARATION
 - REDUNDANT EQUIPMENT IN SEPARATE ROOMS WITH CLEAR PHYSICAL BARRIERS (FIREWALLS) NOT ONLY BETWEEN DIVISIONS BUT ALSO BETWEEN TRAINS WITHIN EACH DIVISION
 - SEPARATE AND DEDICATED PLANT SHUTDOWN CAPABILITY FOR CONTROL ROOM FIRE
- DETAILED FIRE ANALYSIS WILL BE PROVIDED

OBE/SSE (ISSUE 14):**o DESIGN BASIS:**

- OBE DECOUPLED FROM SSE AND ESTABLISHED INDEPENDENTLY, BASED UPON INVESTMENT PROTECTION.
- SEISMIC DESIGN SPECTRA INCLUDES LATEST TECHNOLOGICAL DEVELOPMENTS INCLUDING HIGHER AMPLITUDES AT HIGHER FREQUENCY RANGES ALONG WITH AN ENVELOPING SOIL-STRUCTURE INTERACTION ANALYSES

o DESIGN FEATURES:

- SAFE SHUTDOWN EARTHQUAKE (SSE) PEAK GROUND ACCELERATIONS OF 0.3g.
- DESIGN BASIS OBE GROUND ACCELERATION OF 0.1g
- OBE OF 0.1g WILL STILL CONTROL THE DESIGN OF PLANT STRUCTURES AND SOME PIPING SYSTEMS COMPONENTS

SYSTEM 80+ CONTAINMENT...

BENEFITS OF SPHERICAL STEEL CONTAINMENT VESSEL:

- o ANALYSIS CONSIDERATIONS
- o CONCRETE SHIELD BUILDING
- o LARGE SUBSPHERE AREA
- o EFFICIENT UTILIZATION OF VOLUME AND SPACE
- o UTILIZATION OF INTERIOR STRUCTURAL COMPONENTS
 - CRANE WALL
 - IRWST IN LOWER CONTAINMENT
 - RV CAVITY DESIGN FOR ACCIDENT MITIGATION
 - CONTAINMENT VENTILATION
- o SAFETY CONSIDERATIONS
- o CONSTRUCTION SCHEDULE IMPROVEMENTS
- o OPERATIONS AND MAINTENANCE ADVANTAGES

SYSTEM 80+ CONTAINMENT...

SUMMARY:

- SPHERE BETTER SATISFIES THE FUTURE NUCLEAR PLANT REQUIREMENTS FOR THE SYSTEM 80+™
- MORE POTENTIAL SOLUTIONS FOR SEVERE ACCIDENTS REQUIREMENTS AND SAFETY ISSUES
- OPEN CONTAINMENT MINIMIZES CONGESTION AND EASES OPERATIONS AND MAINTENANCE ACTIVITIES
- PARALLEL PATH CONSTRUCTION ADVANTAGES THUS REDUCING CONSTRUCTION SCHEDULES
- OVER OPERATING LIFE, PROVIDES A MAJOR ADVANTAGE IN EFFICIENCY AND COST

K. SCAROLA,

SUPERVISOR

ADVANCED INSTRUMENTATION DESIGN

NUPLEX 80+ DESIGN BASES


- 0 MEET ALL CURRENT REGULATORY AND INDUSTRY REQUIREMENTS FOR INSTRUMENTATION AND CONTROLS:
 - POST-TMI ACTION PLAN
 - HUMAN FACTORS ENGINEERING
 - FIRE PROTECTION AND SABOTAGE
 - VERIFICATION AND VALIDATION
 - PRA

- 0 TO IMPROVE PLANT SAFETY:
 - DIGITAL PROTECTION SYSTEMS WITH CONTINUOUS AUTOMATIC TESTING
 - FOUR-TRAIN ESFAS
 - IMPROVED MAN-MACHINE INTERFACE

- 0 TO IMPROVE PLANT AVAILABILITY:
 - FAULT TOLERANT CONTROL SYSTEMS
 - PRE-TRIP CONTROL ACTIONS
 - POWER DEPENDENT PROTECTION LIMITS
 - IMPROVED MAN-MACHINE INTERFACE

- 0 TO IMPROVE THE COST EFFECTIVENESS OF NUCLEAR POWER GENERATION:
 - LOWER CONSTRUCTION COSTS
 - SHORTER DESIGN AND CONSTRUCTION SCHEDULES
 - LOWER OPERATION AND MAINTENANCE COSTS

NUFLEX 80+ ADVANCED CONTROL COMPLEX





NUPLEX 80+ HUMAN FACTORS APPROACH

- o ESTABLISH A MULTIDISCIPLINARY DESIGN AND INDEPENDENT REVIEW TEAM
 - HF SPECIALIST
 - REACTOR OPERATORS
 - NUCLEAR SYSTEM ENGINEERS
 - INSTRUMENT AND CONTROLS ENGINEERS
- o PERFORM TOP DOWN INDEPENDENT SYSTEM ANALYSIS
 - FUNCTION ALLOCATION EVALUATION
 - IDENTIFY INFORMATION AND CONTROLS REQUIREMENTS

ATWS (ISSUE 3)

- o DESIGN BASES: 10 CFR 50.62
- o DESIGN FEATURES:
 - DIVERSITY IN NUPLEX 80+ PROVIDES DEFENSE-IN-DEPTH TO PROTECT AGAINST COMMON MODE FAILURES
 - CLASS 1E PLANT PROTECTION SYSTEM
 - RPS AND ESFAS
 - 4 CHANNELS
 - DUAL PROCESSORS IN EACH CHANNEL PROCESSING PRIMARY AND SECONDARY TRIPS FOR EACH EVENT
 - NON-CLASS 1E ALTERNATE PROTECTION SYSTEM
 - REACTOR TRIP AND EMERGENCY FEEDWATER ACTUATION
 - DIVERSE FROM PPS
 - NON-CLASS 1E TURBINE TRIP
 - INDEPENDENT OF AND DIVERSE FROM PLANT PROTECTION SYSTEM





SFSC:Rx Trip

RC	LC	PC	SF
CH	RH	CI	EG
CE	RE	VA	HR

Mode:Rx Trip

Rx P 95.1

△ CVCS ▲ **SI** ▲ SOC

△ IA △ CCW △ SW

△ CW

RCP 1A SEAL	RCP 1B SEAL	RCP 2A SEAL	RCP 2B SEAL
RCP 1A COOLING	RCP 1B COOLING	RCP 2A COOLING	RCP 2B COOLING
RCP 1A PP/MTR	RCP 1B RCP/MTR	RCP 2A PP/MTR	RCP 2B PP/MTR
RCP 1A SEAL/OIL	RCP 1B SEAL/OIL	RCP 2A SEAL/OIL	RCP 2B SEAL/OIL
ALARM LIST	CLEAR	RCP 1B SEAL #2 INLET PRESS HI	
		RC-P-162	

RCP ALARM TILES (DEECO)

TILE	STATUS	ALARM DESCRIPTION	POINT ID
RCP IB SEAL/OIL		RCP IB SEAL #1 INLET PRESS LO	RC-P-161
	0	RCP IB SEAL #2 INLET PRESS HI	RC-P-162
		RCP IB SEAL #3 INLET PRESS HI	RC-P-163
		RCP IB PP BRG OIL RSVR LVL LO	RC-L-117
		RCP IB MTR LWR OIL RSVR LVL HI	RC-L-118
		RCP IB MTR LWR OIL RSVR LVL LO	RC-L-118
		RCP IB MTR UPR OIL RSVR LVL HI	RC-L-119
		RCP IB MTR UPR OIL RSVR LVL LO	RC-L-119
	0	RCP IB OIL LIFT TANK LVL HI	RC-L-141
		RCP IB OIL LIFT TANK LVL LO	RC-L-141
		RCP IB OIL LIFT PUMP FLOW LO	RC-Y-FRCPIB
		RCP IB OIL LIFT PUMP OUT PRESS LO	RC-Y-PRCPIB


ALARM STATUS

ALARM LIST


CLEAR

RCP IB SEAL/OIL ALARM STATUS PAGE

T_{hot}



T_{cold}



NPS-PANELFRONT(SHT1)

T_{hot}
T_{cold}

610

°F

VALID
PAMI

RANGE 525-675°F

T-112HA	T-112HB
T-112HC	T-112HD
T-113HA	T-113HB

50-750°F PAMI

RANGE 525-675°F

T-122HA	T-122HB
T-122HC	T-122HD
T-123HA	T-123HB

LOOP 1 T_h

LOOP 2 T_h

CALCULATED

RCS T_h

ANALOG
DISPLAY

RANGE 465-615°F

T-112CA	T-112CB
T-113CA	

50-750°F (PAMI)

RANGE 465-615°F

T-122CA	T-122CB
T-113CB	

LEG 1A T_c

LEG 1B T_c

LOOP 1 T_c

CALCULATED

RCS T_c

ANALOG
DISPLAY

465

°F

T-112 CA

RANGE 465-615°F

T-112CA	T-112CB
T-113CA	

50-750°F (PAMI)

RANGE 465-615°F

T-122CA	T-122CB
T-113CB	

LEG 1A T_c

LEG 1B T_c

LOOP 1 T_c

CALCULATED

RCS T_c

ANALOG
DISPLAY

RANGE 465-615°F

T-112CA	T-112CB
T-113CA	

50-750°F (PAMI)

RANGE 465-615°F

T-122CA	T-122CB
T-113CB	

LEG 1A T_c

LEG 1B T_c

LOOP 1 T_c

CALCULATED

RCS T_c

ANALOG
DISPLAY

NPS-PANELFRONTS(SHT12)





FIGURE 10 INVENTORY CONTROL
TYPICAL 2ND LEVEL CRITICAL FUNCTION DISPLAY PAGE

MUPLEX 80+ SEPARATION AND ISOLATION



NUPLEX 80+ DIVERSITY

- o NUPLEX 80+ MAXIMIZES STANDARDIZATION WHILE MAINTAINING DIVERSITY IN KEY AREAS TO ENSURE THAT THE DEFENSE IN-DEPTH CONCEPT IS NOT COMPROMISED

- o NUPLEX 80+ DIVERSITY:

<u>FUNCTION</u>	<u>DESIGN TYPE 1</u>	<u>DESIGN TYPE 2</u>
REACTOR TRIP	PLANT PROTECTION SYSTEM	ALTERNATE REACTOR TRIP WITHIN PROCESS-CCS
FLUID SYSTEM CONTROLS	EMERGENCY SUCCESS PATHS (E.G., EMERGENCY FEEDWATER) VIA ESF-CCS	NORMAL SUCCESS PATHS (E.G., MAIN FEEDWATER) VIA PROCESS-CCS
REACTIVITY CONTROLS	EMERGENCY BORATION VIA ESF-CCS	NORMAL CEA CONTROL - VIA POWER CONTROL SYSTEM
ALARM AND INDICATION	ALARM TILES AND DISCRETE INDICATORS - VIA DIAS	CRT DISPLAYS - VIA DPS
POWER	DIESEL	GAS TURBINE

STATION BLACKOUT (ISSUE 5)

- o DESIGN BASIS: 10 CFR 50.63 AND REGULATORY GUIDE 1.155
- o DESIGN FEATURES:
 - REDUNDANT CLASS 1E DIESEL GENERATORS
 - NON-CLASS 1E GAS TURBINE
 - 8 HOUR BATTERIES
 - REDUNDANT STEAM DRIVEN EMERGENCY FEEDWATER PUMPS

SYSTEM 80+ STATION BLACKOUT PREVENTION

- o **NORMAL AC - MAIN GENERATOR**
 - **PREFERRED GRID**
 - **ALTERNATE GRID**
- o **EMERGENCY AC**
 - **DIESEL GENERATOR I (CLASS 1E)**
 - **DIESEL GENERATOR II (CLASS 1E)**
 - **GAS TURBINE GENERATOR (NON-1E)**
- o **EMERGENCY AC STARTED ON LOSS OF 2-OUT-OF-3
NORMAL AC OR ESFAS**
- o **RELAXED EMERGENCY AC LOADING DEMANDS**
 - **DG: 20 SEC**
 - **GTG: 10 MIN**
 - **EVENT BASED SEQUENCER MINIMIZES LOAD
GROUP SIZE**
- o **GTG SIZED TO ACCOMMODATE ONE CLASS 1E DIVISION
FOR DG FAILURE OR OUT-OF-SERVICE**

Amendment E
December 30, 1988

ADDITIONAL NUPLEX 80+ SAFETY IMPROVEMENTS

- o PLANT PROTECTION SYSTEM PROVIDES CONTINUOUS SOFTWARE EXECUTION TO VERIFY TRIP LOGIC FUNCTIONALITY
- o DfS PROVIDES COMPUTER ASSISTED LOGGING AND VERIFICATION FOR PERIODIC COMPONENT SURVEILLANCE TESTS
- o PLANT PROTECTION SYSTEM PROVIDES EVENT BASED SEGMENTATION WITHIN EACH CHANNEL
- o PLANT PROTECTION SYSTEM INITIATES PRE-TRIP CONTROL ACTIONS SUCH AS RPC
- o MEGAWATT DEMAND SETTER KEEPS PLANT WITHIN OPERATING LIMITS

SUMMARY

- o **NUPLEX 80+ ADVANCED CONTROL COMPLEX:**
 - **LARGE-SCREEN PLANT OVERVIEW DISPLAY**
 - **TOUCH-SENSITIVE CRT & EL DISPLAYS**
 - **INTEGRATION OF ACCIDENT AND NORMAL DISPLAYS**
 - **COMPUTER-PROCESSED DATA REDUCTION AND VALIDATION**
 - **HIERARCHY OF DEDICATED AND SELECTABLE DISPLAYS**
 - **PRIORITIZED, MODE DEPENDENT ALARMS**
 - **MULTIPLEXING**
 - **OFF-THE-SHELF, FIELD-PROVEN EQUIPMENT AND SOFTWARE**
 - **AUTOMATIC SELF-TESTING**

R. S. TURK

SYSTEM 80+ DEGRADED CORE DESIGN FEATURES

0 STEEL SPHERICAL CONTAINMENT

- LARGE FREE VOLUME FOR HYDROGEN CONTROL UNDER SEVERE ACCIDENT CONDITIONS
- VENT PATHS FOR PROPER HYDROGEN MIXING

0 REACTOR CAVITY

- DESIGNED TO RETAIN CORE DEBRIS AND PREVENT DIRECT CONTAINMENT HEATING
- LARGE FLOOR AREA TO FACILITATE DEBRIS COOLABILITY

0 SAFETY DEPRESSURIZATION CAPABILITY OF THE RCS

0 IN-CONTAINMENT REFUELING WATER STORAGE TANK

- PROVIDES WATER SUPPLY FOR SAFETY INJECTION AND CONTAINMENT SPRAY SYSTEMS
- PROVIDES INVENTORY FOR THE CAVITY FLOODING SYSTEM
- ABILITY FOR SELF-COOLING THROUGH ANY AVAILABLE PUMP/HEAT EXCHANGER COMBINATION
- ELIMINATES THE NEED FOR RECIRCULATION FROM THE CONTAINMENT SUMP
- HYDROGEN IGNITERS CAN BE ADDED IF NECESSARY

SYSTEM 80+ DEGRADED CORE DESIGN FEATURES...

- 0 SAFETY DEPRESSURIZATION SYSTEM TO PREVENT VESSEL FAILURE AT HIGH PRESSURE
 - 2500 PSIA TO 400 PSIA WITHIN 1 TO 2 HOURS.
- 0 REACTOR CAVITY CONFIGURATION TO PREVENT DEBRIS TRANSPORT AND PROVIDE COOLABILITY
 - EXIT AREA GREATER THAN AREA AROUND VESSEL
 - COLLECTION VOLUME TWICE CORE VOLUME
 - FLOOR AREA GREATER THAN $0.02 \text{ M}^2/\text{MWT}$
 - FLOOD CAPABILITY FROM IRWST
- 0 LARGE CONTAINMENT WITH NATURAL CIRCULATION TO PREVENT H_2 BUILDUP
 - METAL WATER REACTION BASED ON 75% OF CORE METAL
 - 13% LIMIT ON H_2 CONCENTRATION

HYDROGEN GENERATION AND CONTROL (ISSUE 8)

0 DESIGN BASIS - EPRI ALWR REQUIREMENTS:

- HYDROGEN GENERATION EQUIVALENT TO 75% METAL-WATER REACTION OF THE ACTIVE FUEL CLADDING WILL NOT CAUSE THE UNIFORM HYDROGEN CONCENTRATION IN CONTAINMENT TO EXCEED 13 PERCENT BY VOLUME
- CONTAINMENT DESIGN WILL PROMOTE A MIXED ATMOSPHERE WHICH MAKES THE LOCAL DETONATION OF HYDROGEN UNLIKELY
- HYDROGEN BURNING WILL NOT RESULT IN FAILURE OF EQUIPMENT NECESSARY TO MAINTAIN CONTAINMENT INTEGRITY

0 DESIGN FEATURES:

- THE SYSTEM 80+ SPHERICAL CONTAINMENT, WITH A FREE VOLUME OF $3.4E+6$ FT³, MEETS THE EPRI REQUIREMENTS.
- USE OF IGNITERS IS NECESSARY FOR HYDROGEN CONTROL ASSUMING 100% METAL-WATER REACTION AND A DETONABILITY LIMIT OF 10%

**CORE-CONCRETE INTERACTION/DEBRIS
COOLABILITY (ISSUE 9)**

o DESIGN BASIS - EPRI ALWR REQUIREMENTS:

- **ALWRs SHALL PROVIDE SUFFICIENT CAVITY FLOOR SPACE TO ENHANCE CORE DEBRIS SPREADING**
- **ALWRs SHALL PROVIDE FOR QUENCHING DEBRIS IN THE REACTOR CAVITY**
- **THE STEEL CONTAINMENT (PRESSURE BOUNDARY) SHALL BE PROTECTED FROM CORE DEBRIS BY AT LEAST 3 FEET OF CONCRETE**

o DESIGN FEATURES:

- **TO PROMOTE LONG TERM DEBRIS COOLABILITY, THE SYSTEM 80+ CAVITY FLOOR PROVIDES A MINIMUM OF $0.02 \text{ m}^2/\text{MWT}$**
- **SYSTEM 80+ CONTAINS AN IN-CONTAINMENT REFUELING WATER STORAGE TANK TO PROVIDE WATER DIRECTLY TO THE CAVITY (METHOD OF DELIVERING WATER TO CAVITY NOT YET FINALIZED).**
- **THE CONCRETE BASEMAT THAT LIES BETWEEN THE CAVITY FLOOR AND THE STEEL PRESSURE BOUNDARY HAS A MINIMUM THICKNESS OF THREE FEET AND A THICKNESS OF FIVE FEET DIRECTLY BENEATH THE CAVITY FLOOR (NEAR ITS CENTER).**

HIGH PRESSURE CORE MELT EJECTION (ISSUE 10)

0 DESIGN BASIS - EPRI ALWR REQUIREMENTS:

- PREVENTION; ALWR DESIGNS SHALL INCLUDE A DEPRESSURIZATION SYSTEM FOR THE REACTOR COOLANT SYSTEM TO MINIMIZE THE POSSIBILITY OF A HIGH PRESSURE CORE MELT EJECTION.
- MITIGATION: ALWR DESIGNS SHALL INCLUDE A REACTOR CAVITY ARRANGEMENT SUCH THAT DEBRIS FROM A HIGH PRESSURE EJECTION IS NOT LIKELY TO EXIT THE CAVITY.

0 DESIGN FEATURES:

- THE SYSTEM 80+ DESIGN INCLUDES A SAFETY-GRADE DEPRESSURIZATION SYSTEM.
- THE SYSTEM 80+ CAVITY DESIGN INCLUDES A CORE DEBRIS CHAMBER AND LABYRINTHINE VENT PATH FOR DISENTRAINMENT OF MOLTEN DEBRIS.

"ABWR" CONTAINMENT VENT (ISSUE 12)

o DESIGN BASIS:

NONE

o DESIGN FEATURE:

A VENT CAN BE ADDED TO THE DESIGN IN THE
FUTURE, IF NECESSARY.

EQUIPMENT SURVIVABILITY (ISSUE 13)

o DESIGN BASIS:

- ENSURE THAT SYSTEMS AND EQUIPMENT REQUIRED TO MITIGATE SEVERE ACCIDENTS ARE AVAILABLE TO PERFORM THEIR INTENDED FUNCTION.
- SYSTEMS AND EQUIPMENT REQUIRED ONLY FOR SEVERE ACCIDENT PREVENTION AND MITIGATION NEED NOT BE SUBJECT TO 10 CFR 50.49 ENVIRONMENTAL QUALIFICATION REQUIREMENTS, 10 CFR PART 50, APPENDIX B QUALITY ASSURANCE REQUIREMENTS AND 10 CFR PART 50, APPENDIX A REDUNDANCY/DIVERSITY REQUIREMENTS.

o DESIGN FEATURES:

- REASONABLE ASSURANCE WILL BE PROVIDED THAT EQUIPMENT REQUIRED TO COPE WITH SEVERE ACCIDENTS WILL OPERATE IN THE ENVIRONMENT AND TIME SPAN FOR WHICH IT IS NEEDED.
 - RUGGED, BEST-ESTIMATE DESIGN REQUIREMENTS
 - REALISTIC EVALUATION
 - SUPPLEMENTAL PHYSICAL PROTECTION (E.G., COVERS, BARRIERS)

**R. E. JAQUITH,
SUPERVISOR
RELIABILITY SYSTEMS**

PROBABILISTIC RISK ASSESSMENT

OBJECTIVES:

- 0 COMPLY WITH SEVERE ACCIDENT POLICY STATEMENT PROVIDING A LEVEL III PRA FOR THE SYSTEM 80+ DESIGN.
- 0 DEMONSTRATE COMPLIANCE WITH EPRI ALWR MEAN CORE DAMAGE FREQUENCY GOAL OF $1.0E-5$ EVENTS/YEAR.
- 0 DEMONSTRATE COMPLIANCE WITH LARGE RELEASE GOAL OF $1.0E-6$ EVENTS/YEAR.
- 0 DEMONSTRATE CONTAINMENT PERFORMANCE/RELIABILITY.
- 0 SUPPORT EVALUATION OF DESIGN CHANGES AND DEMONSTRATION THAT SYSTEM 80+ PROVIDES AN INCREASED LEVEL OF SAFETY.

PROBABILISTIC RISK ASSESSMENT

APPROACH:

- 0 ESTABLISH BASELINE PRA FOR SYSTEM 80
- 0 USE PRA AS EVALUATION TOOL FOR ASSESSMENT OF DESIGN CHANGES
- 0 PREPARE LEVEL III PRA FOR SYSTEM 80+

SYSTEM 80+ PRA
CORE DAMAGE FREQUENCY (INTERNAL EVENTS)

<u>INITIATING EVENT</u>	<u>CORE DAMAGE FREQUENCY (WITH RECOVERY) (MEAN/YEAR)</u>
LARGE LOCA	3.54E-8
MEDIUM LOCA	8.62E-8
SMALL LOCA	4.31E-8
LOSS OF FEEDWATER	5.84E-9
OTHER TRANSIENTS	4.64E-9
STEAMLINE BREAKS	2.74E-10
S.G. TUBE RUPTURE	1.38E-7
LOSS OF OFFSITE POWER + SBO	9.14E-8
ATWS	1.97E-7
LOSS OF CCW/SSW	1.25E-8
LOSS OF 4.16Kv BUS	2.75E-11
LOSS OF 125 VDC BUS	2.61E-12
INTERFACING SYSTEM LOCA	3.01E-9
VESSEL RUPTURE	<u>1.00E-7</u>
TOTAL	7.17E-7

CORE DAMAGE FREQUENCY (INTERNAL & EXTERNAL EVENTS)*

INTERNAL EVENTS	7.2E-7
SEISMIC	8.6E-7
TORNADO STRIKE	6.6E-9
TOTAL	1.6E-6

- * FIRES AND INTERNAL FLOODS ARE BEING EVALUATED SEPARATELY; CORE DAMAGE FREQUENCY CONTRIBUTION EXPECTED TO BE SMALL DUE TO THE DIVISION OF THE CONTAINMENT.

CONTAINMENT PERFORMANCE (ISSUE 11)

0 OBJECTIVES:

- DEMONSTRATE RUGGEDNESS OF THE CONTAINMENT DESIGN BY PREDICTING THE RELIABILITY FOR SEVERE ACCIDENT SCENARIOS.
- THE CONDITIONAL UNAVAILABILITY OF THE CONTAINMENT, GIVEN A SEVERE ACCIDENT, SHALL NOT EXCEED APPROXIMATELY $1.0E-1$ PER DEMAND WHEN WEIGHTED OVER CREDIBLE CORE DAMAGE SEQUENCES,

- OR -

DETERMINISTIC ANALYSIS SHALL DEMONSTRATE COMPARABLE PROTECTION.

0 RESULTS:

- LEVEL II PRA NOT YET COMPLETE

PUBLIC SAFETY GOALS (ISSUE 1)

o OBJECTIVE:

- COMPLY WITH THE SAFETY GOAL POLICY STATEMENT

o RESULTS:

- MEET MEAN CORE DAMAGE FREQUENCY GOAL OF $1.0\text{E}-5$ EVENTS/YEAR.
- MEET LARGE OFFSITE RELEASE GOAL OF $1.0\text{E}-6$ EVENTS/YEAR.
- EVALUATE DESIGN CHANGES WITH RESPECT TO THE ABOVE GOALS.
- DEMONSTRATE A SUBSTANTIALLY INCREASED LEVEL OF SAFETY RELATIVE TO CURRENT GENERATION PLANTS.

RISK REDUCING FEATURES FOR DOMINANT SEQUENCE #1

SEQUENCE TYPE - LOSS OF OFFSITE POWER (LOOP)
INCLUDING STATION BLACKOUT WITH
BATTERY DEPLETION

REPRESENTATIVE DOMINANT SEQUENCE
(LOOP) (FAILURE OF EFW)

FREQUENCY

OLD - $3.8E-5$
NEW - $9.1E-8$

FEATURES

- 0 ALTERNATE AC POWER SOURCE (GAS TURBINE)
- 0 SEPARATE OFFSITE POWER SOURCE THAT BYPASSES THE SWITCHYARD
- 0 DEDICATED BATTERY FOR EACH DIESEL GENERATOR
- 0 FOUR TRAIN EMERGENCY FEEDWATER (TWO WITH TURBINE DRIVEN PUMPS)
- 0 TURBINE GENERATOR ABLE TO RUN BACK TO HOTEL LOAD.

RISK REDUCING FEATURES FOR DOMINANT SEQUENCE #2**SEQUENCE TYPE - TRANSIENTS****REPRESENTATIVE DOMINANT SEQUENCE****(LOFW) (FAILURE TO DELIVER EMERGENCY FW)****FREQUENCY****OLD - 1.2E-5****NEW - 2.3E-8****FEATURES**

- 0 FOUR TRAIN EMERGENCY FEEDWATER SYSTEM**
- 0 REDUNDANT SOURCES OF EMERGENCY FEEDWATER**
 - 2 EFW TANKS**
 - CONDENSATE STORAGE TANKS**
- 0 HIGH RELIABILITY COMPONENT COOLING SYSTEM**
 - TWO PUMPS PER TRAIN**
 - NORMALLY RUNNING**
- 0 START-UP FEEDWATER SYSTEM**
 - FROM CONDENSATE STORAGE TANK**
 - ACTUATED BEFORE EFW**
- 0 FULL RUN-BACK CAPABILITY**
- 0 TWO EFW ACTUATION SYSTEMS**
 - REDUNDANT**
 - DIVERSE**

RISK REDUCING FEATURES FOR DOMINANT SEQUENCE #3**SEQUENCE TYPE - STEAM GENERATOR TUBE RUPTURE****REPRESENTATIVE DOMINANT SEQUENCE**

(SGTR) (FAILURE TO DELIVER EFW)

(SGTR) (FAILURE OF SAFETY INJECTION)

FREQUENCYOLD - $1.1\text{E}-5$ NEW - $1.4\text{E}-7$ **FEATURES**

- 0 FOUR TRAIN EMERGENCY FEEDWATER SYSTEM
- 0 FOUR TRAIN SAFETY INJECTION SYSTEM
- 0 SAFETY DEPRESSURIZATION SYSTEM

RISK REDUCING FEATURES FOR DOMINANT SEQUENCE TYPE #4

SEQUENCE TYPE - SMALL LOCA

REPRESENTATIVE DOMINANT SEQUENCE

(SMALL LOCA) (FAILURE OF SI RECIRCULATION)

(SMALL LOCA) (FAILURE OF SI INJECTION)

FREQUENCY

OLD - $9.4E-6$

NEW - $4.3E-8$

FEATURES

- 0 IN-CONTAINMENT REFUELING WATER
STORAGE TANK
- 0 FOUR TRAIN SAFETY INJECTION SYSTEM
- 0 ELIMINATION OF RAS
- 0 SAFETY DEPRESSURIZATION SYSTEM

RISK REDUCING FEATURES FOR DOMINANT SEQUENCE #5**SEQUENCE TYPE - ATWS****REPRESENTATIVE DOMINANT SEQUENCES**
(ATWS) (ADVERSE MTC)**FREQUENCY****OLD - 4.8E-6**
NEW - 2.0E-7**FEATURES**


- 0 LARGER PRESSURIZER**
- 0 LARGER STEAM GENERATOR**
- 0 SAFETY DEPRESSURIZATION SYSTEM**
- 0 DIVERSE PROTECTION SYSTEM**

CORE DAMAGE FREQUENCY COMPARISON


<u>INTERNAL EVENT</u>	<u>FREQUENCY (MEAN/YEAR)</u>	
	<u>SYSTEM 80+</u>	<u>SYSTEM 80*</u>
LARGE LOCA	3.54E-8	1.57E-6
MEDIUM LOCA	8.62E-8	3.59E-6
SMALL LOCA	4.31E-8	9.41E-6
LARGE SLB	2.74E-10	9.04E-7
SGTR	1.38E-7	1.05E-5
TRANSIENTS:	2.30E-8	1.17E-5
LOSS OF FEEDWATER FLOW		
OTHER TRANSIENTS		
LOSS OF COMPONENT		
COOLING WATER		
LOSS OF 4.16 Kv VITAL BUS		
LOSS OF 125 VDC VITAL BUS		
LOOP/SBO	9.14E-8	3.78E-5
ATWS	1.97E-7	4.79E-6
IS-LOCA	3.01E-9	4.48E-9
RV RUPTURE	1.00E-7	1.00E-7
TOTAL	7.17E-7	8.14E-5

*TYPICAL; NOT PLANT SPECIFIC


IMPACT OF SYSTEM 80+ DESIGN FEATURES ON SEVERE ACCIDENT RISK (Core Damage Frequency, Internal Events)



DOMINANT CONTRIBUTORS TO SEVERE ACCIDENT RISK (Core Damage Frequency, Internal Events)



FACTOR OF 113
REDUCTION



- LOOP/SBO
- LOCA
- TRANSIENTS
- OTHER