

INSERVICE INSPECTION NINETY-DAY REPORT

BEAVER VALLEY POWER STATION UNIT 1

Outage 7 Year 1989

Inspection Term from 2/27/88 to 12/21/89

9004050073 900316
PDR ADOCK 05000334
G PIC

INSERVICE INSPECTION NINETY-DAY REPORT

BEAVER VALLEY POWER STATION UNIT 1

Outage 7 Year 1989

Inspection Term from 2/27/88 to 12/21/89

Issue date: 3/9/90

Owner: Duquesne Light Company
One Oxford Center
301 Grant Street
Pittsburgh, Pennsylvania 15279

NRC Docket Number: 50-334

Reactor Supplier: Westinghouse Electric Corporation
Commercial Service Date: September 30, 1976

Prepared by: [Signature] Date: 2/7/90

Reviewed by: [Signature] Date: 2/9/90

Approved by: [Signature] Date: 2/13/90

TABLE OF CONTENTS

<u>Item</u>	<u>Page Number</u>
Cover Page	1
Table of Contents	2
Form NIS-1	3 - 5
Outage Summary	6
ASME Section XI Vessel, Piping and Support Examinations	
1. Class 1	6
2. Class 2	6
3. Class 3	6
Reactor Vessel Examination	7
Instrumented Inspection Technique Testing	7
Pressure Testing	8
Steam Generator Tube Examination	8
I.E. Bulletin 88-08	8
I.E. Bulletin 88-11	8
Baseline Exams	8
Snubber Exams	7
Deficiency Resolution	7
NIS-2 Forms	7
Appendix I - ASME Examination List	AI - 1 thru 42
Appendix II - I.E. Bulletin 88-08	AII - 1 thru 2
Appendix III - I.E. Bulletin 88-11	AIII - 1 thru 2
Appendix IV - Deficiency Report Summary	AIV - 1
Appendix V - NIS-2 Forms	
Appendix VI - Steam Generator ET NRC Special Report	

FORM NIS-1 OWNER'S REPORT FOR INSERVICE INSPECTIONS
As required by the Provisions of the ASME Code Rules

1. Owner Duquesne Light Company, One Oxford Centre, Pittsburgh, PA 15279
(Name and Address of Owner)
2. Plant Beaver Valley Power Station, P.O. Box 4, Shippingport, PA 15077
(Name and Address of Plant)
3. Plant Unit 1 4. Owner Certificate of Authorization (if required) 26-07000*
5. Commercial Service Date 9/30/76 6. National Board Number for Unit N/A
7. Components Inspected

Component or Appurtenance	Manufacturer or Installer	Manufacturer or Installer Serial No.	State or Province No.	National Board No.
Reactor Vessel	Combustion Engineering	69103	B105642	21011
Reactor Vessel Closure Head	Combustion Engineering	69203	N/A	21011
Pressurizer	Westinghouse	1311	434676	68-50
Steam Generators	Westinghouse			
'A' Loop		1301	434597	68-45
'B' Loop		1302	434598	68-46
'C' Loop		1303	434599	68-47
'A' Reactor Coolant Pump	Westinghouse	1-618J931G01	N/A	N/A
Reactor Coolant Piping	S.W. Fabricating	N/A	N/A	N/A
Auxiliary Piping Systems	Schneider Power Corp.	N/A	N/A	N/A
'A' Residual Heat Exchanger	Joseph Oat & Sons	1832-1	434682	368
'B' Residual Heat Exchanger		1832-2	434683	369
Boron Injection Tank	Struthers Wells Corp.	N/A	434783	1374
Regenerative Heat Exchanger	Joseph Oat & Sons	1831-10	434686	438
Non-Regenerative Heat Exchanger	Joseph Oat & Sons	1830-1	434718	361
Seal Water Return Filter	AMF, Cuno	102	434723	2615

* Designates account number of arrangement with Authorized Inspection Agency to provide inspection services.

Note: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-1 (Back)

- 8. Examination Dates _____ to _____ 9. Inspection Interval from _____ to _____
- 10. Abstract of Examinations. Include a list of examinations and a statement concerning status of work required for current interval.
- 11. Abstract of Conditions Noted
- 12. Abstract of Corrective Measures Recommended and Taken

We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Certificate of Authorization No. (if applicable) _____ Expiration Date _____

Date _____ 19 ____ Signed _____ By _____
Owner

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of _____ and employed by _____ of _____ have inspected the components described in this Owner's Report during the period _____ to _____, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Charles H. ... Commissions MD 8441 PA 2166
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/9 19 80

FORM NIS-1 OWNER'S REPORT FOR INSERVICE INSPECTIONS
As required by the Provisions of the ASME Code Rules

1. Owner Duquesne Light Company, One Oxford Centre, Pittsburgh, PA 15279
(Name and Address of Owner)
2. Plant Beaver Valley Power Station, P.O. Box 4, Shippingport, PA 15077
(Name and Address of Plant)
3. Plant Unit 1 4. Owner Certificate of Authorization (if required) 26-05000*
5. Commercial Service Date 9/30/76 6. National Board Number for Unit N/A
7. Components Inspected

Component or Appurtenance	Manufacturer or Installer	Manufacturer or Installer Serial No.	State or Province No.	National Board No.
'1A' Recirculation Spray Pump	Bingham-Willamette Co.	290594	N/A	N/A
Component Cooling Surge Tank	PX Engineering	N/A	N/A	N/A
'A' Residual Heat Removal Pump	Ingersoll Rand	1170-20	N/A	N/A
Excess Letdown Heat Exchanger	Atlas Manufacturing	1308	N/A	1127
Valves MOV-RC 535, 536, 537		88418/3(MOD#)	N/A	N/A
Valves PCV-RC-455A, 455B	Fisher Governor	5787946 5787947	N/A	N/A
Valve PCV-RV-456	Masoneilan	H26693-5-3	N/A	N/A
Valve RV-RC-551A	Target Rock	69C(MOD#)	N/A	N/A
Valve MOV-RC-585	Rockwell	7517(MOD#)	N/A	N/A
Valve MOV-RH-701	Copes/Vulcan	14G44BSER(MOD#)	N/A	N/A
Valves SI-48, 49, 51, 52, 53	Anchor/Darling	5350W(MOD#)	N/A	N/A
Valves SI-10, 11, 12, 15, 20, 23	Velan	78704(MOD#)	N/A	N/A
Valve SI-84	Velan	78409(MOD#)	N/A	N/A

* Designates account number of arrangement with Authorized Inspection Agency to provide inspection services.

Note: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8½ in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-1 (Back)

- 8. Examination Dates 2/27/88 to 12/21/89 9. Inspection Interval from 11/21/87 to 11/21/97
- 10. Abstract of Examinations. Include a list of examinations and a statement concerning status of work required for current interval.
See Appendices I, II, and III
- 11. Abstract of Conditions Noted
See Text
- 12. Abstract of Corrective Measures Recommended and Taken
See Appendix IV

We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Certificate of Authorization No. (if applicable) 26-05000 Expiration Date N/A
 Date 2/13 19 90 Signed Duquense Light company By J.P. Noonan
 Owner

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of _____ and employed by Actway's mfg. co. of Walden, N.H. have inspected the components described in this Owner's Report during the period _____ to _____, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commissions NB 2441 PA 2266
 Inspector's Signature National Board, State, Province, and Endorsements
 Date 2/9 19 90

Outage Summary

During the Seventh Refueling Outage (7R) at the Beaver Valley Power Station, Unit 1, Inservice Inspection (ISI) exams were performed on Class 1, 2, and 3 components. This was the first outage in the second ten year interval.

The exams were based on ASME Section XI, 1983 Edition through the Summer 1983 Addenda, using Code Case N-408 for Class 2 piping welds.

ASME XI Exams

1. Six hundred (600) Class 1 exams were performed and are divided into four groups as follows:
 - a. Welds (piping and vessels)
 - Ultrasonic Exams - 68
 - Penetrant Exams - 120
 - Magnetic Particle - 1
 - b. Bolting
 - Ultrasonic Exams - 19
 - Magnetic Particle - 38
 - Visual Exams - 269
 - c. Supports
 - Visual Exams - 76
 - d. Nine (9) visual exams were performed on vessel and valve interiors.
2. Two hundred, ninety (290) Class 2 exams were performed and are divided into three groups as follows:
 - a. Welds (piping, pumps, and vessels)
 - Ultrasonic Exams - 39
 - Penetrant Exams - 46
 - Magnetic Particle Exams - 24
 - Visual Exams - 16
 - b. Bolting
 - Ultrasonic Exams - 5
 - c. Supports
 - Visual Exams - 160
3. One hundred, twenty-seven (127) visual exams of Class 3 supports were performed and divided into two groups as follows:
 - a. Supports
 - Visual Exams - 58
 - b. Attachments
 - Visual Exams - 69

The ASME XI exams were performed by Duquesne Light Company and ERASCO NDE Technicians. These exams are summarized below and listed in full in Appendices I through III.

Appendix I compiles those exams that have been credited towards fulfilling the Ten Year Plan requirements. Appendix II lists exams associated with I.E. Bulletins 88-11 and 88-08. Appendix III identifies baseline exams.

Reactor Vessel Examination

During the outage, the Westinghouse/Dynacon Mini-Scanner was used to remotely perform automated ultrasonic examination of three (3) outlet nozzle-to-shell welds from the nozzle bores, nozzle inner radius areas, nozzle-to-safe-end welds and the safe-end to pipe butt welds. Additionally, 60% (225') of the flange to shell weld (from the flange mating surface) was ultrasonically examined using manual techniques.

These areas, with the exception of the flange weld, were examined using the Ultrasonic Data Recording and Processing System (UDRPS) and meet or exceed the requirements pursuant to Section XI of the ASME B&PV Code 1983 Edition Summer 83 Addenda, and USNRC Reg. Guide 1.150.

No recordable indications were observed in the data obtained, but the data from the safe-end welds indicated a substantial I.D. surface evaluation change (i.e. counterbore) over the extended scanning area. This change caused a deviation from the calibration set-up including shifts in the calibrated sweep range and the actual refracted angle in the material. Manual O.D. ultrasonic exams were performed to supplement the initial I.D. exams. No indications were recorded.

Visual examination of the three (3) outlet nozzles interiors (up to the safe-end to pipe weld), all accessible areas of the upper internals and a general scan of the lower core barrel resulted in no recordable indications.

Instrumented Inspection Technique Testing

During August 1989 and continuing through 7R, the Instrumented Inspection Technique (IIT) and/or Acoustic Emission (AE) method was applied to several plant systems as an approved inspection alternative to hydrostatic testing. This alternative was approved for use at BVPS Unit 1 by the NRC in D. McDonald's letter dated May 15, 1986 and H. Askwith to G. Johnson letter dated October 7, 1987. This testing was performed by HAFA International using Duquesne Light procedures.

Safety related piping of portions of the following Unit 1 plant systems was examined using this methodology: (a total of 15 tests were performed on the systems listed below)

- Chemical and Volume Control
- Safety Injection
- Containment Depressurization
- Auxiliary Feedwater
- River Water

Three 'acoustic only' IIT tests were performed on the Unit 1 'A' and 'C' Feedwater lines to meet the requirements of ASME Section XI, IWA 4400, pressure testing requirements for repair and replacement as an approved inspection alternative. This alternative was approved for use at BVPS Unit 1 by the NRC in P. Yam's letter dated February 29, 1988.

Of the systems tested, no through wall leakage was detected. The system piping met the IIT/AE acceptance criteria. A total of 18 IIT/AE tests were performed.

Pressure Testing

The Class 1 piping System Leakage Test and accompanying VT-2 exam were performed prior to plant start-up. Also, Class 2 and 3 system functional and system leakage tests were performed during the outage on various systems to fulfill the 40-month pressure testing requirement.

Steam Generator Tube Examination

One hundred percent of the in-service tubes were examined in the three generators. Results of the examinations and information on tube plugging are contained in Appendix VI.

I.E. Bulletin 88-08

Appendix II lists the examinations performed in accordance with I.E. Bulletin 88-08, Thermal Stresses in Piping Connected to Reactor Coolant Systems. All UT exams were satisfactory. Penetrant (PT) indications were noted in the base metal of one fitting. These indications were removed by surface conditioning and a supplementary PT exam cleared the indications.

I.E. Bulletin 88-11

The examination of the Pressurizer surge line and associated components was completed this outage per I.E. Bulletin 88-11, Pressurizer Surge Line Thermal Stratification (Appendix II). No discernible distress or structural damage of piping or support members was noted. Gap measurements on the Surge Line restraints were obtained and reported to Engineering for disposition.

Baseline Exams

Appendix III identifies those components repaired during this outage that required baseline examination per ASME XI.

Snubber Exams

Snubber exams were performed this outage in accordance with Technical Specification 3/4.7.12. The results of the exams are contained in the Unit 1 7R Snubber Outage Summary Report.

Deficiency Resolution

All recorded deficiencies were evaluated and reported by the Inservice Inspection Department per administrative procedures. Appendix IV is a disposition matrix identifying the rejectable indication found this outage.

NIS-2 Forms

Included as Appendix V are the NIS-2 Forms associated with Repairs and Replacements made at BVPS-2.

APPENDIX I

PAGE NO. 1
02/07/90

APPENDIX J - CODE EXAMS

DUQUESNE LIGHT COMPANY
RVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
** ASME ITEM NUMBER/EXAM CATEGORY: B01.030 B-A			
* ISOMETRIC: E-0001A RC-R-1-C-1	SHELL TO FLANGE CIRCUMFERENTIAL WELD	RV TOOL	
** ASME ITEM NUMBER/EXAM CATEGORY: B01.040 B-A			
* ISOMETRIC: E-0001J RC-R-8-C-5	RVCH FLG CIRCUMFERENTIAL WELD		UT89326 EXAMINED CW FROM STUDHOLE 41 TO 1 MT89071
** ASME ITEM NUMBER/EXAM CATEGORY: B02.011 B-B			
* ISOMETRIC: E-0001P RC-TK-1-C-4	CIRCUMFERENTIAL WELD		UT89298 EXAMINED FROM DATUM 0 TO 8
** ASME ITEM NUMBER/EXAM CATEGORY: B02.040 B-B			
* ISOMETRIC: E-0001N RC-E-1A-C-1	CIRCUMFERENTIAL WELD		UT89382
** ASME ITEM NUMBER/EXAM CATEGORY: B03.090 B-D			
* ISOMETRIC: E-0001B RC-R-1-N-18 RC-R-1-N-20 RC-R-1-N-22	OUTLET NOZZLE WELD OUTLET NOZZLE WELD OUTLET NOZZLE WELD	RV TOOL RV TOOL RV TOOL	
** ASME ITEM NUMBER/EXAM CATEGORY: B03.100 B-D			
* ISOMETRIC: E-0001B RC-R-1-N-181R RC-R-1-N-201R RC-R-1-N-221R	NOZZLE INSIDE RADIUS NOZZLE INSIDE RADIUS NOZZLE INSIDE RADIUS	RV TOOL RV TOOL RV TOOL	
** ASME ITEM NUMBER/EXAM CATEGORY: B03.140 B-D			
* ISOMETRIC: E-0001M RC-E-1C-RADIUS(3H) RC-E-1C-RADIUS(3C)	NOZZLE INSIDE RADIUS NOZZLE INSIDE RADIUS	VB91030 VB91029	
** ASME ITEM NUMBER/EXAM CATEGORY: B05.010 B-F			
* ISOMETRIC: L-001A DLW-LOOP1-1-F-01	SAFE END WELD		UT89383 PT INDICATIONS WITHIN CODE. WESTINGHOUSE TOOL PT89199 RESULTS MEANINGLESS. O. D. EXAM RECOMMENDED.

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: L-002A DLW-LOOP2-1-F-13	SAFE END WELD		UT89384 WESTINGHOUSE TOOL RESULTS MEANINGLESS. O. D. PT89200 EXAM RECOMMENDED.
* ISOMETRIC: L-003A DLW-LOOP3-1-F-25	SAFE END WELD		UT89385 WESTINGHOUSE TOOL RESULTS MEANINGLESS. O. D. PT89202 EXAM RECOMMENDED.
** ASME ITEM NUMBER/EXAM CATEGORY: B05.040 B-F			
* ISOMETRIC: 0348D RC-72-7-E-01	NOZZLE TO SAFE END	UT89293 PT89221	
* ISOMETRIC: 0350B RC-98-1-E-02	NOZZLE TO SAFE END		UT89282 LIMITED EXAM DUE TO NOZZLE TAPER (70% DONE) PT89218
** ASME ITEM NUMBER/EXAM CATEGORY: B05.070 B-F			
* ISOMETRIC: L-002A DLW-LOOP2-2-F-16	SAFE END WELD	UT89373 PT89280	
DLW-LOOP2-3-F-17	SAFE END WELD	UT89374 PT89282	
** ASME ITEM NUMBER/EXAM CATEGORY: B05.130 B-F			
* ISOMETRIC: 0348D RC-72-7-F-09	SAFE END WELD	UT89292 PT89220	
* ISOMETRIC: 0350B RC-98-1-F-01	SAFE END WELD		UT89283 LIMITED EXAM DUE TO SAFE END TAPER (80% DONE) PT89217 UT89284
** ASME ITEM NUMBER/EXAM CATEGORY: B06.010 B-G-1			
* ISOMETRIC: E-0001L RC-R-1-NUT-1	BOLTING	MT89076	
RC-R-1-NUT-2	BOLTING	MT89076	
RC-R-1-NUT-3	BOLTING	MT89076	
RC-R-1-NUT-4	BOLTING	MT89076	
RC-R-1-NUT-5	BOLTING	MT89076	
RC-R-1-NUT-6	BOLTING	MT89076	

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
RC-R-1-NUT-7	BOLTING	MT89076	
RC-R-1-NUT-8	BOLTING	MT89076	
RC-R-1-NUT-9	BOLTING	MT89078	
RC-R-1-NUT-10	BOLTING	MT89078	
RC-R-1-NUT-11	BOLTING	MT89078	
RC-R-1-NUT-12	BOLTING	MT89079	
RC-R-1-NUT-13	BOLTING	MT89079	
RC-R-1-NUT-14	BOLTING	MT89079	
RC-R-1-NUT-15	BOLTING	MT89079	
RC-R-1-NUT-16	BOLTING	MT89079	
RC-R-1-NUT-17	BOLTING	MT89079	
RC-R-1-NUT-18	BOLTING	MT89074	
RC-R-1-NUT-19	BOLTING	MT89074	
** ASME ITEM NUMBER/EXAM CATEGORY: B06.030 B-G-1			
* ISOMETRIC: E-0001L			
RC-R-1-STUD-1	BOLTING	UT89329	
RC-R-1-STUD-2	BOLTING	MT89072	
RC-R-1-STUD-3	BOLTING	UT89329	
RC-R-1-STUD-4	BOLTING	MT89072	
RC-R-1-STUD-5	BOLTING	UT89329	
RC-R-1-STUD-6	BOLTING	MT89072	
RC-R-1-STUD-7	BOLTING	UT89329	
RC-R-1-STUD-8	BOLTING	MT89072	
RC-R-1-STUD-9	BOLTING	UT89329	
RC-R-1-STUD-10	BOLTING	MT89073	
RC-R-1-STUD-11	BOLTING	UT89329	
RC-R-1-STUD-12	BOLTING	MT89073	
RC-R-1-STUD-13	BOLTING	UT89328	
RC-R-1-STUD-14	BOLTING	MT89077	
RC-R-1-STUD-15	BOLTING	UT89330	

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
RC-R-1-STUD-16	BOLTING	MT89077 UT89330	
RC-R-1-STUD-17	BOLTING	MT89077 UT89330	
RC-R-1-STUD-18	BOLTING	MT89077 UT89328	
RC-R-1-STUD-19	BOLTING	MT89075 UT89328	

** ASME ITEM NUMBER/EXAM CATEGORY: B06.050 B-G-1

* ISOMETRIC: E-0001L

RC-R-1-WASHER-1	BOLTING	VT89940	
RC-R-1-WASHER-2	BOLTING	VT89940	
RC-R-1-WASHER-3	BOLTING	VT89940	
RC-R-1-WASHER-4	BOLTING	VT89948	
RC-R-1-WASHER-5	BOLTING	VT89940	
RC-R-1-WASHER-6	BOLTING	VT89940	
RC-R-1-WASHER-7	BOLTING	VT89940	
RC-R-1-WASHER-8	BOLTING	VT89940	
RC-R-1-WASHER-9	BOLTING	VT89940	
RC-R-1-WASHER-10	BOLTING	VT89940	
RC-R-1-WASHER-11	BOLTING	VT89947	
RC-R-1-WASHER-12	BOLTING	VT89947	
RC-R-1-WASHER-13	BOLTING	VT89947	
RC-R-1-WASHER-14	BOLTING	VT89947	
RC-R-1-WASHER-15	BOLTING	VT89947	
RC-R-1-WASHER-16	BOLTING	VT89947	
RC-R-1-WASHER-17	BOLTING	VT89947	
RC-R-1-WASHER-18	BOLTING	VT89949	
RC-R-1-WASHER-19	BOLTING	VT89949	

** ASME ITEM NUMBER/EXAM CATEGORY: B07.020 B-G-2

* ISOMETRIC: E-0001P

RC-TK-1-B-1	BOLTING	VB91011	
RC-TK-1-B-2	BOLTING	VB91011	
RC-TK-1-B-3	BOLTING	VB91011	
RC-TK-1-B-4	BOLTING	VB91011	
RC-TK-1-B-5	BOLTING	VB91011	
RC-TK-1-B-6	BOLTING	VB91011	
RC-TK-1-B-7	BOLTING	VB91011	
RC-TK-1-B-8	BOLTING	VB91011	

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION	COMPONENT DESCRIPTION	NDE REPORT NUMBER	OUTAGE REMARKS
RC-TK-1-B-9	BOLTING	VB91011	
RC-TK-1-B-10	BOLTING	VB91011	
RC-TK-1-B-11	BOLTING	VB91011	
RC-TK-1-B-12	BOLTING	VB91011	
RC-TK-1-B-13	BOLTING	VB91011	
RC-TK-1-B-14	BOLTING	VB91011	
RC-TK-1-B-15	BOLTING	VB91011	
RC-TK-1-B-16	BOLTING	VB91011	

** ASME ITEM NUMBER/EXAM CATEGORY: B07.050 B-G-2

* ISOMETRIC: 0246A

ORIFICE (4)-B-1	BOLTING	VT89586	
ORIFICE (4)-B-2	BOLTING	VT89586	
ORIFICE (4)-B-3	BOLTING	VT89586	
ORIFICE (4)-B-4	BOLTING	VT89586	

* ISOMETRIC: 0350B

FLANGE (16)-B-1	BOLTING	VT89917	
FLANGE (16)-B-2	BOLTING	VT89917	
FLANGE (16)-B-3	BOLTING	VT89917	
FLANGE (16)-B-4	BOLTING	VT89917	
FLANGE (16)-B-5	BOLTING	VT89917	
FLANGE (16)-B-6	BOLTING	VT89917	
FLANGE (16)-B-7	BOLTING	VT89917	
FLANGE (16)-B-8	BOLTING	VT89917	
FLANGE (16)-B-9	BOLTING	VT89917	
FLANGE (16)-B-10	BOLTING	VT89917	
FLANGE (16)-B-11	BOLTING	VT89917	
FLANGE (16)-B-12	BOLTING	VT89917	
FLANGE (17)-B-1	BOLTING	VT89964	
FLANGE (17)-B-2	BOLTING	VT89964	
FLANGE (17)-B-3	BOLTING	VT89964	
FLANGE (17)-B-4	BOLTING	VT89964	
FLANGE (17)-B-5	BOLTING	VT89964	
FLANGE (17)-B-6	BOLTING	VT89964	
FLANGE (17)-B-7	BOLTING	VT89964	
FLANGE (17)-B-8	BOLTING	VT89964	
FLANGE (17)-B-9	BOLTING	VT89964	
FLANGE (17)-B-10	BOLTING	VT89964	
FLANGE (17)-B-11	BOLTING	VT89964	
FLANGE (17)-B-12	BOLTING	VT89964	

* ISOMETRIC: 0354A

ORIFICE (5)-B-1	BOLTING	VT89589	
ORIFICE (5)-B-2	BOLTING	VT89589	

DUPJESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
DRIFICE (5)-B-3	BOLTING	VT89889	
DRIFICE (5)-B-4	BOLTING	VT89889	
DRIFICE (5)-B-5	BOLTING	VT89889	
DRIFICE (5)-B-6	BOLTING	VT89889	
DRIFICE (5)-B-7	BOLTING	VT89889	
DRIFICE (5)-B-8	BOLTING	VT89889	
** ASME ITEM NUMBER/EXAM CATEGORY: B07.060 B-G-2			
* ISOMETRIC: E-0001R			
RC-P-1A-B(5)-1	BOLTING	VT89883	
RC-P-1A-B(5)-2	BOLTING	VT89883	
RC-P-1A-B(5)-3	BOLTING	VT89883	
RC-P-1A-B(5)-4	BOLTING	VT89883	
RC-P-1A-B(5)-5	BOLTING	VT89883	
RC-P-1A-B(5)-6	BOLTING	VT89883	
RC-P-1A-B(5)-7	BOLTING	VT89883	
RC-P-1A-B(5)-8	BOLTING	VT89883	
RC-P-1A-B(5)-9	BOLTING	VT89883	
RC-P-1A-B(5)-10	BOLTING	VT89883	
RC-P-1A-B(5)-11	BOLTING	VT89883	
RC-P-1A-B(5)-12	BOLTING	VT89883	
** ASME ITEM NUMBER/EXAM CATEGORY: B07.070 B-G-2			
* ISOMETRIC: 0348B			
PCV-RC-455A-B-1	VALVE BOLTING	VB91004	
PCV-RC-455A-B-2	VALVE BOLTING	VB91004	
PCV-RC-455A-B-3	VALVE BOLTING	VB91004	
PCV-RC-455A-B-4	VALVE BOLTING	VB91004	UNSAT THREAD ENGAGEMENT ACCEPTED PER EM65008. UT89331 UT PER EM95085. EM65008
PCV-RC-455A-B-5	VALVE BOLTING	VB91004	
PCV-RC-455A-B-6	VALVE BOLTING	VB91004	
PCV-RC-455A-B-7	VALVE BOLTING	VB91004	
PCV-RC-455A-B-8	VALVE BOLTING	VB91004	UNSAT THREAD ENGAGEMENT ACCEPTED PER EM65008. UT89331 UT PER EM95085. EM65008
* ISOMETRIC: 0348D			
PCV-RC-455B-B-1	VALVE BOLTING	VB91097	
PCV-RC-455B-B-2	VALVE BOLTING	VB91097	
PCV-RC-455B-B-3	VALVE BOLTING	VB91097	
PCV-RC-455B-B-4	VALVE BOLTING	VB91097	
PCV-RC-455B-B-5	VALVE BOLTING	VB91097	
PCV-RC-455B-B-6	VALVE BOLTING	VB91097	

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVP6 UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
PCV-RC-455B-B-7	VALVE BOLTING	VB91097	
PCV-RC-455B-B-8	VALVE BOLTING	VB91097	
* ISOMETRIC: 0350A			
MOV-RC-535-B-1	VALVE BOLTING	VT89958	
MOV-RC-535-B-2	VALVE BOLTING	VT89958	
MOV-RC-535-B-3	VALVE BOLTING	VT89958	
MOV-RC-535-B-4	VALVE BOLTING	VT89958	
MOV-RC-535-B-5	VALVE BOLTING	VT89958	
MOV-RC-535-B-6	VALVE BOLTING	VT89958	
MOV-RC-535-B-7	VALVE BOLTING	VT89958	
MOV-RC-535-B-8	VALVE BOLTING	VT89958	
MOV-RC-535-B-9	VALVE BOLTING	VT89958	
MOV-RC-535-B-10	VALVE BOLTING	VT89958	
MOV-RC-535-B-11	VALVE BOLTING	VT89958	
MOV-RC-535-B-12	VALVE BOLTING	VT89958	
MOV-RC-536-B-1	VALVE BOLTING	VT89918	
MOV-RC-536-B-2	VALVE BOLTING	VT89918	
MOV-RC-536-B-3	VALVE BOLTING	VT89918	
MOV-RC-536-B-4	VALVE BOLTING	VT89918	UNSAT DUE TO CORROSION, BASELINE IN PLACE PER VT89979 VT89979. SEE ALSO EM95090.
MOV-RC-536-B-5	VALVE BOLTING	VT89918	UNSAT DUE TO CORROSION, BASELINE IN PLACE PER VT89979 VT89979. SEE ALSO EM95090.
MOV-RC-536-B-6	VALVE BOLTING	VT89918	
MOV-RC-536-B-7	VALVE BOLTING	VT89918	
MOV-RC-536-B-8	VALVE BOLTING	VT89918	
MOV-RC-536-B-9	VALVE BOLTING	VT89918	
MOV-RC-536-B-10	VALVE BOLTING	VT89918	
MOV-RC-536-B-11	VALVE BOLTING	VT89918	
MOV-RC-536-B-12	VALVE BOLTING	VT89918	
PCV-RC-456-B-1	VALVE BOLTING	VT89919	
PCV-RC-456-B-2	VALVE BOLTING	VT89919	
PCV-RC-456-B-3	VALVE BOLTING	VT89919	
PCV-RC-456-B-4	VALVE BOLTING	VT89919	
PCV-RC-456-B-5	VALVE BOLTING	VT89919	
PCV-RC-456-B-6	VALVE BOLTING	VT89919	
PCV-RC-456-B-7	VALVE BOLTING	VT89919	
PCV-RC-456-B-8	VALVE BOLTING	VT89919	
MOV-RC-537-B-1	VALVE BOLTING	VT89954	
MOV-RC-537-B-2	VALVE BOLTING	VT89954	
MOV-RC-537-B-3	VALVE BOLTING	VT89954	
MOV-RC-537-B-4	VALVE BOLTING	VT89954	
MOV-RC-537-B-5	VALVE BOLTING	VT89954	
MOV-RC-537-B-6	VALVE BOLTING	VT89954	
MOV-RC-537-B-7	VALVE BOLTING	VT89954	
MOV-RC-537-B-8	VALVE BOLTING	VT89954	

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
MOV-RC-537-B-9	VALVE BOLTING	VT89954	
MOV-RC-537-B-10	VALVE BOLTING	VT89954	
MOV-RC-537-B-11	VALVE BOLTING	VT89954	
MOV-RC-537-B-12	VALVE BOLTING	VT89954	
* ISOMETRIC: 0350B			
RV-RC-551A-B-1	VALVE BOLTING	VT89951	
RV-RC-551A-B-2	VALVE BOLTING	VT89951	
RV-RC-551A-B-3	VALVE BOLTING	VT89951	
RV-RC-551A-B-4	VALVE BOLTING	VT89951	
RV-RC-551A-B-5	VALVE BOLTING	VT89951	
RV-RC-551A-B-6	VALVE BOLTING	VT89951	
* ISOMETRIC: 0999A			
MOV-RC-585-B-1	VALVE BOLTING	VB91006	
MOV-RC-585-B-2	VALVE BOLTING	VB91006	
MOV-RC-585-B-3	VALVE BOLTING	VB91006	
MOV-RC-585-B-4	VALVE BOLTING	VB91006	
* ISOMETRIC: 0074A			
MOV-RH-701-B-1	VALVE BOLTING	VB91065	
MOV-RH-701-B-2	VALVE BOLTING	VB91065	
MOV-RH-701-B-3	VALVE BOLTING	VB91065	
MOV-RH-701-B-4	VALVE BOLTING	VB91065	
MOV-RH-701-B-5	VALVE BOLTING	VB91065	
MOV-RH-701-B-6	VALVE BOLTING	VB91065	
MOV-RH-701-B-7	VALVE BOLTING	VB91065	
MOV-RH-701-B-8	VALVE BOLTING	VB91065	
MOV-RH-701-B-9	VALVE BOLTING	VB91065	
MOV-RH-701-B-10	VALVE BOLTING	VB91065	
MOV-RH-701-B-11	VALVE BOLTING	VB91065	
MOV-RH-701-B-12	VALVE BOLTING	VB91065	
MOV-RH-701-B-13	VALVE BOLTING	VB91065	
MOV-RH-701-B-14	VALVE BOLTING	VB91065	
MOV-RH-701-B-15	VALVE BOLTING	VB91065	
MOV-RH-701-B-16	VALVE BOLTING	VB91065	
* ISOMETRIC: 0106A			
1S1-51-B-1	VALVE BOLTING	VT89885	
1S1-51-B-2	VALVE BOLTING	VT89885	
1S1-51-B-3	VALVE BOLTING	VT89885	
1S1-51-B-4	VALVE BOLTING	VT89885	
1S1-51-B-5	VALVE BOLTING	VT89885	
1S1-51-B-6	VALVE BOLTING	VT89885	
1S1-51-B-7	VALVE BOLTING	VT89885	
1S1-51-B-8	VALVE BOLTING	VT89885	

DUQUESNE LIGHT COMPANY
EVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION	COMPONENT DESCRIPTION	NDE REPORT NUMBER	OUTAGE REMARKS
151-51-B-9	VALVE BOLTING	VT89885	
151-51-B-10	VALVE BOLTING	VT89885	
151-51-B-11	VALVE BOLTING	VT89885	
151-51-B-12	VALVE BOLTING	VT89885	
151-51-B-13	VALVE BOLTING	VT89885	
151-51-B-14	VALVE BOLTING	VT89885	
151-51-B-15	VALVE BOLTING	VT89885	
151-51-B-16	VALVE BOLTING	VT89885	INADEQUATE THREAD ENGAGEMENT REWORKED PER VT89980 EM95082.
* ISOMETRIC: 0200C			
151-84-B-1	VALVE BOLTING	VT89914	
151-84-B-2	VALVE BOLTING	VT89914	
151-84-B-3	VALVE BOLTING	VT89914	
151-84-B-4	VALVE BOLTING	VT89914	
151-84-B-5	VALVE BOLTING	VT89914	
151-84-B-6	VALVE BOLTING	VT89914	
151-84-B-7	VALVE BOLTING	VT89914	
151-84-B-8	VALVE BOLTING	VT89914	
151-84-B-9	VALVE BOLTING	VT89914	
151-84-B-10	VALVE BOLTING	VT89914	
151-84-B-11	VALVE BOLTING	VT89914	
151-84-B-12	VALVE BOLTING	VT89914	
* ISOMETRIC: 0222B			
151-15-B-1	VALVE BOLTING	VT89921	
151-15-B-2	VALVE BOLTING	VT89921	
151-15-B-3	VALVE BOLTING	VT89921	
151-15-B-4	VALVE BOLTING	VT89921	
151-15-B-5	VALVE BOLTING	VT89921	
151-15-B-6	VALVE BOLTING	VT89921	
151-15-B-7	VALVE BOLTING	VT89921	
151-15-B-8	VALVE BOLTING	VT89921	
151-15-B-9	VALVE BOLTING	VT89921	
151-15-B-10	VALVE BOLTING	VT89921	
151-15-B-11	VALVE BOLTING	VT89921	
151-15-B-12	VALVE BOLTING	VT89921	
151-20-B-1	VALVE BOLTING	V891064	
151-20-B-2	VALVE BOLTING	V891064	
151-20-B-3	VALVE BOLTING	V891064	
151-20-B-4	VALVE BOLTING	V891064	
151-20-B-5	VALVE BOLTING	V891064	
151-20-B-6	VALVE BOLTING	V891064	
151-20-B-7	VALVE BOLTING	V891064	
151-20-B-8	VALVE BOLTING	V891064	
151-20-B-9	VALVE BOLTING	V891064	

DUQUESNE LIGHT COMPANY
BVP5 UNIT 1 1989 ODTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
1S1-20-B-10	VALVE BOLTING	VB91064	
1S1-20-B-11	VALVE BOLTING	VB91064	
1S1-20-B-12	VALVE BOLTING	VB91064	
* ISOMETRIC: 0375C			
1S1-10-B-1	VALVE BOLTING	VT89905	
1S1-10-B-2	VALVE BOLTING	VT89905	
1S1-10-B-3	VALVE BOLTING	VT89905	
1S1-10-B-4	VALVE BOLTING	VT89905	
1S1-10-B-5	VALVE BOLTING	VT89905	
1S1-10-B-6	VALVE BOLTING	VT89905	
1S1-10-B-7	VALVE BOLTING	VT89905	
1S1-10-B-8	VALVE BOLTING	VT89905	
1S1-10-B-9	VALVE BOLTING	VT89905	
1S1-10-B-10	VALVE BOLTING	VT89905	
1S1-10-B-11	VALVE BOLTING	VT89905	
1S1-10-B-12	VALVE BOLTING	VT89905	
* ISOMETRIC: 0375E			
1S1-12-B-1	VALVE BOLTING	VT89890	
1S1-12-B-2	VALVE BOLTING	VT89890	
1S1-12-B-3	VALVE BOLTING	VT89890	
1S1-12-B-4	VALVE BOLTING	VT89890	
1S1-12-B-5	VALVE BOLTING	VT89890	
1S1-12-B-6	VALVE BOLTING	VT89890	
1S1-12-B-7	VALVE BOLTING	VT89890	
1S1-12-B-8	VALVE BOLTING	VT89890	
1S1-12-B-9	VALVE BOLTING	VT89890	
1S1-12-B-10	VALVE BOLTING	VT89890	
1S1-12-B-11	VALVE BOLTING	VT89890	
1S1-12-B-12	VALVE BOLTING	VT89890	
1S1-23-B-1	VALVE BOLTING	VT89890	
1S1-23-B-2	VALVE BOLTING	VT89890	
1S1-23-B-3	VALVE BOLTING	VT89890	
1S1-23-B-4	VALVE BOLTING	VT89890	UNSAT THREAD ENGAGEMENT ACCEPTED PER EM95082.
		EM95082	
1S1-23-B-5	VALVE BOLTING	VT89890	
1S1-23-B-6	VALVE BOLTING	VT89890	
1S1-23-B-7	VALVE BOLTING	VT89890	
1S1-23-B-8	VALVE BOLTING	VT89890	UNSAT THREAD ENGAGEMENT ACCEPTED PER EM95082.
		EM95082	
1S1-23-B-9	VALVE BOLTING	VT89890	
1S1-23-B-10	VALVE BOLTING	VT89890	
1S1-23-B-11	VALVE BOLTING	VT89890	
1S1-23-B-12	VALVE BOLTING	VT89890	

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: 0375F			
1S1-11-B-1	VALVE BOLTING	VTB9906	
1S1-11-B-2	VALVE BOLTING	VTB9906	
1S1-11-B-3	VALVE BOLTING	VTB9906	
1S1-11-B-4	VALVE BOLTING	VTB9906	
1S1-11-B-5	VALVE BOLTING	VTB9906	
1S1-11-B-6	VALVE BOLTING	VTB9906	
1S1-11-B-7	VALVE BOLTING	VTB9906	
1S1-11-B-8	VALVE BOLTING	VTB9906	
1S1-11-B-9	VALVE BOLTING	VTB9906	
1S1-11-B-10	VALVE BOLTING	VTB9906	
1S1-11-B-11	VALVE BOLTING	VTB9906	
1S1-11-B-12	VALVE BOLTING	VTB9906	
** ASME ITEM NUMBER/EXAM CATEGORY: B08.020 B-H			
* ISOMETRIC: E-0001P			
RC-TK-1-C-B	SKIRT CIRC WELD		UTB9295 SCANNED BETW DATUM #0 AND #8, APPROX 96".
** ASME ITEM NUMBER/EXAM CATEGORY: B09.011 B-J			
* ISOMETRIC: 0348A			
RC-71-1-S-01	BUTT WELD	UTB9322	
		PTB9245	
RC-71-1-S-02	BUTT WELD	UTB9323	
		PTB9245	
RC-71-1-S-03	BUTT WELD	UTB9324	
		PTB9245	
RC-71-1-S-04	BUTT WELD	UTB9325	LIMITED EXAM DUE TO WELDED ATTACH' NTS (60% PTB9245 EXAMINED).
* ISOMETRIC: 0348C			
RC-72-1-S-03	BUTT WELD	UTB9256	
		PTB9207	
RC-72-1-S-04	BUTT WELD	UTB9257	
		PTB9207	
* ISOMETRIC: 0350B			
RC-97-1-S-02	BUTT WELD	UTB9281	
		PTB9219	
RC-97-1-S-03	BUTT WELD	UTB9279	
		PTB9219	
		UTB9280	
* ISOMETRIC: 0999A			
DLW-LOOP1-9-F-42	BUTT WELD		UTB9320 LIMITED EXAM DUE TO VALVE (71% EXAMINED).

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
DLW-LOOP1-9-S-02	BUTT WELD	PTB9242 UTB9319 PTB9242	
* ISOMETRIC: 09990 DLW-PRESS-1-F-37	BUTT WELD	UTB9289	2 SAT PT INDICATIONS.
DLW-PRESS-2-F-38	BUTT WELD	PTB9224 UTB9290 PTB9223	
DLW-PRESS-2-S-02	BUTT WELD	PTB9223 UTB9291 PTB9223	
DLW-PRESS-2-S-01	BUTT WELD	UTB9294 PTB9223	
* ISOMETRIC: L-002A DLW-LOOP2-5-F-19	BUTT WELD	UTB9375 PTB9284	
* ISOMETRIC: 0074A RH-1-1-F-01	BUTT WELD	UTB9332 PTB9254	
RH-1-1-S-04	BUTT WELD	UTB9333 PTB9254	
RH-1-1-S-03	BUTT WELD	UTB9338 PTB9261	
RH-1-1-S-02	BUTT WELD	UTB9337 PTB9261	
RH-1-1-S-01	BUTT WELD	UTB9336 PTB9261	
RH-1-2-S-01	BUTT WELD	UTB9342 PTB9261	
* ISOMETRIC: 0107A RH-23-1-S-04	BUTT WELD	UTB9278 PTB9216	
RH-23-1-S-02	BUTT WELD	UTB9277 PTB9216 UTB9388	
* ISOMETRIC: 0106A SI-121-3-F-05	BUTT WELD	UTB9302 PTB9235	
SI-121-4-S-06	BUTT WELD	UTB9303 PTB9235	
SI-121-4-S-05	BUTT WELD	UTB9304 PTB9235	

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
S1-121-4-S-04	BUTT WELD	UT89305 PT89235	
S1-121-4-S-03	BUTT WELD	UT89306 PT89235	
S1-121-4-F-06	BUTT WELD	UT89307 PT89241	
* ISOMETRIC: 0220C			
S1-29-9-F-10	BUTT WELD	UT89356 PT89269	
S1-29-9-S-01	BUTT WELD	UT89353 PT89269	
S1-29-9-S-02	BUTT WELD	UT89354 PT89269	
S1-29-9-S-03	BUTT WELD	UT89355 PT89269	
S1-29-9-F-11	BUTT WELD	UT89357 PT89269	
* ISOMETRIC: 0222B			
S1-20-11-F-13	BUTT WELD	UT89321 PT89244	
S1-20-11-S-04	BUTT WELD	UT89314 PT89233	
S1-20-11-S-03	BUTT WELD	UT89313 PT89233	
S1-20-11-S-02	BUTT WELD	UT89312 PT89233	
S1-20-11-S-01	BUTT WELD	UT89311 PT89233	
* ISOMETRIC: 0223B			
S1-30-5-F-07	BUTT WELD	UT89258 PT89210	
S1-30-5-S-01	BUTT WELD	UT89260 PT89210	
S1-30-5-S-02	BUTT WELD	UT89262 PT89210	
S1-30-5-S-03	BUTT WELD	UT89261 PT89210	
S1-30-5-F-08	BUTT WELD	UT89259 PT89210	
* ISOMETRIC: 0375E			
S1-72-5-F-06	BUTT WELD	UT89317 PT89236	

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPB UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION	COMPONENT DESCRIPTION	NDE REPORT NUMBER	OUTAGE REMARKS
S1-72-6-F-07	BUTT WELD	UT89318 PT89236	
** ASME ITEM NUMBER/EXAM CATEGORY: B09.012 B-J			
* ISOMETRIC: L-002A			
DLW-LOOP2-4-L-01	LONGITUDINAL ELBOW WELD	PT89283	
DLW-LOOP2-4-L-02	LONGITUDINAL ELBOW WELD	PT89283	
DLW-LOOP2-5-L-03	LONGITUDINAL ELBOW WELD	PT89284	
DLW-LOOP2-5-L-04	LONGITUDINAL ELBOW WELD	PT89284	
** ASME ITEM NUMBER/EXAM CATEGORY: B09.021 B-J			
* ISOMETRIC: 0200C			
S1-134-2-F-03	BUTT WELD	PT89204	
S1-134-2-S-04	BUTT WELD	PT89204	
S1-134-2-S-03	BUTT WELD	PT89204	
S1-134-2-S-02	BUTT WELD	PT89204	
* ISOMETRIC: 0375E			
S1-72-7-S-07	BUTT WELD	PT89240	
** ASME ITEM NUMBER/EXAM CATEGORY: B09.031 B-J			
* ISOMETRIC: L-002A			
DLW-LOOP2-1-S-03	BRANCH CONNECTION WELD	PT89281	
** ASME ITEM NUMBER/EXAM CATEGORY: B09.032 B-J			
* ISOMETRIC: L-002B			
DLW-LOOP2-5-S-03	BRANCH CONNECTION WELD	PT89299	
** ASME ITEM NUMBER/EXAM CATEGORY: B09.040 B-J			
* ISOMETRIC: 0195A			
CH-97-1A-S-02	SOCKET WELD	PT89205	
* ISOMETRIC: 0196A			
CH-96-1E-F-01	SOCKET WELD	PT89227	
CH-96-1E-F-1E	SOCKET WELD	PT89227	
CH-96-1D-F-1F	SOCKET WELD	PT89227	
CH-96-1A-F-1B	SOCKET WELD	PT89227	
CH-96-1-F-1C	SOCKET WELD	PT89227	
CH-96-1-S-01	SOCKET WELD	PT89227	
CH-96-1-F-02	SOCKET WELD	PT89227 3 SAT PT INDICATIONS	
CH-96-2-S-01	SOCKET WELD	PT89288	

APPENDIX I - CODE EXAMS
DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION	COMPONENT DESCRIPTION	NDE REPORT NUMBER	OUTAGE REMARKS
CH-96-2-S-02	SOCKET WELD	PTB9288	
* ISOMETRIC: 02424			
CH-1-1A-F-1X	SOCKET WELD	PTB9247	
CH-1-1B-F-1B	SOCKET WELD	PTB9247	
CH-1-1B-S-02	SOCKET WELD	PTB9247	SAT PT INDICATION
CH-1-1-F-01	SOCKET WELD	PTB9247	
* ISOMETRIC: 0243A			
CH-140-7-F-11	SOCKET WELD	PTB9248	
CH-140-8-S-07	SOCKET WELD	PTB9248	
CH-140-8-S-06	SOCKET WELD	PTB9248	
CH-140-8-S-05	SOCKET WELD	PTB9248	
CH-140-8-S-04	SOCKET WELD	PTB9248	
CH-140-8-S-03	SOCKET WELD	PTB9248	
CH-140-8-F-12	SOCKET WELD	PTB9296	
* ISOMETRIC: 0244A			
CH-141-2-F-03	SOCKET WELD	PTB9258	PT UNSAT LINEAR INDICATION REWORKED PER PTB9295 EM9509B/MWRB93844.
* ISOMETRIC: 0254A			
CH-23-3-S-03	SOCKET WELD	PTB9252	ARC STRIKE ADJ'T TO WELD REWORKED EM95107/MWRB93847/PTB9298/VTB91039. SEE ALSO VTB9-946.
CH-23-4-F-06	SOCKET WELD	PTB9252	ARC STRIKE ADJ'T TO WELD REWORKED EM95107/MWRB93848/PTB9298/VTB91040. SEE ALSO VTB9946.
CH-23-4-S-01	SOCKET WELD	PTB9225	
CH-23-4-S-02	SOCKET WELD	PTB9225	
CH-23-4A-F-6A	SOCKET WELD	PTB9225	
* ISOMETRIC: 0357A			
DG-56-3-F-03	SOCKET WELD	PTB9243	
DG-56-3-S-02	SOCKET WELD	PTB9243	
DG-56-2-S-01	SOCKET WELD	PTB9243	
DG-56-2-F-03	SOCKET WELD	PTB9243	
DG-56-3-S-01	SOCKET WELD	PTB9243	UNSAT PT INDICATION REWORKED PER PTB9286 EM95087/MWRB93839.
DG-56-3-F-04	SOCKET WELD	PTB9243	UNSAT PT INDICATIONS REWORKED PER PTB9286 EM95087/MWRB93840.
* ISOMETRIC: 0358A			
DG-52-3-S-01	SOCKET WELD	PTB9263	
DG-52-3A-F-04	SOCKET WELD	PTB9263	

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: 0243A RC-44-1-S-02	SOCKET WELD	PT89248	
RC-44-1-S-01	SOCKET WELD	PT89248	
* ISOMETRIC: 0244A RC-54-1-S-02	SOCKET WELD	PT89258	
RC-54-1-F-4A	SOCKET WELD	PT89258	
* ISOMETRIC: 0245A RC-64-1-S-02	SOCKET WELD	PT89209	
RC-64-1-S-01	SOCKET WELD	PT89209	
* ISOMETRIC: 0254A RC-72-5-F-08	SOCKET WELD	PT89225	
RC-72-5-S-10	SOCKET WELD	PT89225	
* ISOMETRIC: 0354B RC-25-2-S-04	SOCKET WELD	PT89257	
* ISOMETRIC: 0200A S1-102-2-S-06	SOCKET WELD	PT89292	
S1-102-2-S-05	SOCKET WELD	PT89292	
S1-102-2-S-04	SOCKET WELD	PT89292	
S1-102-2-S-03	SOCKET WELD	PT89292	
* ISOMETRIC: 0375E S1-72-7-F-06	SOCKET WELD	PT89239	
** ASME ITEM NUMBER/EXAM CATEGORY: B10.010 B-K-1			
* ISOMETRIC: 0074A RH-1-1-A-01 TO 02	WELDED ATTACHMENT SUPPORT SH-40	PT89253	
RH-1-2-A-03 TO 06	WELDED ATTACHMENT SUPPORT SH-39	PT89260	LIMITED EXAM DUE TO SUPPORT
RH-1-2-A-07	WELDED ATTACHMENT SMUBBER HSS-106	PT89260	
* ISOMETRIC: 0108B RH-24-1A-A-01	WELDED ATTACHMENT SUPPORT A-42	PT89229	2 SAT PT INDICATIONS
RH-24-1A-A-02	WELDED ATTACHMENT SUPPORT A-42	PT89229	SAT PT INDICATION
** ASME ITEM NUMBER/EXAM CATEGORY: B12.050 B-M-2			
* ISOMETRIC: 0106A 1S1-48	VALVE BODY	VB91005	
1S1-51	VALVE BODY	VT89938	LIMITED EXAM DUE TO DISC NOT REMOVED

PAGE NO. 17
02/07/90

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: 0107A 1S1-49	VALVE BODY	VT89920	
* ISOMETRIC: 0107B 1S1-52	VALVE BODY	VT89939	LIMITED EXAM DUE TO DISC NOT REMOVED
* ISOMETRIC: 0108B 1S1-53	VALVE BODY	VT89943	LIMITED EXAM DUE TO DISC NOT REMOVED
** ASME ITEM NUMBER/EXAM CATEGORY: B13.010 B-N-1			
* ISOMETRIC: E-0001F RC-R-1-ACC-INT	INTERIOR	VT89901	
* ISOMETRIC: E-0001G RC-R-1-UPPER-INT	CORE SUPPORT STRUCTURE	VT89902	
** ASME ITEM NUMBER/EXAM CATEGORY: C01.010 C-A			
* ISOMETRIC: E-0003A CH-E-1-C-2	CIRCUMFERENTIAL BUTT WELD	VB91177	
* ISOMETRIC: E-0003C CH-E-3-C-7	CIRCUMFERENTIAL BUTT WELD	VB91190	
CH-E-3-C-8	CIRCUMFERENTIAL BUTT WELD	VB91190	
CH-E-3-C-9	CIRCUMFERENTIAL BUTT WELD	VB91190	
CH-E-3-C-10	CIRCUMFERENTIAL BUTT WELD	VB91190	
CH-E-3-C-11	CIRCUMFERENTIAL BUTT WELD	VB91190	
CH-E-3-C-12	CIRCUMFERENTIAL BUTT WELD	VB91190	
* ISOMETRIC: E-0003F CH-FL-3-C-2	CIRCUMFERENTIAL BUTT WELD	PT89277	
* ISOMETRIC: E-0003B CH-E-2-C-2	CIRCUMFERENTIAL BUTT WELD	VB91175	
* ISOMETRIC: E-0001M RC-E-1A-C-6	CIRCUMFERENTIAL BUTT WELD	UT89386	100% WELD LENGTH EXAMINED
** ASME ITEM NUMBER/EXAM CATEGORY: C01.020 C-A			
* ISOMETRIC: E-0003A CH-E-1-C-1	CIRCUMFERENTIAL BUTT WELD	VB91177	
* ISOMETRIC: E-0003C CH-E-3-C-1	CIRCUMFERENTIAL BUTT WELD	VB91190	

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVP5 UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
CH-E-3-C-2	CIRCUMFERENTIAL BUTT WELD	VB91190	
CH-E-3-C-3	CIRCUMFERENTIAL BUTT WELD	VB91190	
CH-E-3-C-4	CIRCUMFERENTIAL BUTT WELD	VB91190	
CH-E-3-C-5	CIRCUMFERENTIAL BUTT WELD	VB91190	
CH-E-3-C-6	CIRCUMFERENTIAL BUTT WELD	VB91190	
* ISOMETRIC: E-0003F CH-FL-3-C-1	CIRCUMFERENTIAL BUTT WELD	PT89276	
* ISOMETRIC: E-0005B SI-TK-2-C-1	CIRCUMFERENTIAL BUTT WELD	UT89370	
* ISOMETRIC: E-0003B CH-E-2-C-1	CIRCUMFERENTIAL BUTT WELD	VB91176	
* ISOMETRIC: E-0004A RH-E-1A-C-1	CIRCUMFERENTIAL BUTT WELD	UT89387	LIMITED EXAM DUE TO TAPER (84% EXAMINED)
** ASME ITEM NUMBER/EXAM CATEGORY: C01.030 C-A			
* ISOMETRIC: E-0001N RC-E-1A-C-2	CIRCUMFERENTIAL BUTT WELD	UT89380	100% WELD LENGTH EXAMINED
** ASME ITEM NUMBER/EXAM CATEGORY: C02.033 C-B			
* ISOMETRIC: E-0004A RH-E-1A-N-3	NOZZLE-TO-VESSEL WELD	VT89658	
RH-E-1A-N-4	NOZZLE-TO-VESSEL WELD	VT89658	
** ASME ITEM NUMBER/EXAM CATEGORY: C03.010 C-C			
* ISOMETRIC: E-0003F CH-FL-3-A-01	WELDED ATTACHMENT SUPPORT SUPP-1	PT89278	
CH-FL-3-A-02	WELDED ATTACHMENT SUPPORT SUPP-2	PT89278	
CH-FL-3-A-03	WELDED ATTACHMENT SUPPORT SUPP-3	PT89278	
CH-FL-3-A-04	WELDED ATTACHMENT SUPPORT SUPP-4	PT89278	
* ISOMETRIC: E-0005B SI-TK-2-WS-4	WELDED ATTACHMENT SUPPORT WS-4	PT89300	EM95121/E-89-37 ACCEPTS PT INDICATION EM95121
* ISOMETRIC: E-0001N RC-E-1A-WS-1	TRUNNION WELD	MT89118	
RC-E-1A-WS-2	TRUNNION WELD	MT89118	

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
** ASME ITEM NUMBER/EXAM CATEGORY: C03.020 C-C			
* ISOMETRIC: 0062A			
WFPD-22-4-A-01 TO 02	WELDED ATTACHMENT SUPPORT R-5	MTB9122	
WFPD-22-5-A-03 TO 06	WELDED ATTACHMENT SNUBBER HSS203,204,R4	MTB9124	
WFPD-22-6-A-07 TO 08	WELDED ATTACHMENT SUPPORT R-3	MTB9123	
* ISOMETRIC: 0062B			
WFPD-23-3-A-01 TO 02	WELDED ATTACHMENT SUPPORT SII-9	MTB9121	
* ISOMETRIC: 0062C			
WFPD-24-5-A-03 TO 06	WELDED ATTACHMENT SUPPORT R11,209,210	MTB9150	ARC STRIKES ADJ/T TO A-3,5,6 PER VTB91101, VBT91101 MTB9149 SATS 3,4,5, MTB9150 UNSAT -6, REWORK MTB9149 -6 EM95129/MWRB94829, MTB9161 SAT MTB9161
** ASME ITEM NUMBER/EXAM CATEGORY: C04.010 C-D			
* ISOMETRIC: E-0005B			
S1-TK-2-STUD-1	BOLTING	UTB9360	
S1-TK-2-STUD-2	BOLTING	UTB9361	
S1-TK-2-STUD-3	BOLTING	UTB9362	
S1-TK-2-STUD-4	BOLTING	UTB9363	
S1-TK-3-STUD-5	BOLTING	UTB9364	
** ASME ITEM NUMBER/EXAM CATEGORY: C05.011 C-F-1			
* ISOMETRIC: 0115A			
P11-G-S-09	PIPE WELD	UTB9253 PTB9201	
* ISOMETRIC: 0109A			
S1-1B-1-S-05	PIPE WELD	UTB9250	ARC STRIKE CLEARED PTB9274, EM95017, PTB9196 MWRB92214, LIMITED EXAM DUE TO REDUCER (67% UTB9251 EXMND).
* ISOMETRIC: 0223A			
S1-30-1-F-1A	PIPE WELD	UTB9255 PTB9206 UTB9254	SAT PT INDICATIONS
* ISOMETRIC: 0272A			
S1-TK-2-E-02	PIPE WELD	UTB9372	LIMITED EXAM DUE NOZZLE CONFIGURATION(63% PTB9279 EXAMINED), PT IND, SAT,
S1-TK-2-E-01	PIPE WELD	UTB9371	LIMITED EXAM DUE TO NOZZLE CONFIGURATION(43% PTB9279 EXAMINED)

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: 0074B RH-1B-1-S-08	PIPE WELD	UT89275 PT89214	
RH-1B-1-S-09	PIPE WELD	UT89276 PT89214	
RH-1B-1-S-04	PIPE WELD	UT89274	SAT PT INDICATION PT89214
RH-1B-1-S-03	PIPE WELD	UT89273	3 SAT PT INDICATIONS PT89214
RH-1B-1-S-01	PIPE WELD	UT89272	SAT PT INDICATION PT89214
* ISOMETRIC: 0075B RH-12-4-F-03	PIPE WELD	UT89270 PT89215	
RH-12-5-F-04	PIPE WELD	UT89271 PT89215	
** ASME ITEM NUMBER/EXAM CATEGORY: C05.012 C-F-1			
* ISOMETRIC: 0083A SI-5-1H-F-1P	ALIGNING CONN. LONGITUDINAL WELD	UT89252 PT89198	
** ASME ITEM NUMBER/EXAM CATEGORY: C05.021 C-F-1			
* ISOMETRIC: 0170A CH-125-9B-S-06	PIPE WELD	UT89288 PT89222	
CH-125-9B-S-05	PIPE WELD	UT89287 PT89222	
CH-125-9B-S-04	PIPE WELD	UT89286 PT89222	
CH-125-9B-S-03	PIPE WELD	UT89285 PT89222	
* ISOMETRIC: 0367A SI-133-5-S-07	PIPE WELD	UT89247 PT89192	
SI-133-5-S-06	PIPE WELD	UT89246 PT89192	
SI-133-5-S-05	PIPE WELD	UT89245 PT89192	
SI-133-5-S-04	PIPE WELD	UT89244 PT89192	
SI-133-5-S-03	PIPE WELD	UT89243	

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPB UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION	COMPONENT DESCRIPTION	NDE REPORT NUMBER	OUTAGE REMARKS
SI-133-5-S-02	PIPE WELD	PT89192	
SI-133-5-S-01	PIPE WELD	UT89242	
SI-133-5-F-06	PIPE WELD	PT89192	
SI-133-6A-S-05	PIPE WELD	UT89240	
SI-133-6A-S-04	PIPE WELD	PT89192	
		UT89241	
		PT89192	
		UT89249	UT REQ'D
		PT89194	
		UT89248	PT IND. REWORKED PER EM95016/MWR893434
		PT89193	
		PT89272	

** ASME ITEM NUMBER/EXAM CATEGORY: C05.030 C-F-1

* ISOMETRIC: 0192A

SI-82-1-S-02	SOCKET WELD	PT89289	
SI-82-1-F-01A	SOCKET WELD	PT89289	
SI-82-2-S-04	SOCKET WELD	PT89289	

* ISOMETRIC: 0193A

SI-84-1-S-03	SOCKET WELD	PT89290	
--------------	-------------	---------	--

* ISOMETRIC: 0194A

SI-86-2-S-01	SOCKET WELD	PT89291	
SI-86-2B-F-02	SOCKET WELD	PT89291	

* ISOMETRIC: 0267B

CH-87-3-F-03B	SOCKET WELD	PT89195	
CH-87-4-F-03C	SOCKET WELD	PT89195	

* ISOMETRIC: 0109A

SI-16-B-F-22	SOCKET WELD	PT89197	
--------------	-------------	---------	--

** ASME ITEM NUMBER/EXAM CATEGORY: C05.051 C-F-2

* ISOMETRIC: 0062A

WFPD-24-7A-F-09	PIPE WELD	UT89367	SEE UT89-392 FOR NDE REQUEST 107 EXAMS.
		MT89087	
WFPD-24-7A-S-03	PIPE WELD	UT89368	SEE ALSO E-89-036
		MT89087	
		UT89378	
WFPD-24-7A-S-02	PIPE WELD	UT89394	UT ONLY
* ISOMETRIC: 0062B			
WFPD-23-6C-F-02	PIPE WELD	UT89377	

PAGE NO. 22
02/07/90

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
WFPD-23-6C-F-01	PIPE WELD	MTB9097	UTB9376 UT IND ACCEPTED ON E-89-037 MTB9097
* ISOMETRIC: 0062C WFPD-22-8F-F-02	PIPE WELD	UTB9301	UNSAT MT INDICATION REPAIRED PER EM95079 MTB9065 MTB9081 UTB9300 MTB9065 UTB9381
WFPD-22-8F-F-01	PIPE WELD		
** ASME ITEM NUMBER/EXAM CATEGORY: C05.052 C-F-2			
* ISOMETRIC: 0001A SHP-56-9-L-05	LONGITUDINAL WELD ALONG ELBOW	UTB9379 MTB9110	
** ASME ITEM NUMBER/EXAM CATEGORY: C05.081 C-F-2			
* ISOMETRIC: 0002A SHP-56-10-S-09	REINFORCING RING WELD	MTB9080	
** ASME ITEM NUMBER/EXAM CATEGORY: C06.010 C-G			
* ISOMETRIC: DLW2-3140 RS-P-1A-1 RS-P-1A-2 RS-P-1A-3	PUMP CASING WELD PUMP CASING WELD PUMP CASING WELD	PTB9293 PTB9293 PTB9293	
** ASME ITEM NUMBER/EXAM CATEGORY: D01.020 D-A			
* ISOMETRIC: 0065A WAPD-2-1-A-01 WAPD-2-1A-A-02 TO 03 WAPD-2-2-A-04 WAPD-1-4-A-05 WAPD-1-4-A-06 WAPD-1-4-A-07	WELDED ATTACHMENT SUPPORT RH-5 WELDED ATTACHMENT SUPPORT R-6 WELDED ATTACHMENT SUPPORT A-7 WELDED ATTACHMENT SUPPORT RH-20 WELDED ATTACHMENT SUPPORT R-19 WELDED ATTACHMENT SUPPORT A-18	VTB9605 VTB9605 VTB9605 VTB9605 VTB9605 VTB9605	
* ISOMETRIC: 0775A WAPD-25-2-A-06 WAPD-25-11-A-05	WELDED ATTACHMENT SUPPORT PSA013 WELDED ATTACHMENT SUPPORT PSA001	VTB9609 VTB9609	
** ASME ITEM NUMBER/EXAM CATEGORY: D02.010 D-B			

DUQUESNE LIGHT COMPANY
BVPF UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: RHE2 RH-E-2A-WB-1	SADDLE SUPP. ATTACHMENT	VT89876	
** ASME ITEM NUMBER/EXAM CATEGORY: D02.020 D-B			
* ISOMETRIC: 0164A CC-116-4-A-11 CC-116-5-A-01 TO 02	WELDED ATTACHMENT SUPPORT R-27C-2 WELDED ATTACHMENT SUPPORT R-18C-3	VT89820 VT89820	
* ISOMETRIC: 0165A CC-248-1-A-02 TO 05 CC-249-2C-A-0A	WELDED ATTACHMENT SUPPORT A-18B-1 WELDED ATTACHMENT SUPPORT A-281A	VT89816 VT89816	
* ISOMETRIC: 0175A CC-261-1A-A-06 CC-261-3-A-07 TO 10 CC-257-1-A-01 CC-257-2-A-02 TO 05	WELDED ATTACHMENT SUPPORT A-10B-4 WELDED ATTACHMENT SUPPORT A-42B-1 WELDED ATTACHMENT SUPPORT A-18B-3 WELDED ATTACHMENT SUPPORT A-26B-3	VT89813 VT89813 VT89813 VT89813	
* ISOMETRIC: 0178A CC-258-5-A-01 CC-258-6-A-02 CC-265-6-A-04 TO 07 CC-265-B-A-03	WELDED ATTACHMENT SUPPORT R-23C-2 WELDED ATTACHMENT SUPPORT A-301 WELDED ATTACHMENT SUPPORT A-40C-1 WELDED ATTACHMENT SUPPORT A-333	VT89815 VT89815 VT89815 VT89815	
* ISOMETRIC: 0179A CC-114-4-A-22 CC-114-5-A-25 CC-114-8-A-26 TO 29 CC-114-11-A-30 TO 33 CC-114-11-A-34 TO 37 CC-118-5-A-09 TO 12 CC-118-8-A-14 TO 17 CC-118-8-A-18 TO 21	WELDED ATTACHMENT SUPPORT R-17D-3 WELDED ATTACHMENT SUPPORT R-10D-6 WELDED ATTACHMENT SUPPORT R-40D-1 WELDED ATTACHMENT SUPPORT R-182 WELDED ATTACHMENT SUPPORT R-180 WELDED ATTACHMENT SUPPORT R-26D-3 WELDED ATTACHMENT SUPPORT R-181 WELDED ATTACHMENT SUPPORT R-179	VT89819 VT89819 VT89819 VB91009 VB91009 VT89819 VB91009 VB91009	
* ISOMETRIC: 0184A CC-258-2-A-01 TO 08 CC-258-3-A-09 CC-25E-4A-A-10	WELDED ATTACHMENT SUPPORT R-269B WELDED ATTACHMENT SUPPORT A-269 WELDED ATTACHMENT SUPPORT R-270	VT89796 VT89779 VT89779	
* ISOMETRIC: 0185A CC-265-2-A-01 TO 08 CC-265-3-A-09 CC-265-5-A-10	WELDED ATTACHMENT SUPPORT R-274B WELDED ATTACHMENT SUPPORT A-273 WELDED ATTACHMENT SUPPORT R-274	VT89797 VT89773 VT89773	

APPENDIX I - CODE EXAMS
DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: 0186A CC-263-2-A-01 CC-263-4-A-02	WELDED ATTACHMENT SUPPORT A-262 WELDED ATTACHMENT SUPPORT R-263	VT89777 VT89777	
* ISOMETRIC: 0187A CC-261-5-A-01	WELDED ATTACHMENT SUPPORT A-276	VT89782	
* ISOMETRIC: 0188A CC-262-2-A-01	WELDED ATTACHMENT SUPPORT A-264	VT89776	
* ISOMETRIC: 0189A CC-257-4A-A-01	WELDED ATTACHMENT SUPPORT A-272	VT89793	
* ISOMETRIC: 0284A CC-177-1B-A-02 CC-112-5-A-01	WELDED ATTACHMENT SUPPORT R-237 WELDED ATTACHMENT SUPPORT R-208	VT89614 VT89614	
* ISOMETRIC: 0286A CC-249-5-A-01 CC-266-1-A-02 CC-202-9-A-07 TO 10	WELDED ATTACHMENT SUPPORT R-216 WELDED ATTACHMENT SUPPORT R-203 WELDED ATTACHMENT SUPPORT R-214	VT89784 VT89784 VT89784	
* ISOMETRIC: 0287A CC-266-2A-A-04	WELDED ATTACHMENT SUPPORT A-21	VT89762	
* ISOMETRIC: CCTK1 CC-1K-1-W1	INTEGRALLY WELDED ATTACHMENT	VT89822	
* ISOMETRIC: E-0003A CH-E-1-WS-3	UPPER RESTRAINT INTEGRAL LUG ATTACHMENT	VT89849	
* ISOMETRIC: E-0004A RH-E-1A-A-17 TO 22	UPPER LUG WELDED ATTACHMENT	VB91015	
** ASME ITEM NUMBER/EXAM CATEGORY: D02.030 D-B			
* ISOMETRIC: 0068A WR-19-3C-A-10 TO 11 WR-19-6-A-01 TO 04 JR-7-1-A-21 TO 22	WELDED ATTACHMENT SNUBBER HSS-303A&B WELDED ATTACHMENT SNUBBER HSS-301&302 WELDED ATTACHMENT SNUBBER HSS-311&312	VT89800 VT89800 VT89800	
* ISOMETRIC: 0069A WR-17-4-A-01 TO 03	WELDED ATTACHMENT SNUBBER HSS-304A,B,19	VT89769	
* ISOMETRIC: 0128A WR-20-2F-A-11	WELDED ATTACHMENT SNUBBER HSS-309	VT89770	

DUQUESNE LIGHT COMPANY
DVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
WR-20-2E-A-12	WELDED ATTACHMENT SNUBBER HSS-308	VT89770	
** ASME ITEM NUMBER/EXAM CATEGORY: D02.040 D-B			
* ISOMETRIC: 0131A CC-105-1-A-11 CC-4-1-A-12	WELDED ATTACHMENT SUPPORT SH-59A WELDED ATTACHMENT SUPPORT SH-56A	VT89791 VT89791	
* ISOMETRIC: 0131B CC-112-4C-A-02	WELDED ATTACHMENT SUPPORT VS-206	VT89612	
* ISOMETRIC: 0285A CC-113-1-A-01 CC-113-1B-A-02	WELDED ATTACHMENT SUPPORT VS-204 WELDED ATTACHMENT SUPPORT SH 205A	VT89616 VT89616	
* ISOMETRIC: 0287A CC-125-1B-A-01 CC-125-1A-A-02 CC-266-2-A-03	WELDED ATTACHMENT SUPPORT SH-204A WELDED ATTACHMENT SUPPORT VS-205 WELDED ATTACHMENT SUPPORT VS-201	VT89621 VT89787 VT89621	LIMITED EXAM DUE TO CONFIGURATION
* ISOMETRIC: 0069A WR-17-7-A-12	WELDED ATTACHMENT SNUBBER HSS-316	VT89768	
* ISOMETRIC: 0128B WR-19-12-A-17	WELDED ATTACHMENT SNUBBER HSS-310	VT89783	
** ASME ITEM NUMBER/EXAM CATEGORY: D03.020 D-C			
* ISOMETRIC: 0070A FC-B-1-A-01 FC-B-2B-A-02 TO 05	WELDED ATTACHMENT SUPPORT R-19 WELDED ATTACHMENT SUPPORT R-18	VT89760 VT89760	
** ASME ITEM NUMBER/EXAM CATEGORY: D03.030 D-C			
* ISOMETRIC: 0071A FC-5-3-A-06	WELDED ATTACHMENT SNUBBER HSS-201	VT89786	
* ISOMETRIC: 0150A FC-1-2-A-09 TO 10	WELDED ATTACHMENT SNUBBER HSS-204,205	VT89758	
** ASME ITEM NUMBER/EXAM CATEGORY: F01.010 F-A			
* ISOMETRIC: E-0001P RC-TX-1-SS-1 RC-TX-1-SS-2	SKIRT SUPPORT STRUCTURAL SUPPORT	VT89952 VT89953	

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: E-0003A CH-E-1-SUPP-3	UPPER STRUCT. RESTRAINT	VT89851	
* ISOMETRIC: E-0003F CH-FL-3-SUPP-1 CH-FL-3-SUPP-2 CH-FL-3-SUPP-3 CH-FL-3-SUPP-4	LEG SUPPORT NO. 1 LEG SUPPORT NO. 2 LEG SUPPORT NO. 3 LEG SUPPORT NO. 4	VT89978 VT89978 VT89978 VT89978	
* ISOMETRIC: E-0004A RH-E-1B-SUPP-1 RH-E-1B-SUPP-2	LOWER FOOT SUPPORT NO. 1 LOWER FOOT SUPPORT NO. 2	VT89878 VT89878	UNSAT NUTS NOT FLUSH WITH MATING SURFACE EM95073 ACCEPTED PER EM95073.
* ISOMETRIC: E-0004G RH-P-1A-SC-1 RH-P-1A-SC-2 RH-P-1A-SC-3	SUPPORT SUPPORT SUPPORT	VT89845 VT89845 VT89845	
* ISOMETRIC: CCTK1 CC-TK-1-SUPP-1	SKIRT SUPPORT	VT89823	EM95055 ACCEPTS UNSAT BOLTING SURFACES EM95055
* ISOMETRIC: E-0004A RH-E-1A-WS-3	UPPER RESTRAINT ASSEMBLY	V891016	
** ASME ITEM NUMBER/EXAM CATEGORY: F01.020 F-A			
* ISOMETRIC: E-0003A CH-E-1-SUPP-1 CH-E-1-SUPP-2	LOWER STRUCT. WELDED SUPP. LOWER STRUCT. WELDED SUPP.	VT89851 VT89851	
* ISOMETRIC: E-0003B CH-E-2-SUPP-1 CH-E-2-SUPP-2	SUPPORT 1 & STRUCTURE SUPPORT 2 & STRUCTURE	VT89847 VT89847	
** ASME ITEM NUMBER/EXAM CATEGORY: F01.030 F-A			
* ISOMETRIC: E-0001A RC-ES-1	NEUTRON SHIELD TANK/SKIRT	VT89723 VT89809	
* ISOMETRIC: E-0004A RH-E-1A-SUPP-1 RH-E-1A-SUPP-2	LOWER FOOT SUPPORT NO. 1 LOWER FOOT SUPPORT NO. 2	VT89848 VT89848	UNSAT NUTS NOT FLUSH WITH MATING SURFACE EM95058 ACCEPTED PER EM95058. UNSAT NUTS NOT FLUSH WITH MATING SURFACE

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
			V891130 REWORKED PER EM95058/MWR894450.
* ISOMETRIC: RHE2 RH-E-2A-SUPP-1	SADDLE (DUCT) SUPP.	VT89877	
** ASME ITEM NUMBER/EXAM CATEGORY: F02.030 V-B			
* ISOMETRIC: E-0001A RC-R-1-52	LOOP 1 OUTLET NOZZLE SADDLE	V891048	
RC-R-1-54	LOOP 2 OUTLET NOZZLE SADDLE	V891048	
RC-R-1-56	LOOP 3 OUTLET NOZZLE SADDLE	V891048	
** ASME ITEM NUMBER/EXAM CATEGORY: F03.010 F-C			
* ISOMETRIC: 0242A CH-1-2B-R-PS-22	SUPPORT	VT89888	
* ISOMETRIC: 0246A CH-96-6-PS-1	SUPPORT	VT89893	
CH-96-6-PS-2	SUPPORT	VT89893	
CH-96-7A-PS-3	SUPPORT	VT89893	
* ISOMETRIC: 0348B RC-71-7-A-17	SUPPORT	VT89862	
RC-71-7-R-17A	SUPPORT	VT89862	
* ISOMETRIC: 0348C RC-72-4-R-6	SUPPORT		VT89872 UNSAT THREAD ENGAGEMENT ACCEPTED PER EM95071. EM95071
* ISOMETRIC: 0348D RC-72-4B-A-7	SUPPORT		VT89861 UNSAT THREAD ENGAGEMENT REWORKED PER V891156 EM95071A/MWR893849.
RC-72-5-R-9	SUPPORT	V891003	
* ISOMETRIC: 0074A RH-1-2-R-38	SUPPORT	VT89934	
* ISOMETRIC: 0200A SI-102-2-A-PS-2	SUPPORT	VT89771	
SI-21-1B-R-73B	SUPPORT	VT89771	
* ISOMETRIC: 0200B SI-106-1C-A-PS-3	SUPPORT	VT89780	
SI-23-1-R-PS-2	SUPPORT	VT89795	

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: 0200C			
S1-134-2-R-319	SUPPORT	VT89915	
S1-134-2-R-318	SUPPORT	VT89915	
S1-134-2-R-317	SUPPORT	VT89915	
S1-134-3-R-316	SUPPORT	VT89915	
S1-130-9-R-146	SUPPORT	VT89915	
S1-130-10-R-85	SUPPORT	VT89798	
S1-130-11-R-82	SUPPORT	VT89798	
S1-102-1-R-71	SUPPORT	VT89798	
* ISOMETRIC: 0375F			
S1-73-4-R-305A	SUPPORT		VT89916 UNSAT DUE TO LOOSE LOCKNUT, PAINTED BEARING. VT89981 VT89981 VERIFIED NUT TIGHTENED(EM95089).
* ISOMETRIC: 0114A			
P12-H1-PSR-33B	SUPPORT	VT89607	
* ISOMETRIC: 0265A			
CH-79-2B-PS-10	SUPPORT	V891001	
CH-79-2D-PS-R-12	SUPPORT	V891001	
CH-79-5-VS-1	VALVE SUPPORT	V891001	
CH-79-5-PS-R-9	SUPPORT	V891001	
CH-78-2B-PS-R-6	SUPPORT	V891001	
CH-78-2D-PS-R-8	SUPPORT	V891001	
CH-78-3-VS-2	VALVE SUPPORT	V891001	
CH-78-3-PS-R-5	SUPPORT	V891001	
CH-80-1-R-44	SUPPORT	VT89908	
CH-80-1-R-45	SUPPORT	VT89908	
CH-80-1-R-46	SUPPORT	V891001	
CH-80-1-A-47	SUPPORT	V891001	
CH-80-1-R-48	SUPPORT	V891001	
CH-80-1-R-49	SUPPORT	V891001	
* ISOMETRIC: 0266A			
CH-76-1-R-40	SUPPORT	VT89907	
CH-76-1-R-41	SUPPORT	V891002	
CH-76-1-A-42	SUPPORT	V891002	
CH-76-1-R-43	SUPPORT	V891002	
* ISOMETRIC: 0267A			
CH-74-1-R-54	SUPPORT		V891000 UNSAT CRACK ON WALL-CLEARED EM95084 Q-97394. Q97394
CH-74-1-R-85	SUPPORT	V891000	
CH-75-1-R-55	SUPPORT	V891000	
CH-75-1-R-86	SUPPORT	V891000	
CH-72-2-R-35	SUPPORT	VT89909	

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
CH-72-2-R-36	SUPPORT	VT89909	
CH-72-2-R-37	SUPPORT	V891000	
CH-72-2-A-38	SUPPORT	V891000	
CH-72-2-R-39	SUPPORT	V891000	
CH-72-1-R-39A	SUPPORT	V891000	
CH-81-1-R-133	SUPPORT	V891000	
CH-81-2-R-224	VALVE SUPPORT	V891000	
CH-81-3-R-227	VALVE SUPPORT	V891000	
CH-82-2-R-58	SUPPORT	V891000	
* ISOMETRIC: 0267B			
CH-81-4-A-60	SUPPORT	VT89865	
CH-81-4-R-3-12C-2	SUPPORT	VT89865	
CH-81-4-R-3-11C-2	SUPPORT	VT89865	
CH-81-4-R-3-10C-2	SUPPORT	VT89865	
CH-81-4-R-3-9C-2	SUPPORT	VT89865	
CH-81-5B-R-2-10C-4	SUPPORT	VT89865	
CH-81-5B-R-2-12C-4	SUPPORT	VT89865	
CH-81-5B-R-2-13C-4	SUPPORT	VT89865	
CH-81-5B-R-2-15C-4	SUPPORT	VT89865	
CH-81-6-R-2-17C-4	SUPPORT	VT89865	
CH-81-6-R-2-19C-4	SUPPORT	VT89865	
CH-81-6-R-2-21C-4	SUPPORT	VT89865	
CH-81-6-R-2-23C-4	SUPPORT	VT89865	
CH-81-6-R-2-25C-4	SUPPORT	VT89865	
CH-81-7-R-2-27C-4	SUPPORT	VT89865	
CH-81-7-A-2-29C-4	SUPPORT	VT89865	
CH-81-7-R-2-31C-4	SUPPORT	VT89865	
CH-81-8A-PS-R-19	SUPPORT	VT89865	
CH-94-1-PS-R-26	VALVE SUPPORT	VT89864	INCOMPLETE THREAD ENGAGEMENT, MISSING HILT!
		EM95072	BOLT ACCEPTED PER EM95072.
CH-94-3-PS-R-27	SUPPORT	VT89865	
CH-95-1-PS-P-21	VALVE SUPPORT	VT89865	
CH-95-1-PS-R-22	SUPPORT	VT89865	
CH-93-1A-PS-SH-23	VALVE SUPPORT	VT89865	
CH-93-1A-PS-R-24	VALVE SUPPORT	VT89865	
* ISOMETRIC: 0268A			
CH-125-1-VC-174	SUPPORT	VT89863	
CH-125-2-R-73	SUPPORT	VT89863	
CH-125-2-R-74A	SUPPORT	VT89863	
CH-125-2-R-74	SUPPORT	VT89863	
CH-125-5-R-75A	SUPPORT	VT89863	
CH-125-5A-H-75	SUPPORT	VT89863	
CH-125-5A-H-3-9B-1	SUPPORT	VT89863	
CH-125-5A-H-3-10B-1	SUPPORT	VT89863	

DUQUESNE LIGHT COMPANY
EVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
CH-125-6-R-2-10A-1	SUPPORT	VT89863	
CH-125-6-R-2-12A-1	SUPPORT	VT89863	
CH-125-6-R-2-13A-1	SUPPORT	VT89875	
CH-125-6-R-2-15A-1	SUPPORT	VT89875	
CH-125-6-R-2-17A-1	SUPPORT	VT89875	
CH-125-7-VC-2-19A-1	SUPPORT	VT89875	
CH-125-7-VS-88	SUPPORT	VT89875	
CH-125-7-R-2-21A-1	SUPPORT	VT89875	
CH-125-7-R-2-22A-1	SUPPORT	VT89875	
CH-125-7-VS-89	SUPPORT	VT89875	
CH-125-7-R-2-24A-1	SUPPORT	VT89875	
CH-125-7A-VS-90	SUPPORT	VT89875	
CH-125-7A-R-2-26A-1	SUPPORT	VT89863	
CH-125-7A-VS-91	SUPPORT	VT89863	
CH-125-7A-R-2-28A-1	SUPPORT	VT89863	
CH-125-7A-H-275A	SUPPORT	VT89863	
CH-125-7A-R-2-30A-1	SUPPORT	VT89863	
CH-125-7A-R-275	SUPPORT	VT89863	
CH-125-7A-R-2-31A-1	SUPPORT	VT89863	
CH-125-7A-R-274	SUPPORT	VT89863	
CH-125-7B-R-273	SUPPORT	VT89863	
* ISOMETRIC: 0270A			
CH-85-3-PS-06	SUPPORT	VT89904	
CH-85-3-PS-05	SUPPORT	VT89904	
CH-85-4-PS-01	SUPPORT	VT89904	
CH-85-4-PS-02	SUPPORT	VT89904	
CH-85-4-PS-12	SUPPORT	VT89904	
CH-85-4-PS-13	SUPPORT	VT89904	
CH-85-5-PS-14	SUPPORT	VT89904	
CH-85-5-PS-15	SUPPORT	VT89904	
CH-85-5-PS-7A	SUPPORT	VT89904	
CH-85-6-PS-07	SUPPORT	VT89904	
CH-85-6-PS-8A	SUPPORT	VT89904	
CH-85-6-PS-08	SUPPORT	VT89904	
CH-85-6-PS-09	SUPPORT	VT89904	
CH-85-6-PS-R-17	SUPPORT	VT89904	
CH-85-6-PS-R-16	SUPPORT	VT89904	
CH-85-7-PS-R-10	SUPPORT	VT89904	
CH-85-7-PS-R-11	SUPPORT	VT89904	
* ISOMETRIC: E-0003C			
CH-E-3-SUPP-1	STRUC/CLAMP SUPP.	VT89936	
CH-E-3-SUPP-2	STRUC/CLAMP SUPP.	VT89936	

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: 0083A			
SI-7-1-VS-13	SUPPORT	VT89757	
SI-8-1-VS-14	SUPPORT	VT89757	
* ISOMETRIC: 0083B			
SI-1-6A-R-17A	SUPPORT	VT89766	
SI-1-7-R-17B	SUPPORT	VT89766	
SI-1-7-R-16	SUPPORT	VT89766	
SI-1-7-A-15	SUPPORT	VT89766	
* ISOMETRIC: 0114A			
SI-26-3-R-70	SUPPORT	VT89607	
SI-26-3-PSR-070A	SUPPORT	VT89607	UNSAT FROZEN BEARING AND LOCK NUT NOT FLUSH
		VT89879	REWORKED PER EM95075/EM95013/MWR893962.
		V891127	
* ISOMETRIC: 0115A			
SI-16-3-PSR-061B	SUPPORT	VT89610	UNSAT PAINTED BEARING REWORKED PER
		V891124	EM95012/MWR894801.
* ISOMETRIC: 0074B			
RH-1B-1-R-33	SUPPORT	VT89825	
RH-2-1-R-30	SUPPORT	VT89825	
RH-1B-2-R-31	SUPPORT	VT89825	
* ISOMETRIC: 0075A			
RH-12-2-DS-1	SUPPORT	VT89829	
RH-12-2-R-6A	SUPPORT	VT89829	
* ISOMETRIC: 0065A			
WAPD-2-A-7	SUPPORT	VT89606	
WAPD-1-A-1B	SUPPORT	VT89606	
* ISOMETRIC: 0775A			
WAPD-25-PSA013	SUPPORT	VT89608	
WAPD-25-PSA001	SUPPORT	VT89608	EM95015 ACCEPTS GAPS BETWEEN WALL AND
		EM95015	BASEPLATE.
* ISOMETRIC: 0131B			
CC-112-VS-206	SUPPORT	VT89613	
* ISOMETRIC: 0165A			
CC-24B-A-2B1A	SUPPORT	VT89817	
* ISOMETRIC: 0178A			
CC-25B-A-301	SUPPORT	VT89814	

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
CC-265-A-333	SUPPORT	VT89814	
* ISOMETRIC: 0179A			
CC-114-R-182	SUPPORT	V891010	
CC-114-R-180	SUPPORT	V891010	
CC-118-R-181	SUPPORT	V891010	
CC-118-R-179	SUPPORT	V891010	
* ISOMETRIC: 0184A			
CC-258-R-269B	SUPPORT	VT89796	
CC-258-A-269	SUPPORT	VT89779	
CC-258-R-270	SUPPORT	VT89779	
* ISOMETRIC: 0185A			
CC-265-R-274-B	SUPPORT	VT89797	
CC-265-A-273	SUPPORT	VT89773	
CC-265-R-274	SUPPORT	VT89773	
* ISOMETRIC: 0186A			
CC-263-A-262	SUPPORT	VT89778	
CC-263-R-263	SUPPORT	VT89778	
* ISOMETRIC: 0187A			
CC-261-A-276	SUPPORT	VT89781	
* ISOMETRIC: 0188A			
CC-262-A-264	SUPPORT	VT89775	
* ISOMETRIC: 0189A			
CC-257-A-272	SUPPORT	VT89801	
* ISOMETRIC: 0284A			
CC-112-R-208	SUPPORT	VT89615	
* ISOMETRIC: 0285A			
CC-113-VS-204	SUPPORT	VT89617	
* ISOMETRIC: 0286A			
CC-518-R-216	SUPPORT	VT89785	
CC-526-R-214	SUPPORT	VT89785	
* ISOMETRIC: 0287A			
CC-125-VS-205	SUPPORT	VT89761	
CC-266-VS-201	SUPPORT	VT89623	
CC-125-A-21	SUPPORT	VT89761	EM95022 ACCEPTS UNSAT THREAD ENGAGEMENT EM95022

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: 0070A FC-B-R-19 FC-B-R-18	SUPPORT SUPPORT	VT89759 VT89759	UNSAT BOLTING ACCEPTED PER EM95023 EM95023
** ASME ITEM NUMBER/EXAM CATEGORY: F03.020 F-C			
* ISOMETRIC: 0243A CH-140-B-PS-5	SUPPORT	VT89955	
* ISOMETRIC: 0350B RC-N-36	VALVE SUPPORT	VT89846	
* ISOMETRIC: 0200A S1-102-1-R-PS-1	SUPPORT	VT89794	
* ISOMETRIC: 0200B S1-23-1-R-PS-5 S1-23-2-R-PS-4 S1-23-2-R-PS-3 S1-23-2B-R-PS-1	SUPPORT SUPPORT SUPPORT SUPPORT	VT89795 VT89795 VT89795 VT89795	
* ISOMETRIC: 0375C S1-74-5-R-329 S1-74-5-R-330 S1-74-5-R-331	SUPPORT SUPPORT SUPPORT	VT89743 VT89743 VT89743	
* ISOMETRIC: 0375E S1-72-4-R-312A S1-72-6-R-320 S1-72-7-R-321	SUPPORT SUPPORT SUPPORT	 VT89890 VT89853	UNSAT PAINTED BEARINGS ACCEPTED PER EM95083 EM95083
* ISOMETRIC: 0115A S1-40-1-A-37	SUPPORT	VT89835	
* ISOMETRIC: 0065A WAPD-2-RH-5 WAPD-1-RH-20	SUPPORT SUPPORT	VT89606 VT89606	
* ISOMETRIC: 0165A CC-24B-A-18B-1	SUPPORT	VT89817	
* ISOMETRIC: 0175A CC-261-A-10B-4 CC-261-A-42B-1	SUPPORT SUPPORT	VT89812 VT89812	

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
CC-257-A-188-3	SUPPORT	VT89812	
CC-257-A-268-3	SUPPORT	VT89812	
* ISOMETRIC: 0178A			
CC-258-R-23C-2	SUPPORT	VT89814	
CC-265-A-40C-1	SUPPORT	VT89814	
* ISOMETRIC: 0284A			
CC-510-R-237	SUPPORT	VT89615	
* ISOMETRIC: 0286A			
CC-266-R-203	SUPPORT	VT89785	
** ASME ITEM NUMBER/EXAM CATEGORY: F03.030 F-C			
* ISOMETRIC: 0196A			
CH-96-1-PS-2	SUPPORT	VT89828	
CH-96-2-PS-1	SUPPORT	VT89828	
CH-96-3-R-PS-3	SUPPORT	VT89828	
CH-96-3-R-PS-4	SUPPORT	VT89828	
CH-96-3-R-PS-5	SUPPORT	VT89828	
CH-96-3-R-PS-6	SUPPORT	VT89828	
CH-96-3A-R-PS-7	SUPPORT	VT89828	
CH-96-3A-R-PS-8	SUPPORT	VT89828	
CH-96-4-PS-9	SUPPORT	VT89828	
CH-96-4-R-PS-10	SUPPORT	VT89828	
CH-96-4-R-PS-11	SUPPORT	VT89828	
CH-96-4A-R-PS-12	SUPPORT	VT89828	
CH-96-4A-R-PS-13	SUPPORT	VT89828	
CH-96-4A-R-PS-14	SUPPORT	VT89828	
CH-96-5-R-PS-15	SUPPORT	VT89828	
* ISOMETRIC: 0242A			
CH-1-3-PS-21	SUPPORT	VT89888	
* ISOMETRIC: 0243A			
CH-140-6-PS-1	SUPPORT	VT89929	
CH-140-6-PS-4	SUPPORT	VT89929	
CH-140-6-PS-2	SUPPORT	VT89929	
CH-140-6-PS-3	SUPPORT	VT89929	
* ISOMETRIC: 0348D			
RC-72-6-R-11	SUPPORT	VT89837	
* ISOMETRIC: 0108B			
RH-24-1A-A-42	SUPPORT	VT89774	

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: 0375C SI-74-5-DS-2	SUPPORT	VT89743	
* ISOMETRIC: 0375E SI-72-7-DS-1	SUPPORT	VT89853	
SI-72-7-R-322	SUPPORT	VT89853	
SI-72-7-R-323	SUPPORT	VT89853	
* ISOMETRIC: 0265A CH-77-2B-PS-R-2	SUPPORT	VT89598	
CH-77-3-VS-3	VALVE SUPPORT	VT89598	
CH-77-3-PS-R-1	SUPPORT	VT89598	
CH-80-2-R-50	SUPPORT	V891001	
CH-80-2-VS-50A	SUPPORT	V891001	
CH-80-2-R-51	SUPPORT	V891001	
CH-80-3-R-51A	SUPPORT	V891001	
* ISOMETRIC: 0266A CH-82-1-PS-R-2	SUPPORT	V891002	
CH-82-1-PS-A-1	SUPPORT	V891002	
* ISOMETRIC: 0267A CH-73-1-R-53	SUPPORT	VT89598	
CH-73-1-R-84	SUPPORT	VT89598	
CH-72-1-R-39B	SUPPORT	V891000	
* ISOMETRIC: 0065A WAPD-2-R-6	SUPPORT	VT89606	
WAPD-1-R-19	SUPPORT	VT89606	
* ISOMETRIC: 0164A CC-116-R-27C-2	SUPPORT	VT89821	
CC-116-R-18C-3	SUPPORT	VT89821	
* ISOMETRIC: 0179A CC-114-R-17D-3	SUPPORT	VT89819	
CC-114-R-10D-6	SUPPORT	VT89819	
CC-114-R-40D-1	SUPPORT	VT89819	
CC-118-R-26D-3	SUPPORT	VT89819	
** ASME ITEM NUMBER/EXAM CATEGORY: F03.050 F-C			
* ISOMETRIC: 0999A DLW-LOOP1-9-SH-3	SUPPORT	VT89850	

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: 0999B DLW-LOOP2-9-SH-4	SUPPORT	VT89852	
* ISOMETRIC: 0999D DLW-PRESS-1-SH-1	SUPPORT	VT89882	
* ISOMETRIC: 0074A RH-1-1-SH-40	SUPPORT	VT89891	
RH-1-2-SH-39	SUPPORT	VT89933	LOOSE BOLTING REWORKED PER EM95096/MWR893846
RH-1-3-SH-36	SUPPORT	V891038 VT89933	
* ISOMETRIC: 0107A RH-23-1-SH-11F	VALVE SUPPORT	VT89959	
* ISOMETRIC: 0108B RH-24-1-SH-42A	SUPPORT	VT89799	
* ISOMETRIC: 0267A CH-81-3-SH-233	SUPPORT	V891000	
* ISOMETRIC: 0267B CH-81-7-SH-2-241-4	SUPPORT	VT89866	
CH-88-2A-PS-SH-25	SUPPORT	VT89866	
CH-89-2-PS-SH-20	SUPPORT	VT89866	
* ISOMETRIC: 0002A SHP-56-10-SH-10	SUPPORT	VT89765	UNSAT REWORKED EM95103/MWR893829 (EXPAND TO VT89945 SH-11/VT89824 SAT, SH-138/VT891023 UNSAT AA1 V891153 EM95115)
* ISOMETRIC: 0002B SHP-57-5-SH-15	SUPPORT	VT89764	NO LOAD PLATE REWORKED PER EM95103/MWR893830. VT89944 EXPANDED TO SH-16 ON VT89824. V891096
* ISOMETRIC: 0002C SHP-58-5-SH-20	SUPPORT	VT89763	
* ISOMETRIC: 0074B RH-18-1-SH-34	SUPPORT	VT89826	UNSAT LOAD SETTING ACCEPTED PER EM95047 EM95047
RH-18-1-SH-32	SUPPORT	VT89826	UNSAT LOCKNUT REWORKED PER EM95046/MWR893828 V89962

APPENDIX I - CODE EXAMS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: 0075A RH-9-1-SH-25	SUPPORT	VT89827	EM95057 ACCEPTS UNSAT SETTING EM95057
RH-12-2-SH-6	SUPPORT	V891012	
RH-12-3-SH-5A	SUPPORT	V891012	
* ISOMETRIC: 0131A CC-105-SH-59A	SUPPORT	VT89788	
CC-4-SH-56A	SUPPORT	VT89788	
* ISOMETRIC: 0285A CC-113-SH-205A	SUPPORT	VT89618	EM95011 ACCEPTS UNSAT SETTING EM95011
* ISOMETRIC: 0287A CC-125-SH-204A	SUPPORT	VT89611	INADEQUATE THREAD ENGAGEMENT REWORKED PER V891032 EM95010/MWR893961. V891122

APPENDIX II

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
** ASME ITEM NUMBER/EXAM CATEGORY:			
* ISOMETRIC: PZR SURGE	PRESSURIZER SURGE LINE	VT89833 VT89858	VT89-833 PRE-INSUL REM'L (INFO ONLY) PER NDE REQ# 150.
* ISOMETRIC: 0074A RH-74A-FIT1	FITTING	UT89334 PT89255	
RH-74A-FIT2	FITTING	UT89335 PT89262	
RH-74A-FIT3	FITTING	UT89344 PT89262	
RH-74A-FIT4	FITTING	UT89345 PT89262	
* ISOMETRIC: 0220C SI-220C-FIT5	FITTING	UT89351 PT89268	SAT PT INDICATION
SI-220C-FIT6	FITTING	UT89350 PT89268	
* ISOMETRIC: 0222B SI-222B-FIT7	FITTING	UT89316 PT89234	
SI-222B-FIT8	FITTING	UT89315 PT89234	
* ISOMETRIC: 0223B SI-223B-FIT9	FITTING	UT89263 PT89211	
SI-223B-FIT10	FITTING	UT89264 PT89211	
* ISOMETRIC: 0243A RC-243A-FIT11	FITTING	PT89246	
* ISOMETRIC: 0244A RC-244A-FIT12	FITTING	PT89259	2 UNSAT PT INDICATIONS REWORKED PER PT89294 EM95097/MWR893845.
* ISOMETRIC: 0245A RC-245A-FIT13	FITTING	PT89208	
* ISOMETRIC: 0254A RC-254A-FIT14	FITTING	PT89226	

APPENDIX II - IE BULLETINS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
* ISOMETRIC: 0375C SI-375C-FIT15	FITTING	UT89265 PT89212	
* ISOMETRIC: 0375E SI-375E-FIT16	FITTING	UT89309 PT89232	
* ISOMETRIC: 0375F SI-375F-FIT17	FITTING	UT89352 PT89271	
** ASME ITEM NUMBER/EXAM CATEGORY: 809.011 B-J			
* ISOMETRIC: 0074A RH-1-1-F-01	BUTT WELD	UT89332 PT89254	
RH-1-1-S-04	BUTT WELD	UT89333 PT89254	
RH-1-1-S-03	BUTT WELD	UT89338 PT89261	
RH-1-1-S-02	BUTT WELD	UT89337 PT89261	
RH-1-1-S-01	BUTT WELD	UT89336 PT89261	
RH-1-2-S-01	BUTT WELD	UT89342 PT89261	
* ISOMETRIC: 0220C SI-29-9-S-01	BUTT WELD	UT89353 PT89269	
SI-29-9-S-02	BUTT WELD	UT89354 PT89269	
SI-29-9-S-03	BUTT WELD	UT89355 PT89269	
SI-29-9-F-11	BUTT WELD	UT89357 PT89269	
* ISOMETRIC: 0222B SI-20-11-S-04	BUTT WELD	UT89314 PT89233	
SI-20-11-S-03	BUTT WELD	UT89313 PT89233	
SI-20-11-S-02	BUTT WELD	UT89312 PT89233	
SI-20-11-S-01	BUTT WELD	UT89311	

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
			PT89233
* ISOMETRIC: 0223B S1-30-5-S-01	BUTT WELD	UT89260 PT89210	
S1-30-5-S-02	BUTT WELD	UT89262 PT89210	
S1-30-5-S-03	BUTT WELD	UT89261 PT89210	
S1-30-5-F-0B	BUTT WELD	UT89259 PT89210	
** ASME ITEM NUMBER/EXAM CATEGORY: B09.040 B-J			
* ISOMETRIC: 0243A RC-44-1-S-02 RC-44-1-S-01	SOCKET WELD SOCKET WELD	PT89248 PT89248	
* ISOMETRIC: 0244A RC-54-1-S-02 RC-54-1-F-4A	SOCKET WELD SOCKET WELD	PT89258 PT89258	
* ISOMETRIC: 0245A RC-64-1-S-02 RC-64-1-S-01	SOCKET WELD SOCKET WELD	PT89209 PT89209	
* ISOMETRIC: 0254A RC-72-5-F-0B RC-72-5-S-10	SOCKET WELD SOCKET WELD	PT89225 PT89225	

APPENDIX III

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
** ASME ITEM NUMBER/EXAM CATEGORY: B07.030 B-G-2			
* ISOMETRIC: E-0001M			
RC-E-1A-AH-1	BOLTING	VT89630	
RC-E-1A-AH-2	BOLTING	VT89630	
RC-E-1A-AH-3	BOLTING	VT89630	
RC-E-1A-AH-4	BOLTING	VT89630	
RC-E-1A-AH-5	BOLTING	VT89630	
RC-E-1A-AH-6	BOLTING	VT89630	
RC-E-1A-AH-7	BOLTING	VT89630	
RC-E-1A-AH-8	BOLTING	VT89630	
RC-E-1A-AH-9	BOLTING	VT89630	
RC-E-1A-AH-10	BOLTING	VT89630	
RC-E-1A-AH-11	BOLTING	VT89630	
RC-E-1A-AH-12	BOLTING	VT89630	
RC-E-1A-AH-13	BOLTING	VT89630	
RC-E-1A-AH-14	BOLTING	VT89630	
RC-E-1A-AH-15	BOLTING	VT89630	
RC-E-1A-AH-16	BOLTING	VT89630	
RC-E-1A-AC-1	BOLTING	VT89631	
RC-E-1A-AC-2	BOLTING	VT89631	
RC-E-1A-AC-3	BOLTING	VT89631	
RC-E-1A-AC-4	BOLTING	VT89631	
RC-E-1A-AC-5	BOLTING	VT89631	
RC-E-1A-AC-6	BOLTING	VT89631	
RC-E-1A-AC-7	BOLTING	VT89631	
RC-E-1A-AC-8	BOLTING	VT89631	
RC-E-1A-AC-9	BOLTING	VT89631	
RC-E-1A-AC-10	BOLTING	VT89631	
RC-E-1A-AC-11	BOLTING	VT89631	
RC-E-1A-AC-12	BOLTING	VT89631	
RC-E-1A-AC-13	BOLTING	VT89631	
RC-E-1A-AC-14	BOLTING	VT89631	
RC-E-1A-AC-15	BOLTING	VT89631	
RC-E-1A-AC-16	BOLTING	VT89631	
RC-E-1B-BH-1	BOLTING	VT89630	
RC-E-1B-BH-2	BOLTING	VT89630	
RC-E-1B-BH-3	BOLTING	VT89630	
RC-E-1B-BH-4	BOLTING	VT89630	
RC-E-1B-BH-5	BOLTING	VT89630	
RC-E-1B-BH-6	BOLTING	VT89630	
RC-E-1B-BH-7	BOLTING	VT89630	
RC-E-1B-BH-8	BOLTING	VT89630	
RC-E-1B-BH-9	BOLTING	VT89630	
RC-E-1B-BH-10	BOLTING	VT89630	
RC-E-1B-BH-11	BOLTING	VT89630	

APPENDIX III - IE BULLETINS

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
RC-E-1B-BH-12	BOLTING	VT89630	
RC-E-1B-BH-13	BOLTING	VT89630	
RC-E-1B-BH-14	BOLTING	VT89630	
RC-E-1B-BH-15	BOLTING	VT89630	
RC-E-1B-CH-16	BOLTING	VT89630	
RC-E-1B-BC-1	BOLTING	VT89630	
RC-E-1B-BC-2	BOLTING	VT89630	
RC-E-1B-BC-3	BOLTING	VT89630	
RC-E-1B-BC-4	BOLTING	VT89630	
RC-E-1B-BC-5	BOLTING	VT89630	
RC-E-1B-BC-6	BOLTING	VT89630	
RC-E-1B-BC-7	BOLTING	VT89630	
RC-E-1B-BC-8	BOLTING	VT89630	
RC-E-1B-BC-9	BOLTING	VT89630	
RC-E-1B-BC-10	BOLTING	VT89630	
RC-E-1B-BC-11	BOLTING	VT89630	
RC-E-1B-BC-12	BOLTING	VT89630	
RC-E-1B-BC-13	BOLTING	VT89630	
RC-E-1B-BC-14	BOLTING	VT89630	
RC-E-1B-BC-15	BOLTING	VT89630	
RC-E-1B-BC-16	BOLTING	VT89630	
RC-E-1C-CH-1	BOLTING	VT89631	
RC-E-1C-CH-2	BOLTING	VT89631	
RC-E-1C-CH-3	BOLTING	VT89631	
RC-E-1C-CH-4	BOLTING	VT89631	
RC-E-1C-CH-5	BOLTING	VT89631	
RC-E-1C-CH-6	BOLTING	VT89631	
RC-E-1C-CH-7	BOLTING	VT89631	
RC-E-1C-CH-8	BOLTING	VT89631	
RC-E-1C-CH-9	BOLTING	VT89631	
RC-E-1C-CH-10	BOLTING	VT89631	
RC-E-1C-CH-11	BOLTING	VT89631	
RC-E-1C-CH-12	BOLTING	VT89631	
RC-E-1C-CH-13	BOLTING	VT89631	
RC-E-1C-CH-14	BOLTING	VT89631	
RC-E-1C-CH-15	BOLTING	VT89631	
RC-E-1C-CH-16	BOLTING	VT89631	
RC-E-1C-CC-1	BOLTING	VT89631	
RC-E-1C-CC-2	BOLTING	VT89631	
RC-E-1C-CC-3	BOLTING	VT89631	
RC-E-1C-CC-4	BOLTING	VT89631	
RC-E-1C-CC-5	BOLTING	VT89631	
RC-E-1C-CC-6	BOLTING	VT89631	
RC-E-1C-CC-7	BOLTING	VT89631	
RC-E-1C-CC-8	BOLTING	VT89631	
		VT89841	EM95014 ACCEPTS UNSAT THREAD DAMAGE
			EM95014

DUQUESNE LIGHT COMPANY
BVPS UNIT 1 1989 OUTAGE
NINETY DAY REPORT

COMPONENT IDENTIFICATION *****	COMPONENT DESCRIPTION *****	NDE REPORT NUMBER *****	OUTAGE REMARKS *****
RC-E-1C-CC-9	BOLTING	VT89631	
RC-E-1C-CC-10	BOLTING	VT89631	
RC-E-1C-CC-11	BOLTING	VT89631	
RC-E-1C-CC-12	BOLTING	VT89631	
RC-E-1C-CC-13	BOLTING	VT89631	
RC-E-1C-CC-14	BOLTING	VT89631	
RC-E-1C-CC-15	BOLTING	VT89631	
RC-E-1C-CC-16	BOLTING	VT89631	
** ASME ITEM NUMBER/EXAM CATEGORY: B07.080 B-G-2			
* ISOMETRIC: E-0001J			
CONOSEAL BOLT ASSEMBLY 47	BOLTS AND NUTS	VT89963	
CONOSEAL BOLT ASSEMBLY 49	BOLTS AND NUTS	VT89963	
CONOSEAL BOLT ASSEMBLY 51	BOLTS AND NUTS	VT89963	
CONOSEAL BOLT ASSEMBLY 53	BOLTS AND NUTS	VT89963	
** ASME ITEM NUMBER/EXAM CATEGORY: C05.051 C-F-2			
* ISOMETRIC: 0062A			
WFPD-24-7C-F-01A	PIPE WELD	UT89393	BASELINE EXAMS OF MWR894035
		MT89125	
		RT89032	
WFPD-24-7C-F-02A	PIPE WELD	UT89395	BASELINE EXAMS OF MWR894035
		MT89125	
		RT89033	
** ASME ITEM NUMBER/EXAM CATEGORY: F03.050 F-C			
* ISOMETRIC: 0999D			
DLW-PRESS-1-SH-2	SUPPORT	VT89882	UNSAT LOOSE LOCK NUT. SUPP'T REPLCD PER DCP OT-0417 1431. NEW SUPP'T INSPCTD PER MIR OT-0417.

APPENDIX IV

APPENDIX IV
UNSAT SUMMARY
UNIT 17R

COMPONENT -----	REJECTING REPORT -----	EM NUMBER MWR NUMBER -----	DESCRIPTION -----	CLOSING DOC'MT -----
CC-125-SH-204A	VT89611	95010-A 893961	CORRODED BOLT, LOOSE NUT	VT891032
CC-113-SH-205A	VT89618	95011-A	OUT OF TOLERANCE SETTING	EM95011
SI-16-3-PSR-061B	VT89610	95012-A 894801	STRUT FROZEN(PAINTED BEAR'G), SPACER NEEDED	VT891124
SI-26-3-PSR-070A	VT89607	95013-A 893962	LUBE BEARING, LOOSE NUT	VT891127
BCC-C (NUT)	VT89619	95014-A	DAMAGED THREAD	VT89841
SA-193-B7-C170 (STUD)	VT89622	95014-A	GALLED THREAD	VT89842
WAPD-25-PSA-001	VT89608	95015-A	GAPS BETW WALL & BASE PLATE	EM95015
SI-133-6A-S-04	PT89193	95016-A 893434	LINEAR	PT89272
ARC STRIKE	PT89196	95017-A 892214	ARC STRIKE NEAR SI-18-1-S-05	PT89274
SI-26-3-PSR-070B	VT89745	95021-A	PAINTED BEARING	EM95021
P11-J-PSR-36B	VT89756	95021-A	PAINTED BEARING	EM95021
SI-16-3-PSR-062C	VT89767	95021-A	PAINTED BEARING	EM95021
FC-8-R-1B	VT89759	95023-A	BOLTING COCKED, NOT FLUSHED	EM95023
CC-125-A-21	VT89761	95022-A	LACK OF THREAD ENGAGEMENT	EM95022
SHP-57-5-SH-15	VT89764	95024-A 893830	SETTING OUT OF TOLERANCE	EM95103
SHP-56-10-SH-10	VT89765	95024-A 893829	SETTING OUT OF TOLERANCE	EM95103
P11-J-R-36	VT89818	95044-A 893834	SPALLING CHIPPING OF BASEPLATE	VT891125
CC-66-A-77	VT89831	95045-A	LACK OF THREAD ENGAGEMENT	EM98045
RH-18-1-SH-32	VT89826	95046-A 893828	LOOSE NUT	VT89962
RH-18-1-SH-34	VT89826	95047-A	OUT-OF-TOLERANCE SETTING	EM95047
CC-TK-A-SUPP-1	VT89823	95055-A	BOLTING NOT FLUSH	EM95055
RH-9-1-SH-25	VT89827	95057-A	SPRING CAN SETTING?	EM95057
BCC-C (NUT)	VT89841	95014-A	MANUFACTURING DEFECT	EM95014
SA-193-B7-C170 (STUD)	VT89842	95014-A	MANUFACTURING DEFECT	EM95014
RH-E-1A-SUPP-1,-2	VT89848	95058-A 894450	LOOSE NUTS, BORIC ACID	VT891130
1" SI-54 U-BOLT	VT89868	95069-A 893838	LOOSE NUT	VT891043
RC-72-4B-A-7	VT89861	95071-A 893849	LACK OF THREAD ENGAGEMENT	VT891156
RC-72-4-R-6	VT89872	95071-A	LACK OF THREAD ENGAGEMENT	EM95071
CH-94-1-PS-R-26	VT89864	95072-A	LACK OF THREAD ENGAGEMENT, HILT! BOLT MISSING	EM95072
RH-E-1B-SUPP-2	VT89878	95073-A	NUTS NOT FLUSH	EM95073
CH-E-2-REST	VT89869	95074-A	LACK OF THREAD ENGAGEMENT	EM95074
SI-26-3-PSR-70A	VT89879	95075-A 894803	LOOSE NUT, WASHERS IMPROPERLY INSTALLED	VT891127
RC-P-1C FLYWHEEL	PT89228	95068-A 893831	LINEAR INDICATIONS	PT89275

UNSAT SUMMARY
UNIT 1 7R

COMPONENT -----	REJECTING REPORT -----	EM NUMBER MWR NUMBER -----	DESCRIPTION -----	CLOSING DOC#MT -----
WFPD-22-BF-F-02	MT89065	95079-A 893835	LINEAR INDICATIONS	MT89081
DLW-PRESS-1-SH-2	VT89882	95080-A 893836	LOOSE LOCK NUT. SH-2 REPL'D PER DCP1431.	MIRMOT0417
1S1-51-B-16	VT89885	95082-A	LACK OF THREAD ENGAGEMENT	EM95082
1S1-23-B-4,-8	VT89890	95082-A	LACK OF THREAD ENGAGEMENT	EM95082
S1-74-4-R-312A	VT89892	95083-A	NO MOVEMENT, PAINTED BEARINGS	EM95021
CH-74-1-R-54	VT891000	95084-A 893658	CRACK IN WALL	Q-97394
PCV-RC-455A-BOLTS	VT891004	95085-A 893842 UT89331	LOOSE NUTS	EM65008
DG-56-3-S-01	PT89243	95087-A 893839	LINEAR INDICATIONS	PT89286
DG-54-3-F04	PT89243	95087-A 893840	LINEAR INDICATIONS	PT89286
RC-104-1-SH-43	VT89912	95088-A	SETTING MEASUREMENTS?	EM95088
S1-73-4-R-305A	VT89916	95089-A 893837	LOOSE NUT	VT89981
MOV-RC-536-B-4,-5	VT89918	95090-A 893843	DEFORMED THREADS	VT89979
RH-1-2-SH-39	VT89933	95096-A 893846	LOOSE NUTS	VT891038
RC-244A-FIT-12	PT89259	95097-A 893845	TWO INDICATIONS	PT89294
CH-141-2-F-03	PT89258	95098-A 893844 WP89155	BASE METAL INDICATION	PT89295
SHP-56-10-SH-10	VT89945	95103-A 893829	AWAITING EM ON SETTING MEASUREMENTS	VT891153
SHP-57-5-SH-15	VT89944	95103-A 893830	AWAITING EM SETTING MEASUREMENTS	VT891096
CH ARC STRIKES	VT89946	95107-A 893847,-48	NEAR WELDS CH-23-3-S-03 AND CH-23-4-F-06 (VT891040)	VT891039
WFPD-24-7C-F-01	UT89369	95110-A	UT INDICATIONS	EM95110
RH-B-1-SH-15	VT891014	95112-A	SETTING ACCEPTABILITY?	EM95112
RH-B-1-SH-17	VT891014	95112-A	SETTING ACCEPTABILITY?	EM95112
RH-B-1-SH-13	VT891022	95114-A 893850	LOOSE LOCK NUT	VT891099
SHP-25-SH-138	VT891023	95115-A	SETTING?	EM95115
RH-12-3-R-5	VT891031	95116-A 894500	MISSING/LOOSE NUTS	VT891098
RH-12-5-R-3	VT891031	95116-A 894802	LOOSE NUT	VT891098
S1-TK-2-WS-4	PT89300	95121-A	LINEAR INDICATION	EM95121
RH-12-4-SH-4A	VT891013	NA	LOOSE LOCK NUT	VT891013
WFPD ARC STRIKES	VT891101	95123-A 894817,18,19	NEAR ATT WELDS	MT89149,61
WFPD-24-5-A-6	MT89150	95129-A 894829	LINEAR INDICATION	MT89161

APPENDIX V

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 1/22/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 893724
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by DlCo - Maint. Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address

4. Identification of System Main Steam

5. (a) Applicable Construction Code ANSI B16.34 10 73 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 10 B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No. (Model)	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MS-18	Crane Valve	175-1/2XR	N/A	3 inch Check Valve	1973	Repaired	No
Disc	Crane Valve	D847	N/A	—	1989	Replaced	No

7. Description of Work Overhauled valve, replaced valve internals.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks: Disc material is A217 GR CA15 and was built to ANSI B16.34 - 1988
Applicable Manufacturer's Data Reports to be obtained
Reference CDER MM 0695

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed David M. Hull Date 2/8/90 19 90
Owner or Owner's Designee

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 1/5/90 to 2/8/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

Michael R. Hull Commission NO 8741 PA 2246
Inspector's Signature National Board, State, Province, and Endorsements

Date 2/8 1990

FORM NB-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 1/22/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address
 2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 893725
Address Repair Organization P.O. No., Job No., etc.
 3. Work Performed by DLCO - Maint. Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address

4. Identification of System Main Steam
 5. (a) Applicable Construction Code ANSI B16.34 19 73 Edition, Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No. (Model)	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MS-19	Crane Valve	175-1/2XR	N/A	3 inch Check Valve	1973	Repaired	No
Disc	Crane Valve	D847	N/A	_____	1989	Replaced	No

7. Description of Work Overhauled valve, Replaced valve internals.
 8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of logs, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks: Disc material is A217 CR CA15 and was built to ANSI B16.34 - 1988.
Reference CDER MM 0694
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed David M. Hoff Date 2/8 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/5/89 to 2/4/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

Mark R. Smith Commission LB 8881 PA 2116
Inspector's Signature National Board, State, Province, and Endorsements

Date 2/8 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 1/22/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077
Address
MWR 883130
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Maint. Dept. Type Code Symbol Stamp Not Applicable
Name
Shippingport, PA 15077
Address
Authorization No. _____
Expiration Date _____

4. Identification of System Main Steam

5. (a) Applicable Construction Code ANSI B16.34 19 73 Edition, _____ Addenda _____ Code Case _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No. (Model)	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamp (Yes or No)
MS-80	Crane Valve	175-1/2XR	N/A	3 inch Check Valve	1973	Repaired	No
Disc	Crane Valve	D847	N/A	_____	1989	Replaced	No

7. Description of Work Overhauled valve, replaced valve internals.

8. Tests Conducted: Hydraulic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of the form.

FORM NIS-2 (Back)

9. Remarks: Disc material is A217 GR CA15 and was built to ANSI B16.34 - 1988

Reference CDER MM 692 Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code By Initial Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed Daniel M. Hall Date 2/8 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Walham, Massachusetts

have inspected the components described in this Owner's Report during the period 10/5/84 to 2/8/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commissions NA 8491 PA 7266
Inspector's Signature National Board, State, Province, and Endorsements

Date 2/8 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 1/22/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address
2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077
Address MWR 893780
Repair Organization P.O. No., Job No., etc.
3. Work Performed by DLC - Maint. Dept. Type Code Symbol Stamp Not Applicable
Name
Shippingport, PA 15077
Address Authorization No. "
 Expiration Date "
4. Identification of System Ch. 36 4KV Station Services Sys. - Diesel Gen. Air Start Sys.
5. (a) Applicable Construction Code ANSI B31.1 19 67 Edition, S'71 Addenda _____ Code Case _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B3E-S'83A
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
DA-109 Valve	Smith Valve Co.	F12 SR	N/A	1 1/2" Ball Valve	---	Replaced	No
DA-109 Valve	Smith Valve Co.	8409024	N/A	1 1/2" Ball Valve	---	Replacement	No

7. Description of Work Replacement of existing valve with new (Threaded ends).
8. Tests Conducted: Hydraulic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks: No NPV-1 form.

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed David M. Hill Date 2/8 10 96
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 2/4/96 to 2/8/96 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Factory Mutual Systems

Mark R. Smith Commission No. 4B 8771 PA 2206
Inspector's Signature National Board, State, Province, and Dependencies

Date 2/8 10 96

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 1/22/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address
2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077
Address MWR 890280
Repair Organization P.O. No., Job No., etc.
3. Work Performed by DLCo - Maint. Dept. Type Code Symbol Stamp Not Applicable
Name
Shippingport, PA 15077
Address Authorization No. *
 Expiration Date *
4. Identification of System Auxiliary Feedwater
5. (a) Applicable Construction Code ANSI B31.1 19 67 Edition, S'71 Addenda ----- Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
FW-39	Crane Valve	-----	N/A	6 inch gate valve	N/A	Repaired	No
Gate	Crane Valve	-----	N/A	-----	N/A	Repaired	No

7. Description of Work Machined .010 inches from the seating are of the valve's gate to remove slight indication
8. Tests Conducted: Hydraulic Pneumatic Nominal Operating Pressure
 Other Pressure ----- psi Test Temp. ----- °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks No NPV-1 form.

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed David M. Wolf Date 2/8/90 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 1/27/90 to 2/8/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

John R. Smith Commissions LA 8771 PA 2266
 Inspector's Signature National Board, State, Province, and Endorsements

Date 2/8/90 19 90

FORM NB-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 1/22/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address
2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077
Address MWR 882224
Repair Organization P.O. No., Job No., etc.
3. Work Performed by DLCo - Maint. Dept. Type Code Symbol Stamp Not Applicable
Name
Shippingport, PA 15077
Address Authorization for: _____
 Expiration Date: _____
4. Identification of System Reactor Coolant
5. (a) Applicable Construction Code ANSI B31.1 10 67 Edition 5'71 Addenda _____ Code Class _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 10, B3E-S'83A
6. Identification of Components Required or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Required, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PCV-RC-455D	Masonelian	H-20693 -5-4	N/A	3 inch globe valve	N/A	Repaired	No
Plug	Masonelian	None	N/A	_____	N/A	Repaired	No

7. Description of Work Machined .005 inches off of plug and seat ring seating areas to remove slight indications.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Valve trim was manufactured to ANSI B16.5-68.

No NPV-1 form.

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed Daniel McCall Date 2/8/90 19 90
Owner or Owner's Designee, etc.

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Walther, Massachusetts have inspected the components described in this Owner's Report during the period 9/2/88 to 2/8/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

Mark R. Smith Commissions 20244 PA2206
Inspector's Signature National Board, State, Province, and Exemptions

Date 4/7 19 90

FORM NB-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/7/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address
2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077
Address MWR #893299
Repair Organization P.O. No., Job No., etc.
3. Work Performed by DLCo - Maintenance Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No. _____
Shippingport, PA 15077 Expiration Date _____
Address
4. Identification of System Main Steam
5. (a) Applicable Construction Code B16.34 19 73 Edition, _____ Address _____ Code Case _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B3E-S'83A
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamp (Yes or No)
MS-82	Crane Valve	175 1/2 XR	N/A	3" Check Valve	1973	Repaired	No
Disc	Crane Valve	D847	N/A	_____	1989	Replacement	No

7. Description of Work Overhauled valve, replaced valve internals.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ ps Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9 Remarks No NPV-1 form. Disc manufactured to ANSI B16.34: 1988E.

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed Daniel M. Hall Senior Eng. Date Feb 15 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts

have inspected the components described in this Owner's Report during the period 1/5/90 to 2/15/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commissions MASS PA 4166
Inspector's Signature National Board, State, Province, and Endorsements

Date 2/15 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/7/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

2. Plant Beaver Valley Power Station Sheet 1 of 2
Name
Shippingport, PA 15077
Address Unit No. 1
MWR #843176
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Maintenance Dept. Type Code Symbol Stamp Not Applicable
Name
Shippingport, PA 15077
Address Authorization No. "
Expiration Date "

4. Identification of System Main Steam

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda, " Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
HCV-MS-104	Masonellan	H-49378-264	N/A	4" Globe Valve	1974	Repaired	No
Plug	Masonellan	475000-RH3-1A2	N/A		1989	Replacement	No

7. Description of Work Replaced valve trim (internals), weld build-up cage seating surface.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Plug build to ASME III, Class 2, 1986 Ed. CMTR attached.

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed Daniel M. Huff Senior Engineer Date Feb 15 19 90
Owner or Owner's Designated Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co.* of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 1/24/88 to 2/15/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

M.R. April 20844 PAL66
Inspector's Signature National Board, State, Province, and Endorsements

Date 2/15 19 90

5005 E JULIER STEEL & FURGE LUMPANT
 Special Metals in Bars and Forgings - Tool Steels

1000 87th Street
 P.O. BOX 6008 EMERYVILLE CALIFORNIA 94602
 TELEPHONE 415-539-3500 TELEFAX 415-539-3500 FAX 415-535-9038

1200 40th Street, Emeryville
 1050 Lakeside California 94608
 312-801-6119 - TELEFAX 877790

334 40th Street Emeryville
 3411 Lake City Ave Emeryville
 200-627-0008 - TELEFAX 30463

Lot No.	Q. No.	Spec.	Q. No.	Spec.	Q. No.	Spec.	Q. No.	Spec.		
676330	036	46	023	010	61	115	32	4.15	22	24
LOT NO. 13344						TA		CU	CO	
						.010		3.25	.05	

APPROVED BY: *[Signature]*
 DATE: 11/18/87
 WASHINGTON

We certify that no weld repair has been performed on the material supplied for this purchase order.

ASME QUALITY SYSTEM CERTIFICATE (MATERIALS)
NUMBER QSC-210
EXPIRATION DATE OF CERTIFICATE 8-4-90

We certify that the contents of this report are correct and accurate, and that all operations performed by us, and our subcontractors, are in compliance with the requirements of all specifications listed in the material description. This warranty of quality provides for the placement only of any part of this material which subsequent inspection, test or use shows non-conformance with the specifications. Inspection records, certifications, chemical and/or physical test reports are on file for your examination at EMERYVILLE, CALIFORNIA.

November 18, 1987

[Signature]
 PETER TOWNSEND
 QUALITY ASSURANCE MANAGER

CUSTOMER ACCT NO: 55340

ORDER DATE: 27 OCT 1987

DESCRIPTION: YELLOW

DATE SHIPPED: COLLECT

ITEM NO: 01322

DESCRIPTION: BAR T F 4-3/4" DIA X 72" LONG P/N 475002-BH3-1A2

ITEM NO: P68633

DESCRIPTION: MASCHILLI/MONOFER 201 HIA 01322-0000

ITEM NO: 01322

DESCRIPTION: MASCHILLI/MONOFER 201 HIA 01322-0000

ITEM NO: 01322

DESCRIPTION: MASCHILLI/MONOFER 201 HIA 01322-0000

Q. No.	Spec.	Q. No.	Spec.
1	TA	2	CU
2	CO	3	TA
3	TA	4	CU
4	CO	5	TA
5	CO	6	TA
6	CO	7	TA
7	CO	8	TA
8	CO	9	TA
9	CO	10	TA

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/7/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address Sheet 1 of 2
2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077
Address MWR #878104
Repair Organization P.O. No., Job No., etc.
3. Work Performed by DLCo - Maintenance Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address
4. Identification of System Fire Protection
5. (a) Applicable Construction Code B31.1 19 67 Edition S'71 Addenda ----- Code Case -----
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B31E-S'83A
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
TV-FP-103	Masonellan	N00228-004	N/A	4" Globe Valve	-----	Repaired	No
Plug	Masonellan	-----	N/A	013537-071-1Y4	1488	Replacement	Yes

7. Description of Work Replaced existing trim with soft seat trim.
8. Tests Conducted: Hydraulic Pneumatic Nominal Operating Pressure
 Other Pressure ----- psi Test Temp. ----- °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks: N-2 form attached. Replacement plug manufactured to ASME
Section III, 1971E-S'73 Addenda, Class 2.
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed David M. Hull Senior Engineer Date Feb 15 19 90
Owner or Owner's Designee Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 2/11/90 to 2/15/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

MR. [Signature]
Inspector's Signature

Commissions MS 144 MLL6
National Board, State, Province, and Endorsements

Date 2/15 19 90

FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES*

As Required by the Provisions of the ASME Code, Section III
Not To Exceed One Day's Production

1. Manufactured and certified by Masonellan-Dresser Industries, 85 Bodwell St., Avon, Ma. 02322
(Name and address of NPT Certificate holder)

2. Manufactured for Duquesne Light Company, 301 Grant St., Pittsburgh, Pa. 15279
(Name and address of purchaser)

3. Location of installation Duquesne Light Company, Beaver Valley Unit 1, Shippingport, Pa.
(Name and address)

4. Type P10362 ASME SA479/316 81,400 NA 1988
(Drawing no.) (Mater. spec. no.) (Design strength) (CRN) (Year built)

5. ASME Code, Section III: 1971 SUMMER 1973 2 NA
(Edition) (Addenda date) (Class) (Code Case no.)

6. Fabricated in accordance with Const. Spec. (Div. 2 only) NA Revision NA Date NA
(No.)

7. Remarks: Replacement for Masonellan Valve Serial No. N00228-004
Tag No. TV-FP-105
Masonellan Part No. 013537-071-1Y4

8. Nom. thickness (in.) NA Min. design thickness (in.) NA Dia. ID (ft & in.) NA Length overall (ft & in.) NA

9. When applicable, Certificate Holders' Data Reports are attached for each item of this report:

Part or Appurtenance Serial Number HEAT NUMBERS	National Board No. in Numerical Order
(1) 8654592-7 INSERT RETAINER	
(2) 163875-56 SKIRT	
(3) 90149-27 SHANK	
(4)	
(5)	
(6)	
(7)	
(8)	
(9)	
(10)	
(11)	
(12)	
(13)	
(14)	
(15)	
(16)	
(17)	
(18)	
(19)	
(20)	
(21)	
(22)	
(23)	
(24)	
(25)	

Part or Appurtenance Serial Number	National Board Number in Numerical Order
(26)	
(27)	
(28)	
(29)	
(30)	
(31)	
(32)	
(33)	
(34)	
(35)	
(36)	
(37)	
(38)	
(39)	
(40)	
(41)	
(42)	
(43)	
(44)	
(45)	
(46)	
(47)	
(48)	
(49)	
(50)	

10. Design pressure 175 psi Temp. 85 °F. Hydro test pressure NA at temp. °F
(when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

CERTIFICATION OF DESIGN

Design specifications certified by Carl Richardson P.E. State Pa. Reg. no. 16297-E
(when applicable)

Design report certified by NA P.E. State NA Reg. no. NA
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) 4" Plug S/A
 conforms to the rules of construction of the ASME Code, Section III.

NPT Certificate of Authorization No. N-1837 Expires 8-19-88

Date 1-18-88 Name Masonellan-Dresser Industries Signed John Kern
(NPT Certificate Holder) (Authorized Representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of
Pa. and employed by H.S.B.I. & I. Co.
 of Hartford, Ct. have inspected those items described in this Data Report on 18 January 1988 and state that to the

best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section
 III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described
 in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or
 loss of any kind arising from or connected with this inspection.

Date 1-18-88 Signed J.H. Evans Commissions MA-1222/PA-WX2514
(Authorized Inspector) (Nat'l. Bd. incl. endorsements; state or prov. and no.)

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/7/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address
2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077
Address MWR #878105
Repair Organization P.O. No., Job No., etc.
3. Work Performed by DLCO - Maintenance Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address
4. Identification of System Fire Protection
5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B3E-S'83A
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
TV-FP-106	Masoneilan	N00168-061	N/A	3" Globe Valve	—	Repaired	No
Plug	Masoneilan	85718-4	N/A	011490-285-1A2	1988	Replacement	Yes

7. Description of Work Replaced existing trim with soft seat trim.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks N-2 form attached. Replacement plug manufactured to ASME
Applicable Manufacturer's Data Reports to be attached
Section III, 1971E-S'73 Addenda, Class 2.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI.
Repair or Replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed David M. Hill Senior Engineer Date Feb 15 19 90
Owner or Owner's Representative

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 2/15/90 to 2/15/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

md. hill 289491 PA2666
Inspector's Signature National Board, State, Province, and Jurisdiction

Date 2/15 19 90

FORM N-2 CERTIFICATE HOLDERS' DATA REPORT FOR IDENTICAL
NUCLEAR PARTS AND APPURTENANCES*

As Required by the Provisions of the ASME Code, Section III
Not To Exceed One Day's Production

1. Manufactured and certified by Masonellan-Dresser Industries, 85 Bodwell St., Avon, MA. 02322
(Name and address of NPT Certificate holder)

2. Manufactured for Duquesne Light Company, 301 Grant St., Pittsburgh, Pa. 15279
(Name and address of purchaser)

3. Location of installation Duquesne Light Company, Beaver Valley Unit 1, Shippingport, Pa.
(Name and address)

4. Type P10435 ASME SA564/630 164,300 NA 1988
(drawing no.) (mat'l. spec. no.) (nominal strength) (CRN) (year built)

5. ASME Code Section III: 1971 SUMMER 1973 2 NA
(edition) (addenda date) (class) (Code Case no.)

6. Fabricated in accordance with Const. Spec. (Div. 2 only) NA Revision NA Date NA
(no.)

7. Remarks: Replacement for Masonellan Valve Serial No. NU0168-061
Tag No. TV-FP-106
Part No. 011490-285-1A2

8. Nom. thickness (in.) NA Min. design thickness (in.) NA Dia. ID (ft & in.) NA Length overall (ft & in.) NA

9. When applicable, Certificate Holders' Data Reports are attached for each item of this report:

Part or Appurtenance Serial Number HEAT NUMBER	National Board No. in Numerical Order
(1) 8571B-4	
(2)	
(3)	
(4)	
(5)	
(6)	
(7)	
(8)	
(9)	
(10)	
(11)	
(12)	
(13)	
(14)	
(15)	
(16)	
(17)	
(18)	
(19)	
(20)	
(21)	
(22)	
(23)	
(24)	
(25)	

Part or Appurtenance Serial Number	National Board Number in Numerical Order
(26)	
(27)	
(28)	
(29)	
(30)	
(31)	
(32)	
(33)	
(34)	
(35)	
(36)	
(37)	
(38)	
(39)	
(40)	
(41)	
(42)	
(43)	
(44)	
(45)	
(46)	
(47)	
(48)	
(49)	
(50)	

10. Design pressure 175 psi. Temp. 85 °F. Hydro. test pressure NA at temp. °F
(when applicable)

*Supplemental information in the form of lists, sketches, or drawings may be used provided (1) size is 8 1/2 x 11, (2) information in items 2 and 3 on this Data Report is included on each sheet, (3) each sheet is numbered and the number of sheets is recorded at the top of this form.
(12/86)
This form (E00040) may be obtained from the Order Dept., ASME, 22 Law Drive, Box 2300, Fairfield, NJ 07007-2300.

FORM N-2 (back)

Mfr. Serial No. N-35022B-002

CERTIFICATION OF DESIGN

Design specifications certified by Carl Richardson P.E. State Pa. Reg. no. 16297-E
(when applicable)

Design report* certified by NA P.E. State NA Reg. no. NA
(when applicable)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that this (these) 3" Plug
 conforms to the rules of construction of the ASME Code, Section III.

NPT Certificate of Authorization No. N-1837 Expires 8-18-89

Date 1-18-88 Name Masonellan-Dresser Industries Signed J. M. Kern
(NPT Certificate Holder) (Authorized Representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of
Pa. and employed by H.S.B.I. & I. Co.

of HARTFORD CT have inspected these items described in this Data Report on 18 JANUARY 1988, and state that to the
 best of my knowledge and belief, the Certificate Holder has fabricated these parts or appurtenances in accordance with the ASME Code, Section
 III. Each part listed has been authorized for stamping on the date shown above.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described
 in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or
 of any kind arising from or connected with this inspection.

Date 1-18-88 Signed J. L. C. Evans Commissions NA-1222/PA-WC 2514
(Authorized Inspector) (Nat. Bd. (INC) and/or state/prov. and no.)

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/7/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR #882234
Address Repair Organization P. O. No. Job No. etc.

3. Work Performed by DLCo -Maintenance Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address

4. Identification of System Safety Injection

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SI-421	Rockwell International	_____	N/A	2" Globe Valve	_____	Replaced	No
SI-421	Rockwell International	_____	N/A	2" Globe Valve	_____	Replacement	No

7. Description of Work Replaced valve with a newer style.

8. Tests Conducted: Hydraulic Pneumatic Nominal Operating Pressure
 Other Pressure 925 psi Test Temp. 71 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks No NPV-1 form. Replacement valve manufactured to ASME Section III.

Applicable Manufacturer's Data Reports to be attached

Div. 1 1977E-W'77 Addenda, P.O. # C018713

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed David M. Hall Senior Eng. Date Feb. 15 19 90
Owner or Owner's Designated Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 12/14/88 to 2/15/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commissions NO 884 PA2166
Inspector's Signature National Board, State, Province, and Endorsements

Date 2/15 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/7/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address
 Sheet 1 of 1

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077
Address
 MWR #882235
Repair Organization P. O. No., Job No., etc.

3. Work Performed by PLCo - Maintenance Dept. Type Code Symbol Stamp Not Applicable
Name
Shippingport, PA 15077
Address
 Authorization No. "
 Expiration Date "

4. Identification of System Safety Injection

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda --- Code Case ---
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SI-429	Rockwell International	---	N/A	2" Globe Valve	---	Replaced	No
SI-429	Rockwell International	---	N/A	2" Globe Valve	---	Replacement	No

7. Description of Work Replaced valve with a newer style.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 925 ps Test Temp. 71 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9 Remark: No NPV-1 form. Replacement valve manufactured to ASME Section III.
Applicable Manufacturer's Data Reports to be attached
Div. 1, 1977E-W'77 Addenda, P.O. # C018713.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the repair or replacement ASME Code, Section XI.

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed David M. Smith Senior Eng. Date Feb. 15 19 90
Owner or Owner's Designee

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 1/15/90 to 2/15/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

M.R. Smith AB 8741 PA2466
Inspector's Signature National Board, State, Province, and Enrollments

Date 2/15 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/8/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address
2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077
Address MWR #893233
Repair Organization P.O. No., Job No., etc.
3. Work Performed by DlCo - Nuclear Const. Dept. Type Code Symbol Stamp Not Applicable
Name
Shippingport, PA 15077
Address Authorization No.
 Expiration Date
4. Identification of System Diesel Generator Air Start Piping
5. (a) Applicable Construction Code B31.1 19 67 Edition S'71 Addenda Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B31-S'83A
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Piping	Stone and Webster	Line Nos. (see back)	N/A	Diesel Air Start Piping	—	Replaced	No
Piping	Stone and Webster	Line Nos. (see back)	N/A	Diesel Air Start Piping	1989	Replacement	No

7. Description of Work Replacement of D/G #2 Air Start Piping
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 276 psi Test Temp. 69 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks Line nos. (1 1/2" - ASC - xx - 151 - 03): ASC-76, ASC-77,
ASC-78, ASC-79, ASC-80, ASC-81, ASC-82 were replaced.
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed Robert A. Kubin MAINT. ENGR Date 2/14 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and Employed by Arkwright Mutual Insurance Co.* of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 2/9/89 to 2/15/89, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

M. R. Smith Commissioner MBI PA 116
Inspector's Signature National Board, State, Province, and Endorsements

Date 2/15 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/9/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address
 Sheet 1 of 2

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077
Address
 MWR # 883420
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCO - Maintenance Dept. Type Code Symbol Stamp Not Applicable
Name
Shippingport, PA 15077
Address
 Authorization No. "
 Expiration Date "

4. Identification of System Recirculation Spray

5. (a) Applicable Construction Code Sect. III.C 19 68 Edition, W'71 Addenda, " Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 83E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RS-E-1B	Industrial Process Eng.	6301-2	3180	Recirc Spray Heat Exch.	1971	Repaired	Yes

7. Description of Work Mechanically plugged thirty-two (32) tubes, pulled one (1) tube and seal welded plug to tubesheet.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 93.5 psi Test Temp. 70 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks N-1 form attached.
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed David M. Hill Date 2/15 10 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. of Waltham, Massachusetts

have inspected the components described in this Owner's Report during the period 11/1/89 to 2/15/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commission No. PA 211 PA 246
Inspector's Signature National Board, State, Province, and Jurisdictions

Date 2/15 10 90

Name: W. H. ...
 Title: ...
 Company: ...
 Address: ...
 City: ... State: ... Zip: ...
 Telephone: ...

10. TUBES: Material SA240-304L in thickness 20 No. of tubes 70 Type ...
 Min. comp. (when alternate working pressure 150 psi at max. temp. 280 °F. less than -20°)

11. TUBES: Material SA240-304L in thickness 20 No. of tubes 70 Type ...
 Min. comp. (when alternate working pressure 150 psi at max. temp. 280 °F. less than -20°)

12. SHELL: Material SA515-70 T.S. 70,000 Min. comp. (when alternate working pressure 150 psi at max. temp. 280 °F. less than -20°)

13. SEAMS: Long D.B.W. H.T. Yes R.T. complete No. of courses: 1
 SEE FIG. ...

14. HEADS (a) Material SA515-70 T.S. 70,000 Min. comp. (when alternate working pressure 150 psi at max. temp. 280 °F. less than -20°)



(a) Top inner corr. ...
 (b) Channel 1.13/16"
 (c) Flaring ...
 (d) 624 bolts - 3/4" dia. - SA193-B1

15. Concentrated for max. 150 PSI - Int. Min. comp. (when alternate working pressure 150 psi at max. temp. 280 °F. less than -20°)

16. SAFETY VALVE OUTLETS: Material ... No. ... Location ...

Part	Number	Dim. or Size	Type	Material	Thickness	Notes
Shell	1	14 x 10	B.W. Red.	SA240-304L	1/4	SA260-304L Welded
Shell	1	14 x 12	B.W. Red.	SA240-304L	1/4	SA260-304L Welded
Shell	1	1"	Weld End	SA312	.109	Welded
Shell	1	1/8"	Coup. Thr'd.	SA182F	304L/60008	Welded
Channel	2	14"	Weld End	SA53-B	.438	SA515-70 Welded
Channel	2	1/2"	Weld End	SA53-B	Sch. 80	Welded

17. NOZZLES: Material ... Thickness ...
 Min. comp. (when alternate working pressure 150 psi at max. temp. 280 °F. less than -20°)

1. INSPECTOR: Manufacturer, No. _____ Size _____ Location _____
 2. ENGINEER: Manufacturer, No. _____ Size _____ Location _____
 3. PLANT: No. _____ Size _____ Location _____
 4. SUPPORTS: Dia. No. _____ Legs _____ Feet _____ Legs _____ Other _____

5. REMARKS: Recirculation Spray Cooler TEMA Type C.F.N.
Item No. RS-E-10 I.D. No. 11700 RCV. 75
Content: Shell Side Spray Water, Tube Side River Water
Vessel Certified as ASME Code Section III Class "C" Unit by John H. Noble
Registered P.E. #11901-E, Commonwealth of Pennsylvania and is
constructed in accordance with the winter 1968 Addenda of ASME Section III, Article 31.

(Brief description of purpose of the vessel, as Air Pre-Heater, After Cooler, Jacketed Cooler, etc. Give capacities of each part.)

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

Date December 14, 1971 Industrial Process Engineers by D. B. Miller
 Certificate of Authorization Expires December 31, 1973

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY Industrial Process Engineers at Newark, New Jersey
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province N.J. and employed by The State of _____
 have inspected the pressure vessel described in this manufacturer's data report as December 3, 1971, and state that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable portions of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date December 14, 1971
[Signature] Commission NB#6575 Penna-WC 1879
 Nat'l Board, State, or Province and No.

MAJOR	MINOR	UNIT	NO.
P	2.4	1	75

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province _____ and employed by _____ of _____
 have inspected the statements in this manufacturer's data report with the described pressure vessel and state that parts referred to on data items _____ not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the applicable portions of the ASME Boiler and Pressure Vessel Code. The described vessel was inspected and subjected to a hydrostatic test of _____ psi.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ 19 _____
 Inspector's Signature _____ Commission _____
 Nat'l Board, State, or Province and No.

P

01664

U N DIVISION W PHT RT	INDUSTRIAL PROCESS ENGINEERS NEWARK, N.J.	
	SERIAL NUMBER 6301-2	NATIONAL BOARD NO. 3180
	WELD 150PSI(TN)	TUBE
	MAX. WORK PRESS. 150 PSI	48PSI EXT
MAX. WORK TEMP. 280° F	230° F	
THICKNESS 1/4 7/16 7/8	HD. CVR: 1/10	
HYDRO TEST PRESS. 250 PSI	225 PSI	
STATE NUMBER <input type="text"/>	YEAR BUILT 1971	

7
DYS CODE
RS
DO. NO. NO.
RS-E-1B
MAJOR
P
MAJOR
2.4
PO.
75

CUST. ITEM NO. RS-E-1B

P



11700 BV-75

RECEIVED

JAN - 1972

SIC 6
Eng

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/9/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address Sheet 1 of 2

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077
Address MWR #894449
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DlCo - Maintenance Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address

4. Identification of System Recirculation Spray

5. (a) Applicable Construction Code Sect. III.C 19 68 Edition, W'71 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is R3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RS-E-1C	Industrial Process Eng.	6301-3	3181	Recirc Spray Heat Exch.	1971	Repaired	Yes

7. Description of Work: Mechanically plugged one (1) tube, pulled one (1) tube and seal welded a plug to tubesheet.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 93.5 psi Test Temp. 70 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks: N-1 form attached.
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed Daniel M. Hall SR. SVC Date FEB 15 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 1/15/88 to 2/15/88 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

M. A. Smith Commissions 148224 PA 2266
Inspector's Signature National Board, State, Province, and Endorsements

Date 2/15/88

1. Manufactured by INDUSTRIAL PROCESS ENGINEERS, NEWARK, NEW JERSEY

2. Manufactured for Stone & Webster Eng. Co. for Duquesne Light Co., Allentown, Pa.

3. Type Vert. Kind Heat Exch. Vessel No. 6301-3 (Name of Vessel) (Type, Section, Div. Code) (Fig. or P. & I. Diagram) (ASME Code) (Date of Issue)
 Hyd. Test No. 3101- (Date) 1977

4. SHELL: Material SA240-304L T.S. 70,000 (ASME Spec. No.) (Fig. or P. & I. Diagram) (ASME Code) (Date of Issue)
 Shell Dia. 27.7 in. Allowance for Corrosion 0.125 in. Length 100 ft.

5. SEAMS: Long D.B.W. H.T. No R.T. complete (Welded, Bolt, Lap, Butt) (Yes or No) (Type of Seam) (Yes or No)
 Efficiency 100 %

6. HEADS (a) Material SA240-304L T.S. 70,000 (ASME Spec. No.) (Fig. or P. & I. Diagram) (ASME Code) (Date of Issue)
 (b) Material No T.S. No (ASME Spec. No.) (Fig. or P. & I. Diagram) (ASME Code) (Date of Issue)

7. STAYBOLTS: (Material) No If bolted (Size of Bolt) Attachment (Type of Bolt) 2 (Number of Bolts) (Type) No

8. JACKET CLOSURE: (Material) No (Type of Closure) (Material) No (Type of Closure)

9. Constructed for max. allowable working pressure 150 psi at max. temp. 280 °F. (Min. temp. (when less than -20°) No) (ASME Code) (Date of Issue) (ASME Code) (Date of Issue)
 Hyd. Test Pressure 225 psi

10. TUBE SHEETS: Stationary. Material SA240-304L (ASME Spec. No.) (Fig. or P. & I. Diagram) (ASME Code) (Date of Issue)
 Dia. 31 in. Thickness 1/4 in. Attachment Welded

11. TUBES: Material TP304-L O.D. 5/8" in. Thickness 20 ga. (ASME Spec. No.) (Fig. or P. & I. Diagram) (ASME Code) (Date of Issue)
 Dia. 31 in. Thickness 1/4 in. Attachment Welded

12. SHELL: Material SA515-70 T.S. 70,000 (ASME Spec. No.) (Fig. or P. & I. Diagram) (ASME Code) (Date of Issue)
 Shell Dia. 27.7 in. Allowance for Corrosion 0.125 in. Length 100 ft.

13. SEAMS: Long D.B.W. H.T. Yes R.T. complete (Welded, Bolt, Lap, Butt) (Yes or No) (Type of Seam) (Yes or No)
 Efficiency 100 %

14. HEADS (a) Material SA515-70 T.S. 70,000 (ASME Spec. No.) (Fig. or P. & I. Diagram) (ASME Code) (Date of Issue)
 (b) Material No T.S. No (ASME Spec. No.) (Fig. or P. & I. Diagram) (ASME Code) (Date of Issue)

(a) Top, bottom, ends: Thickness 1-13/16" Crown Radius No (ASME Spec. No.) (Fig. or P. & I. Diagram) (ASME Code) (Date of Issue)
 (b) Channol: Thickness 37" (ASME Spec. No.) (Fig. or P. & I. Diagram) (ASME Code) (Date of Issue)

(c) Flaring: (ASME Spec. No.) (Fig. or P. & I. Diagram) (ASME Code) (Date of Issue)


If removable, bolt and (a) (Material, Spec. No., Fig. or P. & I. Diagram) (ASME Code) (Date of Issue) (b) 24 bolts - 3/4" dia. - SA193-B7

15. Constructed for max. allowable working pressure 150 psi-int. 48 psi-ext. (ASME Code) (Date of Issue) (ASME Code) (Date of Issue)
 Hyd. Test Pressure 225 psi

16. SAFETY VALVE OUTLETS: Number No Size No Location No By Other

17. NOZZLES

Purpose (Inlet, Outlet, Drain)	Number	Dia. or Size	Type	Material	Thickness	Design or Code	Attachment
Shell	1	14 x 10	B. W. Red.	SA240-304L	1/4	SA240-304L	Welded
Shell	1	14 x 12	B. W. Red.	SA240-304L	1/4	SA240-304L	Welded
Shell	1	1"	Weld End	SA 312	.109	-----	Welded
Shell	1	1/8"	Coup. Thrd	SA182F304L	6000H	-----	Welded
Channol	2	14"	Weld End	SA53-B	.438	SA515-70	Welded
Channol	2	1/2.1"	Weld End	SA53-B	Sch. 80	-----	Welded



If removed the cover shall fully expose the ends of the tubes.

15-301 12-242
 RS RHS
 P. 4 11 75

P

16. INSPECTOR (Inspector, No. _____ Size _____ Location _____)
 (Inspector, No. _____ Size _____ Location _____)
 (Inspector, No. _____ Size _____ Location _____)
 17. SUBJECT (Size _____ No. _____ Legs _____ Pans _____ Legs _____ Other _____ Asses. Shell _____)

18. APPARATUS, Recirculating Spray Cooler, TEMA Type -- CEN

Tag No. NA-11C I.O. No. 11700-R-V-78
 Camera, Shell Side -- Spray Water, Tube Side -- River Water.
 Vessel certified as ASME Code Sec. III, Class "C" Unit by John H. Noble,
 Registered P.E. 811501-E Commonwealth of Pennsylvania and is constructed in
 accordance with the Winter 1968 Addenda of ASME Sec. III, Article 21.

(Short description of purpose of the vessel, an Air Tank, After Cooler, Jacketed Cooler, etc. Show contents of each part.)

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code (Pressure Vessels, Section VIII, Division 1).

Date December 16 19 71 Signed Industrial Process Engineers by D. B. Halloran

Certificate of Authorization Expires December 31, 1973

0170

M. T. R. S. E. I. P. 24 1175

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY Industrial Process Engineers at Newark, New Jersey

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province N.J. and employed by The State of _____

have inspected the pressure vessel described in this manufacturer's data report on December 10 19 71 and state that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date December 16 19 71

[Signature]
 Inspector's Signature

Commission NR 6575 Penna. WC-1878
 Nat'l Board, State, or Province and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province _____ and employed by _____ of _____

have compared the statements in this manufacturer's data report with the described pressure vessel and state that parts referred to as data items _____ not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the applicable sections of the ASME

Boiler and Pressure Vessel Code. The described vessel was inspected and subjected to a hydrostatic test of _____ psi.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ 19 _____

 Inspector's Signature

Commission _____
 Nat'l Board, State, or Province and No.

P

M
 OPS CODE
 RS
 PS-E-10
 MAJOR
 P
 MINOR
 24
 00
 75

U N DIVISION I W PHT RT	INDUSTRIAL PROCESS ENGINEERS NEWARK, N.J.	
	SERIAL NUMBER 6301-3	NATIONAL BUARD NO. 0101
	SHELL	.TUBE 150F 3/16
	MAX. WORK PRESS. 150 FSI	100 FSI
MAX. WORK TEMP. 200 F	200 F	
THICKNESS 1/4 7/16 7/16	1.00 CV	
HYDRO TEST PRESS. 250 FSI	225 FSI	
STATE NUMBER <input type="text"/>	YEAR BUILT 1975	

PART ITEM NO. - RS-E-10 11700 BV-75



P

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/12/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 2
Address

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR #394349
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Maintenance Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address

4. Identification of System Recirculation Spray

5. (a) Applicable Construction Code Sect. III.C 19 68 Edition, W'71 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 83E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RS-E-1D	Industrial Process Eng.	6301-4	3182	Recirc Spray Heat Exch.	1971	Repaired	Yes
Tubes	Greenville Tube Co.	_____	N/A	_____	1989	Replaced	No
Studs	Cardinal	_____	N/A	_____	1989	Replaced	No
Nuts	Cardinal	_____	N/A	_____	1989	Replaced	No

7. Description of Work Replaced one hundred thirty-four (134) tubes and end cover studs and nuts.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 93.5 psi Test Temp. 70 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks N-1 form attached.
 Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed Daniel M. Hall Date Feb 15 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 1/24/90 to 2/15/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commission AB 8441 PS 1066
 Inspector's Signature National Board, State, Province, and Endorsements

Date 2/15 19 90

As shown on the drawings, this vessel is to be constructed in accordance with the ASME Code, Section VIII, Division 1, 1959 Edition.

Manufactured by INDUSTRIAL PROCESS EQUIPMENT CO. NEW YORK, N.Y.

Manufactured for Stone & Webster Eng. Co. for Duquesne Light Co., Shippingport, Pa.

Vent. Heat Exch. Vessel No. 6301-4 (See Notes) Heat Ex. No. 3188

Items 1-6 to be completed for all vessels unless otherwise specified. Items 7-10 to be completed for all vessels unless otherwise specified. Items 11-15 to be completed for all vessels unless otherwise specified.

SEALS: Leag. D.B.W. H.T. No R.T. complete Sectioned No Efficiency 100

HEADS: (a) Material SA240-304L T.S. 70,000 (b) Material SA240-304L T.S. 70,000 (c) Material SA240-304L T.S. 70,000

7. STAYBOLTS: Material if hollow Assumptions Pitch Weld if Weld if Weld

8. JACKET CLOSURE: Material if hollow Assumptions Pitch Weld if Weld if Weld

9. Constructed for max. allowable working press. 150 psi at max. temp. 280 °F. Min. temp. (when less than -20°) 7. Test Press 250

10. TUBE SHEETS: Material SA240-304L (See Note No.) Dia. 31 in. Thickness 3/16 in. Assumptions Welded

Floating Material SA213 5ml's (See Note No.) Dia. in. Thickness in. Assumptions

11. TUBES: Material TP304L O.L. (See Note No.) Dia. 5/8" in. Thickness 20 lbs. or Gage Number 850 Type Straight (Straight or U)

Items 12-15 to be completed for all vessels unless otherwise specified. Channels of heat exchangers.

12. SHELL Material SA515-70 T.S. 70,000 Nominal Thickness 7/16 in. Allowance 0 in. Dia. 2 ft. 7 in. Length 2 ft. 3/4 in.

13. SEAMS: Leag. D.B.W. H.T. Yes R.T. complete Sectioned No Efficiency 100

14. HEADS (a) Material SA515-70 T.S. 70,000 (b) Material SA515-70 T.S. 70,000 (c) Material SA515-70 T.S. 70,000

(a) Top, bottom, ends Thickness 1-13/16" Crown Radius Elliptical Ratio Conical Apex Angle Hemispherical radius Flat Diameter 37" Code to be followed (ASME or Custom)

(b) Choccol (c) Floating If reasonable, bolts used (a) 24 bolts - 3/4" dia. SA193-B7 (Other fastenings)

(c) 150 PSI - Int. (Other fastenings)

15. Constructed for max. allowable working press. 48 PSI - Ext. 280 °F. Min. temp. (when less than -20°) 7. Test Press 225

Items below to be completed for all vessels where applicable.

16. SAFETY VALVE OUTLETS: Number Size Location BY OTHERS

17. NOZZLES

Purpose (Top, Outlet, Dia in)	Number	Diam. or Size	Type	Material	Thickness	Code to be followed (ASME or Custom)	How Attached
Shell	1	14 x 10	B. W. Red.	SA240-304L	1/4	SA240-304L	Welded
Shell	1	14 x 12	B. W. Red.	SA240-304L	1/4	SA240-304L	Welded
Shell	1	1"	Weld End	SA312	109		Welded
Shell	1	1/8"	Coup Thr'd	SA2FYM L	6000#		Welded
Channel	2	1/4"	Weld End	SA53-B	43B	SA515-70	Welded
Channel	2	1/2, 1"	Weld End	SA53-B	Sch. 80		Welded



INTL JAN 1 1972

P

18. INSPECTION Holes, No. _____ Size _____ Location _____
 19. SUPPORTS: Handhole, No. _____ Size _____ Location _____
 Threaded, No. _____ Size _____ Location _____
 19. SUPPORTS: Size No Legs Four Legs _____ Other _____ Attached Shell Welded

20. REMARKS: Recirculation Spray Cooler--TEMA Type CEN

Item No. RS-E-ID -- I.O. No. U700 -- RV-75
Contents: Shell Side -- Spray Water -- Tube Side -- River Water
Vessel Certified as ASME Code Sect. III Class "C" Unit by John M. Noble
Registered P. E. 011501-E Commonwealth of Pennsylvania and is
constructed in accordance with the Winter 1968 Addenda of ASME Sect. III, Article 21

(State description of purpose of the vessel, or Air Test, After Cooler, Jacketed Cooler, etc. Also contents of each part.)

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

Date December 17, 19 71 signed Industrial Process Engineers by B.B. Heller

Certificate of Authorization Expires December 31, 1973

01693

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY Industrial Process Engineers of Newark, New Jersey

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province N. J. and employed by The State of _____ have inspected the pressure vessel described in this manufacturer's data report on December 17, 19 71 and state that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date December 17, 19 71 _____ Commission N. J. 6575 Penna. WC 1879

NO.	DATE	BY	UNIT	P. E.
1	12-17-71	B.B. Heller	24	1175

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province _____ and employed by _____ have compared the statements in this manufacturer's data report with the described pressure vessel and state that parts referred to as data items _____ not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code. The described vessel was inspected and subjected to a hydrostatic test of _____ psi.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ 19 _____

Inspector's Signature _____ Commission _____ Nat'l Board, State, or Province and No. _____

P

U
N
DIVISION I
W
PHT
RT

INDUSTRIAL PROCESS ENGINEERS
NEWARK, N.J.

SERIAL NUMBER 630 I-4 NATIONAL BUREAU NO. 3102

SHEET TUBE
150 PSI INT.

MAX. WORK PRESS. 150 PSI 48 PSI-EXT.

MAX. WORK TEMP. 280° F 250° F

THICKNESS 1/4 9/16 7/16 HD CVR. 1 13/16

HYDRO-TEST PRESS. 250 PSI 225 PSI

STATE NUMBER YEAR BUILT 1971

M
SYS. CODE
RS
EQ. ID. NO.
RS-E-1D
MAJOR
P
MINOR
24
PO.
95

CUST. ITEM NO. - RS-E-1D

11700 BV-75



P

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

Date 2/26/90
Sheet 1 of 1

2. Plant Beaver Valley Power Station
Name
Shippingport, PA 15077
Address

Unit No. 1
MWR #883188
Repair Organization # O. No., Job No., etc.

3. Work Performed by DLCO - Maintenance Dept.
Name
Shippingport, PA 15077
Address

Type Code Symbol Stamp Not Applicable
Authorization No. _____
Expiration Date _____

4. Identification of System Reactor Coolant

5. (a) Applicable Construction Code Section III, 19 68 Edition, S'68 Addenda, _____ Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RV-RC-551B	Target Rock	2	---	6" x 6" Relief Valve	1973	Replaced	YES
RV-RC-551B	Target Rock	1	---	6" x 6" Relief Valve	1973	Replacement	YES

7. Description of Work Replaced existing valve with a spare

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached _____

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A _____

Signed Ronald A. Ullrich ENG 1 Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 3/9/90 to 3/9/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

Ronald A. Ullrich Commissions ND 8441 P 28666
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/26/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address
2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR #893726, 891744
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by DLCo - Maintenance Dept. Type Code Symbol Stamp Not Applicable
Name Authorization fee "
Shippingport, PA 15077 Expiration Date "
Address
4. Identification of System Main Steam
5. (a) Applicable Construction Code B16.34 19 73 Edition, ASME Code Book
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No. (Model)	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MS-20	Crane Valve	175-ixR	N/A	3" check valve	1973	Repaired	NO
	Crane Valve	D847	N/A	Disc.	1989	Replaced	NO

7. Description of Work Overhauled valve, replaced valve internals, seal welded hinge pin plu

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks No NPV-1 form
 Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG 3 Date March 9 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts

have inspected the components described in this Owner's Report during the period 10/5/89 to 3/9/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Inspector's Signature
 Commissions AB 844 PA 446
 National Board, State, Province, and Endorsements

Date 3/8 19 90

FORM NIS-1 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 3/8/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077
Address MWR 893383, 894331, 894305;
 DCP 1452; DCP 682/MWR 882346
Repair Organization P. O. No., Job No., etc.

3. Work Performed by DLCO - NCD Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address

4. Identification of System Feedwater System (024)/RCS

5. (a) Applicable Construction Code ASME III 19 65 Edition W66 Addenda 1429 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Unit 1 "B" Steam Gen.	Westinghouse	1302	68-46	RC-E-1B	1971	Repair	YES

7. Description of Work Machining of 2" Inspection Openings in Lower Shell, machining of 6" handhole & cover/machining of 02 secondary manway cover; plugging & staking & plug removal/DCP 682-change out of bolts to studs.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9 Remarks These 2" dia. inspection openings did not require reinforcement with weld-build-up material because the shell wall thickness at this location is considerably over the minimum wall requirements.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENR Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co.* of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 11-4-89 to 3/9/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Inspector's Signature Commission 238441 PA2125 National Board, State, Province, and Endorsements

Date 3/9 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 3/8/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address Sheet 1 of 1
2. Plant Beaver Valley Power Station Unit No. _____
Name TER 2800; DCP 6P MWR 882339;
Shippingport, PA 15077 DLC P.O. D08069 MWR 893963; MWR 8942
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by DLCo - Nuclear Const. Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No. _____
Shippingport, PA 15077 Expiration Date _____
Address
4. Identification of System Reactor Coolant System (06)
5. (a) Applicable Construction Code ASME III 19 65 Edition, W 66 Addenda, 1429 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RC-E-1A Steam Gen.	Westinghouse	1301	68-45	Pa. Serial 434597	1971	Repair	YES

7. Description of Work Thermal Stress Relief of Row 1 and 2 Tube U-bends; plugging, staking, plug removal, DCP 6R2/change out of bolts to studs.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F
Eddy Current Test per Technical Specifications

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9 Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG 2 Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co.* of Waltham, Massachusetts

_____ have inspected the components described in this Owner's Report during the period 11/24/85 to 3/9/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] _____ Commissions NO 8441 PAL 66
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 3/5/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR # 894452 and 894035
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Nuclear Const. Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address

4. Identification of System Feedwater

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda, Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
16"-WFPD-22	Stone and Webster			Piping		Repaired	No

7. Description of Work: Feedwater elbow to steam generator was cut out and replaced. Piping upstream was cut, repositioned and rewelded.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 902 psi Test Temp. 440 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9 Remarks _____
 Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol State ASME Section XI Repair/Replacement Program

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENR 1 Date March 9 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 1/6/89 to 2/9/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commission 458771 PA1116
 Inspector's Signature National Board, State, Province, and Endorsements

Date 3/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 3/2/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address Sheet 1 of 1

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR # 894608
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by DlCo - Nuclear Const. Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address

4. Identification of System Feedwater

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
16"-WFPD-24	Stone and Webster	_____	_____	Piping	_____	Repaired	No

7. Description of Work Piping was cut, repositioned, and rewelded.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 902 psi Test Temp. 440 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9 Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp _____ Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co.* of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 11/2/89 to 3/9/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] _____ Commissions 25 8741 PA 444
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 3/8/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address
 Sheet 1 of 1

2. Plant Beaver Valley Power Station Unit No. _____
Name
Shippingport, PA 15077
Address
 DCP 1452; MWR 890831, 894486;
 DCP 682/MWR 882346
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - NCD Type Code Symbol Stamp Not Applicable
Name
Shippingport, PA 15077
Address
 Authorization No. _____
 Expiration Date _____

4. Identification of System Feedwater/RCS

5. (a) Applicable Construction Code ASME III 19 65 Edition, W66 Addenda, 1429 Code Case _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Unit 1 'C' Steam Gen.	Westinghouse	1303	68-47	RC-E-1C	1971	Repair	Yes

7. Description of Work Machining of 2" inspection opening in lower shell, machining of secondary manway cover, plug removal, stabilization & description of work plugging; DCP 682 - change out of bolts to studs.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this N/A conforms to the rules of the
ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ Per SAP 39 *ASME Section XI Repair/Replacement Program

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A

Signed [Signature] ENG Date March 9 19 81
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State
or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. of
Waltham, Massachusetts have inspected the components described
in this Owner's Report during the period _____ to _____, and state that
to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the
Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the
examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer
shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this
inspection. ***Factory Mutual Systems**

[Signature] _____ Commission 44874 Pratt
Inspector's Signature National Board, State, Province, and Jurisdictions

Date 3/9/81

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/28/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 894818
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Nuclear Construction Type Code Symbol Stamp Not Applicable
Name Authorization No. _____
Shippingport, PA 15077 Expiration Date _____
Address

4. Identification of System Feedwater

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda _____ Code Case _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
WFPD-24-5-A-3	Stone & Webster	-	-	-	-	Repaired	No

7. Description of Work Arc strike near weld removed. Min wall was not violated.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ ps Test Temp. _____ °F
 VT, MT, UT

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
 Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 *ASME Section XI Repair/Replacement Program*

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG S Date March 9 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 11/10/89 to 2/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commissions AB 8441 PA 2226
 Inspector's Signature National Board, State, Province, and Endorsements

Date 3/5 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/28/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 892214
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Nuclear Construction Type Code Symbol Stamp Not Applicable
Name Authorization No. _____
Shippingport, PA 15077 Expiration Date _____
Address

4. Identification of System Safety Injection

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda _____ Code Case _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Weld SI-18-1-S-05	Stone and Webster	-	-	-	-	repaired	No

7. Description of Work Removed Arc Strike at weld. Minimum wall was not violated

8. Tests Conducted: Hydraulic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F
PT-89-274

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENGL Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 9/17/89 to 2/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commission 20 944 82266
Inspector's Signature National Board, State, Province, and Endorsements

Date 2/5 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

Date 2/28/90

Sheet 1 of 1

2. Plant Beaver Valley Power Station
Name
Shippingport, PA 15077
Address

Unit No. 1

MWR 893783
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Maint. Dept.
Name
Shippingport, PA 15077
Address

Type Code Symbol Stamp Not Applicable

Authorization No. _____

Expiration Date _____

4. Identification of System Main Steam

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda, _____ Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A

6. Identification of Components Required or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Required, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MS-81	Crane	-	-	Model 1754X	-	repaired	No
Disc	Crane	-	-	Part #D847	-	replaced	No

7. Description of Work Replaced internals

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

B. Remarks: No NPV-1 form
 Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 *ASME Section XI Repair/Replacement Program*

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] EUG L Date March 9 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/5/89 to 2/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commissions 20 8441 P34166
 Inspector's Signature National Board, State, Province, and Endorsements

Date 3/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/28/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address
 2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 894034
Address Repair Organization P.O. No., Job No., etc.
 3. Work Performed by DLCo - Maint. Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No. _____
Shippingport, PA 15077 Expiration Date _____
Address

4. Identification of System Main Steam

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda _____ Code Case _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PCV-MS-101C	Copes Vulcan	-	-	-	-	repaired	no
Bal. Cylinder	Copes Vulcan	-	-	-	-	replaced	no
Trim Set	Copes Vulcan	-	-	-	-	replaced	no

7. Description of Work Overhauled valve internals.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

8. Remarks No NPV-1
 Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repaired conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 *ASME Section XI Repair/Replacement Program*

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG I Date March 9 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Province of Pennsylvania and employed by Arkwright Mutual Insurance Co.* of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/21/89 to 2/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commission UBV-21 PV-2166
 Inspector's Signature National Board, State, Province, and Endorsements

Date 3/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

Date 2/28/90
 Sheet 1 of 1

2. Plant Beaver Valley Power Station
Name
Shippingport, PA 15077
Address

Unit No. 1
MWR 894819
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Nuclear Const.
Name
Shippingport, PA 15077
Address

Type Code Symbol Stamp Not Applicable
 Authorization No.
 Expiration Date

4. Identification of System Feedwater

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Weld # WFPD-24-5-A-5	-	-	-	-	-	repaired	NO

7. Description of Work Removed arc strike near weld. Min wall not violated

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure psi Test Temp. °F
 MT-89-149

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of the form.

FORM NIS-2 (Back)

9. Remarks _____

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENR-I Date March 9 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 11/10/89 to 2/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] AB 4741 PA 1126
 Inspector's Signature National Board, State, Province, and Endorsements

Date 3/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/28/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

2. Plant Beaver Valley Power Station Sheet 1 of 1
Name
Shippingport, PA 15077
Address Unit No. 1
MWR 894823
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DlCo - Nuclear Const Type Code Symbol Stamp Not Applicable
Name
Shippingport, PA 15077
Address Authorization No.
 Expiration Date

4. Identification of System Feedwater

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Appends. - Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Snubber WFPD-HSS-209	Grinnell	8835	-	-		replaced	no
Snubber WFPD-HSS-209	Grinnell	25474	-	-		replace- ment	no

7. Description of Work One for one replacement due to bad seal.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure psi Test Temp. °F
 Visual Exam.

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
 Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] EUGL Date March 9 19 80
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/14/89 to 2/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Inspector's Signature Commissions 28444 PL146
 National Board, State, Province, and Endorsements

Date 2/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

Date 2/28/90

Sheet 1 of 1

2. Plant Beaver Valley Power Station
Name
Shippingport, PA 15077
Address

Unit No. 1

MWR 894178
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DlCo - Nuclear Const.
Name
Shippingport, PA 15077
Address

Type Code Symbol Stamp Not Applicable

Authorization No. *

Expiration Date *

4. Identification of System Reactor Coolant

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda - Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Snubber RC-HSS-8	Grinnell	illegable	-	-		replaced	no
Snubber RC-HSS-8	Grinnell	25924	-	-		replacement	no

7. Description of Work Replaced snubber

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F
Visual Exam.

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks: _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] EUG I Date March 9 19 80
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 11/7/89 to 2/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in the Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Inspector's Signature Commission 28844 PA 1166
National Board, State, Province, and Endorsements

Date 3/9 19 80

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/28/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 894822
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Nuclear Const. Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address

4. Identification of System Feedwater

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda - Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Snubber WFPD-HSS-212	Grinnell	8171	-	Snubber	-	replaced	no
Snubber WFPD-HSS-212	Grinnell	25476	-	Snubber	-	replacement	no

7. Description of Work One for one replacement of snubber due to leaking seal.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F
Visual Inspection.

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
 Applicable Manufacturer's Data Reports to be attached _____

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 *ASME Section XI Repair/Replacement Program*

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] EX-1 Date March 9 '19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co.* of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 11/14/89 to 2/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] PA 6126
 Inspector's Signature National Board, State, Province, and Endorsements

Date 3/7 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/28/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address
 2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 871581
Address Repair Organization P.O. No., Job No., etc.
 3. Work Performed by DLCo - Maint. Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No. _____
Shippingport, PA 15077 Expiration Date _____
Address

4. Identification of System Safety Injection

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda _____ Code Case _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A

6. Identification of Components Required or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Required, Replaced, or Replacement	ASME Code Stamped (Yes or No)
MOV-S1-865C	Velan	-	-	DRWG, 88907/3	-	repaired	no
Bonnet studs	Cardinal	-	-	-	-	replaced	no
Bonnet nuts	Cardinal	-	-	-	-	replaced	no

7. Description of Work Replaced 19 out of 20 Bonnet Stud/Nut assemblies

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of the form.

FORM NIS-2 (Back)

9. Remarks: No NPV-1 form
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Robert J. White* ENG I Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/12/89 to 2/22/89 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

Robert R. Smith 282441 P92266
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/5 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/28/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 892209
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Nuclear Const. Type Code Symbol Stamp Not Applicable
Name Authorization No.
Shippingport, PA 15077 Expiration Date
Address

4. Identification of System Safety injection

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda - Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B3E-S'B3A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Weld# SI-16-8-F-09	Stone & Webster	-	-	-	-	repaired	no

7. Description of Work Removed vibroetch markings at weld. Min wall was not violated.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure psi Test Temp. °F
PT-89-273

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed Thomas J. White EUG. I. Date March 9 '19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co.* of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/21/89 to 2/22/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

Thomas J. White Commission 28944 P02166
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/28/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 893434
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLC - Nuclear Construction Type Code Symbol Stamp Not Applicable
Name Authorization No.
Shippingport, PA 15077 Expiration Date
Address

4. Identification of System Safety Injection

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B31-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Weld SI-133-6A-S-06	Stone & Webster	-	-	-	-	Repaired	No

7. Description of Work Removed linear indication in weld. Min. wall was not violated.

8. Tests Conducted: Hydraulic Pneumatic Nominal Operating Pressure
 Other Pressure psi Test Temp. °F
PT-89-272

NOTE: Supplemental sheets in form of tabs, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Rev.)

9. Remarks _____

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG I Date March 9 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 9/17/89 to 2/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[®]Factory Mutual Systems

[Signature] Commission #3224 PA 4262
 Inspector's Signature National Board, State, Province, and Endorsements

Date 3/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/28/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address
 2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 894817 and 894829
Address Repair Organization P.O. No., Job No., etc.
 3. Work Performed by DlCo - Nuclear Const. Type Code Symbol Stamp Not Applicable
Name Authorization No. _____
Shippingport, PA 15077 Expiration Date _____
Address

4. Identification of System Feedwater

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda _____ Code Case _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
WFPD-24-5-A-6	Stone and Webster	-	-	-	-	repaired	no

7. Description of Work Removed arc strike and linear indication near weld

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F
MT-89-149 & 161

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 8 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks: _____
Applicable Manufacturer's Data Records to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENR-I Date March 9 19 92
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 1/10/89 to 2/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Factory Mutual Systems

[Signature] _____ Commission 45844 P02166
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/2/92

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/28/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address
2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 871522
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by DLCO - Maint. Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No.
Shippingport, PA 15077 Expiration Date
Address
4. Identification of System Main Steam
5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
PCV-MS-101A	Copes Vulcan	-	-	-	-	Repaired	No
Balance Cylinder	Copes Vulcan	-	-	-	-	Replaced	No
Trim Set	Copes Vulcan	-	-	-	-	Replaced	No

7. Description of Work Replaced trim assembly and balance cylinder
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
 Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG'G Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/19/89 to 2/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

***Factory Mutual Systems**

[Signature] [Signature]
Inspector's Signature National Board, State, Province, and Embroiderments

Date 3/9 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/28/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address
2. Plant Beaver Valley Power Station Sheet 1 of 1
Name
Shippingport, PA 15077
Address Unit No. 1
MWR 894454
Repair Organization P.O. No., Job No., etc.
3. Work Performed by DLCo - Maint. Dept. Type Code Symbol Stamp Not Applicable
Name Authorization No.
Shippingport, PA 15077 Expiration Date
Address
4. Identification of System Residual Heat Removal
5. (a) Applicable Construction Code B31.1 10 67 Edition, S'71 Addenda Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B31E-S'83A
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RH-1	Anchor Darling	-	N/A	-	-	repaired	no
Flange studs	Cardinal	N/A	N/A	1 3/8" - 8	-	replaced	no
Flange nuts	Cardinal	N/A	N/A	1 3/8" - 8	-	replaced	no
Bonnet studs	Cardinal	N/A	N/A		-	replaced	no
Bonnet nuts	Cardinal	N/A	N/A		-	replaced	no

7. Description of Work Replaced degraded fasteners
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks No NPV-1
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 32 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG I Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. of Walham, Massachusetts have inspected the components described in this Owner's Report during the period 10/22/89 to 9/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Inspector's Signature
Commissions MB 8741 PA 2666
National Board, State, Province, and Endorsements

Date 3/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

Date 3/2/90

Sheet 1 of 1

2. Plant Beaver Valley Power Station
Name
Shippingport, PA 15077
Address

Unit No. 1

MWR 893847
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Nuclear Const.
Name
Shippingport, PA 15077
Address

Type Code Symbol Stamp Not Applicable

Authorization No. -

Expiration Date -

4. Identification of System Charging

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda - Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
CH-23-3-S-03	Stone & Webster	-	-	Weld	-	Repaired	No

7. Description of Work Removed arc strike. Min. wall not violated

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure VT-89-1039 psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG 2 Date March 9 '19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/21/89 to 3/2/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commissions US 2441 PA2266
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/5 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

Date 3/2/90

Sheet 1 of 1

2. Plant Beaver Valley Power Station
Name
Shippingport, PA 15077
Address

Unit No. 1

MWR 893845
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Nuclear Const.
Name
Shippingport, PA 15077
Address

Type Code Symbol Stamp Not Applicable

Authorization No. -

Expiration Date -

4. Identification of System Reactor Coolant

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'7 Addenda - Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
2"-RC-244A	Stone & Webster	-	-	Elbow	-	Repaired	No

7. Description of Work Fitting indications removed

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F
PT-89-294

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks: _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG I Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/19/89 to 3/2/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commissions PA 844 PA 246
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

2. Plant Beaver Valley Power Station
Name
Shippingport, PA 15077
Address

3. Work Performed by DLCo - Nuclear Conts.
Name
Shippingport, PA 15077
Address

Date 3/2/90

Sheet 1 of 1

Unit No. 1

MWR 894178
Repair Organization P.O. No., Job No., etc.

Type Code Symbol Stamp Not Applicable

Authorization No.

Expiration Date

4. Identification of System Reactor Coolant

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Snubber RC-HSS-2	Grinnell	537	-	-	-	Replaced	No
Snubber RC-HSS-2	Grinnell	11287	-	-	-	Replacement	No

7. Description of Work Replaced snubber due to broken fitting

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure psi Test Temp. °F
 Visual Exam by ISI

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached _____

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. _____ N/A _____ Expiration Date _____ N/A

Signed _____ ENG I _____ Date _____ March 9, 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 11/6/89 to 3/2/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

Inspector's Signature _____ Commission No. 8441 PAL266
National Board, State, Province, and Endorsements

Date _____ 3/9 19 90 _____

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

Date 3/2/90

Sheet 1 of 1

2. Plant Beaver Valley Power Station
Name
Shippingport, PA 15077
Address

Unit No. 1

MWR 893848
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Nuclear Const.
Name
Shippingport, PA 15077
Address

Type Code Symbol Stamp Not Applicable

Authorization No. -

Expiration Date -

4. Identification of System Charging

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'7 Addenda - Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
CH-23-4-F-06	Stone & Webster	-	-	Pipe Weld	-	Repaired	No

7. Description of Work: Removed Arc Strike near weld. Min. wall not violated

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure _____ psi Test Temp. _____ °F
PT-89-297

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Code Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG I Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/24/89 to 3/2/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commissions NO 8471 PA 2066
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 3/2/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address
2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 893844
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by DlCo - Nuclear Const. Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address
4. Identification of System Charging
5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda " Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
CH-141-2-F-3	Stone & Webster	-	-	Pipe Weld	-	Repaired	No

7. Description of Work Removed linear indication near weld
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____, psi Test Temp. _____ °F
 PT-89-295

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENR 2 Date March 9 19 90 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State of Pennsylvania and employed by Arkwright Mutual Insurance Co. of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/19/89 to 3/2/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Factory Mutual Systems

[Signature] Inspector's Signature Commission # B 2441 PA 2262 National Board, State, Province, and Endorsements

Date 3/9 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

Date 3/2/90

Sheet 1 of 1

2. Plant Beaver Valley Power Station
Name
Shippingport, PA 15077
Address

Unit No. 1

MSR 893835
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DlCo - Nuclear Const.
Name
Shippingport, PA 15077
Address

Type Code Symbol Stamp Not Applicable

Authorization No.

Expiration Date

4. Identification of System Feedwater

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'7 Addenda - Code Case

(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
WFPD-22-8F-F-02	Stone and Webster	-	-	Weld	-	Repaired	No

7. Description of Work Removed linear indication. Min wall not violated.

8. Tests Conducted: Hydraulic Pneumatic Nominal Operating Pressure
 Other Pressure psi Test Temp. °F
MT-89-81

NOTE: Supplemental sheet, in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached _____

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repaired conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENGL Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/5/89 to 3/2/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commission No. 48844 PA 446
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/5 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 3/2/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

2. Plant Beaver Valley Power Station Sheet 1 of 1
Name
Shippingport, PA 15077
Address Unit No. 1

3. Work Performed by DlCo - Nuclear Const. Type Code Symbol Stamp Not Applicable
Name Authorization No.
Shippingport, PA 15077 Expiration Date
Address Repair Organization P.O. No., Job No., etc. MWR 893839

4. Identification of System Primary drains

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'7 Addenda Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A

6. Identification of Components Required or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Required, Replaced, or Replacement	ASME Code Stamped (Yes or No)
DG-56-3-S-01	Stone and Webster	-	-	Weld	-	Repaired	No

7. Description of Work Removed indications on weld. Min. wall not violated

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure psi Test Temp. °F
PT-89-286

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks: _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG. I Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/10/89 to 3/2/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Inspector's Signature Commissions 488441 P7266
National Board, State, Province, and Endorsements

Date 3/5 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

Date 3/2/90

Sheet 1 of 1

2. Plant Beaver Valley Power Station
Name
Shippingport, PA 15077
Address

Unit No. 1

MWR 892373
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DlCo - Mech. Maint.
Name
Shippingport, PA 15077
Address

Type Code Symbol Stamp Not Applicable

Authorization No.

Expiration Date

4. Identification of System Safety Injection

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda, Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
S1-51	Anchor Darling	-	-	Check Valve	-	Repaired	no
Bonnet stud	Cardinal	-	-	-	-	Replaced	no
Bonnet nut	Cardinal	-	-	-	-	Replaced	no

7. Description of Work Replaced galled stud/nut assembly

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure psi Test Temp. °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
 Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed *Thomas J. White* ENG 1 Date March 9 19 90
 Owner or Owner's Designer, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co.* of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/12/89 to 3/2/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

John R. Smith Commission ABPT-1 PA 226
 Inspector's Signature National Board, State, Province, and Endorsements

Date 3/2 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company
Name
One Oxford Centre - Pittsburgh, PA 15279
Address

Date 3/2/90
 Sheet 1 of 1

2. Plant Beaver Valley Power Station
Name
Shippingport, PA 15077
Address

Unit No. 1
MWR 894483
Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Nuclear Const.
Name
Shippingport, PA 15077
Address

Type Code Symbol Stamp Not Applicable
 Authorization No. -
 Expiration Date -

4. Identification of System Safety Injection

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'7 Addenda, - Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
SI-HSS-520	Grinnell	10894	-	Snubber	-	Repaired	No
Clamp	Grinnell	-	-	-	-	Replaced	No

7. Description of Work Replaced snubber clamp

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F
 Visual Exam.

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG I Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 11/11/89 to 3/2/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] MA 841 PKL66
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/7 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/28/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 894644
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by DlCo - Nuclear Const. Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address

4. Identification of System River Water

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda, " Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 83E-S'83A

6. Identification of Components Required or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Required, Replaced, or Replacement	ASME Code Stamped (Yes or No)
18" WR-14-151-03	Stone and Webster	-	-	-	-	repaired	no

7. Description of Work: Welded patch over thin wall area

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure TOP-1-89-24
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repaired conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp _____ Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed Roman J. L. [Signature] ENG I Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 12/7/89 to 2/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commission ND 924 P 246
Inspector's Signature National Board, State, Province, and Endorsements

Date _____ 19 _____

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
 As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 3/2/90
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 1
Address

2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077 MWR 893840
Address Repair Organization P.O. No., Job No., etc.

3. Work Performed by DLCo - Nuclear Const. Type Code Symbol Stamp Not Applicable
Name Authorization No. "
Shippingport, PA 15077 Expiration Date "
Address

4. Identification of System Primary Drains

5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda - Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements 19 B3E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
DG-56-3-F-04	Stone & Webster	-	-	Weld	-	Repaired	No

7. Description of Work Removed indications on socket weld fitting

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

PT-89-286

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

2. Remarks _____
 Applicable Manufacturer's Data Reports to be attached _____

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG. I Date March 9 19 90
 Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. * of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 10/10/89 to 3/2/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commission NO 8421 PA-226
 Inspector's Signature National Board, State, Province, and Endorsements

Date 3/5 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 2/28/90
Name
One Oxford Centre - Pittsburgh, PA 15279
Address
2. Plant Beaver Valley Power Station Unit No. 1
Name
Shippingport, PA 15077
Address MWR 891620
Repair Organization P.O. No., Job No., etc.
3. Work Performed by DlCo - Nuclear Construction Type Code Symbol Stamp Not Applicable
Name
Shippingport, PA 15077
Address Authorization No. _____
 Expiration Date _____
4. Identification of System River Water
5. (a) Applicable Construction Code B31.1 19 67 Edition, S'71 Addenda _____ Cor's Code _____
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is B3E-S'83A
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
18"-WR-15-151-Q3	Stone & Webster	-	-	-	-	Repaired	No

7. Description of Work Welded ^{patch} ~~patch~~ over pipe with pinhole leak.
8. Tests Conducted: Hydraulic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

TOP 1-89-24

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks _____
 Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this repair conforms to the rules of the ASME Code, Section XI.
repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed [Signature] ENG 1 Date March 9 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 12/7/89 to 2/28/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

[Signature] Commissions 20 PVT PR-1266
Inspector's Signature National Board, State, Province, and Endorsements

Date 3/7 19 90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 11/22/89
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet _____ of _____
Address
2. Plant Beaver Valley Power Station Unit _____
Name
Shippingport, PA 15077 DCP 1452; NCD
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by DlCo - NCD Type Code Symbol Stamp Not Applicable
Name Authorization No. _____
Shippingport, PA - NCD Expiration Date _____
Address
4. Identification of System Feedwater System (#24)
5. (a) Applicable Construction Code ASME III 19 65 Edition, W66 Addenda, 1429 Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements is 83E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
Unit 1 "B" Steam Gen.	Westinghouse	1302	68-46	RC-E-1B	1971	Repair	YES
Unit 1 "C" Steam Gen.	Westinghouse	1303	68-47	RC-E-1C	1971	Repair	YES

7. Description of Work Machining of 2" Inspection Openings in Lower Shell

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure _____ psi Test Temp. _____ °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks These 2" dia. inspection openings did not require reinforcement with
Applicable Manufacturer's Data Reports to be attached
weld-build-up material because the shell wall thickness at this location
is considerably over the minimum wall requirements.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this Repair conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed Richard D. Bologna / ENGINEER Date 2-22 19 90
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co.* of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 1/22/89 to 2/22/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

M.R. Smith Commissions NB 8741 PA 2266
Inspector's Signature National Board, State, Province, and Endorsements

Date 2/22 19 89

FORM NIS-3 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Name Date 12/20/89
One Oxford Centre - Pittsburgh, PA 15279 Address Sheet 1 of 1
2. Plant Beaver Valley Power Station Name Unit No. 1
Shippingport, PA 15077 Address TER 2800
DLC P.O. D080692/MWR 893963
Repair Organization P.O. No., Job No., etc.
3. Work Performed by DLC - NED/Babcock & Wilcox Name Type Code Symbol Stamp Not Applicable
Shippingport, PA 15077 Address Authorization No. _____
Expiration Date _____
4. Identification of System Reactor Coolant System (06)
5. (a) Applicable Construction Code ASME III 1965 Section W 66 Addenda 1429 Code Case _____
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1983E-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RC-E-1A Steam Gen.	Westinghouse	1301	68-45	Pa. Serial 434597	1971	Repair	YES

7. Description of Work: Thermal Stress Relief of Row 1 and 2 Tube U-bends
8. Tests Conducted: Hydrostatic Pneumatic Normal Operating Pressure
Other Pressure _____ ps Test Temp. _____ °F
Eddy Current Test per Technical Specifications

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks: N/A

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this REPAIR conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp Per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed William J. Sheaton / Engineer Date February 22, 1990
Owner or Owner's Representative, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Pennsylvania and employed by Arkwright Mutual Insurance Co. of Waltham, Massachusetts have inspected the components described in this Owner's Report during the period 2/22/90 to 2/22/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

*Factory Mutual Systems

W. J. Sheaton Inspector's Signature Commission No. 108831 PA 2265
National Board, State, Province, and Jurisdiction

Date 2/22 1990

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code Section XI

1. Owner Duquesne Light Company Date 12-19-89
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 1 of 2
Address
2. Plant Beaver Valley Power Station Unit BVPS-1
Name
Shippingport, PA 15077 DCP 698
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Duquesne Light Company Type Code Symbol Stamp Not Applicable
Name Authorization No. Not Applicable
Shippingport, PA 15077 Expiration Date Not Applicable
Address
4. Identification of System Reactor Coolant System - System Number 6
5. (a) Applicable Construction Code ANSI B31.1 1967 Edition Summer 1971 Addenda N/A Code Case
 (b) Applicable Edition of Section XI Utilized for Repairs or Replacements RIE-S'83A

6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RC - Loop A	Southwest Fabrication	29" RC-1-2501R	N/A	Penn. Spec. 5390	1968	Replacement	NO
RC - Loop A	Southwest Fabrication	31" RC-7-2501R	N/A	Penn. Spec. 5390	1968	Replacement	NO
RC - Loop A	Southwest Fabrication	27 1/2" RC 3-2501R	N/A	Penn. Spec. 5390	1968	Replacement	NO
RC - Loop B	Southwest Fabrication	29" RC-4-2501R	N/A	Penn. Spec. 5390	1968	Replacement	NO
RC - Loop B	Southwest Fabrication	32" RC-5-2501R	N/A	Penn. Spec. 5390	1968	Replacement	NO

7. Description of Work Removed RTD Bypass System, Modified RCS Loop RTD Bypass Connections.

8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
 Other Pressure 2280 psi Test Temp. 500 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks N/A

Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp per SAP 30 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A

Expiration Date N/A

Signed R.A. Hankin
Owner or Owner's Designee, Title

Lead Engineer

Date December 19, 1989

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of _____ and employed by ALLIANCE Fuel Gas Co. of _____ have inspected the components described in this Owner's Report during the period 2/27/90 to 3/27/90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

M.R. Smith
Inspector's Signature

Commissions NR-111 PA 111
National Board, State, Province, and Endorsements

Date 2/27/90

FORM NIS-2 OWNER'S REPORT FOR REPAIRS OR REPLACEMENTS
As Required by the Provisions of the ASME Code (Section XI)

1. Owner Duquesne Light Company Date 12-19-89
Name
One Oxford Centre - Pittsburgh, PA 15279 Sheet 2 of 2
Address
2. Plant Beaver Valley Power Station Unit BVPS-1
Name
Shippingport, PA 15077 DCP 698
Address Repair Organization P.O. No., Job No., etc.
3. Work Performed by Duquesne Light Company Type Code Symbol Stamp Not Applicable
Name Authorization No. Not Applicable
Shippingport, PA 15077 Expiration Date Not Applicable
Address
4. Identification of System Reactor Coolant System - System Number 6
5. (a) Applicable Construction Code ANSI B31.1 1967 Edition, Summer 1971 Addenda N/A Code Case
(b) Applicable Edition of Section XI Utilized for Repairs or Replacements 1983E-S'83A
6. Identification of Components Repaired or Replaced and Replacement Components

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other Identification	Year Built	Repaired, Replaced, or Replacement	ASME Code Stamped (Yes or No)
RC - Loop B	Southwest Fabrication	27 1/2" RC 6-2501R	N/A	Penn. Spec. 5390	1968	Replacement	NO
RC - Loop C	Southwest Fabrication	29" RC- 7-2501R	N/A	Penn. Spec. 5390	1968	Replacement	NO
RC - Loop C	Southwest Fabrication	31" RC- 8-2501R	N/A	Penn. Spec. 5390	1968	Replacement	NO
RC - Loop C	Southwest Fabrication	27 1/2" RC 9-2501R	N/A	Penn. Spec. 5390	1968	Replacement	NO

7. Description of Work Removed RTD Bypass System. Modified RCS Loop RTD Bypass Connections.
8. Tests Conducted: Hydrostatic Pneumatic Nominal Operating Pressure
Other Pressure 2280 psi Test Temp. 500 °F

NOTE: Supplemental sheets in form of lists, sketches, or drawings may be used, provided (1) size is 8 1/2 in. x 11 in., (2) information in items 1 through 6 on this report is included on each sheet, and (3) each sheet is numbered and the number of sheets is recorded at the top of this form.

FORM NIS-2 (Back)

9. Remarks N/A
Applicable Manufacturer's Data Reports to be attached

CERTIFICATE OF COMPLIANCE

We certify that the statements made in the report are correct and this replacement conforms to the rules of the ASME Code, Section XI. repair or replacement

Type Code Symbol Stamp per SAP 39 "ASME Section XI Repair/Replacement Program"

Certificate of Authorization No. N/A Expiration Date N/A

Signed R. Q. Hardy Jr Lead Engineer Date December 19, 19 89
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of _____ and employed by Rockwell International Corp of _____ have inspected the components described in this Owner's Report during the period 2/12/90 to 2/22/90, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

[Signature] Commission 28924 PA 2166
Inspector's Signature National Board, State, Province, and Endorsements

Date 2/22 19 90

APPENDIX VI

NRC Special Report

Title: Beaver Valley Unit No. 1
1989 Seventh Refueling Outage
Steam Generator Tube Inservice
Inservice Results
Twelve Month Special Report

STEAM GENERATORS (ET)

One hundred percent of the in-service tubes were examined in the three steam generators; RC-E-1A (S/G A), RC-E-1B (S/G B), and RC-E-1C (S/G C), following the first sample examination of 3352 tubes in S/G B resulting into a C-3 Category examination.

The tubes were examined by Babcock and Wilcox, (B&W) with the primary analysis performed using the B&W Automated Data Screening, Rev. 5.0. An independent second party analysis review for all bobbin coil examinations was performed manually by ECHORAM Technology, Inc.

The examinations and evaluations were performed in compliance with the Duquesne Light Company Beaver Valley No. 1 Technical Specification, NRC Regulatory Guide 1.83 and the EPRI Steam Generator Examination Guidelines: Revision 2.

BOBBIN COIL EXAMINATION

The bobbin coil examination was the primary eddy current examination with the exception of the Row 1 and 2 u-bend regions in which a rotating pancake coil probe was used for detection and sizing defects in this area.

Prior to the bobbin coil examinations a probe speed comparison study was performed at 18, 20, and 24 inches per second on ten tubes in S/G B. It was concluded the 20 inch per second probe speed would be acceptable for the data acquisition. This included an ANII reviewing, witnessing and accepting the faster probe speed.

Tube location and percent through wall depth for each bobbin coil indication are listed in Attachment I. The following table summarizes the results of the bobbin coil examinations:

	S/G A	S/G B	S/G C
No. of tubes examined	3310	3352	3360
≥40% TWD	56	39	15
20 - 39% TWD	96	115	43
<20% TWD	31	46	33
DSI	411	179	168

%TWD = % through wall depth

DSI = distorted support plate indication

ROTATING EDDY CURRENT

The B&W rotating pancake coil (RPC) system was used to acquire primary data from the Row 1 and 2 u-bend region. Note that only the S/G A tubes in the Row 1 and 2 u-bend region were stress relieved (UBSR) this outage and RPC was performed before and after the stress relief activity.

Tube location and percent through wall depth for the RPC indications at the Row 1 and 2 u-bend region are listed in Attachment II. The following table summarizes the RPC examination results in the u-bend region:

	S/G A	S/G B	S/G C
Row 1 & 2 U-bends examined	154	177	184
U-bends with \geq TWD	8	1	0
Row 1 & 2 U-bends post UBSR	146	N/A	N/A
U-bends with \geq TWD post UBSR	0	N/A	N/A

Supplemental data as a result of the bobbin coil examinations identifying tubes with DSI's was obtained with the RPC method to further characterize the defect.

The following table summarizes the RPC results. The tube location and \geq TWD are listed in Attachment III.

	S/G A	S/G B	S/G C
Tubes examined with DSI's	525	280	224
\geq 40% TWD	32	12	3
20 - 39% TWD	166	36	34
<20% TWD	78	159	44

Additional data was obtained on selected tubes with areas of concern by using the RPC method.

The following tables summarize the RPC results. Attachment IV identifies the tube locations and \geq TWD.

Tubes examined in the Wextex region	33	169	0
\geq 40% TWD	0	5	0
20 - 39% TWD	0	0	0
<20% TWD	0	0	0

Tubes with no roll expansion examined for Cold Leg Wastage	34	0	0
\geq 40% TWD	0	0	0
20 - 39% TWD	22	0	0
<20% TWD	24	0	0

Tubes with roll expansion at the 1 & 2 cold leg tube support plate examined for Cold Leg Wastage	37	0	0
\geq 40% TWD	1	0	0
20 - 39% TWD	21	0	0
<20% TWD	13	0	0

LOOSE PARTS EXAMINATION

A loose parts analysis for the three steam generators was performed to detect possible loose parts in the outer three rows of the steam generators. The results identified the presence of loose parts at two tubes in S/G A and C and three tubes in S/G B. The parts were retrieved with a post examination being performed.

ROTATING PROBE ULTRASONIC EXAMINATION

A total of six tube support plate (TSP) intersections were examined in two tubes with the B&W UT-360 system. Each intersection was examined with both an angle beam transducer looking for axial cracks and a zero degree beam transducer. The angle beam examinations provided no evidence of axial cracks of any substantial depth or axial extent. Zero degree examinations of TSP locations provided indications of reduced and disrupted backwall responses similar to those observed in laboratory samples containing inter-granular attack, (IGA).

TUBES PLUGGED AND STABILIZED

The following table summarizes the tubes plugged and tubesheet stabilizers installed as a result of the examinations performed this outage. Attachment V identifies the tubes plugged.

	S/G A	S/G B	S/G C
No. of tubes plugged (total)	86	45	19
No. of tubes preventively plugged	30	5	4
No. of tubes stabilized (hot leg only)	2	6	4

- Preventatively plugged = 1. Any Row 1 or 2 tube with any % TWD loss in the u-bend region was removed from service.
2. Tubes removed from service as a result of RPC examinations exhibiting wall degradation of $\geq 40\%$ TWD.

Tubesheet stabilizer locations are:

<u>S/G B</u>		<u>S/G B</u>		<u>S/G C</u>	
Tube	Column	Tube	Column	Tube	Column
11	34	1	87	30	16
14	35	2	87	31	16
		3	87	44	55
		4	87	44	56
		5	87		
		33	16		

ATTACHMENT I

Plant: Beaver Valley Unit 1
Date: 9/89 RES

Steam Generator: A

QUERY: BOBBIN INDICATIONS ** 40% T_v

TFS*	ROW	COL	IND	STW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
B&W BOB	2	32	001	50	4.00	M2	100	1H	* 0.40	7H	33	84373
B&W BOB	2	34	001	42	2.50	M2	107	1H	* 0.40	7H	33	84373
B&W BOB	2	46	001	40	2.40	M2	113	3H	* 0.20	7H	30	L1107
B&W BOB			001	53	2.40	M2	113	1H	* 0.10	7H	30	S2680
B&W BOB	2	63	001	49	1.20	M2	104	1H	* 0.20	7H	30	L1107
B&W BOB			001	46	1.00	M2	104	1H	* 0.40	7H	33	84373
B&W BOB	3	1	001	68	1.50	M2	88	1H	* 0.10	7H	30	S2680
B&W BOB	3	2	001	52	1.40	M2	104	1H	* 0.10	7H	30	S2680
B&W BOB	3	39	001	41	1.90	M2	115	1H	* 0.10	7H	65	L1107
B&W BOB	3	75	001	48	3.40	M2	102	1H	* 0.00	7H	33	H3921
B&W BOB	4	13	001	45	1.40	M2	101	2H	* 0.10	FL	26	N0942
B&W BOB	4	18	001	42	2.50	M2	103	1H	* 0.10	FL	64	H3921
B&W BOB	4	43	001	40	3.90	M2	108	1H	- 0.20	FL	7	H8259
B&W BOB	4	64	001	53	3.00	M2	104	1H	* 0.40	FL	53	S2680
B&W BOB	5	6	001	57	1.30	M2	81	1H	* 0.00	FL	56	N0942
B&W BOB	5	37	001	45	1.20	M2	104	1H	* 0.20	FL	7	N0942
B&W BOB	5	38	001	42	2.50	M2	106	1H	- 0.10	FL	7	H8259
B&W BOB	5	45	001	45	1.40	M2	104	1H	- 0.10	FL	7	H8259
B&W BOB	6	4	001	56	2.20	M2	95	1H	* 0.00	FL	56	H3921
B&W BOB	6	31	001	57	1.10	M2	99	1H	- 0.20	FL	25	H8259
B&W BOB	6	34	001	49	1.30	M2	105	1H	- 0.10	FL	25	H8259
B&W BOB	6	40	001	41	1.70	M2	107	1H	* 0.10	FL	7	H8259
B&W BOB	6	77	001	40	1.70	M2	99	1H	* 0.10	FL	52	H8259
B&W BOB	7	34	001	41	2.80	M2	112	1H	* 0.10	FL	25	H8259
B&W BOB	7	45	001	48	1.80	M2	106	1H	* 0.30	FL	6	84373
B&W BOB	7	60	001	46	2.30	M2	98	1H	* 0.10	7H	27	L1107
B&W BOB	8	2	001	63	1.30	M2	83	1H	* 0.00	FL	64	H3921
B&W BOB	8	33	001	48	2.50	M2	106	1H	- 0.10	FL	25	S2680
B&W BOB	10	14	001	43	2.30	M2	108	1H	- 0.10	FL	24	H8259
B&W BOB	10	27	001	46	1.20	M2	104	1H	- 0.10	FL	24	H8259
B&W BOB	11	41	001	48	2.30	M2	102	1H	- 0.20	FL	5	H8259
B&W BOB	11	45	001	48	1.10	M2	100	1H	- 0.20	FL	6	S2680
B&W BOB	12	38	001	52	1.90	M2	99	1H	- 0.10	FL	5	H8259
B&W BOB	12	45	001	41	1.80	M2	108	1H	- 0.10	FL	5	H8259
B&W BOB	14	35	001	49	2.00	M2	91	1H	- 0.20	FL	5	S2680
B&W BOB	15	31	001	41	3.90	M2	114	1H	* 0.10	FL	22	H3921
B&W BOB	17	59	001	45	4.70	M2	104	1H	* 0.00	FL	48	H3921
B&W BOB	19	14	001	49	3.90	M2	108	1H	- 0.40	FL	20	S2680
B&W BOB	20	25	001	49	1.90	M2	109	1H	- 0.40	FL	20	S2680
B&W BOB	20	28	001	49	3.20	M2	109	1H	- 0.40	FL	20	S2680
B&W BOB	22	74	001	66	1.70	M2	87	1H	* 0.00	FL	44	L1107
B&W BOB	24	85	001	46	1.00	M3	100	1C	- 0.10	FL	7	N0942
B&W BOB	25	30	001	67	2.00	M2	80	2H	- 0.10	FL	17	H8259
B&W BOB	26	62	001	42	1.50	M2	114	1H	- 0.10	FL	42	S2680
B&W BOB	27	72	001	47	1.00	M2	106	1H	* 0.00	FL	42	L1107
B&W BOB	27	74	001	51	1.80	M2	101	1H	- 0.10	FL	42	L1107
B&W BOB	29	20	001	41	1.20	M2	100	2H	- 0.40	FL	14	84373
B&W BOB	29	24	001	57	1.00	M2	89	1H	- 0.40	FL	14	84373
B&W BOB	31	18	001	82	1.20	M2	82	1H	* 0.00	FL	13	S2680
B&W BOB	31	73	001	55	1.90	M2	108	1H	- 0.20	FL	37	S2680
B&W BOB	32	42	001	40	3.90	M4	0	AV4	* 0.00	FL	12	S2680
B&W BOB	33	32	001	72	1.20	M2	83	1H	- 0.40	FL	12	84373
B&W BOB	33	77	001	44	1.50	M3	106	3C	- 0.20	FL	58	S2680
B&W BOB	35	30	001	64	1.20	M2	88	1H	- 0.10	FL	11	H8259
B&W BOB	35	31	001	41	2.10	M2	100	1H	* 0.00	FL	11	S2680
B&W BOB	37	23	001	45	1.40	M3	109	1C	- 0.20	FL	4	S2680
B&W BOB	37	25	001	48	1.80	M2	110	2H	- 0.40	FL	4	S2680
B&W BOB	37	32	001	48	1.20	M2	103	2H	- 0.10	FL	4	S2680

TOTAL TUBES FOUND * 56
TOTAL INDICATIONS FOUND * 58
TOTAL TUBES IN INPUT FILE * 3368

Plant: Beaver Valley Unit 1
Date: 9/89 RES

Steam Generator: A

QUERY: BOBBIN INDICATIONS 20 TO 39% TW

TEST	ROW	COL	IND	XTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	RWLIST	COMMENTS
B&W BOB	1	4	001	35	3.10	1	136	TSH	+ 17.00	7H	30	L1107
B&W BOB	2	34	001	26	1.10	M2	119	3H	+ 0.00	7H	33	S4373
B&W BOB	2	46	001	30	1.10	M2	120	2H	+ 0.20	7H	30	L1107
B&W BOB	2	93	001	27	2.70	M3	130	1C	+ 0.00	7C	10	S4373
B&W BOB	3	6	001	36	1.90	M2	115	2H	+ 0.10	7H	30	L1107
B&W BOB			001	30	1.00	M2	120	1H	+ 0.00	7H	30	L1107
B&W BOB	3	31	001	34	2.60	M2	113	1H	+ 0.00	7H	33	S4373
B&W BOB	3	37	001	32	2.00	M1	110	1H	+ 0.00	7H	65	S2680
B&W BOB	3	38	001	39	2.70	M2	116	1H	+ 0.10	7H	65	L1107
B&W BOB	3	72	001	24	1.20	M2	121	1H	+ 0.00	7H	33	S2680
B&W BOB	4	8	001	37	1.30	M2	111	2H	- 0.10	FL	56	H3921
B&W BOB	4	16	001	38	1.80	M2	115	1H	- 0.30	FL	28	M0942
B&W BOB	4	25	001	36	4.40	M2	118	1H	- 0.30	FL	28	M0942
B&W BOB	4	29	001	26	3.80	M2	122	1H	- 0.40	FL	28	S4373
B&W BOB	4	34	001	34	1.40	M2	118	1H	- 0.40	FL	28	M0942
B&W BOB	4	40	001	38	2.00	M2	109	1H	- 0.10	FL	7	H8259
B&W BOB	4	43	001	31	1.50	M2	115	2H	- 0.10	FL	7	H8259
B&W BOB	4	44	001	38	2.20	M2	106	1H	- 0.10	FL	7	M0942
B&W BOB	4	69	001	25	1.60	M2	125	2H	+ 0.20	FL	53	S4373
B&W BOB	5	2	001	21	0.70	M3	122	2C	+ 0.10	FL	56	H3921
B&W BOB	5	26	001	39	1.10	M2	110	1H	- 0.30	FL	28	M0942
B&W BOB	5	78	001	33	1.40	M2	124	1H	+ 0.10	FL	53	S2680
B&W BOB	6	26	001	29	1.20	M2	117	1H	- 0.30	FL	28	M0942
B&W BOB	6	37	001	36	3.00	M2	110	2H	- 0.10	FL	7	H8259
B&W BOB	6	38	001	24	1.90	M2	121	1H	- 0.10	FL	7	H8259
B&W BOB	6	39	001	31	1.50	M2	115	2H	- 0.10	FL	7	H8259
B&W BOB	6	45	001	34	1.30	M2	112	1H	- 0.10	FL	7	H8259
B&W BOB	6	46	001	39	1.90	M2	108	1H	- 0.10	FL	6	S2680
B&W BOB	7	9	001	32	2.80	M2	115	1H	+ 0.00	FL	56	H3921
B&W BOB			001	21	2.00	M2	123	3H	- 0.10	FL	56	H3921
B&W BOB	7	13	001	20	2.10	M2	130	2H	- 0.10	FL	25	S2680
B&W BOB	7	15	001	36	1.60	M2	117	1H	- 0.10	FL	25	H8259
B&W BOB	7	29	001	38	2.20	M2	115	1H	- 0.10	FL	25	H8259
B&W BOB	7	35	001	28	2.20	M2	121	1H	+ 0.30	FL	6	S4373
B&W BOB	7	46	001	39	1.10	M2	112	1H	- 0.40	FL	6	S4373
B&W BOB	8	8	001	32	1.70	M1	112	1H	+ 0.00	FL	64	S2680
B&W BOB	8	33	001	31	3.90	M2	120	3H	+ 0.10	FL	25	S2680
B&W BOB	8	37	001	34	2.60	M2	116	1H	- 0.30	FL	6	S4373
B&W BOB	9	24	001	29	1.40	M2	126	1H	+ 0.00	FL	25	S2680
B&W BOB	9	28	001	34	0.90	M2	112	1H	- 0.10	FL	25	S2680
B&W BOB	9	30	001	34	1.40	M2	118	1H	- 0.10	FL	25	H8259
B&W BOB	9	88	001	35	1.10	M2	98	2H	+ 0.10	FL	9	H3921
B&W BOB	10	36	001	27	2.90	M2	122	1H	- 0.30	FL	6	S4373
B&W BOB	10	67	001	35	4.00	M2	113	2H	+ 0.00	FL	51	S4373
B&W BOB	11	15	001	28	1.10	M2	121	1H	- 0.10	FL	24	H8259
B&W BOB	11	34	001	38	0.70	M1	134	TSH	+ 1.20	FL	24	S2680
B&W BOB			001	34	0.70	M1	121	TSH	+ 1.40	FL	24	S2680
B&W BOB	12	92	001	25	1.40	M3	130	1C	- 0.10	FL	8	M0942
B&W BOB	14	4	001	25	2.00	M3	120	1C	+ 0.10	FL	38	S4373
B&W BOB	14	35	001	23	2.30	1	155	TSH	+ 1.80	FL	5	S2680
B&W BOB	15	56	001	28	6.20	M2	112	1H	+ 0.40	FL	29	H3921
B&W BOB	16	60	001	35	3.00	M2	107	1H	+ 0.20	FL	29	H3921
B&W BOB	17	5	001	30	2.30	M3	116	1C	- 0.20	FL	38	S4373
B&W BOB	19	6	001	24	1.70	M3	122	1C	- 0.20	FL	38	S4373
B&W BOB	19	29	001	30	1.70	M2	126	2H	- 0.40	FL	20	S2680
B&W BOB	20	25	001	37	1.20	1	114	3H	- 0.40	FL	20	S2680
B&W BOB	21	60	001	34	1.60	M2	126	1H	- 0.20	FL	45	S2680
B&W BOB	22	9	001	25	1.80	M3	121	1C	+ 0.10	FL	38	S4373
B&W BOB	24	51	001	27	1.40	M4	129	AV1	- 1.10	FL	43	S2680
B&W BOB	25	9	001	21	1.00	M2	0	AV4	+ 0.00	FL	64	S2680
B&W BOB	25	18	001	33	2.50	M1	111	2H	+ 0.00	FL	64	S2680
B&W BOB	26	10	001	29	2.20	M3	117	1C	- 0.10	FL	38	S4373
B&W BOB	26	11	001	35	1.10	M2	114	1H	+ 0.00	FL	57	M0942
B&W BOB	26	59	001	34	2.00	M2	120	2H	+ 0.10	FL	42	L1107
B&W BOB	27	35	001	22	1.20	M4	0	7H	+ 33.00	FL	16	S4373
B&W BOB			001	26	1.80	M4	0	7H	+ 47.00	FL	16	S4373
B&W BOB			001	33	2.40	M4	0	7C	+ 48.00	FL	16	S4373
B&W BOB	29	14	001	23	1.20	M3	129	1C	- 0.20	FL	14	S2680
B&W BOB	30	14	001	22	1.20	M3	124	1C	- 0.20	FL	14	S4373
B&W BOB	30	36	001	23	1.90	M2	115	2H	- 0.10	FL	14	S4373

Plant: Beaver Valley Unit 1
 Stage: 9/89 RES

Steam Generator: A

QUERY: BOBBIN INDICATIONS 20 TO 39% TW

TEST	ROW	COL	IND	TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
B&W BOB	31	15	001	31	3.80	M3	122	2C	+ 0.00	FL	13	H8259
B&W BOB			001	32	2.50	M3	122	1C	+ 0.20	FL	13	H8259
B&W BOB	31	23	001	33	7.00	1	139	15H	+ 43.00	FL	13	H8259
B&W BOB	31	69	WAR	28	1.60	M4	0	AV1	+ 0.00	FL	37	H8259
B&W BOB	32	32	WAR	34	3.80	M4	0	AV1	+ 0.00	FL	13	S2680
B&W BOB			WAR	27	3.40	M4	0	AV2	+ 0.00	FL	13	S2680
B&W BOB			WAR	29	1.80	M4	0	AV3	+ 0.00	FL	13	S2680
B&W BOB			WAR	24	1.30	M4	0	AV4	+ 0.00	FL	13	S2680
B&W BOB	32	42	001	28	1.50	M4	0	AV2	+ 0.00	FL	12	S2680
B&W BOB			001	33	1.20	M4	0	AV3	+ 0.00	FL	12	S2680
B&W BOB	32	67	001	34	1.90	M2	133	1H	+ 0.10	FL	37	S2680
B&W BOB	33	17	001	28	1.50	M4	29	AV4	+ 0.00	FL	12	S4373
B&W BOB	33	18	001	36	2.40	M3	118	1C	+ 0.20	FL	12	S4373
B&W BOB	33	56	001	23	1.20	M4	0	AV1	+ 0.00	FL	58	H8259
B&W BOB			001	29	1.40	M4	0	AV2	+ 0.00	FL	58	H8259
B&W BOB			001	31	1.60	M4	0	AV3	+ 0.00	FL	58	H8259
B&W BOB	33	64	001	27	2.20	M2	118	2H	+ 0.10	FL	58	H8259
B&W BOB	33	79	001	32	3.20	M3	130	3C	+ 0.10	FL	37	H8259
B&W BOB	35	17	001	23	1.30	M3	132	2C	+ 0.10	FL	11	L1107
B&W BOB	36	19	001	22	1.60	M3	133	1C	+ 0.20	FL	11	L1107
B&W BOB	36	36	001	30	0.70	M2	118	2H	+ 0.40	FL	10	S4373
B&W BOB	37	19	001	37	1.50	M3	117	2C	+ 0.20	FL	4	S2680
B&W BOB	37	71	001	34	1.00	M2	112	1H	+ 0.10	FL	34	H8259
B&W BOB	38	25	001	31	0.90	M3	132	1C	+ 0.10	FL	4	S4373
B&W BOB	38	36	001	34	1.70	M2	123	3H	+ 0.10	FL	4	S2680
B&W BOB	38	48	001	32	1.70	M2	114	1H	+ 0.00	FL	34	H8259
B&W BOB	38	54	001	37	1.30	M2	118	2H	+ 0.10	FL	34	H8259
B&W BOB	39	24	001	27	1.80	M3	132	2C	+ 0.00	FL	3	L1107
B&W BOB			001	27	1.30	M3	132	1C	+ 0.20	FL	3	L1107
B&W BOB	40	27	001	30	3.00	M3	128	2C	+ 0.10	FL	3	L1107
B&W BOB	40	44	001	35	2.50	M4	68	AV2	+ 4.20	FL	3	S2680
B&W BOB	41	57	WAR	23	1.30	M4	0	AV3	+ 0.30	FL	31	H3921
B&W BOB			WAR	34	2.50	M4	0	AV4	+ 0.00	FL	31	H3921
B&W BOB	42	29	001	21	2.20	M3	132	1C	+ 0.10	FL	2	L1107
B&W BOB	43	33	001	24	1.40	M3	128	2C	+ 0.20	FL	2	L1107
B&W BOB	43	35	001	25	1.80	M3	127	3C	+ 0.20	FL	2	L1107
B&W BOB			001	22	1.80	M3	131	2C	+ 0.10	FL	2	L1107
B&W BOB	43	38	001	21	1.40	M2	132	1H	+ 0.30	FL	2	L1107
B&W BOB	45	39	001	25	2.00	M3	127	4C	+ 0.10	FL	2	S2680
B&W BOB	45	59	001	28	3.40	M3	121	3C	+ 0.10	FL	26	L1107
B&W BOB	46	42	001	33	3.00	M3	109	2C	+ 0.10	FL	1	S4373

TOTAL TUBES FOUND * 96
 TOTAL INDICATIONS FOUND * 111
 TOTAL TUBES IN INPUT FILE * 3388

Plant: Beaver Valley Unit 1
 Date: 9/89 RES

Steam Generator: A

QUERY: BOBBIN INDICATIONS * 20X TW

TEST	ROW	COL	IND	XTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
56W BOB	3	34	001	19	1.00	1	165	2H	+ 31.40	7N	33	54373
56W BOB	4	20	001	19	1.30	M2	130	4H	- 0.20	FL	28	N0942
56W BOB	10	2	001	19	0.90	M3	150	2C	- 0.20	FL	40	L1107
56W BOB	15	90	001	19	1.10	M3	141	1C	- 0.10	FL	8	54373
56W BOB	16	4	001	19	1.30	M3	147	1C	+ 0.00	FL	38	54373
56W BOB	17	5	001	19	1.00	M3	143	2C	+ 0.10	FL	38	54373
56W BOB	18	89	001	19	1.10	M3	141	1C	- 0.10	FL	8	54373
56W BOB	19	6	001	19	1.00	M3	135	2C	+ 0.20	FL	38	54373
56W BOB	21	22	001	11	0.60	M4	0	AV2	+ 0.00	FL	64	H3921
56W BOB	22	80	001	18	1.00	M4	116	AV4	+ 0.00	FL	44	L1107
56W BOB	24	51	WAR	13	0.90	M4	90	AV4	+ 0.00	FL	43	54373
56W BOB			WAR	14	1.00	M4	111	AV3	+ 0.00	FL	43	54373
56W BOB	25	65	001	11	0.80	M4	51	AV4	+ 0.00	FL	43	54373
56W BOB	26	34	001	16	0.90	M4	141	AV4	+ 0.00	FL	16	N0942
56W BOB	29	84	001	19	1.40	M3	148	3C	- 0.10	FL	41	L1107
56W BOB	30	53	WAR	12	0.70	M4	0	AV2	+ 0.00	FL	39	H3921
56W BOB	31	23	001	19	0.60	1	150	TSH	+ 34.00	FL	13	H8259
56W BOB	33	43	001	12	0.70	M4	56	AV1	+ 0.00	FL	12	54373
56W BOB	33	56	001	19	1.10	M4	0	AV4	+ 0.00	FL	58	H8259
56W BOB	36	61	001	16	0.80	M4	0	AV2	+ 0.00	FL	58	H8259
56W BOB	36	66	001	14	0.80	M4	0	AV4	+ 0.00	FL	35	H8259
56W BOB	38	24	001	19	1.00	M3	149	1C	+ 1.10	FL	4	54373
56W BOB	40	25	001	19	1.50	M3	137	1C	+ 0.00	FL	3	S2680
56W BOB	41	65	001	19	1.50	M3	146	1C	- 0.20	FL	32	S2680
56W BOB	42	29	001	19	1.40	M3	135	2C	- 0.20	FL	2	L1107
56W BOB	42	67	001	15	1.50	M3	128	3C	- 0.10	FL	31	S2680
56W BOB	43	30	001	19	1.60	M3	140	3C	- 0.10	FL	2	L1107
56W BOB	43	31	001	19	2.00	M3	144	3C	- 0.20	FL	2	L1107
56W BOB	44	33	001	19	1.70	M3	141	3C	- 0.10	FL	2	S2680
56W BOB	44	37	001	19	1.40	M3	134	3C	- 0.20	FL	2	S2680
56W BOB	44	38	001	19	1.30	1	149	1C	- 0.10	FL	2	S2680
56W BOB	45	38	001	19	1.30	M3	141	3C	- 0.20	FL	2	S2680

TOTAL TUBES FOUND * 31
 TOTAL INDICATIONS FOUND * 32
 TOTAL TUBES IN INPUT FILE * 3368

Plant: Beaver Valley Unit 1
 Date: 9/89 RES

Steam Generator: A

QUERY: BOBBIN INDICATIONS - DBI

TEST	ROW	COL	IND	XTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
B&V BOB	1	17	DBI		0.90	H2	114	2H	- 0.10	7H	33	64373
B&V BOB			DBI		0.90	H2	104	1H	+ 0.40	7H	33	64373
B&V BOB	1	28	DBI		1.20	H2	113	1H	+ 0.40	7H	33	64373
B&V BOB	1	33	DBI		0.90	H2	121	3H	+ 0.10	7H	33	64373
B&V BOB			DBI		0.80	H2	104	1H	+ 0.40	7H	33	64373
B&V BOB	1	34	DBI		1.50	H2	88	1H	+ 0.40	7H	33	64373
B&V BOB	1	43	DBI		1.10	H2	116	1H	+ 0.00	7H	53	64373
B&V BOB	1	46	DBI		0.90	H2	99	1H	+ 0.00	7H	30	62680
B&V BOB			DBI		1.00	H2	117	1H	+ 0.40	7H	53	62680
B&V BOB	2	1	DBI		1.20	H2	111	2H	+ 0.10	7H	30	L1107
B&V BOB	2	2	DBI		1.00	H2	102	2H	+ 0.10	7H	30	L1107
B&V BOB	2	8	DBI		0.70	H2	130	1H	+ 0.10	7H	30	L1107
B&V BOB	2	9	DBI		0.90	H2	89	1H	+ 0.10	7H	30	L1107
B&V BOB	2	26	DBI		1.10	H2	93	1H	+ 0.30	7H	33	64373
B&V BOB	2	29	DBI		1.10	H2	119	1H	+ 0.00	7H	33	64373
B&V BOB	2	30	DBI		1.10	H2	113	1H	+ 0.40	7H	33	64373
B&V BOB	2	31	DBI		1.50	H2	134	1H	+ 0.00	7H	33	64373
B&V BOB	2	32	DBI		1.20	H2	128	3H	+ 0.40	7H	33	64373
B&V BOB	2	34	DBI		1.00	H2	108	2H	+ 0.10	7H	33	62680
B&V BOB	2	37	DBI		0.90	H2	118	1H	- 0.10	7H	53	64373
B&V BOB	2	53	DBI		0.80	H2	109	1H	+ 0.00	7H	29	62680
B&V BOB	2	54	DBI		1.20	H2	120	1H	+ 0.00	7H	29	K3921
B&V BOB	2	63	DBI		0.90	H2	110	2H	+ 0.10	7H	30	L1107
B&V BOB			DBI		1.00	H2	111	2H	+ 0.30	7H	33	62680
B&V BOB	2	69	DBI		0.60	H2	123	1H	+ 0.40	7H	33	64373
B&V BOB	2	70	DBI		0.60	H2	106	2H	+ 0.10	7H	33	64373
B&V BOB	2	73	DBI		0.70	H2	99	1H	+ 0.40	7H	33	64373
B&V BOB	2	79	DBI		1.20	H2	123	1H	+ 0.10	7H	33	64373
B&V BOB	2	86	DBI		1.10	H2	160	2H	+ 0.40	7H	33	64373
B&V BOB	3	2	DBI		0.70	H2	102	2H	+ 0.10	7H	30	L1107
B&V BOB	3	3	DBI		0.70	H2	126	2H	+ 0.20	7H	30	L1107
B&V BOB	3	5	DBI		1.20	H2	120	1H	+ 0.20	7H	30	62680
B&V BOB	3	22	DBI		2.00	H2	122	1H	+ 0.00	7H	33	64373
B&V BOB	3	23	DBI		1.60	H2	151	2H	+ 0.30	7H	33	64373
B&V BOB			DBI		2.10	H2	119	1H	+ 0.10	7H	33	64373
B&V BOB	3	27	DBI		1.00	H2	112	1H	+ 0.00	7H	33	62680
B&V BOB			DBI		1.40	H2	119	2H	- 0.10	7H	33	64373
B&V BOB	3	28	DBI		3.50	H2	111	1H	+ 0.00	7H	33	64373
B&V BOB	3	34	DBI		0.80	H2	114	1H	+ 0.40	7H	33	64373
B&V BOB	3	37	DBI		1.10	H2	116	2H	- 0.10	7H	65	L1107
B&V BOB	3	38	DBI		1.50	H2	113	2H	- 0.20	7H	65	L1107
B&V BOB	3	42	DBI		1.50	H2	109	1H	- 0.10	7H	65	62680
B&V BOB	3	45	DBI		0.70	H2	135	1H	+ 0.20	7H	30	L1107
B&V BOB	3	52	DBI		1.30	H2	106	1H	+ 0.00	7H	29	K3921
B&V BOB	3	53	DBI		0.90	H2	96	1H	+ 0.10	7H	29	K3921
B&V BOB	3	56	DBI		0.80	H2	108	2H	+ 0.00	7H	29	62680
B&V BOB			DBI		1.50	H2	112	1H	- 0.10	7H	29	K3921
B&V BOB	3	57	DBI		0.70	H2	124	2H	+ 0.10	7H	29	K3921
B&V BOB			DBI		0.70	H2	97	1H	+ 0.00	7H	29	K3921
B&V BOB	3	59	DBI		1.30	H2	106	1H	+ 0.10	7H	29	K3921
B&V BOB	3	61	DBI		0.60	H2	133	1H	- 0.20	7H	29	K3921
B&V BOB	3	62	DBI		0.70	H2	119	2H	+ 0.00	7H	29	K3921
B&V BOB			DBI		1.10	H2	124	1H	+ 0.10	7H	29	K3921
B&V BOB	3	63	DBI		0.70	H2	110	1H	+ 0.00	7H	33	62680
B&V BOB	3	65	DBI		0.90	H2	117	2H	+ 0.10	7H	33	K3921
B&V BOB			DBI		1.10	H2	128	1H	+ 0.20	7H	33	K3921
B&V BOB	3	71	DBI		1.00	H2	95	1H	+ 0.10	7H	33	K3921
B&V BOB	3	75	DBI		1.20	H2	95	2H	+ 0.00	7H	33	62680
B&V BOB	3	78	DBI		2.40	H2	94	1H	+ 0.20	7H	33	62680
B&V BOB	3	84	DBI		0.80	H2	98	1H	+ 0.10	7H	33	K3921
B&V BOB	4	2	DBI		1.60	H2	87	2H	- 0.10	FL	57	K3921
B&V BOB	4	4	DBI		1.00	H2	122	1H	+ 0.00	FL	57	K3921
B&V BOB	4	6	DBI		1.20	H2	113	1H	+ 0.00	FL	57	N0942
B&V BOB	4	12	DBI		0.70	H2	105	1H	- 0.10	FL	26	L1107
B&V BOB	4	13	DBI		0.70	H2	126	1H	+ 0.00	FL	26	N0942
B&V BOB			DBI		0.70	H2	131	3H	- 0.10	FL	26	N0942
B&V BOB	4	15	DBI		0.80	H2	110	1H	- 0.20	FL	28	64373
B&V BOB	4	18	DBI		0.90	H2	115	2H	- 0.10	FL	64	K3921
B&V BOB	4	20	DBI		2.20	H2	116	1H	- 0.30	FL	28	N0942
B&V BOB	4	25	DBI		1.00	H2	125	2H	- 0.30	FL	28	N0942

Plant: Beaver Valley Unit 5
 Stage: 9/89 RES

Steam Generator: B

QUERY: BOBBIN INDICATIONS ** 40% TW

TEST	ROW	COL	IND	XTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TYPE	ANLST	COMMENTS
B&W	BOB	1	9	001	57	1.80	M3	106	1H	+ 0.00	7N	29 S2680
B&W	BOB	1	19	001	45	1.60	M3	104	1H	+ 0.10	7N	29 L1107
B&W	BOB	1	91	001	47	7.50	1	119	TSH	+ 17.00	7N	29 L1107
B&W	BOB	2	37	001	42	1.50	M3	108	1H	+ 0.40	7N	29 S2680
B&W	BOB	3	13	001	45	1.60	M2	109	1H	+ 0.10	7C	40 L1107
B&W	BOB			001	48	2.10	M3	107	1H	+ 0.20	7N	31 M0942
B&W	BOB	3	14	001	43	2.20	M3	111	1H	+ 0.40	7N	31 M0942
B&W	BOB	3	17	001	54	2.30	M2	100	1H	+ 0.20	7C	40 L1107
B&W	BOB			001	65	2.50	M3	92	1H	+ 0.40	7N	31 M0942
B&W	BOB	3	19	001	57	1.30	M2	97	1H	+ 0.10	7C	40 L1107
B&W	BOB			001	48	1.60	M3	107	1H	+ 0.10	7N	31 M0942
B&W	BOB	4	2	001	43	3.60	M1	114	1H	+ 0.10	FL	9 S2680
B&W	BOB	4	22	001	51	2.90	M2	110	1H	+ 0.00	FL	47 S2680
B&W	BOB	5	7	001	51	2.40	M2	107	2H	+ 0.10	FL	9 H3921
B&W	BOB	5	70	001	54	1.30	M2	120	4H	+ 0.20	FL	28 S2680
B&W	BOB	6	10	001	44	2.00	M2	115	1H	+ 0.10	FL	9 S2680
B&W	BOB	6	15	001	63	1.70	M2	85	1H	+ 0.30	FL	47 H3921
B&W	BOB	6	27	001	43	1.80	M2	102	1H	+ 0.40	FL	47 H3921
B&W	BOB	6	91	001	54	0.60	M3	100	1C	+ 0.00	FL	57 S2680
B&W	BOB	7	33	001	46	1.10	M2	115	1H	+ 0.00	FL	44 L1107
B&W	BOB	9	7	001	50	1.10	M2	108	1H	+ 0.00	FL	8 S2680
B&W	BOB	9	43	001	42	1.90	M2	114	1H	+ 0.20	FL	58 H8259
B&W	BOB	9	76	001	41	2.20	M2	105	1H	+ 0.40	FL	51 S4373
B&W	BOB			001	56	2.30	M2	94	2H	+ 0.40	FL	51 S4373
B&W	BOB	10	58	001	44	2.70	M1	96	1H	+ 0.00	FL	4 S2680
B&W	BOB	11	30	001	41	2.50	M2	126	1H	+ 0.10	FL	43 S2680
B&W	BOB	12	10	001	41	2.40	M2	103	1H	+ 0.20	FL	33 H8259
B&W	BOB	12	13	001	41	3.40	M2	127	2H	+ 0.10	FL	43 S2680
B&W	BOB	12	18	001	51	1.30	M2	114	1H	+ 0.20	FL	43 H8259
B&W	BOB	14	9	001	43	1.60	M2	95	1H	+ 0.10	FL	33 H8259
B&W	BOB	15	8	001	55	1.90	M2	99	1H	+ 0.30	FL	8 H8259
TW	BOB	1L	19	001	44	1.20	M2	101	1H	+ 0.10	FL	52 L1107
TW	BOB	19	8	001	49	0.80	M2	107	1H	+ 0.10	FL	7 S2680
B&W	BOB	21	10	001	44	1.50	M2	110	1H	+ 0.10	FL	7 S2680
B&W	BOB	21	60	001	42	1.90	M2	108	1H	+ 0.30	FL	51 S4373
B&W	BOB	21	68	001	46	1.60	M3	116	1C	+ 0.20	FL	56 S2680
B&W	BOB	25	19	001	42	1.20	M2	102	1H	+ 0.00	FL	42 S2680
B&W	BOB	29	82	001	50	1.00	M3	103	1C	+ 0.00	FL	17 S2680
B&W	BOB	31	82	001	42	1.00	M3	122	1C	+ 0.10	FL	16 S2680
B&W	BOB	33	16	001	52	2.70	1	117	TSH	+ 0.40	FL	36 S2680
B&W	BOB	33	78	001	41	2.80	M3	109	1C	+ 0.00	FL	15 S2680
B&W	BOB	34	40	001	44	1.70	M2	106	1H	+ 0.10	FL	36 S4373
B&W	BOB	46	53	001	43	3.60	M3	115	1C	+ 0.10	FL	10 S2680

TOTAL TUBES FOUND * 39
 TOTAL INDICATIONS FOUND * 43
 TOTAL TUBES IN INPUT FILE * 3368

Plant: Beaver Valley Unit 1
Stage: 9/89 RES

Steam Generator: B

QUERY: BOBBIN INDICATIONS 20 TO 39% TW

TEST	ROW	COL	IND	STM	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS	
BAV BOB	33	79	001	25	1.40	M1	136	1C	+ 0.00	FL	15	S2680	
BAV BOB	34	46	001	28	1.50	M4	0	AV1	+ 1.70	FL	36	S2680 WEAR	
BAV BOB			001	28	1.60	M4	0	AV2	+ 1.60	FL	36	S2680 WEAR	
BAV BOB			001	31	1.70	M4	0	AV3	+ 0.00	FL	36	S4373 WEAR	
BAV BOB	34	77	001	33	0.80	M3	122	2C	+ 0.20	FL	14	S2680	
BAV BOB			001	26	2.10	M3	126	1C	+ 0.10	FL	14	86259	
BAV BOB	34	78	001	36	2.00	M3	124	1C	+ 0.20	FL	14	86259	
BAV BOB	35	17	001	23	1.20	M3	132	1C	+ 0.20	FL	35	H3921	
BAV BOB	35	31	001	38	1.60	M2	122	1H	+ 0.40	FL	35	S2680	
BAV BOB	35	75	001	30	2.30	M3	131	2C	+ 0.00	FL	14	86259	
BAV BOB	36	26	001	23	1.00	M4	0	AV3	+ 0.00	FL	35	S2680 WEAR	
BAV BOB	36	73	001	39	0.90	M1	115	1C	+ 0.10	FL	13	S2680	
BAV BOB	36	74	001	31	3.10	M3	125	2C	+ 0.10	FL	13	86259	
BAV BOB			001	39	1.30	M3	117	1C	+ 0.10	FL	13	86259	
BAV BOB	37	59	001	24	1.20	M4	0	AV1	+ 0.00	FL	13	S2680 WEAR	
BAV BOB			001	30	1.60	M2	0	AV2	+ 0.00	FL	13	S2680 WEAR	
BAV BOB	37	62	001	26	1.40	M4	0	AV3	+ 0.00	FL	13	H3921 WEAR	
BAV BOB	38	24	001	30	2.50	M2	142	1H	+ 0.20	FL	34	86259	
BAV BOB	38	72	001	25	1.45	M	1	133	2C	+ 0.13	FL	12	H3921
BAV BOB	39	29	001	28	1.90	M4	0	AV2	+ 30.80	FL	32	S2680 WEAR	
BAV BOB	39	61	001	25	1.36	M	2	0	AV3	+ 0.00	FL	12	H3921
BAV BOB	39	72	001	27	2.37	M	1	131	2C	+ 0.22	FL	12	H3921
BAV BOB	40	25	001	28	1.80	M3	127	2C	+ 0.10	FL	32	S2680	
BAV BOB			001	29	2.50	M	1	147	1C	+ 0.10	FL	32	S2680
BAV BOB	40	33	001	30	1.70	M4	0	AV3	+ 4.70	FL	32	S2680	
BAV BOB	40	69	001	30	5.70	M3	124	2C	+ 0.10	FL	11	L1107	
BAV BOB	40	70	001	27	1.70	M3	128	2C	+ 0.20	FL	11	L1107	
BAV BOB	41	30	001	32	1.70	M3	123	2C	+ 0.20	FL	32	86259	
BAV BOB	41	43	001	21	0.90	M4	0	AV2	+ 0.00	FL	32	S2680	
BAV BOB	42	28	001	23	1.70	M3	153	2C	+ 0.20	FL	32	86259	
BAV BOB	42	36	001	27	0.70	M3	114	1C	+ 0.00	FL	61	S2680	
BAV BOB	42	66	001	22	1.80	M3	133	1C	+ 0.00	FL	10	L1107	
BAV BOB			001	29	1.10	M3	126	1C	+ 0.30	FL	10	L1107	
BAV BOB	43	30	001	22	1.10	M3	131	2C	+ 0.10	FL	30	S2680	
BAV BOB	43	33	001	21	1.70	M3	150	2C	+ 0.10	FL	30	S2680	
BAV BOB			001	29	0.90	M3	141	1C	+ 0.20	FL	30	S2680	
BAV BOB	43	55	001	30	1.90	M3	124	1C	+ 0.00	FL	10	L1107	
BAV BOB	43	60	001	27	1.70	M3	128	2C	+ 0.20	FL	10	L1107	
BAV BOB	43	65	001	28	1.60	M3	126	2C	+ 0.10	FL	10	L1107	
BAV BOB	44	35	001	25	2.50	M3	129	2C	+ 0.10	FL	30	S2680	
BAV BOB	44	36	001	27	1.50	M3	127	2C	+ 0.20	FL	30	H3921	
BAV BOB	44	49	001	20	1.00	M1	133	1C	+ 0.00	FL	10	S2680	
BAV BOB	44	53	001	29	1.70	M3	125	1C	+ 0.00	FL	10	L1107	
BAV BOB	44	55	001	28	1.50	M3	127	2C	+ 0.10	FL	10	L1107	
BAV BOB	45	36	001	30	2.30	M3	124	2C	+ 0.10	FL	30	H3921	
BAV BOB	45	37	001	28	2.50	M3	128	2C	+ 0.00	FL	30	S2680	
BAV BOB	45	39	001	23	2.40	M3	148	2C	+ 0.10	FL	30	H3921	
BAV BOB	45	42	001	23	2.40	M3	148	2C	+ 0.20	FL	30	S2680	
BAV BOB	45	43	001	21	0.90	M3	124	1C	+ 0.10	FL	30	S2680	
BAV BOB	45	44	001	23	0.90	M3	138	1C	+ 0.10	FL	30	S2680	
BAV BOB	45	50	001	24	1.50	M3	132	1C	+ 0.00	FL	10	L1107	
BAV BOB	45	51	001	26	1.90	M3	129	1C	+ 0.00	FL	10	L1107	
BAV BOB	45	54	001	24	0.40	M	1	149	TSM	+ 10.20	FL	10	S2680
BAV BOB	45	55	001	24	1.80	M1	128	TSM	+ 2.80	FL	10	S2680	
BAV BOB	45	59	001	32	2.10	M3	122	2C	+ 0.20	FL	10	L1107	
BAV BOB	46	44	001	31	0.90	M3	130	1C	+ 0.10	FL	28	S2680	
BAV BOB	46	45	001	23	1.30	M3	134	2C	+ 0.00	FL	28	W0942	
BAV BOB	46	46	001	31	1.30	M3	126	1C	+ 0.00	FL	28	W0942	

TOTAL TUBES FOUND * 115
TOTAL INDICATIONS FOUND * 128
TOTAL TUBES IN INPUT FILE * 3388

Plant: Beaver Valley Unit 1
 Date: 9/89 RES

Steam Generator: B

QUERY: ROBBIN INDICATIONS * 20% TV

TEST	ROW	COL	IND	RTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
B&W	BOB	5	8	001	19	2.00	1	162 TSH	+ 4.50	FL	9	H3921
B&W	BOB	5	94	001	9	1.70	H3	156 2C	- 0.10	FL	60	S2680
B&W	BOB	8	2	001	11	0.68	H1	146 2C	+ 0.00	FL	9	S2680
B&W	BOB	9	50	001	13	0.50	1	165 1H	+ 7.41	FL	5	S2680 001
B&W	BOB	12	92	001	9	2.00	H3	139 1C	- 0.10	FL	56	S2680
B&W	BOB	13	90	001	15	1.20	H3	143 2C	+ 0.20	FL	56	S2680
B&W	BOB	15	3	001	15	0.90	H1	138 1C	+ 0.00	FL	8	H8259
B&W	BOB	15	6	001	14	1.40	H1	139 1C	+ 0.09	FL	8	S2680
B&W	BOB	15	55	001	14	0.35	1	160 1H	+ 48.20	FL	3	L1107
B&W	BOB	16	34	001	12	0.70	H1	120 TSH	+ 0.70	FL	52	S2680
B&W	BOB	22	86	001	16	0.80	H3	136 2C	+ 0.00	FL	54	S4373
B&W	BOB	25	10	001	17	0.69	H1	134 1C	- 0.06	FL	7	S2680
B&W	BOB	27	84	001	11	1.30	H3	140 1C	+ 0.00	FL	54	S2680
B&W	BOB	27	85	001	11	1.10	H3	147 1C	+ 0.00	FL	54	S2680
B&W	BOB	28	82	001	9	0.80	H3	135 1C	+ 0.00	FL	17	S2680
B&W	BOB	29	12	001	5	1.00	H3	140 1C	- 0.20	FL	38	S2680
B&W	BOB	29	14	001	12	1.70	H3	127 1C	- 0.10	FL	38	S2680
B&W	BOB	30	82	001	11	1.70	1	158 1C	- 0.10	FL	16	S2680
B&W	BOB	31	17	001	13	1.30	H3	150 1C	- 0.10	FL	37	S2680
B&W	BOB	32	78	001	15	1.40	H3	140 1C	- 0.10	FL	1	S2680
B&W	BOB	36	21	001	17	0.90	H3	143 2C	- 0.20	FL	35	H3921
B&W	BOB	36	68	001	19	0.50	1	104 4C	- 16.00	FL	13	H8259
B&W	BOB	37	21	001	16	1.10	H3	150 2C	+ 0.20	FL	34	S2680
B&W	BOB	37	22	001	9	1.10	H3	136 2C	- 0.20	FL	34	S2680
B&W	BOB	37	62	001	14	0.50	H4	0 7H	+ 31.70	FL	12	S2680 WEAR
B&W	BOB	37	74	001	18	1.30	H3	117 2C	+ 0.20	FL	13	S2680
B&W	BOB	38	21	001	9	0.60	H3	147 2C	+ 0.00	FL	34	S2680
B&W	BOB	39	25	001	13	1.30	H3	149 2C	- 0.10	FL	32	S2680
B&W	BOB	40	66	001	10	0.90	H1	137 2C	+ 0.10	FL	11	S2680
B&W	BOB	42	60	001	10	1.30	H1	137 2C	- 0.20	FL	11	S2680
B&W	BOB	43	32	001	10	1.00	H3	143 1C	+ 0.00	FL	30	S2680
B&W	BOB	43	34	001	14	1.00	H3	141 2C	+ 0.10	FL	30	S2680
B&W	BOB	43	35	001	19	0.80	H3	135 1C	+ 0.00	FL	30	S2680
B&W	BOB	43	35	001	18	1.80	H3	121 2C	+ 0.10	FL	30	S2680
B&W	BOB	43	59	001	8	1.40	H3	138 1C	- 0.20	FL	10	S2680
B&W	BOB	44	33	001	16	1.00	H3	145 2C	+ 0.20	FL	30	S2680
B&W	BOB	44	33	001	12	1.10	H3	135 1C	+ 0.10	FL	30	S2680
B&W	BOB	44	38	001	18	2.00	1	151 2C	- 0.10	FL	30	H3921
B&W	BOB	44	39	001	19	0.60	H3	143 2C	+ 0.00	FL	30	S2680
B&W	BOB	44	43	001	14	0.80	H3	148 2C	- 0.10	FL	30	S2680
B&W	BOB	44	50	001	15	0.90	H1	136 2C	- 0.20	FL	10	S2680
B&W	BOB	44	62	001	14	1.20	H1	137 2C	- 0.10	FL	10	L1107
B&W	BOB	45	38	001	15	1.00	H3	136 2C	+ 0.20	FL	30	S2680
B&W	BOB	45	42	001	16	0.80	H3	142 1C	- 0.20	FL	30	S2680
B&W	BOB	45	49	001	15	1.10	H3	138 1C	- 0.10	FL	10	S2680
B&W	BOB	45	54	001	19	0.70	1	142 TSH	+ 11.00	FL	10	S2680
B&W	BOB	45	55	001	18	0.90	H1	134 2C	- 0.20	FL	10	S2680
B&W	BOB	45	56	001	9	1.10	H1	140 2C	- 0.10	FL	10	S2680

TOTAL TUBES FOUND * 46
 TOTAL INDICATIONS FOUND * 48
 TOTAL TUBES IN INPUT FILE * 3368

Plant: Beaver Valley Unit 1
 Date: 9/29 RES

Steam Generator: B

QUERY: BOBBIN INDICATIONS - DSI

TEST	ROW	COL	IND	%TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
86W BOB	43	38	DSI		0.80	M2	120	1H	+ 0.30	FL	30	S2680
86W BOB	44	35	DSI		0.60	M1	125	1H	+ 0.20	FL	30	S2680
86W BOB	44	49	DSI		1.90	M2	153	1H	- 0.20	FL	10	L1107
86W BOB	44	62	DSI		0.80	M3	142	1H	+ 0.00	FL	10	L1107
86W BOB	45	39	DSI		1.00	M2	133	1H	+ 0.00	FL	30	H3921

TOTAL TUBES FOUND * 179
 TOTAL INDICATIONS FOUND * 215
 TOTAL TUBES IN INPUT FILE * 3388

Plant: Beaver Valley Unit 1
 Date: 9/89 RES

Steam Generator: C

QUERY: BOBBIN INDICATIONS ** 40% TW

TEST	ROW	COL	IND	%TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
B&W BOB	1	3	001	50	2.50	1	120	TSH	+ 17.00	7H	44	H8259
B&W BOB	3	1	001	46	3.50	M2	111	1H	- 0.30	FL	53	H8259
B&W BOB	3	2	001	53	1.20	M2	97	1H	+ 0.20	FL	58	H8259
B&W BOB	4	51	001	43	2.50	M2	104	1H	+ 0.00	FL	52	N0942
B&W BOB	4	53	001	42	2.00	M2	105	1H	+ 0.00	FL	52	N0942
B&W BOB	5	2	001	57	1.60	M2	100	1H	- 0.20	FL	53	H8259
B&W BOB	14	3	001	50	1.10	M2	98	1H	- 0.10	FL	55	H8259
B&W BOB	15	6	001	51	1.30	M2	97	1H	- 0.10	FL	54	H8259
B&W BOB	15	59	001	51	1.00	M2	99	1H	- 0.40	FL	50	S4373
B&W BOB	15	70	001	43	1.70	M1	102	1H	+ 0.00	FL	37	S2680
B&W BOB	21	21	001	49	5.30	M2	104	1H	- 0.10	FL	42	H8259
B&W BOB	26	10	001	40	3.00	M3	112	1C	+ 0.00	FL	54	H8259
B&W BOB	28	15	001	42	2.70	M2	107	1H	- 0.10	FL	39	K3921
B&W BOB	34	53	001	41	3.30	M4	0	AV3	+ 0.00	FL	20	S2680
B&W BOB	42	66	001	40	1.30	A3	110	1C	- 0.20	FL	16	H8259

TOTAL TUBES FOUND = 15
 TOTAL INDICATIONS FOUND = 15
 TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
 Date: 9/89 RES

Steam Generator: C

QUERY: BOBBIN INDICATIONS 20 TO 39% TW

TEST	ROW	COL	IND	WTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
B&W BOB	1	1	001	35	1.40	1	145	TSM	+ 17.50	7H	44	S2680
B&W BOB	1	2	001	38	1.10	1	133	TSM	+ 17.50	7H	44	S2680
B&W BOB	1	4	001	32	2.30	1	140	TSM	+ 17.00	7H	44	S2680 5
B&W BOB	6	92	001	24	0.80	M3	132	1C	- 0.20	FL	22	H8259
B&W BOB	7	13	001	26	1.00	M2	122	1H	- 0.10	FL	24	S2680
B&W BOB	7	25	001	39	2.30	M2	116	1H	- 0.10	FL	29	L1107
B&W BOB	16	4	001	20	1.10	M3	130	2C	+ 0.10	FL	54	H8259
B&W BOB	17	5	001	24	0.70	M3	127	2C	+ 0.10	FL	54	H8259
B&W BOB			001	27	0.70	M3	124	1C	+ 0.10	FL	54	H8259
B&W BOB	23	43	001	30	4.10	M2	117	1H	- 0.10	FL	42	H8259
B&W BOB	25	84	001	34	2.00	M3	123	1C	- 0.10	FL	8	L1107
B&W BOB	25	86	001	25	3.20	M3	126	1C	- 0.10	FL	8	N0942
B&W BOB	27	26	001	26	1.30	M2	0	AV2	+ 0.00	FL	39	S2680
B&W BOB	27	83	001	31	2.90	M3	127	1C	- 0.10	FL	31	L1107
B&W BOB	28	29	001	30	2.30	M2	119	1H	+ 0.20	FL	38	H3921
B&W BOB	28	83	001	22	1.30	M1	128	1C	+ 0.00	FL	28	S2680
B&W BOB	29	46	001	21	0.90	M2	0	AV1	+ 0.00	FL	38	S2680
B&W BOB			001	29	1.60	M2	0	AV2	+ 1.40	FL	38	S2680
B&W BOB			001	21	1.00	M4	0	AV3	+ 0.00	FL	38	S2680
B&W BOB			001	26	1.30	M2	0	AV3	+ 0.70	FL	38	S2680
B&W BOB			001	23	1.10	M2	0	AV4	+ 0.10	FL	38	S2680
B&W BOB	29	50	001	35	1.70	M2	107	1H	- 0.10	FL	28	L1107
B&W BOB	29	82	001	24	0.70	M1	126	2C	+ 0.00	FL	28	S2680
B&W BOB			001	31	3.10	M1	119	1C	+ 0.00	FL	28	S2680
B&W BOB	30	14	001	23	2.70	M3	129	2C	- 0.10	FL	15	N0942
B&W BOB	30	29	001	31	1.40	M2	134	1H	- 0.10	FL	15	N0942
B&W BOB	30	30	001	34	2.50	M2	131	1H	- 0.10	FL	15	L1107
B&W BOB	30	81	001	31	1.10	M3	121	1C	+ 0.00	FL	27	H3921
B&W BOB	32	16	001	35	1.10	1	136	TSM	+ 1.40	FL	14	S2680
B&W BOB			001	32	1.10	1	114	1C	+ 0.10	FL	14	S2680
B&W BOB	33	16	001	39	4.00	M3	120	1C	- 0.10	FL	13	L1107
B&W BOB	33	18	001	32	3.10	M3	127	1C	- 0.20	FL	13	L1107
B&W BOB	34	23	001	29	1.90	M2	131	1H	- 0.10	FL	13	L1107
B&W BOB			001	31	1.90	M2	129	2H	+ 0.00	FL	13	L1107
B&W BOB	34	53	001	24	1.20	M4	0	AV2	+ 0.00	FL	20	S2680
B&W BOB	34	77	001	27	1.50	M3	135	1C	- 0.10	FL	20	L1107
B&W BOB	34	78	001	34	3.70	M3	128	1C	+ 0.00	FL	20	L1107
B&W BOB	35	77	001	35	2.60	M3	112	1C	- 0.10	FL	19	S2680
B&W BOB	36	47	001	23	1.05	M4	0	AV2	+ 0.00	FL	6	S2680
B&W BOB	37	19	001	23	0.70	M3	134	1C	+ 0.00	FL	5	S2680
B&W BOB	37	35	001	33	2.90	M2	112	1H	- 0.10	FL	6	L1107
B&W BOB	40	25	001	22	1.80	M3	128	1C	- 0.20	FL	4	S2680
B&W BOB	40	52	001	21	1.30	M4	0	AV4	+ 0.00	FL	17	S4373 WEAR
B&W BOB	41	27	001	20	1.60	M3	129	1C	+ 0.00	FL	4	S2680
B&W BOB	41	66	001	25	1.20	M3	123	1C	- 0.10	FL	16	H8259
B&W BOB	42	28	001	23	0.70	M3	126	4C	+ 0.00	FL	4	S2680
B&W BOB	42	63	001	38	2.00	M3	115	1C	- 0.10	FL	16	N0942
B&W BOB	43	30	001	33	0.50	M3	117	4C	+ 0.00	FL	3	H8259
B&W BOB	44	33	001	24	1.10	M3	125	3C	- 0.30	FL	99	H8259
B&W BOB	44	47	001	24	2.10	M3	125	2C	- 0.20	FL	3	H8259
B&W BOB	44	62	001	25	1.40	M3	127	1C	- 0.10	FL	15	N0942

TOTAL TUBES FOUND = 43
 TOTAL INDICATIONS FOUND = 51
 TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
 Outage: 9/89 RES

Steam Generator: C

QUERY: BOBB * INDICATIONS - DSI

TEST	ROW	COL	IND	%TW	VOLTS	CHN	DEC	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
B&W BOB	30	70	DSI		1.00	M2	129	1H	- 0.10	FL	27	H3921
B&W BOB	31	21	DSI		1.20	M2	120	1H	+ 0.00	FL	14	S2680
B&W BOB	31	36	DSI		1.10	M2	99	1H	+ 0.00	FL	14	S2680
B&W BOB			DSI		0.90	M2	115	2H	+ 0.00	FL	14	S2680
B&W BOB			DSI		0.70	M2	138	3H	+ 0.00	FL	14	S2680
B&W BOB	31	51	DSI		0.90	M2	120	1H	+ 0.10	FL	26	S4373
B&W BOB			DSI		0.80	M2	115	2H	- 0.20	FL	26	S4373
B&W BOB	31	59	DSI		1.10	M2	119	1H	+ 0.00	FL	27	H3921
B&W BOB	31	65	DSI		1.20	M2	129	1H	- 0.20	FL	27	H3921
B&W BOB	32	20	DSI		1.20	M2	117	1H	- 0.40	FL	14	S2680
B&W BOB	32	21	DSI		0.60	M2	114	2H	+ 0.00	FL	14	S2680
B&W BOB	32	23	DSI		0.90	M2	131	1H	+ 0.00	FL	14	S2680
B&W BOB	32	27	DSI		0.60	M2	108	1H	+ 0.00	FL	14	S2680
B&W BOB	32	28	DSI		0.60	M2	137	1H	+ 0.10	FL	14	S2680
B&W BOB	32	47	DSI		1.30	M2	112	1H	+ 0.00	FL	13	L1107
B&W BOB	32	55	DSI		1.50	M2	107	1H	- 0.10	FL	26	S4373
B&W BOB	32	57	DSI		0.60	M1	114	1H	+ 0.00	FL	26	S2680
B&W BOB	32	60	DSI		0.60	M2	106	1H	- 0.40	FL	26	S4373
B&W BOB	33	19	DSI		0.90	M2	123	1H	- 0.10	FL	13	L1107
B&W BOB			DSI		0.70	M2	106	2H	+ 0.00	FL	13	L1107
B&W BOB	33	36	DSI		0.90	M2	143	1H	- 0.10	FL	13	L1107
B&W BOB	33	51	DSI		0.80	M2	105	1H	- 0.10	FL	20	L1107
B&W BOB	33	64	DSI		1.00	M2	122	1H	- 0.10	FL	20	L1107
B&W BOB	33	68	DSI		0.90	M2	117	1H	- 0.10	FL	26	S4373
B&W BOB	33	78	DSI		0.80	M2	119	4H	+ 0.20	FL	26	S4373
B&W BOB	33	79	DSI		1.30	M2	133	1H	+ 0.20	FL	26	S4373
B&W BOB	34	24	DSI		0.80	M2	115	1H	- 0.10	FL	13	L1107
B&W BOB	35	20	DSI		0.90	M2	122	2H	- 0.10	FL	7	L1107
B&W BOB	35	28	DSI		1.10	M2	101	1H	- 0.10	FL	7	L1107
B&W BOB	35	31	DSI		0.90	M2	103	1H	- 0.10	FL	7	L1107
B&W BOB	35	47	DSI		1.12	M2	127	1H	+ 0.00	FL	7	S2680
B&W BOB	35	55	DSI		0.60	M1	124	1H	+ 0.00	FL	19	S2680
B&W BOB	35	63	DSI		0.90	M2	132	1H	- 0.10	FL	19	H3921
B&W BOB	35	67	DSI		0.60	M2	137	1H	+ 0.10	FL	19	H3921
B&W BOB	36	24	DSI		0.70	M2	87	2H	+ 0.00	FL	7	S2680
B&W BOB	36	31	DSI		0.80	M2	103	1H	- 0.10	FL	7	L1107
B&W BOB	36	36	DSI		0.70	M2	111	2H	- 0.10	FL	7	L1107
B&W BOB	36	65	DSI		0.60	M2	94	2H	+ 0.10	FL	19	S2680
B&W BOB			DSI		1.10	M2	108	3H	- 0.20	FL	19	S2680
B&W BOB	37	34	DSI		0.60	M2	83	1H	+ 0.00	FL	6	S2680
B&W BOB	37	35	DSI		0.90	M2	121	2H	- 0.20	FL	6	L1107
B&W BOB	38	38	DSI		1.00	M2	116	2H	- 0.10	FL	5	L1107
B&W BOB	39	32	DSI		0.80	M2	122	1H	+ 0.10	FL	5	L1107
B&W BOB	41	33	DSI		0.90	M2	124	1H	+ 0.20	FL	4	H8259
B&W BOB	42	39	DSI		0.70	M2	110	1H	- 0.10	FL	4	H8259
B&W BOB	42	48	DSI		0.90	M2	128	1H	+ 0.10	FL	16	H8259
B&W BOB	43	37	DSI		1.00	M2	124	1H	+ 0.20	FL	3	S2680

TOTAL TUBES FOUND = 168
 TOTAL INDICATIONS FOUND = 187
 TOTAL TUBES IN INPUT FILE = 3388

ATTACHMENT II

Plant: Beaver Valley Unit 1
Date: 9/89 RES

Steam Generator: A

BY: TUBES INSPECTED WITH EDDY-360 UBEND EXAMINATION

TEST	ROW	COL	IND	WTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
UB 360 P	1	1	NDD						+ 0.00	U-BEND	3	L1107
UB 360 P	1	4	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	5	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	6	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	7	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	8	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	10	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	11	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	12	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	13	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	14	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	16	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	17	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	18	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	19	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	20	OD1	32	1.63	1	127	7H	+ 4.90	U-BEND	2	L1107
UB 360 P	1	21	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	22	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	23	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	24	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	26	NDD						+ 0.00	U-BEND	8	L1107
UB 360 P	1	28	OD1	24	0.95	1	8	7H	+ 9.30	U-BEND	3	L1107
UB 360 P	1	30	NDD						+ 0.00	U-BEND	3	L1107
UB 360 P	1	31	NDD						+ 0.00	U-BEND	3	L1107
UB 360 P	1	33	NDD						+ 0.00	U-BEND	3	L1107
UB 360 P	1	34	NDD						+ 0.00	U-BEND	3	L1107
UB 360 P	1	38	NDD						+ 0.00	U-BEND	9	N0942
UB 360 P	1	41	NDD						+ 0.00	U-BEND	9	N0942
UB 360 P	1	42	ID1	65	4.04	1	55	7H	+ 10.70	U-BEND	9	N0942
UB 360 P	1	43	NDD						+ 0.00	U-BEND	9	N0942
UB 360 P	1	45	NDD						+ 0.00	U-BEND	3	L1107
UB 360 P	1	46	ID1	83	7.28	1	30	7H	+ 5.10	U-BEND	3	L1107
UB 360 P	1	47	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	49	NDD						+ 0.00	U-BEND	3	L1107
UB 360 P	1	51	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	53	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	54	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	57	NDD						+ 0.00	U-BEND	8	L1107
UB 360 P	1	59	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	60	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	61	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	62	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	63	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	64	ID1	46	4.41	1	33	7H	+ 4.00	U-BEND	2	L1107
UB 360 P	1	65	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	66	ID1	35	2.75	1	26	7H	+ 4.00	U-BEND	2	L1107
UB 360 P	1	67	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	70	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	71	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	73	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	74	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	75	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	76	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	77	ID1	43	3.97	1	17	7H	+ 4.70	U-BEND	2	L1107
UB 360 P	1	83	ID1	42	3.72	1	8	7H	+ 4.20	U-BEND	2	L1107
UB 360 P	1	84	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	1	85	NDD						+ 0.00	U-BEND	9	N0942
UB 360 P	1	86	NDD						+ 0.00	U-BEND	9	N0942
UB 360 P	1	87	NDD						+ 0.00	U-BEND	9	N0942
UB 360 P	1	88	NDD						+ 0.00	U-BEND	9	N0942
UB 360 P	1	89	NDD						+ 0.00	U-BEND	9	N0942
UB 360 P	1	94	NDD						+ 0.00	U-BEND	9	N0942
UB 360 P	2	1	NDD						+ 0.00	U-BEND	2	N0942
UB 360 P	2	2	NDD						+ 0.00	U-BEND	3	L1107
UB 360 P	2	2	NDD						+ 0.00	U-BEND	2	N0942
UB 360 P	2	3	NDD						+ 0.00	U-BEND	3	L1107
UB 360 P	2	3	NDD						+ 0.00	U-BEND	3	L1107
UB 360 P	2	4	NDD						+ 0.00	U-BEND	2	L1107
UB 360 P	2	5	NDD						+ 0.00	U-BEND	2	L1107

Plant: Beaver Valley Unit 1
Date: 9/89 RES

Steam Generator: A

QUERY: TUBES INSPECTED WITH EDDY-360 UBEND EXAMINATION

TEST	ROW	COL	IND	WTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
UB 360 P	2	6	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	7	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	8	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	9	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	10	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	11	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	12	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	13	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	14	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	15	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	16	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	17	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	18	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	19	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	20	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	21	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	22	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	23	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	24	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2		NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	25	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	26	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	27	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	28	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	29	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	30	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	31	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	32	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	33	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	34	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	35	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	36	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	37	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	38	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	39	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	40	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	42	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	43	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	44	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	45	NDD		+ 0.00				U-BEND	3	L1107	
UB 360 P	2	46	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	47	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	48	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	50	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	51	NDD		+ 0.00				U-BEND	7	S2680	
UB 360 P	2	52	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	53	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	54	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	55	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	56	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	57	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	58	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	59	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	60	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	61	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	62	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	63	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	64	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	65	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	66	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	67	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	68	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	69	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	70	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	71	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	72	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	73	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	74	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	75	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	76	NDD		+ 0.00				U-BEND	2	L1107	

Plant: Beaver Valley Unit 1
Date: 9/89 RES

Steam Generator: A

QUERY: TUBES INSPECTED WITH EDDY-360 UBEND EXAMINATION

TEST	ROW	COL	IND	%TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
UB 360 P	2	77	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	78	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	79	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	80	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	81	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	82	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	83	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	84	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	85	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	86	NDD		+ 0.00				U-BEND	2	L1107	
UB 360 P	2	87	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	88	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	89	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	90	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	91	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	92	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	93	NDD		+ 0.00				U-BEND	9	N0942	
UB 360 P	2	94	NDD		+ 0.00				U-BEND	9	N0942	

TOTAL TUBES FOUND = 154
 TOTAL INDICATIONS FOUND = 158
 TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
 Date: 9/89 RES

Steam Generator: A

QUERY: EDDY-360 INDICATIONS UBEND EXAMINATION ALL % TW

TEST	ROW	COL	IND	%TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
UB 360 P	1	20	001	32	1.63	1	127	7H	+	4.90	U-BEND	2 L1107
UB 360 P	1	28	001	24	0.95	1	8	7H	+	9.30	U-BEND	3 L1107
UB 360 P	1	42	101	65	4.06	1	55	7H	+	10.70	U-BEND	9 M0942
UB 360 P	1	46	101	83	7.28	1	30	7H	+	5.10	U-BEND	3 L1107
UB 360 P	1	64	101	46	4.41	1	33	7H	+	4.00	U-BEND	2 L1107
UB 360 P	1	66	101	35	2.75	1	26	7H	+	4.00	U-BEND	2 L1107
UB 360 P	1	77	101	43	3.97	1	17	7H	+	4.70	U-BEND	2 L1107
UB 360 P	1	83	101	42	3.72	1	8	7H	+	4.20	U-BEND	2 L1107

TOTAL TUBES FOUND = 8
 TOTAL INDICATIONS FOUND = 8
 TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
Date: 9/89 RES

Steam Generator: B

QUERY: TUBES INSPECTED WITH EDDY-360 UBEND EXAMINATION

TEST	ROW	COL	IND	%TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
UB 360 P	2	48	NDD		+ 0.00				U-BEND	1	N0942	
UB 360 P	2	49	NDD		+ 0.00				U-BEND	1	N0942	
UB 360 P	2	50	NDD		+ 0.00				7C	10	L1107	
UB 360 P	2	51	NDD		+ 0.00				7C	10	L1107	
UB 360 P	2	52	NDD		+ 0.00				7C	10	L1107	
UB 360 P	2	53	NDD		+ 0.00				7C	10	L1107	
UB 360 P	2	54	NDD		+ 0.00				7C	10	L1107	
UB 360 P	2	55	NDD		+ 0.00				7C	10	L1107	
UB 360 P	2	56	NDD		+ 0.00				7C	10	L1107	
UB 360 P	2	57	NDD		+ 0.00				7C	10	L1107	
UB 360 P	2	58	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	60	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	61	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	62	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	63	NDD		+ 0.00				U-BEND	4	L1107	
UB 360 P	2	64	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	65	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	66	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	67	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	68	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	69	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	70	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	71	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	72	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	73	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	74	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	75	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	76	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	77	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	78	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	79	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	80	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	81	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	82	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	83	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	84	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	85	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	86	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	87	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	88	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	89	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	90	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	91	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	92	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	93	NDD		+ 0.00				U-BEND	2	N0942	
UB 360 P	2	94	NDD		+ 0.00				U-BEND	2	N0942	

TOTAL TUBES FOUND = 177
TOTAL INDICATIONS FOUND = 186
TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
 Date: 9/89 RES

Steam Generator: C

QUERY: TUBES INSPECTED WITH EDDY-360 UBEND EXAMINATION

TEST	ROW	COL	IND	%TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
UB 360 P	2		48	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		49	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		50	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		51	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		52	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		53	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		54	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		55	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		56	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		57	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		58	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		59	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		60	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		61	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		62	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		63	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		64	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		65	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		66	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		67	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		68	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		69	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		70	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		72	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		73	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		74	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		75	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		76	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		77	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		78	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		79	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		80	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		81	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		82	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		83	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		84	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		85	NDD	+	0.00			U-BEND	1	N0942	
UB 360 P	2		86	NDD	+	0.00			U-BEND	2	52680	
UB 360 P	2		87	NDD	+	0.00			U-BEND	9	N0942	
UB 360 P	2		88	NDD	+	0.00			U-BEND	9	N0942	
UB 360 P	2		89	NDD	+	0.00			U-BEND	9	N0942	
UB 360 P	2		90	NDD	+	0.00			U-BEND	9	N0942	
UB 360 P	2		91	NDD	+	0.00			U-BEND	9	N0942	
UB 360 P	2		92	NDD	+	0.00			U-BEND	9	N0942	
UB 360 P	2		93	NDD	+	0.00			U-BEND	9	N0942	
UB 360 P	2		94	NDD	+	0.00			U-BEND	9	N0942	

TOTAL TUBES FOUND = 184
 TOTAL INDICATIONS FOUND = 186
 TOTAL TUBES IN INPUT FILE = 3388

ATTACHMENT III

Plant: Beaver Valley Unit 1
Date: 9/89 RES

Steam Generator: A

QUERY: TUBES INSPECTED WITH EDDY-360 DSI EXAMINATION

TEST	ROW	COL	IND	ATW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
DSI 360P	35	69	ODI	23	0.81	1	31	1H	+ 0.00	1H	5	L1107
DSI 360P	35	70	NDD						+ 0.00	2H	20	S2680
DSI 360P	35	73	NDD						+ 0.00	2H	5	L1107
DSI 360P	36	23	ODI	13	0.54	1	67	3H	+ 0.00	3H	20	S2680
DSI 360P	36	24	NDD						+ 0.00	1H	20	S2680
DSI 360P	36	35	ODI	11	0.47	1	113	1H	+ 0.00	1H	20	S2680
DSI 360P	36	36	NDD						+ 0.00	1H	20	S2680
DSI 360P	36	55	NDD						+ 0.00	1H	5	L1107
DSI 360P			NDD						+ 0.00	2H	5	L1107
DSI 360P	36	58	NDD						+ 0.00	1H	5	L1107
DSI 360P	36	61	NDD						+ 0.00	1H	5	L1107
DSI 360P	36	69	ODI	12	0.50	1	72	1H	+ 0.00	1H	20	S2680
DSI 360P	37		ODI	29	0.94	1	4	1H	+ 0.10	1H	10	L1107
DSI 360P			ODI	33	1.07	1	29	2H	- 0.10	2H	6	L1107
DSI 360P			ODI	32	1.01	1	21	1H	+ 0.20	1H	6	L1107
DSI 360P	37	48	NDD						+ 0.00	2H	5	L1107
DSI 360P	37	54	NDD						+ 0.00	2H	10	L1107
DSI 360P	37	60	NDD						+ 0.00	2H	5	L1107
DSI 360P	37	63	NDD						+ 0.00	2H	5	L1107
DSI 360P	38	36	NDD						+ 0.00	1H	20	S2680
DSI 360P	38	48	ODI	22	0.80	1	19	1H	+ 0.00	1H	5	L1107
DSI 360P	38	50	NDD						+ 0.00	1H	5	L1107
DSI 360P	38	51	NDD						+ 0.00	6H	5	L1107
DSI 360P	38	53	NDD						+ 0.00	2H	20	S2680
DSI 360P	38	64	ODI	17	0.78	1	116	3H	+ 0.30	3H	20	S2680
DSI 360P			NDD						+ 0.00	2H	20	S2680
DSI 360P	38	68	NDD						+ 0.00	2H	20	S2680
DSI 360P	38	74	NDD						+ 0.00	1H	20	S2680
DSI 360P	39	27	NDD						+ 0.00	1H	20	S2680
DSI 360P	39	39	NDD						+ 0.00	2H	20	S2680
DSI 360P	39	51	NDD						+ 0.00	2H	20	S2680
DSI 360P	39	52	NDD						+ 0.00	1H	5	L1107
DSI 360P	39	59	NDD						+ 0.00	2H	5	L1107
DSI 360P	39	65	NDD						+ 0.00	1H	5	L1107
DSI 360P	39	70	NDD						+ 0.00	2H	5	L1107
DSI 360P	40	53	NDD						+ 0.00	1H	20	S2680
DSI 360P	43	38	ODI	43	1.69	1	157	1H	+ 0.20	1H	6	L1107
DSI 360P	45	37	ODI	38	1.31	1	127	2H	+ 0.20	2H	6	L1107

TOTAL TUBES FOUND = 525
TOTAL INDICATIONS FOUND = 598
TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
Tape: 0/09 RES

Steam Generator: A

ALERT: EDDY-360 INDICATIONS DSI EXAMINATION -> 40% TW

TEST	ROW	COL	IND	RTW	VOLTS	CHN	DES	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
DSI 360P	2	32	001	43	1.61	1	101	1H	+ 0.10	1H	6	ND942
DSI 360P	3	1	001	41	1.46	1	57	1H	- 0.10	1H	6	ND942
DSI 360P	3	56	001	69	4.35	1	42	1H	- 0.10	1H	6	ND942
DSI 360P	3	75	001	50	2.30	1	69	1H	+ 0.00	1H	6	L1107
DSI 360P	3	78	001	42	1.56	1	40	1H	+ 0.10	1H	6	L1107
DSI 360P	4	8	001	40	1.70	1	147	2H	+ 0.20	2H	6	ND942
DSI 360P	4	25	001	41	1.48	1	126	1H	+ 0.00	1H	6	ND942
DSI 360P	4	64	001	44	1.74	1	122	1H	- 0.10	1H	6	L1107
DSI 360P	6	37	001	42	2.24	1	56	1H	- 0.10	1H	15	L1107
DSI 360P	7	9	001	41	1.49	1	112	1H	- 0.20	1H	6	ND942
DSI 360P	7	60	001	44	1.98	1	130	1H	+ 0.00	1H	6	ND942
DSI 360P	8	33	001	41	1.50	1	150	2H	- 0.20	2H	6	ND942
DSI 360P			001	48	2.15	1	55	1H	+ 0.00	1H	6	ND942
DSI 360P	10	67	001	44	1.81	1	53	2H	- 0.10	2H	6	L1107
DSI 360P	11	34	001	41	1.46	1	109	1H	- 0.10	1H	6	L1107
DSI 360P	15	56	001	47	1.92	1	111	1H	- 0.40	1H	6	ND942
DSI 360P	17	59	001	54	2.75	1	112	1H	+ 0.10	1H	6	L1107
DSI 360P	19	14	001	50	2.09	1	123	1H	- 0.20	1H	6	ND942
DSI 360P	19	6	001	40	1.44	1	124	1H	+ 0.00	1H	6	L1107
DSI 360P	22	74	001	51	2.65	1	54	1H	+ 0.00	1H	5	L1107
DSI 360P	24	72	001	41	1.63	1	111	1H	- 0.20	1H	5	L1107
DSI 360P	24	76	001	43	1.76	1	67	1H	+ 0.20	1H	5	L1107
DSI 360P	25	3	001	43	1.69	1	117	2H	+ 0.00	2H	6	L1107
DSI 360P	26	59	001	41	1.64	1	122	2H	+ 0.10	2H	5	L1107
DSI 360P	27	34	001	43	1.66	1	68	1H	+ 0.20	1H	6	L1107
DSI 360P	28	19	001	52	3.26	1	68	2H	+ 0.30	2H	10	L1107
DSI 360P	28	26	001	47	3.15	1	83	2H	+ 0.10	2H	15	L1107
DSI 360P	30	36	001	40	2.07	1	132	1H	+ 0.00	1H	15	L1107
DSI 360P	30	43	001	42	2.22	1	79	1H	+ 0.10	1H	15	L1107
DSI 360P	31	75	001	45	2.01	1	120	1H	+ 0.10	1H	5	L1107
DSI 360P	32	67	001	41	2.16	1	102	2H	+ 0.10	2H	15	L1107
DSI 360P	34	37	001	45	2.25	1	72	1H	- 0.10	1H	10	L1107
DSI 360P	43	38	001	43	1.69	1	157	1H	+ 0.20	1H	6	L1107

TOTAL TUBES FOUND * 32
 TOTAL INDICATIONS FOUND * 33
 TOTAL TUBES IN INPUT FILE * 3388

Plant: Beaver Valley Unit 1
 Date: 9/89 RES

Steam Generator: 4

QUERY: EDDY-360 INDICATIONS DSI EXAMINATION 20 TO 39% TW

TEST	ROW	COL	IND	STW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLIST	COMMENTS
DSI 360P	25	53	001	25	0.67	1	135	1H	- 0.10	1H	5	L1107
DSI 360P	25	64	001	21	0.46	1	127	1H	- 0.10	1H	5	L1107
DSI 360P	25	70	001	24	0.63	1	114	2H	+ 0.30	2H	5	L1107
DSI 360P			001	38	1.43	1	41	1H	+ 0.00	1H	5	L1107
DSI 360P	25	75	001	27	0.81	1	145	2H	+ 0.00	2H	5	L1107
DSI 360P	26	54	001	27	0.81	1	144	2H	+ 0.20	2H	5	L1107
DSI 360P			001	33	1.14	1	101	1H	- 0.20	1H	5	L1107
DSI 360P	26	59	001	36	1.34	1	107	1H	+ 0.10	1H	5	L1107
DSI 360P	27	19	001	22	0.46	1	145	2H	+ 0.10	2H	6	L1107
DSI 360P	27	24	001	37	1.25	1	71	2H	+ 0.10	2H	6	L1107
DSI 360P	27	35	001	32	0.97	1	81	1H	+ 0.10	1H	6	L1107
DSI 360P	27	51	001	31	1.04	1	101	1H	+ 0.10	1H	5	L1107
DSI 360P	27	74	001	38	1.41	1	117	1H	+ 0.00	1H	5	L1107
DSI 360P	28	26	001	33	1.55	1	78	1H	- 0.10	1H	15	L1107
DSI 360P	29	24	001	26	0.65	1	16	1H	+ 0.00	1H	6	L1107
DSI 360P	29	29	001	31	0.97	1	124	1H	+ 0.10	1H	6	L1107
DSI 360P	29	56	001	25	0.67	1	160	2H	+ 0.00	2H	5	L1107
DSI 360P	29	57	001	33	1.16	1	165	1H	+ 0.10	1H	5	L1107
DSI 360P	29	58	001	33	1.53	1	113	2H	+ 0.00	2H	15	L1107
DSI 360P	29	59	001	26	0.76	1	165	1H	+ 0.20	1H	5	L1107
DSI 360P	30	51	001	22	0.48	1	101	1H	+ 0.10	1H	5	L1107
DSI 360P	30	69	001	25	0.70	1	115	2H	+ 0.10	2H	5	L1107
DSI 360P			001	26	0.71	1	114	1H	+ 0.20	1H	5	L1107
DSI 360P	30	74	001	24	0.63	1	91	2H	- 0.10	2H	5	L1107
DSI 360P	31	39	001	26	0.75	1	9	2H	+ 0.20	2H	10	L1107
DSI 360P	31	42	001	31	1.10	1	36	1H	+ 0.20	1H	10	L1107
DSI 360P	31	68	001	25	0.68	1	25	1H	+ 0.10	1H	5	L1107
DSI 360P	32	23	001	28	0.89	1	125	1H	+ 0.10	1H	10	L1107
DSI 360P	32	69	001	23	0.84	1	21	1H	+ 0.10	1H	5	L1107
DSI 360P	33	64	001	21	0.67	1	136	2H	- 0.10	2H	5	L1107
DSI 360P			001	22	0.76	1	40	1H	+ 0.00	1H	5	L1107
DSI 360P	33	65	001	24	0.89	1	44	2H	+ 0.00	2H	5	L1107
DSI 360P	34	25	001	33	1.20	1	166	2H	+ 0.00	2H	10	L1107
DSI 360P			001	34	1.10	1	161	2H	+ 0.00	2H	6	L1107
DSI 360P	35	28	001	29	0.98	1	163	1H	+ 0.10	1H	10	L1107
DSI 360P	35	35	001	20	1.22	1	58	1H	- 0.10	1H	20	22680
DSI 360P	35	69	001	23	0.81	1	31	1H	+ 0.00	1H	5	L1107
DSI 360P	37	52	001	29	0.94	1	4	1H	+ 0.10	1H	10	L1107
DSI 360P			001	33	1.07	1	29	2H	- 0.10	2H	6	L1107
DSI 360P			001	32	1.01	1	21	1H	+ 0.20	1H	6	L1107
DSI 360P	38	48	001	22	0.80	1	19	1H	+ 0.00	1H	5	L1107
DSI 360P	45	37	001	38	1.31	1	127	2H	+ 0.20	2H	6	L1107

TOTAL TUBES FOUND * 166
 TOTAL INDICATIONS FOUND * 182
 TOTAL TUBES IN INPUT FILE * 3388

Plant: Beaver Valley Unit 1
Date: 9/89 RES

Steam Generator: A

QUERY: EDDY-360 INDICATIONS DSI EXAMINATION * 201 TM

TEST	ROW	COL	IND	STM	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
DSI 360P	32	29	001	14	0.59	1	53	1H	+ 0.00	1H	20	S2680
DSI 360P	32	38	001	19	1.11	1	63	1H	+ 0.30	1H	20	S2680
DSI 360P	32	63	001	13	0.40	1	132	1H	+ 0.10	1H	5	L1107
DSI 360P	33	43	001	7	0.31	1	74	1H	+ 0.00	1H	20	S2680
DSI 360P	33	63	001	19	0.58	1	21	2H	+ 0.00	2H	5	L1107
DSI 360P	33	65	001	13	0.41	1	46	1H	+ 0.10	1H	5	L1107
DSI 360P	36	23	001	13	0.54	1	67	3H	+ 0.00	3H	20	S2680
DSI 360P	36	35	001	11	0.47	1	113	1H	+ 0.00	1H	20	S2680
DSI 360P	36	69	001	12	0.50	1	72	1H	+ 0.00	1H	20	S2680
DSI 360P	38	64	001	17	0.78	1	116	3H	+ 0.30	3H	20	S2680

TOTAL TUBES FOUND # 78
TOTAL INDICATIONS FOUND # 80
TOTAL TUBES IN INPUT FILE # 3368

Plant: Beaver Valley Unit 1
Tape: 9/89 RES

Steam Generator: B

QUERY: TUBES INSPECTED WITH EDDY-360 DSI EXAMINATION

TEST	ROW	COL	IND	RTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
DSI 360P	24	50	NDD						+ 0.00	1H	3	L1107
DSI 360P	24	53	NDD						+ 0.00	1H	3	L1107
DSI 360P	24	54	NDD						+ 0.00	1H	3	L1107
DSI 360P	24	55	NDD						+ 0.00	1H	3	L1107
DSI 360P	24	56	NDD						+ 0.00	2H	3	L1107
DSI 360P	24	57	NDD						+ 0.00	1H	3	L1107
DSI 360P	25	16	NDD						+ 0.00	1H	3	L1107
DSI 360P	25	19	OD1	35	2.16	1	53	1H	+ 0.10	1H	3	L1107
DSI 360P	25	22	NDD						+ 0.00	1H	22	L1107
DSI 360P	25	69	NDD						+ 0.00	1H	3	L1107
DSI 360P	25	70	NDD						+ 0.00	1H	3	L1107
DSI 360P	27	68	NDD						+ 0.00	3H	3	L1107
DSI 360P			NDD						+ 0.00	2H	3	L1107
DSI 360P			NDD						+ 0.00	1H	3	L1107
DSI 360P	28	13	NDD						+ 0.00	6H	3	L1107
DSI 360P	28	50	NDD						+ 0.00	1H	3	L1107
DSI 360P	28	53	NDD						+ 0.00	1H	3	L1107
DSI 360P	28	57	OD1	6	0.69	1	159	1H	+ 0.00	1H	3	L1107
DSI 360P	29	12	OD1	19	2.39	1	138	1H	+ 0.20	1H	3	L1107
DSI 360P	30	13	OD1	24	3.82	1	102	1H	+ 0.20	1H	3	L1107
DSI 360P	30	35	NDD						+ 0.00	1H	3	L1107
DSI 360P	30	62	NDD						+ 0.00	1H	3	L1107
DSI 360P	30	63	NDD						+ 0.00	1H	3	L1107
DSI 360P	31	34	OD1	14	1.51	1	88	1H	+ 0.10	1H	3	L1107
DSI 360P	31	35	NDD						+ 0.00	2H	3	L1107
DSI 360P	31		OD1	6	0.60	1	105	1H	+ 0.10	1H	3	L1107
DSI 360P	31	36	OD1	11	1.19	1	81	1H	+ 0.10	1H	3	L1107
DSI 360P	31	50	NDD						+ 0.00	1H	3	L1107
DSI 360P	31	62	NDD						+ 0.00	1H	3	L1107
DSI 360P	31	73	NDD						+ 0.00	1H	3	L1107
DSI 360P	32	71	NDD						+ 0.00	1H	3	L1107
DSI 360P	32	72	NDD						+ 0.00	6H	3	L1107
DSI 360P	32	75	NDD						+ 0.00	1H	3	L1107
DSI 360P	33	18	OD1	20	2.27	1	84	1H	+ 0.30	1H	15	L1107
DSI 360P	33	35	OD1	7	0.75	1	149	1H	+ 0.00	1H	3	L1107
DSI 360P	33	36	NDD						+ 0.00	1H	3	L1107
DSI 360P	33	39	OD1	7	0.72	1	115	1H	+ 0.10	1H	3	L1107
DSI 360P	33	46	NDD						+ 0.00	1H	15	L1107
DSI 360P	33	48	OD1	7	0.79	1	61	1H	+ 0.00	1H	3	L1107
DSI 360P	33	50	NDD						+ 0.00	5H	3	L1107
DSI 360P	33	52	OD1	16	1.70	1	50	2H	+ 0.00	2H	3	L1107
DSI 360P	33		OD1	17	1.87	1	61	1H	+ 0.10	1H	3	L1107
DSI 360P	33	76	NDD						+ 0.00	1H	3	L1107
DSI 360P	34	37	OD1	12	0.98	1	134	2H	+ 0.30	2H	15	L1107
DSI 360P	34	39	OD1	13	1.42	1	132	2H	+ 0.10	2H	3	L1107
DSI 360P	34	40	OD1	41	2.59	1	96	1H	+ 0.20	1H	3	L1107
DSI 360P	34	54	NDD						+ 0.00	1H	3	L1107
DSI 360P	34	65	NDD						+ 0.00	2H	3	L1107
DSI 360P	35	19	OD1	20	2.22	1	79	1H	+ 0.30	1H	15	L1107
DSI 360P	35	31	OD1	17	1.94	1	77	3H	+ 0.10	3H	3	L1107
DSI 360P			OD1	18	2.13	1	74	1H	+ 0.20	1H	3	L1107
DSI 360P	35	33	OD1	18	2.25	1	71	1H	+ 0.20	1H	3	L1107
DSI 360P	35	54	NDD						+ 0.00	1H	3	L1107
DSI 360P	35	62	OD1	14	1.25	1	69	1H	+ 0.10	1H	11	W0942
DSI 360P	36	21	OD1	21	2.47	1	103	1H	+ 0.30	1H	15	L1107
DSI 360P	36	49	NDD						+ 0.00	3H	3	L1107
DSI 360P	38	31	OD1	10	1.06	1	87	1H	+ 0.00	1H	3	L1107
DSI 360P	39	45	NDD						+ 0.00	1H	3	L1107
DSI 360P	41	44	NDD						+ 0.00	1H	5	L1107
DSI 360P	41	46	OD1	9	0.76	1	34	1H	+ 0.10	1H	5	L1107
DSI 360P	43	32	OD1	17	1.58	1	111	1H	+ 0.20	1H	15	L1107
DSI 360P	43	38	OD1	21	2.51	1	65	1H	+ 0.50	1H	15	L1107
DSI 360P	44	35	OD1	20	2.19	1	68	1H	+ 0.30	1H	15	L1107
DSI 360P	44	49	OD1	20	2.69	1	132	1H	+ 0.10	1H	3	L1107
DSI 360P	44	62	OD1	17	1.75	1	91	1H	+ 0.00	1H	11	W0942
DSI 360P	45	39	OD1	21	2.61	1	98	1H	+ 0.10	1H	15	L1107

TOTAL TUBES FOUND = 280
TOTAL INDICATIONS FOUND = 346
TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
 Page: 9/89 RES

Steam Generator: B

QUERY: EDDY-360 INDICATIONS DSI EXAMINATION ** 40% TW

TEST	ROW	COL	IND	NTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLIST	COMMENTS
DSI 360P	1	9	001	49	3.55	1	82	1H	+ 0.00	1H	11	NO942
DSI 360P	1	19	001	40	2.11	1	101	1H	+ 0.10	1H	3	L1107
DSI 360P	1	87	001	75	11.79	1	42	TSK	+ 0.00	TSK	14	NO942
DSI 360P	2	37	001	44	2.75	1	86	1H	+ 0.00	1H	3	L1107
DSI 360P	5	7	001	41	2.14	1	126	2H	+ 0.00	2H	11	L1107
DSI 360P			001	41	2.64	1	50	1H	+ 0.10	1H	11	L1107
DSI 360P	6	10	001	41	2.08	1	99	1H	+ 0.10	1H	11	L1107
DSI 360P	10	58	001	55	4.60	1	82	1H	+ 0.10	1H	11	NO942
DSI 360P	11	30	001	42	2.88	1	91	1H	+ 0.10	1H	3	L1107
DSI 360P	12	10	001	41	2.08	1	100	1H	+ 0.10	1H	11	L1107
DSI 360P	15	8	001	40	1.94	1	58	1H	+ 0.00	1H	5	L1107
DSI 360P	16	19	001	41	2.64	1	89	1H	+ 0.10	1H	3	L1107
DSI 360P	34	40	001	41	2.59	1	96	1H	+ 0.20	1H	3	L1107

TOTAL TUBES FOUND * 12
 TOTAL INDICATIONS FOUND * 13
 TOTAL TUBES IN INPUT FILE * 3388

Plant: Beaver Valley Unit 1
Date: 9/89 RES

Steam Generator: B

USER: EDDY_360 INDICATIONS DSI EXAMINATION 20 TO 39% TW

TEST	ROW	COL	IND	WTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
DSI 360P	3	13	001	27	0.99	1	146	1H	+ 0.10	1H	3	L1107
DSI 360P	3	14	001	31	1.88	1	41	1H	+ 0.00	1H	3	L1107
DSI 360P	3	17	001	35	2.14	1	62	2H	+ 0.00	2H	3	L1107
DSI 360P			001	34	1.56	1	65	1H	+ 0.10	1H	3	L1107
DSI 360P	5	36	001	20	2.75	1	122	2H	+ 0.00	2H	3	L1107
DSI 360P	6	10	001	38	2.36	1	113	2H	- 0.10	2H	11	L1107
DSI 360P	6	15	001	38	2.38	1	107	1H	+ 0.19	1H	3	L1107
DSI 360P	6	27	001	35	2.16	1	68	1H	- 0.10	1H	3	L1107
DSI 360P	9	7	001	30	1.76	1	98	1H	+ 0.10	1H	11	L1107
DSI 360P	9	43	001	32	1.95	1	90	1H	+ 0.00	1H	3	L1107
DSI 360P	12	13	001	35	2.13	1	113	2H	- 0.10	2H	3	L1107
DSI 360P	12	18	001	27	1.53	1	65	1H	+ 0.10	1H	5	L1107
DSI 360P	13	26	001	28	1.17	1	113	1H	+ 0.10	1H	22	L1107
DSI 360P	13	27	001	21	0.61	1	97	2H	+ 0.00	2H	22	L1107
DSI 360P	13	92	001	20	1.49	1	139	1H	+ 0.10	1H	22	L1107
DSI 360P	14	9	001	38	1.84	1	98	1H	- 0.10	1H	5	L1107
DSI 360P	15	26	001	28	1.17	1	81	1H	+ 0.00	1H	22	L1107
DSI 360P	15	52	001	32	5.07	1	59	1H	+ 0.30	1H	5	L1107
DSI 360P			001	26	3.47	1	62	1H	- 0.80	1H	5	L1107
DSI 360P			001	22	2.51	1	54	1H	- 2.00	1H	5	L1107
DSI 360P	16	27	001	26	1.02	1	104	1H	+ 0.00	1H	22	L1107
DSI 360P	16	37	001	25	0.94	1	76	1H	+ 0.00	1H	22	L1107
DSI 360P	17	11	001	21	3.02	1	85	1H	+ 0.00	1H	3	L1107
DSI 360P	17	14	001	31	1.43	1	92	1H	+ 0.00	1H	22	L1107
DSI 360P	17	34	001	29	1.25	1	112	3H	- 0.20	3H	22	L1107
DSI 360P	1	44	001	22	0.62	1	94	1H	+ 0.30	1H	22	L1107
DSI 360P	7	53	001	24	3.69	1	103	1H	+ 0.10	1H	3	L1107
DSI 360P	18	29	001	25	0.89	1	46	1H	- 4.90	1H	22	L1107
DSI 360P	21	10	001	38	1.81	1	82	1H	+ 0.10	1H	5	L1107
DSI 360P	22	34	001	20	2.65	1	123	1H	+ 0.10	1H	3	L1107
DSI 360P	25	19	001	35	2.16	1	53	1H	+ 0.10	1H	3	L1107
DSI 360P	30	13	001	24	3.82	1	102	1H	+ 0.20	1H	3	L1107
DSI 360P	33	18	001	20	2.27	1	84	1H	+ 0.30	1H	15	L1107
DSI 360P	35	19	001	20	2.22	1	79	1H	+ 0.30	1H	15	L1107
DSI 360P	36	21	001	21	2.47	1	103	1H	+ 0.30	1H	15	L1107
DSI 360P	43	38	001	21	2.51	1	65	1H	+ 0.50	1H	15	L1107
DSI 360P	44	35	001	20	2.19	1	68	1H	+ 0.30	1H	15	L1107
DSI 360P	44	49	001	20	2.69	1	132	1H	- 0.10	1H	3	L1107
DSI 360P	45	39	001	21	2.61	1	98	1H	+ 0.10	1H	15	L1107

TOTAL TUBES FOUND * 36
TOTAL INDICATIONS FOUND * 39
TOTAL TUBES IN INPUT FILE * 3368

Plant: Beaver Valley Unit 1
 Package: 9/89 RES

Steam Generator: B

QUERY: BODY-360 INDICATIONS DSI EXAMINATION < 20% TW

TEST	ROW	COL	IND	TW	VOLTS	CHN	DES	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
DSI 360P	16	48	001	14	0.76	1	28	1H	+ 0.20	1H	22	L1107
DSI 360P	16	50	001	17	1.60	1	76	1H	+ 0.10	1H	5	L1107
DSI 360P	17	12	001	10	1.05	1	25	1H	+ 0.10	1H	3	L1107
DSI 360P	17	19	001	17	2.06	1	119	2H	+ 0.00	2H	3	L1107
DSI 360P	17	27	001	15	1.57	1	65	1H	+ 0.10	1H	3	L1107
DSI 360P	17	59	001	16	1.82	1	81	1H	+ 0.00	1H	3	L1107
DSI 360P	17	65	001	10	1.10	1	81	1H	+ 0.10	1H	3	L1107
DSI 360P	17	74	001	15	1.66	1	89	1H	+ 0.00	1H	3	L1107
DSI 360P	18	13	001	10	1.08	1	67	2H	+ 0.00	2H	3	L1107
DSI 360P	18	47	001	8	0.86	1	124	1H	+ 0.10	1H	3	L1107
DSI 360P	18	48	001	7	0.78	1	130	1H	+ 0.10	1H	3	L1107
DSI 360P	18	57	001	18	1.92	1	112	2H	+ 0.00	2H	11	N0942
DSI 360P	18	62	001	13	1.36	1	100	1H	+ 0.10	1H	3	L1107
DSI 360P	18	66	001	8	0.71	1	94	1H	+ 0.00	1H	11	N0942
DSI 360P	19	18	001	11	0.87	1	105	1H	+ 0.30	1H	15	L1107
DSI 360P	19	21	001	12	1.01	1	139	1H	+ 0.00	1H	15	L1107
DSI 360P	19	39	001	7	0.73	1	17	1H	+ 0.00	1H	3	L1107
DSI 360P	20	11	001	12	0.97	1	76	1H	+ 0.10	1H	15	L1107
DSI 360P	20	24	001	14	1.50	1	54	1H	+ 0.00	1H	3	L1107
DSI 360P	20	26	001	9	0.69	1	62	1H	+ 0.00	1H	15	L1107
DSI 360P	20	41	001	9	0.73	1	49	1H	+ 0.10	1H	15	L1107
DSI 360P	20	58	001	10	0.86	1	89	1H	+ 0.10	1H	11	N0942
DSI 360P	21	59	001	13	0.71	1	152	3H	+ 0.20	3H	22	L1107
DSI 360P			001	13	0.68	1	28	1H	+ 0.10	1H	22	L1107
DSI 360P	21	66	001	12	1.30	1	71	1H	+ 0.10	1H	3	L1107
DSI 360P	22	22	001	13	1.06	1	31	1H	+ 0.10	1H	15	L1107
DSI 360P	22	23	001	4	0.48	1	85	1H	+ 0.00	1H	3	L1107
DSI 360P	22	70	001	11	1.24	1	113	2H	+ 0.10	2H	3	L1107
DSI 360P			001	12	1.00	1	71	2H	+ 0.10	2H	5	L1107
DSI 360P	22	75	001	17	1.81	1	92	1H	+ 0.20	1H	11	N0942
DSI 360P	24	17	001	9	0.75	1	111	1H	+ 0.10	1H	15	L1107
DSI 360P	24	22	001	11	0.90	1	58	1H	+ 0.10	1H	15	L1107
DSI 360P	24	36	001	10	0.83	1	125	1H	+ 0.00	1H	15	L1107
DSI 360P	28	57	001	6	0.69	1	159	1H	+ 0.00	1H	3	L1107
DSI 360P	29	12	001	19	2.39	1	138	1H	+ 0.20	1H	3	L1107
DSI 360P	31	34	001	14	1.51	1	88	1H	+ 0.10	1H	3	L1107
DSI 360P	31	35	001	6	0.60	1	105	1H	+ 0.10	1H	3	L1107
DSI 360P	31	36	001	11	1.19	1	81	1H	+ 0.10	1H	3	L1107
DSI 360P	33	35	001	7	0.75	1	149	1H	+ 0.00	1H	3	L1107
DSI 360P	33	39	001	7	0.72	1	115	1H	+ 0.10	1H	3	L1107
DSI 360P	33	48	001	7	0.79	1	61	1H	+ 0.00	1H	3	L1107
DSI 360P	33	52	001	16	1.70	1	50	2H	+ 0.00	2H	3	L1107
DSI 360P			001	17	1.87	1	61	1H	+ 0.10	1H	3	L1107
DSI 360P	34	37	001	12	0.98	1	134	2H	+ 0.30	2H	15	L1107
DSI 360P	34	39	001	13	1.42	1	132	2H	+ 0.10	2H	3	L1107
DSI 360P	35	31	001	17	1.94	1	77	3H	+ 0.10	3H	3	L1107
DSI 360P			001	18	2.13	1	74	1H	+ 0.20	1H	3	L1107
DSI 360P	35	33	001	18	2.25	1	71	1H	+ 0.20	1H	3	L1107
DSI 360P	35	62	001	14	1.25	1	69	1H	+ 0.10	1H	11	N0942
DSI 360P	38	31	001	10	1.06	1	87	1H	+ 0.00	1H	3	L1107
DSI 360P	41	46	001	9	0.76	1	34	1H	+ 0.10	1H	5	L1107
DSI 360P	43	32	001	17	1.58	1	111	1H	+ 0.20	1H	15	L1107
DSI 360P	44	62	001	17	1.75	1	91	1H	+ 0.00	1H	11	N0942

TOTAL TUBES FOUND * 159
 TOTAL INDICATIONS FOUND * 193
 TOTAL TUBES IN INPUT FILE * 3388

Plant: Beaver Valley Unit 1
 Page: 9/09 RES

Steam Generator: C

ALERT: TUBES INSPECTED WITH EDDY-360 DSI EXAMINATION

TEST	ROW	COL	IND	RTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
DSI 360P	1	46	NDD						+ 0.00	1H	12	N0942
DSI 360P	1	47	NDD						+ 0.00	1H	4	N0942
DSI 360P	1	86	NDD						+ 0.00	2H	6	N0942
DSI 360P	2	9	NDD						+ 0.00	1H	12	N0942
DSI 360P	2	16	NDD						+ 0.00	2H	12	N0942
DSI 360P	2	19	NDD						+ 0.00	1H	12	N0942
DSI 360P	2	22	OD1	18	0.63	1	55	1H	+ 0.10	1H	3	S2680
DSI 360P	2	24	NDD						+ 0.00	1H	3	S2680
DSI 360P	2	25	NDD						+ 0.00	2H	12	N0942
DSI 360P			NDD						+ 0.00	1H	12	N0942
DSI 360P	2	47	NDD						+ 0.00	1H	4	N0942
DSI 360P	2	65	NDD						+ 0.00	2H	3	S2680
DSI 360P	2	68	NDD						+ 0.00	2H	3	S2680
DSI 360P	2	70	NDD						+ 0.00	2H	3	S2680
DSI 360P			NDD						+ 0.00	1H	3	S2680
DSI 360P	2	76	NDD						+ 0.00	2H	12	N0942
DSI 360P	3	1	NDD						+ 0.00	2H	3	S2680
DSI 360P			OD1	22	0.92	1	64	1H	+ 0.00	1H	3	S2680
DSI 360P	3	2	NDD						+ 0.00	1H	4	N0942
DSI 360P	3	4	NDD						+ 0.00	2H	17	S2680
DSI 360P			NDD						+ 0.00	1H	17	S2680
DSI 360P	3	6	NDD						+ 0.00	1H	4	N0942
DSI 360P	3	31	NDD						+ 0.00	1H	3	S2680
DSI 360P	3	34	NDD						+ 0.00	1H	3	S2680
DSI 360P	3	46	NDD						+ 0.00	2H	4	N0942
DSI 360P	3	55	NDD						+ 0.00	2H	4	N0942
DSI 360P			NDD						+ 0.00	1H	17	S2680
DSI 360P	3	59	NDD						+ 0.00	2H	4	N0942
DSI 360P			NDD						+ 0.00	1H	4	N0942
DSI 360P	3	60	NDD						+ 0.00	1H	17	S2680
DSI 360P	3	61	NDD						+ 0.00	1H	4	N0942
DSI 360P	3	68	NDD						+ 0.00	1H	3	S2680
DSI 360P	3	71	NDD						+ 0.00	1H	3	S2680
DSI 360P	3	72	NDD						+ 0.00	1H	3	S2680
DSI 360P	3	73	OD1	18	0.52	1	156	2H	+ 0.00	2H	11	S2680
DSI 360P	3	78	NDD						+ 0.00	2H	3	S2680
DSI 360P			NDD						+ 0.00	1H	3	S2680
DSI 360P	4	48	NDD						+ 0.00	1H	4	N0942
DSI 360P	4	51	NDD						+ 0.00	1H	4	N0942
DSI 360P	4	52	NDD						+ 0.00	1H	4	N0942
DSI 360P	4	53	NDD						+ 0.00	1H	4	N0942
DSI 360P	4	55	NDD						+ 0.00	2H	4	N0942
DSI 360P			NDD						+ 0.00	1H	4	N0942
DSI 360P	4	58	NDD						+ 0.00	1H	4	N0942
DSI 360P	4	61	NDD						+ 0.00	1H	4	N0942
DSI 360P	4	69	NDD						+ 0.00	1H	3	S2680
DSI 360P	4	73	NDD						+ 0.00	1H	3	S2680
DSI 360P	4	80	NDD						+ 0.00	1H	3	S2680
DSI 360P	4	84	NDD						+ 0.00	1H	4	N0942
DSI 360P	5	1	NDD						+ 0.00	1H	4	N0942
DSI 360P	5	2	NDD						+ 0.00	2H	17	S2680
DSI 360P	5	59	NDD						+ 0.00	1H	4	N0942
DSI 360P	5	63	NDD						+ 0.00	1H	11	S2680
DSI 360P	5	65	NDD						+ 0.00	1H	11	S2680
DSI 360P	6	80	NDD						+ 0.00	1H	3	S2680
DSI 360P	7	8	NDD						+ 0.00	1H	4	N0942
DSI 360P	7	13	OD1	19	0.66	1	122	1H	+ 0.00	1H	3	S2680
DSI 360P	7	17	OD1	22	1.47	1	50	1H	+ 0.00	1H	11	S2680
DSI 360P	7	21	OD1	24	1.03	1	42	2H	+ 0.00	2H	3	S2680
DSI 360P			OD1	24	1.03	1	111	1H	+ 0.00	1H	3	S2680
DSI 360P	7	23	OD1	24	1.09	1	79	1H	+ 0.10	1H	3	S2680
DSI 360P	7	41	NDD						+ 0.00	4H	10	N0942
DSI 360P	7	78	NDD						+ 0.00	1H	3	S2680
DSI 360P	7	80	NDD						+ 0.00	1H	3	S2680
DSI 360P	7	91	NDD						+ 0.00	1H	11	S2680
DSI 360P	7	94	NDD						+ 0.00	3H	10	N0942
DSI 360P	9	3	NDD						+ 0.00	1H	4	N0942
DSI 360P			NDD						+ 0.00	3H	17	S2680
DSI 360P	9	12	NDD						+ 0.00	1H	12	N0942
DSI 360P	10	57	OD1	45	1.21	1	90	1H	+ 0.20	1H	4	N0942

Plant: Beaver Valley Unit 1
 Stage: 9/89 RES

Steam Generator: C

QUERY: TUBES INSPECTED WITH EDDY-360 DSI EXAMINATION

TEST	ROW	COL	IND	XTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
DSI 360P	10	64	NDD						+ 0.00	1M	11	\$2680
DSI 360P	10	71	NDD						+ 0.00	1M	3	\$2680
DSI 360P	11	76	NDD						+ 0.00	1M	3	\$2680
DSI 360P	11	85	NDD						+ 0.00	1M	10	N0942
DSI 360P	12	44	NDD						+ 0.00	1M	11	\$2680
DSI 360P	12	71	NDD						+ 0.00	1M	3	\$2680
DSI 360P	12	75	NDD						+ 0.00	1M	3	\$2680
DSI 360P	12	81	NDD						+ 0.00	2M	3	\$2680
DSI 360P			NDD						+ 0.00	1M	3	\$2680
DSI 360P	14	3	NDD						+ 0.00	1M	4	N0942
DSI 360P	14	69	NDD						+ 0.00	3M	11	\$2680
DSI 360P	15	6	NDD						+ 0.00	1M	4	N0942
DSI 360P	15	49	NDD						+ 0.00	1M	12	N0942
DSI 360P	15	50	NDD						+ 0.00	1M	4	N0942
DSI 360P	15	51	NDD						+ 0.00	1M	4	N0942
DSI 360P	15	53	NDD						+ 0.00	1M	12	N0942
DSI 360P	15	54	NDD						+ 0.00	2M	4	N0942
DSI 360P	15	55	NDD						+ 0.00	1M	12	N0942
DSI 360P	15	56	NDD						+ 0.00	1M	4	N0942
DSI 360P	15	57	DD1	20	1.21	1	168	1M	+ 0.10	1M	12	N0942
DSI 360P	15	58	NDD						+ 0.00	1M	4	N0942
DSI 360P	15	60	NDD						+ 0.00	1M	4	N0942
DSI 360P	15	62	NDD						+ 0.00	1M	4	N0942
DSI 360P	15	63	NDD						+ 0.00	1M	12	N0942
DSI 360P	15	64	NDD						+ 0.00	2M	3	\$2680
DSI 360P	15	66	NDD						+ 0.00	2M	3	\$2680
DSI 360P		DD1	26	0.65	1	126	1M		+ 0.10	1M	3	\$2680
DSI 360P	15	67	NDD						+ 0.00	1M	3	\$2680
DSI 360P	15	69	DD1	29	0.83	1	140	1M	+ 0.00	1M	3	\$2680
DSI 360P	15	70	DD1	37	1.23	1	100	1M	+ 0.00	1M	3	\$2680
DSI 360P	16	48	DD1	18	0.59	1	118	1M	+ 0.00	1M	11	\$2680
DSI 360P	16	49	NDD						+ 0.00	1M	4	N0942
DSI 360P	17	53	NDD						+ 0.00	1M	3	\$2680
DSI 360P	17	58	NDD						+ 0.00	1M	3	\$2680
DSI 360P	17	80	NDD						+ 0.00	1M	3	\$2680
DSI 360P	17	83	NDD						+ 0.00	1M	3	\$2680
DSI 360P	17	85	NDD						+ 0.00	1M	10	N0942
DSI 360P	18	20	DD1	18	0.61	1	65	1M	+ 0.10	1M	3	\$2680
DSI 360P	18	71	NDD						+ 0.00	1M	3	\$2680
DSI 360P	18	87	NDD						+ 0.00	2M	10	N0942
DSI 360P	18	90	DD1	22	1.75	1	134	1M	+ 0.10	1M	10	N0942
DSI 360P	19	61	NDD						+ 0.00	1M	3	\$2680
DSI 360P	19	66	NDD						+ 0.00	2M	3	\$2680
DSI 360P	19	67	NDD						+ 0.00	1M	3	\$2680
DSI 360P	20	71	NDD						+ 0.00	2M	3	\$2680
DSI 360P			NDD						+ 0.00	1M	3	\$2680
DSI 360P	21	72	NDD						+ 0.00	1M	3	\$2680
DSI 360P	20	73	NDD						+ 0.00	1M	3	\$2680
DSI 360P	20	74	NDD						+ 0.00	2M	3	\$2680
DSI 360P			NDD						+ 0.00	1M	3	\$2680
DSI 360P	20	79	NDD						+ 0.00	1M	3	\$2680
DSI 360P	21	81	NDD						+ 0.00	1M	3	\$2680
DSI 360P	21	85	NDD						+ 0.00	1M	10	N0942
DSI 360P	21	21	DD1	13	0.45	1	166	2M	+ 0.00	2M	3	\$2680
DSI 360P		DD1	34	2.05	1	129	1M		+ 0.00	1M	3	\$2680
DSI 360P	22	62	NDD						+ 0.00	1M	3	\$2680
DSI 360P	23	7	NDD						+ 0.00	1M	17	\$2680
DSI 360P	23	15	DD1	11	0.39	1	66	1M	+ 0.00	1M	12	N0942
DSI 360P	23	16	DD1	18	0.83	1	82	2M	+ 0.10	2M	12	N0942
DSI 360P			NDD						+ 0.00	1M	12	N0942
DSI 360P	23	22	DD1	19	1.15	1	34	1M	+ 0.10	1M	12	N0942
DSI 360P	23	35	NDD						+ 0.00	4M	12	N0942
DSI 360P			NDD						+ 0.00	1M	12	N0942
DSI 360P	23	43	DD1	25	1.15	1	75	1M	+ 0.00	1M	3	\$2680
DSI 360P	23	45	DD1	17	0.78	1	100	1M	+ 0.10	1M	12	N0942
DSI 360P	23	46	DD1	22	0.86	1	68	1M	+ 0.00	1M	3	\$2680
DSI 360P	23	54	DD1	20	0.73	1	43	1M	+ 0.00	1M	3	\$2680
DSI 360P	23	60	NDD						+ 0.00	1M	11	\$2680
DSI 360P	23	70	NDD						+ 0.00	1M	11	\$2680
DSI 360P	24	11	NDD						+ 0.00	1M	12	N0942

Plant: Beaver Valley Unit 1
 Date: 9/29/85

Steam Generator: C

QUERY: TUBES INSPECTED WITH EDDY-360 DSI EXAMINATION

TEST	ROW	COL	IND	%TW	VOLTS	CHM	DEG	LOCATION	EXTENT	TAPE	ANLIST	COMMENTS
DS1 360P	24	12	OD1	16	0.61	1	139	1H	- 0.20	1H	12	N0942
DS1 360P	24	13	NDD						* 0.00	1H	12	N0942
DS1 360P	24	14	NDD						* 0.00	1H	12	N0942
DS1 360P	24	15	NDD						* 0.00	1H	12	N0942
DS1 360P	24	26	NDD						* 0.00	1H	3	S2680
DS1 360P	24	28	NDD						* 0.00	1H	12	N0942
DS1 360P	24	33	NDD						* 0.00	1H	12	N0942
DS1 360P	24	59	OD1	18	0.62	1	125	1H	* 0.00	1H	3	S2680
DS1 360P	24	62	NDD						* 0.00	1H	3	S2680
DS1 360P	24	72	NDD						* 0.00	1H	11	S2680
DS1 360P	24	78	OD1	22	0.84	1	80	1H	* 0.00	1H	3	S2680
DS1 360P	24	79	NDD						* 0.00	1H	11	S2680
DS1 360P	25	16	NDD						* 0.00	1H	12	N0942
DS1 360P	25	34	NDD						* 0.00	1H	12	N0942
DS1 360P	25	35	NDD						* 0.00	1H	12	N0942
DS1 360P	25	61	OD1	18	0.53	1	92	1H	* 0.20	1H	11	S2680
DS1 360P	26	12	OD1	21	1.37	1	61	1H	- 0.20	1H	12	N0942
DS1 360P	26	28	NDD						* 0.00	1H	12	N0942
DS1 360P	26	41	NDD						* 0.00	1H	12	N0942
DS1 360P	26	44	NDD						* 0.00	1H	12	N0942
DS1 360P	26	50	NDD						* 0.00	1H	11	S2680
DS1 360P	27	17	OD1	20	1.17	1	25	1H	* 0.00	1H	12	N0942
DS1 360P	27	18	NDD						* 0.00	1H	12	N0942
DS1 360P	27	20	NDD						* 0.00	1H	12	N0942
DS1 360P	27	25	OD1	13	0.47	1	119	2H	+ 0.10	2H	12	N0942
DS1 360P	27	25	NDD						* 0.00	1H	12	N0942
DS1 360P	27	41	NDD						* 0.00	1H	12	N0942
DS1 360P	27	46	NDD						* 0.00	1H	3	S2680
DS1 360P	27	47	NDD						* 0.00	1H	12	N0942
DS1 360P	28	11	OD1	17	1.11	1	138	1H	- 0.10	1H	17	S2680
DS1 360P	28	12	OD1	14	0.50	1	147	1H	- 0.30	1H	12	N0942
DS1 360P	28	15	OD1	18	0.64	1	48	1H	+ 0.10	1H	3	S2680
DS1 360P	28	17	NDD						* 0.00	2H	12	N0942
DS1 360P	28	22	NDD						* 0.00	1H	12	N0942
DS1 360P	28	26	NDD						* 0.00	1H	12	N0942
DS1 360P	28	27	OD1	17	0.70	1	105	1H	- 0.20	1H	12	N0942
DS1 360P	28	32	OD1	17	0.66	1	28	1H	- 0.10	1H	12	N0942
DS1 360P	28	36	NDD						* 0.00	1H	12	N0942
DS1 360P	28	44	OD1	31	1.70	1	121	1H	+ 0.00	1H	3	S2680
DS1 360P	28	52	OD1	17	0.49	1	53	1H	+ 0.00	1H	11	S2680
DS1 360P	29	16	NDD						* 0.00	1H	12	N0942
DS1 360P	29	17	NDD						* 0.00	1H	12	N0942
DS1 360P	29	19	OD1	23	0.99	1	143	1H	* 0.00	1H	3	S2680
DS1 360P	29	27	NDD						* 0.00	1H	12	N0942
DS1 360P	29	50	OD1	19	1.11	1	138	1H	- 0.20	1H	12	N0942
DS1 360P	29	50	OD1	28	1.42	1	117	1H	+ 0.00	1H	3	S2680
DS1 360P	30	28	OD1	14	0.18	1	165	1H	+ 0.00	1H	11	S2680
DS1 360P	30	30	OD1	34	1.97	1	61	1H	+ 0.00	1H	3	S2680
DS1 360P	30	36	NDD						* 0.00	1H	11	S2680
DS1 360P	30	44	NDD						* 0.00	1H	3	S2680
DS1 360P	30	70	OD1	27	2.42	1	49	1H	- 0.30	1H	11	S2680
DS1 360P	31	21	OD1	21	1.23	1	73	1H	+ 0.00	1H	11	S2680
DS1 360P	31	36	OD1	18	0.69	1	53	3H	+ 0.00	3H	11	S2680
DS1 360P	31	36	OD1	18	0.64	1	155	2H	+ 0.00	2H	11	S2680
DS1 360P	31	36	OD1	22	1.50	1	76	1H	+ 0.00	1H	11	S2680
DS1 360P	31	51	OD1	17	0.60	1	130	1H	+ 0.00	1H	3	S2680
DS1 360P	31	59	NDD						* 0.00	1H	11	S2680
DS1 360P	31	65	OD1	18	0.60	1	58	1H	+ 0.00	1H	11	S2680
DS1 360P	32	18	NDD						* 0.00	1H	3	S2680
DS1 360P	32	20	OD1	18	0.61	1	51	1H	+ 0.00	1H	3	S2680
DS1 360P	32	21	OD1	17	0.44	1	86	2H	+ 0.00	2H	11	S2680
DS1 360P	32	23	OD1	16	0.21	1	81	1H	- 4.50	1H	11	S2680
DS1 360P	32	27	NDD						* 0.00	1H	11	S2680
DS1 360P	32	28	NDD						* 0.00	1H	11	S2680
DS1 360P	32	45	OD1	22	0.85	1	131	1H	+ 0.00	1H	3	S2680
DS1 360P	32	47	OD1	20	1.14	1	108	1H	+ 0.10	1H	11	S2680
DS1 360P	32	55	OD1	25	1.16	1	71	1H	+ 0.00	1H	3	S2680
DS1 360P	32	57	OD1	18	0.61	1	106	1H	+ 0.00	1H	11	S2680
DS1 360P	32	60	OD1	19	0.65	1	58	1H	- 0.10	1H	3	S2680
DS1 360P	33	19	OD1	17	0.48	1	135	2H	+ 0.10	2H	11	S2680

Plant: Beaver Valley Unit 1
Date: 9/89 RES

Steam Generator: C

QUERY: TUBES INSPECTED WITH EDDY-360 DSI EXAMINATION

TEST	ROW	COL	IND	WTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
DSI 360P			NDD						+ 0.00	1N	11	\$2680
DSI 360P	33	36	NDD						+ 0.00	1N	11	\$2680
DSI 360P	33	51	OD1	19	0.94	1	42	1N	+ 0.00	1N	11	\$2680
DSI 360P	33	64	OD1	19	0.84	1	117	1N	+ 0.10	1N	11	\$2680
DSI 360P	33	68	OD1	19	2.74	1	127	1N	+ 0.00	1N	11	\$2680
DSI 360P	33	78	OD1	21	1.19	1	113	4N	+ 0.30	4N	11	\$2680
DSI 360P	33	79	OD1	25	2.03	1	100	1N	+ 0.10	1N	12	N0942
DSI 360P	34	23	OD1	24	1.07	1	71	2N	+ 0.00	2N	3	\$2680
DSI 360P			OD1	23	0.99	1	48	1N	+ 0.00	1N	3	\$2680
DSI 360P	34	24	OD1	12	0.15	1	134	1N	+ 0.00	1N	11	\$2680
DSI 360P	35	20	NDD						+ 0.00	2N	11	\$2680
DSI 360P	35	28	OD1	18	0.72	1	88	1N	+ 0.00	1N	11	\$2680
DSI 360P	35	31	NDD						+ 0.00	1N	11	\$2680
DSI 360P	35	47	OD1	16	0.21	1	140	1N	+ 0.10	1N	11	\$2680
DSI 360P	35	55	OD1	20	1.06	1	90	1N	+ 0.00	1N	11	\$2680
DSI 360P	35	63	OD1	19	0.87	1	117	1N	+ 0.00	1N	11	\$2680
DSI 360P	35	67	OD1	17	0.33	1	145	1N	+ 0.10	1N	11	\$2680
DSI 360P	36	24	NDD						+ 0.00	2N	11	\$2680
DSI 360P	36	31	NDD						+ 0.00	1N	11	\$2680
DSI 360P	36	36	NDD						+ 0.00	2N	11	\$2680
DSI 360P	36	48	NDD						+ 0.00	1N	3	\$2680
DSI 360P	36	65	OD1	18	0.66	1	127	3N	+ 0.00	3N	11	\$2680
DSI 360P			OD1	18	0.54	1	83	2N	+ 0.20	2N	11	\$2680
DSI 360P	37	34	OD1	19	0.87	1	148	1N	+ 0.00	1N	11	\$2680
DSI 360P	37	35	OD1	38	2.41	1	68	1N	+ 0.00	1N	3	\$2680
DSI 360P	37	52	NDD						+ 0.00	1N	3	\$2680
DSI 360P	37	62	NDD						+ 0.00	1N	3	\$2680
DSI 360P	38	38	OD1	17	0.38	1	160	2N	+ 0.10	2N	11	\$2680
DSI 360P	39	32	NDD						+ 0.00	1N	11	\$2680
DSI 360P	40	62	NDD						+ 0.00	2N	3	\$2680
DSI 360P	40	65	NDD						+ 0.00	1N	3	\$2680
DSI 360P	41	33	OD1	26	1.24	1	136	1N	+ 0.00	1N	3	\$2680
DSI 360P	41	56	NDD						+ 0.00	1N	3	\$2680
DSI 360P	42	39	OD1	17	0.39	1	152	1N	+ 0.00	1N	11	\$2680
DSI 360P			OD1	28	2.70	1	75	1N	+ 1.00	1N	11	\$2680 MBM
DSI 360P			OD1	25	2.04	1	78	1N	- 2.30	1N	11	\$2680 MBM
DSI 360P	42	48	OD1	17	0.43	1	61	1N	+ 0.00	1N	11	\$2680
DSI 360P	43	37	OD1	23	1.73	1	148	1N	+ 0.20	1N	11	\$2680
DSI 360P	44	55	OD1	65	2.66	1	56	TSH	+ 0.00	TSH	4	N0942
DSI 360P	44	56	OD1	86	6.66	1	60	TSH	+ 0.00	TSH	4	N0942

TOTAL TUBES FOUND * 224
TOTAL INDICATIONS FOUND * 250
TOTAL TUBES IN INPUT FILE * 3368

Plant: Beaver Valley Unit 1
 Date: 9/89 RES

Steam Generator: C

QUERY: EDDY-360 INDICATIONS DSI EXAMINATION -- 40% TW

TEST	ROW	COL	IND	RTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
DSI 360P	10	57	001	45	1.21	1	90	1H	- 0.20	1H	4	N0942
DSI 360P	44	55	001	65	2.66	1	56	TSH	+ 0.00	TSH	4	N0942
DSI 360P	44	56	001	86	6.66	1	60	TSH	+ 0.00	TSH	4	N0942

TOTAL TUBES FOUND = 3
 TOTAL INDICATIONS FOUND = 3
 TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
 Date: 9/89 RES

Steam Generator: 2

QUERY: EDDY 360 INDICATIONS DSI EXAMINATION 20 TO 39% TW

TEST	ROW	COL	IND	WTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
DSI 360P	3	1	001	22	0.92	1	64	1H	+ 0.00	1H	3	S2680
DSI 360P	7	17	001	22	1.47	1	50	1H	+ 0.00	1H	11	S2680
DSI 360P	7	21	001	24	1.03	1	42	2H	+ 0.00	2H	3	S2680
DSI 360P			001	24	1.03	1	111	1H	+ 0.00	1H	3	S2680
DSI 360P	7	23	001	24	1.09	1	79	1H	+ 0.10	1H	3	S2680
DSI 360P	15	57	001	20	1.21	1	168	1H	+ 0.10	1H	12	ND942
DSI 360P	15	66	001	26	0.85	1	126	1H	+ 0.10	1H	3	S2680
DSI 360P	15	69	001	29	0.83	1	140	1H	+ 0.00	1H	3	S2680
DSI 360P	15	70	001	37	1.23	1	100	1H	+ 0.00	1H	3	S2680
DSI 360P	18	90	001	22	1.75	1	134	1H	+ 0.10	1H	10	ND942
DSI 360P	21	21	001	34	2.05	1	129	1H	+ 0.00	1H	3	S2680
DSI 360P	23	43	001	25	1.15	1	75	1H	+ 0.00	1H	3	S2680
DSI 360P	23	46	001	22	0.86	1	68	1H	+ 0.00	1H	3	S2680
DSI 360P	23	54	001	20	0.73	1	43	1H	+ 0.00	1H	3	S2680
DSI 360P	24	78	001	22	0.84	1	80	1H	+ 0.00	1H	3	S2680
DSI 360P	26	12	001	21	1.37	1	61	1H	+ 0.20	1H	12	ND942
DSI 360P	27	17	001	20	1.17	1	25	1H	+ 0.00	1H	12	ND942
DSI 360P	28	44	001	31	1.70	1	121	1H	+ 0.00	1H	3	S2680
DSI 360P	29	19	001	23	0.99	1	143	1H	+ 0.00	1H	3	S2680
DSI 360P	29	50	001	28	1.42	1	117	1H	+ 0.00	1H	3	S2680
DSI 360P	30	30	001	34	1.97	1	61	1H	+ 0.00	1H	3	S2680
DSI 360P	30	70	001	27	2.42	1	49	1H	+ 0.30	1H	11	S2680
DSI 360P	31	21	001	21	1.23	1	73	1H	+ 0.00	1H	11	S2680
DSI 360P	31	36	001	22	1.50	1	76	1H	+ 0.00	1H	11	S2680
DSI 360P	32	45	001	22	0.85	1	131	1H	+ 0.00	1H	3	S2680
DSI 360P	32	47	001	20	1.14	1	108	1H	+ 0.10	1H	11	S2680
DSI 360P	32	55	001	25	1.16	1	71	1H	+ 0.00	1H	3	S2680
DSI 360P	33	78	001	21	1.19	1	113	4H	+ 0.30	4H	11	S2680
DSI 360P	33	79	001	25	2.03	1	100	1H	+ 0.10	1H	12	ND942
DSI 360P	34	23	001	24	1.07	1	71	2H	+ 0.00	2H	3	S2680
DSI 360P			001	23	0.99	1	48	1H	+ 0.00	1H	3	S2680
DSI 360P	35	55	001	20	1.06	1	90	1H	+ 0.00	1H	11	S2680
DSI 360P	37	35	001	38	2.41	1	68	1H	+ 0.00	1H	3	S2680
DSI 360P	41	33	001	26	1.24	1	136	1H	+ 0.00	1H	3	S2680
DSI 360P	42	39	001	28	2.70	1	75	1H	+ 1.00	1H	11	S2680 MBM
DSI 360P			001	25	2.04	1	78	1H	+ 2.30	1H	11	S2680 MBM
DSI 360P	43	37	001	23	1.73	1	148	1H	+ 0.20	1H	11	S2680

TOTAL TUBES FOUND * 34
 TOTAL INDICATIONS FOUND * 37
 TOTAL TUBES IN INPUT FILE * 3388

Plant: Beaver Valley Unit 3
 Stage: 9/BV RES

Steam Generator: C

QUERY: EDDY-360 INDICATIONS DSI EXAMINATION - 20% TW

TEST	ROW	COL	IND	%TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLIST	COMMENTS
DSI 360P	2	22	001	18	0.63	1	55	1H	+ 0.10	1H	3	S2680
DSI 360P	3	73	001	18	0.52	1	156	2H	+ 0.00	2H	11	S2680
DSI 360P	7	13	001	19	0.66	1	122	1H	+ 0.00	1H	3	S2680
DSI 360P	16	48	001	18	0.59	1	118	1H	+ 0.00	1H	11	S2680
DSI 360P	18	20	001	18	0.61	1	65	1H	+ 0.10	1H	3	S2680
DSI 360P	21	21	001	13	0.45	1	166	2H	+ 0.00	2H	3	S2680
DSI 360P	23	15	001	11	0.39	1	66	1H	+ 0.00	1H	12	W0942
DSI 360P	23	16	001	18	0.83	1	82	2H	- 0.10	2H	12	W0942
DSI 360P	23	22	001	19	1.15	1	34	1H	+ 0.10	1H	12	W0942
DSI 360P	23	45	001	17	0.78	1	100	1H	+ 0.10	1H	12	W0942
DSI 360P	24	12	001	16	0.61	1	139	1H	- 0.20	1H	12	W0942
DSI 360P	24	59	001	18	0.62	1	125	1H	+ 0.00	1H	3	S2680
DSI 360P	25	61	001	18	0.53	1	92	1H	+ 0.20	1H	11	S2680
DSI 360P	27	20	001	13	0.47	1	119	2H	+ 0.10	2H	12	W0942
DSI 360P	28	11	001	17	1.11	1	138	1H	- 0.10	1H	17	S2680
DSI 360P	28	12	001	14	0.50	1	147	1H	- 0.30	1H	12	W0942
DSI 360P	28	15	001	18	0.64	1	48	1H	+ 0.10	1H	3	S2680
DSI 360P	28	27	001	17	0.74	1	105	1H	- 0.20	1H	12	W0942
DSI 360P	28	32	001	17	0.66	1	28	1H	- 0.10	1H	12	W0942
DSI 360P	28	52	001	17	0.49	1	53	1H	+ 0.00	1H	11	S2680
DSI 360P	29	27	001	19	1.11	1	138	1H	- 0.20	1H	12	W0942
DSI 360P	30	28	001	14	0.18	1	165	1H	+ 0.00	1H	11	S2680
DSI 360P	31	36	001	18	0.69	1	53	3H	+ 0.00	3H	11	S2680
DSI 360P			001	18	0.64	1	155	2H	+ 0.00	2H	11	S2680
DSI 360P	31	51	001	17	0.60	1	130	1H	+ 0.00	1H	3	S2680
DSI 360P	31	65	001	18	0.60	1	58	1H	+ 0.00	1H	11	S2680
DSI 360P	32	20	001	18	0.61	1	51	1H	+ 0.00	1H	3	S2680
DSI 360P	32	21	001	17	0.44	1	86	2H	+ 0.00	2H	11	S2680
DSI 360P	32	23	001	16	0.21	1	81	1H	- 4.50	1H	11	S2680
DSI 360P	32	57	001	18	0.61	1	106	1H	+ 0.00	1H	11	S2680
DSI 360P	32	60	001	19	0.65	1	58	1H	- 0.10	1H	3	S2680
DSI 360P	33	19	001	17	0.48	1	135	2H	+ 0.10	2H	11	S2680
DSI 360P	33	51	001	19	0.94	1	42	1H	+ 0.00	1H	11	S2680
DSI 360P	33	64	001	19	0.84	1	117	1H	+ 0.10	1H	11	S2680
DSI 360P	33	68	001	19	0.74	1	127	1H	+ 0.00	1H	11	S2680
DSI 360P	34	24	001	12	0.15	1	134	1H	+ 0.00	1H	11	S2680
DSI 360P	35	28	001	18	0.72	1	68	1H	+ 0.00	1H	11	S2680
DSI 360P	35	47	001	16	0.21	1	140	1H	+ 0.10	1H	11	S2680
DSI 360P	35	63	001	19	0.87	1	117	1H	+ 0.00	1H	11	S2680
DSI 360P	35	67	001	17	0.33	1	145	1H	+ 0.10	1H	11	S2680
DSI 360P	36	65	001	18	0.66	1	127	3H	+ 0.00	3H	11	S2680
DSI 360P			001	18	0.54	1	83	2H	+ 0.20	2H	11	S2680
DSI 360P	37	34	001	19	0.87	1	148	1H	+ 0.00	1H	11	S2680
DSI 360P	38	38	001	17	0.38	1	160	2H	+ 0.10	2H	11	S2680
DSI 360P	42	39	001	17	0.39	1	152	1H	+ 0.00	1H	11	S2680
DSI 360P	42	48	001	17	0.43	1	61	1H	+ 0.00	1H	11	S2680

TOTAL TUBES FOUND * 44
 TOTAL INDICATIONS FOUND * 46
 TOTAL TUBES IN INPUT FILE * 3388

ATTACHMENT IV

Plant: Beaver Valley Unit 1
 Page: 5/89 RES

Steam Generator: A

QUERY: TUBES INSPECTED WITH EDDY-360 WEXTEX EXAMINATION

TEST	ROW	COL	IND	NTV	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
WEX 360	11	51	NDD		+ 0.00				TSH	4	N0942	
WEX 360	11	54	NDD		+ 0.00				TSH	4	N0942	
WEX 360	11	57	NDD		+ 0.00				TSH	4	N0942	
WEX 360	11	60	NDD		+ 0.00				TSH	4	N0942	
WEX 360	11	63	NDD		+ 0.00				TSH	4	N0942	
WEX 360	11	66	NDD		+ 0.00				TSH	4	N0942	
WEX 360	11	69	NDD		+ 0.00				TSH	4	N0942	
WEX 360	14	51	NDD		+ 0.00				TSH	4	N0942	
WEX 360	14	54	NDD		+ 0.00				TSH	4	N0942	
WEX 360	14	57	NDD		+ 0.00				TSH	4	N0942	
WEX 360	14	60	NDD		+ 0.00				TSH	4	N0942	
WEX 360	14	63	NDD		+ 0.00				TSH	4	N0942	
WEX 360	14	66	NDD		+ 0.00				TSH	4	N0942	
WEX 360	14	69	NDD		+ 0.00				TSH	4	N0942	
WEX 360	17	48	NDD		+ 0.00				TSH	4	N0942	
WEX 360	17	51	NDD		+ 0.00				TSH	4	N0942	
WEX 360	17	54	NDD		+ 0.00				TSH	4	N0942	
WEX 360	17	57	NDD		+ 0.00				TSH	4	N0942	
WEX 360	17	60	NDD		+ 0.00				TSH	4	N0942	
WEX 360	17	63	NDD		+ 0.00				TSH	4	N0942	
WEX 360	17	66	NDD		+ 0.00				TSH	4	N0942	
WEX 360	17	69	NDD		+ 0.00				TSH	4	N0942	
WEX 360	20	48	NDD		+ 0.00				TSH	4	N0942	
WEX 360	20	51	NDD		+ 0.00				TSH	4	N0942	
WEX 360	20	54	NDD		+ 0.00				TSH	4	N0942	
WEX 360	20	57	NDD		+ 0.00				TSH	4	N0942	
WEX 360	20	60	NDD		+ 0.00				TSH	4	N0942	
WEX 360	20	63	NDD		+ 0.00				TSH	4	N0942	
WEX 360	20	66	NDD		+ 0.00				TSH	4	N0942	
WEX 360	20	69	NDD		+ 0.00				TSH	4	N0942	
WEX 360	23	63	NDD		+ 0.00				TSH	4	N0942	
WEX 360	23	66	NDD		+ 0.00				TSH	4	N0942	
WEX 360	23	69	NDD		+ 0.00				TSH	4	N0942	

TOTAL TUBES FOUND * 33
 TOTAL INDICATIONS FOUND * 33
 TOTAL TUBES IN INPUT FILE * 3368

Beaver Valley Unit 1
139
9/BV RES

Steam Generator: B

TUBES INSPECTED WITH EDDY-360 WEXTEX EXAMINATION

TST	ROW	COL	IND	STM	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
WEX 360	1		9	NDD					+ 0.00	TSH	21	N0942
WEX 360	1		19	NDD					+ 0.00	TSH	21	N0942
WEX 360	1		67	NDD					+ 0.00	TSH	19	L1107
WEX 360	1		85	NDD					+ 0.00	TSH	17	N0942
WEX 360	1		86	NDD					+ 0.00	TSH	17	N0942
WEX 360	1		87	OD1	75	11.79	1	42 TSH	+ 0.00	TSH	14	N0942
WEX 360				OD1	75	11.79	1	42 TSH	+ 0.00	TSH	17	N0942
WEX 360				OD1	75	11.79	1	42 TSH	+ 0.00	TSH	20	L1107
WEX 360	1		88	NDD					+ 0.00	TSH	18	N0942
WEX 360	1		89	NDD					+ 0.00	TSH	18	N0942
WEX 360	1		91	NDD					+ 0.00	TSH	21	N0942
WEX 360	2		37	NDD					+ 0.00	TSH	21	N0942
WEX 360	2		53	NDD					+ 0.00	TSH	19	L1107
WEX 360	2		65	NDD					+ 0.00	TSH	19	L1107
WEX 360	2		66	NDD					+ 0.00	TSH	19	L1107
WEX 360	2		75	NDD					+ 0.00	TSH	19	L1107
WEX 360	2		85	NDD					+ 0.00	TSH	17	N0942
WEX 360	2		86	NDD					+ 0.00	TSH	17	N0942
WEX 360	2		87	OD1	42	2.58	1	155 TSH	+ 0.10	TSH	17	N0942
WEX 360				OD1	82	14.45	1	128 TSH	+ 0.00	TSH	20	L1107
WEX 360	2		88	NDD					+ 0.00	TSH	18	N0942
WEX 360	2		89	NDD					+ 0.00	TSH	18	N0942
WEX 360	3		13	NDD					+ 0.00	TSH	21	N0942
WEX 360	3		14	NDD					+ 0.00	TSH	21	N0942
WEX 360	3		16	NDD					+ 0.00	TSH	19	L1107
WEX 360	3		17	NDD					+ 0.00	TSH	21	N0942
WEX 360	3		19	NDD					+ 0.00	TSH	21	N0942
WEX 360	3		82	NDD					+ 0.00	TSH	18	N0942
WEX 360	3		85	NDD					+ 0.00	TSH	17	N0942
WEX 360	3		86	NDD					+ 0.00	TSH	17	N0942
WEX 360	3		87	OD1	48	3.74	1	129 TSH	+ 0.10	TSH	17	N0942
WEX 360				OD1	66	7.23	1	133 TSH	+ 0.10	TSH	20	L1107
WEX 360	3		88	NDD					+ 0.00	TSH	18	N0942
WEX 360	3		92	NDD					+ 0.00	TSH	18	N0942
WEX 360	4		2	NDD					+ 0.00	TSH	21	N0942
WEX 360	4		22	NDD					+ 0.00	TSH	21	N0942
WEX 360	4		86	NDD					+ 0.00	TSH	25	L1107
WEX 360	4		87	OD1	41	2.38	1	122 TSH	+ 0.00	TSH	17	N0942
WEX 360				OD1	63	6.04	1	129 TSH	+ 0.00	TSH	20	L1107
WEX 360	5		7	NDD					+ 0.00	TSH	21	N0942
WEX 360	5		70	NDD					+ 0.00	TSH	21	N0942
WEX 360	5		79	NDD					+ 0.00	TSH	18	N0942
WEX 360	5		86	NDD					+ 0.00	TSH	25	L1107
WEX 360	5		87	OD1	51	4.24	1	108 TSH	+ 0.00	TSH	17	N0942
WEX 360				OD1	66	6.99	1	106 TSH	+ 0.00	TSH	20	L1107
WEX 360	6		10	NDD					+ 0.00	TSH	21	N0942
WEX 360	6		15	NDD					+ 0.00	TSH	21	N0942
WEX 360	6		17	NDD					+ 0.00	TSH	19	L1107
WEX 360	6		27	NDD					+ 0.00	TSH	21	N0942
WEX 360	6		53	NDD					+ 0.00	TSH	19	L1107
WEX 360	6		86	NDD					+ 0.00	TSH	17	N0942
WEX 360	6		87	NDD					+ 0.00	TSH	17	N0942
WEX 360				NDD					+ 0.00	TSH	20	L1107
WEX 360	6		91	NDD					+ 0.00	TSH	21	N0942
WEX 360	7		33	NDD					+ 0.00	TSH	21	N0942
WEX 360	7		56	NDD					+ 0.00	TSH	19	L1107
WEX 360	7		86	NDD					+ 0.00	TSH	25	L1107
WEX 360	7		87	NDD					+ 0.00	TSH	17	N0942
WEX 360				NDD					+ 0.00	TSH	20	L1107
WEX 360	8		86	NDD					+ 0.00	TSH	25	L1107
WEX 360	8		87	NDD					+ 0.00	TSH	17	N0942
WEX 360				NDD					+ 0.00	TSH	20	L1107
WEX 360	9		3	NDD					+ 0.00	TSH	19	L1107
WEX 360	9		7	NDD					+ 0.00	TSH	21	N0942
WEX 360	9		33	NDD					+ 0.00	TSH	18	N0942
WEX 360	9		54	NDD					+ 0.00	TSH	18	N0942
WEX 360	9		76	NDD					+ 0.00	TSH	21	N0942
WEX 360	9		84	NDD					+ 0.00	TSH	19	L1107
WEX 360	9		86	NDD					+ 0.00	TSH	25	L1107
WEX 360	9		87	NDD					+ 0.00	TSH	17	N0942

WLEPT: TUBES INSPECTED WITH EDDY-360 WEXTEK EXAMINATION

TEST	ROW	COL	IND	RTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
WEX 360			NDD		+ 0.00				TSH	20	L1107	
WEX 360	10	8	NDD		+ 0.00				TSH	19	L1107	
WEX 360	10	22	NDD		+ 0.00				TSH	19	L1107	
WEX 360	10	49	NDD		+ 0.00				TSH	18	N0942	
WEX 360	10	58	NDD		+ 0.00				TSH	21	N0942	
WEX 360	10	79	NDD		+ 0.00				TSH	19	L1107	
WEX 360	10	86	NDD		+ 0.00				TSH	19	L1107	
WEX 360	10	86	NDD		+ 0.00				TSH	25	L1107	
WEX 360	10	87	NDD		+ 0.00				TSH	17	N0942	
WEX 360			NDD		+ 0.00				TSH	20	L1107	
WEX 360	11	3	NDD		+ 0.00				TSH	19	L1107	
WEX 360			NDD		+ 0.00				TSH	19	L1107	
WEX 360	11	24	NDD		+ 0.00				TSH	18	N0942	
WEX 360	11	30	NDD		+ 0.00				TSH	21	N0942	
WEX 360	11	32	NDD		+ 0.00				TSH	18	N0942	
WEX 360	11	86	NDD		+ 0.00				TSH	25	L1107	
WEX 360	11	87	NDD		+ 0.00				TSH	18	N0942	
WEX 360			NDD		+ 0.00				TSH	20	L1107	
WEX 360	12	10	NDD		+ 0.00				TSH	21	N0942	
WEX 360	12	13	NDD		+ 0.00				TSH	21	N0942	
WEX 360	12	18	NDD		+ 0.00				TSH	21	N0942	
WEX 360	12	83	NDD		+ 0.00				TSH	18	N0942	
WEX 360	12	86	NDD		+ 0.00				TSH	25	L1107	
WEX 360	12	87	NDD		+ 0.00				TSH	18	N0942	
WEX 360			NDD		+ 0.00				TSH	20	L1107	
WEX 360	13	51	NDD		+ 0.00				TSH	18	N0942	
WEX 360	13	82	NDD		+ 0.00				TSH	18	N0942	
WEX 360	13	86	NDD		+ 0.00				TSH	27	L1107	
WEX 360	13	87	NDD		+ 0.00				TSH	20	L1107	
WEX 360	14	9	NDD		+ 0.00				TSH	21	N0942	
WEX 360	14	12	NDD		+ 0.00				TSH	18	N0942	
WEX 360	14	64	NDD		+ 0.00				TSH	18	N0942	
WEX 360	14	86	NDD		+ 0.00				TSH	27	L1107	
WEX 360	14	87	NDD		+ 0.00				TSH	20	L1107	
WEX 360	15	8	NDD		+ 0.00				TSH	21	N0942	
WEX 360	15	58	NDD		+ 0.00				TSH	19	L1107	
WEX 360	15	86	NDD		+ 0.00				TSH	27	L1107	
WEX 360	15	87	NDD		+ 0.00				TSH	20	L1107	
WEX 360	16	19	NDD		+ 0.00				TSH	21	N0942	
WEX 360	16	81	NDD		+ 0.00				TSH	19	L1107	
WEX 360	16	86	NDD		+ 0.00				TSH	27	L1107	
WEX 360	16	87	NDD		+ 0.00				TSH	20	L1107	
WEX 360	17	50	NDD		+ 0.00				TSH	18	N0942	
WEX 360	17	51	NDD		+ 0.00				TSH	19	L1107	
WEX 360	17	86	NDD		+ 0.00				TSH	18	N0942	
WEX 360	17	90	NDD		+ 0.00				TSH	18	N0942	
WEX 360	18	29	NDD		+ 0.00				TSH	18	N0942	
WEX 360	18	63	NDD		+ 0.00				TSH	19	L1107	
WEX 360	18	86	NDD		+ 0.00				TSH	27	L1107	
WEX 360	19	8	NDD		+ 0.00				TSH	21	N0942	
WEX 360	19	13	NDD		+ 0.00				TSH	18	N0942	
WEX 360	19	35	NDD		+ 0.00				TSH	19	L1107	
WEX 360	19	86	NDD		+ 0.00				TSH	27	L1107	
WEX 360	20	19	NDD		+ 0.00				TSH	18	N0942	
WEX 360	20	81	NDD		+ 0.00				TSH	18	N0942	
WEX 360	21	10	NDD		+ 0.00				TSH	21	N0942	
WEX 360	21	22	NDD		+ 0.00				TSH	18	N0942	
WEX 360	21	54	NDD		+ 0.00				TSH	18	N0942	
WEX 360	21	60	NDD		+ 0.00				TSH	21	N0942	
WEX 360	21	83	NDD		+ 0.00				TSH	19	L1107	
WEX 360	21	86	NDD		+ 0.00				TSH	18	N0942	
WEX 360	21	88	NDD		+ 0.00				TSH	21	N0942	
WEX 360	22	34	NDD		+ 0.00				TSH	18	N0942	
WEX 360	22	38	NDD		+ 0.00				TSH	19	L1107	
WEX 360	22	62	NDD		+ 0.00				TSH	19	L1107	
WEX 360	22	79	NDD		+ 0.00				TSH	19	L1107	
WEX 360	23	70	NDD		+ 0.00				TSH	18	N0942	
WEX 360			NDD		+ 0.00				TSH	19	L1107	
WEX 360	23	80	NDD		+ 0.00				TSH	18	N0942	
WEX 360	24	32	NDD		+ 0.00				TSH	19	L1107	

Plant: Beaver Valley Unit 1
 Date: 9/89 RES

Steam Generator: B

QUERY: TUBES INSPECTED WITH EDDY-360 WEXTEX EXAMINATION

TEST	ROW	COL	IND	NTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
WEX 360	24	65	NDD						+ 0.00	TSH	19	L1107
WEX 360	25	19	NDD						+ 0.00	TSH	21	N0942
WEX 360	25	22	NDD						+ 0.00	TSH	19	L1107
WEX 360	25	66	NDD						+ 0.00	TSH	18	N0942
WEX 360	25	74	NDD						+ 0.00	TSH	19	L1107
WEX 360	26	52	NDD						+ 0.00	TSH	19	L1107
WEX 360	27	76	NDD						+ 0.00	TSH	18	N0942
WEX 360	28	16	NDD						+ 0.00	TSH	19	L1107
WEX 360	28	73	NDD						+ 0.00	TSH	18	N0942
WEX 360	29	42	NDD						+ 0.00	TSH	18	N0942
WEX 360	29	67	NDD						+ 0.00	TSH	19	L1107
WEX 360	29	82	NDD						+ 0.00	TSH	21	N0942
WEX 360	30	64	NDD						+ 0.00	TSH	18	N0942
WFX 360	30	82	NDD						+ 0.00	TSH	18	N0942
WEX 360	31	19	NDD						+ 0.00	TSH	18	N0942
WEX 360	31	68	NDD						+ 0.00	TSH	19	L1107
WEX 360	31	82	NDD						+ 0.00	TSH	21	N0942
WEX 360	32	18	NDD						+ 0.00	TSH	19	L1107
WEX 360	32	70	NDD						+ 0.00	TSH	19	L1107
WEX 360	33	16	NDD						+ 0.00	TSH	21	N0942
WEX 360	33	26	NDD						+ 0.00	TSH	18	N0942
WEX 360	33	78	NDD						+ 0.00	TSH	21	N0942
WEX 360	34	40	NDD						+ 0.00	TSH	21	N0942
WEX 360	34	44	NDD						+ 0.00	TSH	19	L1107
WEX 360			NDD						+ 0.00	TSH	19	L1107
WEX 360	34	48	NDD						+ 0.00	TSH	19	L1107
WEX 360	34	71	NDD						+ 0.00	TSH	19	L1107
WEX 360	35	37	NDD						+ 0.00	TSH	19	L1107
WEX 360			NDD						+ 0.00	TSH	19	L1107
WEX 360	35	41	NDD						+ 0.00	TSH	18	N0942
WEX 360	36	75	NDD						+ 0.00	TSH	19	L1107
WEX 360	37	21	NDD						+ 0.00	TSH	19	L1107
WEX 360	37	36	NDD						+ 0.00	TSH	19	L1107
WEX 360	37	65	NDD						+ 0.00	TSH	19	L1107
WEX 360	38	52	NDD						+ 0.00	TSH	19	L1107
WEX 360	38	54	NDD						+ 0.00	TSH	19	L1107
WEX 360	40	53	NDD						+ 0.00	TSH	18	N0942
WEX 360	41	41	NDD						+ 0.00	TSH	19	L1107
WEX 360	41	53	NDD						+ 0.00	TSH	19	L1107
WEX 360	42	37	NDD						+ 0.00	TSH	19	L1107
WEX 360	43	31	NDD						+ 0.00	TSH	19	L1107
WEX 360	43	56	NDD						+ 0.00	TSH	19	L1107
WEX 360	43	63	NDD						+ 0.00	TSH	19	L1107
WEX 360	44	51	NDD						+ 0.00	TSH	18	N0942
WEX 360	45	39	NDD						+ 0.00	TSH	18	N0942
WEX 360	46	53	NDD						+ 0.00	TSH	21	N0942

TOTAL TUBES FOUND = 169
 TOTAL INDICATIONS FOUND = 186
 TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit
Date: 9/89 RES

Steam Generator: B

QUERY: EDDH-360 INDICATIONS WEXTEN EXAMINATION >= 40% TW

TEST	ROW	COL	IND	%TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
WEX 360	1	87	001	75	11.79	1	42	TSH	+ 0.00	TSH	14	N0942
WEX 360			001	75	11.79	1	42	TSH	+ 0.00	TSH	17	N0942
WEX 360			001	75	11.79	1	42	TSH	+ 0.00	TSH	20	L1107
WEX 360	2	87	001	42	2.58	1	155	TSH	- 0.10	TSH	17	N0942
WEX 360			001	82	14.45	1	128	TSH	+ 0.00	TSH	20	L1107
WEX 360	3	87	001	48	3.74	1	129	TSH	- 0.10	TSH	17	N0942
WEX 360			001	66	7.23	1	133	TSH	+ 0.10	TSH	20	L1107
WEX 360	4	87	001	41	2.38	1	122	TSH	+ 0.00	TSH	17	N0942
WEX 360			001	63	6.04	1	129	TSH	+ 0.00	TSH	20	L1107
WEX 360	5	87	001	51	4.24	1	108	TSH	+ 0.00	TSH	17	N0942
WEX 360			001	66	6.99	1	106	TSH	+ 0.00	TSH	20	L1107

TOTAL TUBES FOUND = 5
 TOTAL INDICATIONS FOUND = 11
 TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
 Page: 9/89 PRE

Steam Generator: A

QUERY: TUBES INSPECTED WITH EDDY 360 WASTAGE EXAMINATION

TEST	ROW	COL	IND	XTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
WASTAGE	14	92	NDD						+ 0.00	2C	12	N0942
WASTAGE			001	24	2.98	1	48	1C	+ 0.00	1C	12	N0942
WASTAGE	17	90	001	18	1.76	1	77	2C	- 0.10	2C	12	N0942
WASTAGE			001	29	4.27	1	47	1C	- 0.50	1C	12	N0942
WASTAGE	21	66	001	19	1.96	1	12	2C	- 0.10	2C	12	N0942
WASTAGE			001	24	2.92	1	42	1C	+ 0.10	1C	12	N0942
WASTAGE	25	11	001	24	2.94	1	91	1C	- 0.10	1C	12	N0942
WASTAGE			001	12	0.87	1	124	2C	- 0.10	2C	12	N0942
WASTAGE	27	85	001	28	4.05	1	95	2C	+ 0.00	2C	12	N0942
WASTAGE			001	24	3.09	1	162	2C	+ 0.00	1C	12	N0942
WASTAGE	28	85	001	17	1.47	1	61	2C	+ 0.20	2C	12	N0942
WASTAGE			001	17	1.48	1	136	1C	- 0.50	1C	12	N0942
WASTAGE	30	16	001	16	1.28	1	125	2C	- 0.30	2C	12	N0942
WASTAGE			001	20	2.19	1	44	1C	- 0.30	1C	12	N0942
WASTAGE	31	16	001	17	1.38	1	52	2C	+ 0.10	2C	12	N0942
WASTAGE			001	26	3.61	1	134	1C	- 0.10	1C	12	N0942
WASTAGE	32	16	001	14	1.02	1	166	2C	- 0.10	2C	12	N0942
WASTAGE			001	27	3.86	1	93	1C	- 0.20	1C	12	N0942
WASTAGE	33	79	001	14	1.03	1	135	2C	- 0.10	2C	12	N0942
WASTAGE			001	18	1.57	1	39	1C	- 0.40	1C	12	N0942
WASTAGE	34	16	001	17	1.38	1	80	2C	- 0.20	2C	12	N0942
WASTAGE			001	11	0.84	1	142	1C	+ 0.10	1C	12	N0942
WASTAGE			001	11	0.83	1	89	1C	+ 0.00	1C	12	N0942
WASTAGE	34	17	001	17	1.50	1	147	2C	- 0.30	2C	12	N0942
WASTAGE			001	25	3.27	1	113	1C	- 0.10	1C	12	N0942
WASTAGE	35	18	001	18	1.66	1	60	2C	+ 0.30	2C	12	N0942
WASTAGE			NDD						+ 0.00	1C	12	N0942
WASTAGE	35	19	NDD						+ 0.00	2C	12	N0942
WASTAGE			001	21	2.23	1	123	1C	- 0.10	1C	12	N0942
WASTAGE	36	20	NDD						+ 0.00	2C	12	N0942
WASTAGE			001	19	1.94	1	34	1C	- 0.20	1C	12	N0942
WASTAGE	36	22	NDD						+ 0.00	2C	12	N0942
WASTAGE			001	29	4.42	1	54	1C	- 0.10	1C	12	N0942
WASTAGE	36	75	001	14	1.08	1	90	2C	- 0.20	2C	12	N0942
WASTAGE			001	22	2.52	1	41	1C	+ 0.10	1C	12	N0942
WASTAGE	38	21	001	15	1.09	1	71	2C	+ 0.10	2C	12	N0942
WASTAGE			NDD						+ 0.00	1C	12	N0942
WASTAGE	39	26	NDD						+ 0.00	2C	12	N0942
WASTAGE			001	18	1.55	1	33	1C	- 0.30	1C	12	N0942
WASTAGE	40	28	001	27	3.76	1	138	2C	- 0.10	2C	12	N0942
WASTAGE			001	17	1.51	1	89	1C	+ 0.20	1C	12	N0942
WASTAGE	40	71	001	14	1.06	1	121	2C	+ 0.30	2C	12	N0942
WASTAGE			NDD						+ 0.00	1C	12	N0942
WASTAGE	41	30	001	11	0.83	1	165	2C	+ 0.20	2C	12	N0942
WASTAGE			NDD						+ 0.00	1C	12	N0942
WASTAGE	42	28	001	23	2.83	1	125	2C	- 0.40	2C	12	N0942
WASTAGE			NDD						+ 0.00	1C	12	N0942
WASTAGE	42	31	001	25	3.26	1	135	2C	- 0.10	2C	12	N0942
WASTAGE			001	33	5.46	1	59	1C	- 0.30	1C	12	N0942
WASTAGE	42	32	001	28	4.02	1	146	2C	- 0.30	2C	12	N0942
WASTAGE			NDD						+ 0.00	1C	12	N0942
WASTAGE	42	34	001	11	0.83	1	166	2C	+ 0.00	2C	12	N0942
WASTAGE			001	21	2.34	1	70	1C	- 6.80	1C	12	N0942
WASTAGE	43	30	001	27	3.73	1	119	2C	- 0.20	2C	12	N0942
WASTAGE			001	20	2.08	1	109	1C	+ 0.30	1C	12	N0942
WASTAGE	43	31	001	23	2.81	1	141	2C	- 0.50	2C	12	N0942
WASTAGE			001	20	2.04	1	159	1C	- 0.10	1C	12	N0942
WASTAGE	44	57	NDD						+ 0.00	2C	12	N0942
WASTAGE			001	18	1.57	1	147	1C	- 0.10	1C	12	N0942
WASTAGE	44	60	001	19	2.00	1	163	2C	+ 0.40	2C	12	N0942
WASTAGE			001	27	3.76	1	59	1C	- 0.20	1C	12	N0942
WASTAGE	44	62	001	19	1.91	1	161	2C	+ 0.00	2C	12	N0942
WASTAGE			NDD						+ 0.00	1C	12	N0942
WASTAGE	45	36	001	21	2.24	1	126	2C	- 4.00	2C	12	N0942
WASTAGE			NDD						+ 0.00	1C	12	N0942
WASTAGE	45	39	001	16	1.64	1	156	2C	- 2.10	2C	12	N0942
WASTAGE			001	18	1.57	1	160	1C	- 0.30	1C	12	N0942
WASTAGE	45	45	001	27	3.93	1	132	2C	- 0.20	2C	12	N0942
WASTAGE			001	16	1.17	1	127	1C	- 0.20	1C	12	N0942

TOTAL TUBES FOUND = 34
 TOTAL INDICATIONS FOUND = 69
 TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
Date: 9/89 PRE

Steam Generator: A

QUERY: TUBES INSPECTED WITH EDDY-360 WASTAGE CONTROL EXAMINATION

TEST	ROW	COL	IND	%TW	VOLTS	CHW	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
WAST CON	2	03	001	17	1.47	1	138	2C	- 0.10	2C	13	N0942
WAST CON			001	29	4.19	1	116	1C	- 0.20	1C	13	N0942
WAST CON	7	94	NDD						+ 0.00	2C	13	N0942
WAST CON			001	25	3.16	1	113	1C	- 0.20	1C	13	N0942
WAST CON	10	92	NDD						+ 0.00	2C	13	N0942
WAST CON			001	20	2.18	1	156	1C	- 0.10	1C	13	N0942
WAST CON	12	92	001	10	0.76	1	142	2C	+ 0.00	2C	13	N0942
WAST CON			001	27	3.70	1	121	1C	- 0.20	1C	13	N0942
WAST CON	15	90	NDD						+ 0.00	2C	13	N0942
WAST CON			001	19	1.96	1	128	1C	+ 0.00	1C	13	N0942
WAST CON	18	89	NDD						+ 0.00	2C	13	N0942
WAST CON			001	25	3.16	1	126	1C	- 0.10	1C	13	N0942
WAST CON	19	90	NDD						+ 0.00	2C	13	N0942
WAST CON			NDD						+ 0.00	1C	13	N0942
WAST CON	20	89	NDD						+ 0.00	2C	13	N0942
WAST CON			NDD						+ 0.00	1C	13	N0942
WAST CON	24	85	NDD						+ 0.00	2C	13	N0942
WAST CON			001	22	2.88	1	88	1C	- 0.10	1C	13	N0942
WAST CON	28	13	001	23	2.84	1	156	2C	- 0.10	2C	14	N0942
WAST CON			NDD						+ 0.00	1C	14	N0942
WAST CON	29	14	NDD						+ 0.00	2C	14	N0942
WAST CON			001	26	3.71	1	125	1C	- 0.20	1C	14	N0942
WAST CON	29	84	NDD						+ 0.00	2C	13	N0942
WAST CON			NDD						+ 0.00	1C	13	N0942
WAST CON	30	14	001	9	0.65	1	159	2C	- 0.10	2C	14	N0942
WAST CON			001	29	4.29	1	140	1C	- 0.20	1C	14	N0942
WAST CON	31	15	001	34	5.87	1	117	2C	- 0.10	2C	14	N0942
WAST CON			001	30	4.56	1	135	1C	- 0.10	1C	14	N0942
WAST CON	35	17	001	27	3.80	1	139	2C	+ 0.00	2C	14	N0942
WAST CON			NDD						+ 0.00	1C	14	N0942
WAST CON	35	78	NDD						+ 0.00	2C	13	N0942
WAST CON			NDD						+ 0.00	1C	13	N0942
WAST CON	37	19	001	24	3.14	1	113	2C	- 0.20	2C	14	N0942
WAST CON			001	11	0.84	1	136	1C	+ 0.00	1C	14	N0942
WAST CON	37	23	NDD						+ 0.00	2C	14	N0942
WAST CON			001	22	2.66	1	127	1C	- 0.40	1C	14	N0942
WAST CON	37	74	001	16	1.30	1	164	2C	- 0.30	2C	13	N0942
WAST CON			001	19	1.89	1	143	1C	+ 0.20	1C	13	N0942
WAST CON	38	22	NDD						+ 0.00	2C	14	N0942
WAST CON			NDD						+ 0.00	1C	14	N0942
WAST CON	38	23	NDD						+ 0.00	2C	14	N0942
WAST CON			001	18	1.74	1	152	1C	- 5.00	1C	14	N0942
WAST CON	41	27	NDD						+ 0.00	2C	13	N0942
WAST CON			001	24	3.25	1	133	1C	+ 0.10	1C	13	N0942
WAST CON	41	29	001	19	2.09	1	149	2C	+ 0.00	2C	13	N0942
WAST CON			NDD						+ 0.00	1C	13	N0942
WAST CON			001	20	2.19	1	137	2C	+ 0.00	2C	14	N0942
WAST CON			001	17	1.32	1	106	1C	+ 0.00	1C	14	N0942
WAST CON	42	29	001	26	3.78	1	136	2C	- 0.20	2C	13	N0942
WAST CON			001	32	5.36	1	82	1C	+ 0.10	1C	13	N0942
WAST CON	42	59	001	17	1.59	1	112	2C	+ 0.30	2C	13	N0942
WAST CON			001	17	1.60	1	148	1C	- 0.10	1C	13	N0942
WAST CON	42	67	NDD						+ 0.00	2C	13	N0942
WAST CON			NDD						+ 0.00	1C	13	N0942
WAST CON	43	33	001	30	4.88	1	132	2C	- 0.10	2C	13	N0942
WAST CON			NDD						+ 0.00	1C	13	N0942
WAST CON	43	34	001	17	1.53	1	165	2C	- 0.10	2C	13	N0942
WAST CON			001	24	3.34	1	130	1C	+ 0.20	1C	13	N0942
WAST CON	43	35	001	33	5.63	1	118	2C	- 0.10	2C	13	N0942
WAST CON			NDD						+ 0.00	1C	13	N0942
WAST CON	44	53	NDD						+ 0.00	2C	13	N0942
WAST CON			001	20	2.25	1	94	1C	- 0.20	1C	13	N0942
WAST CON	45	38	NDD						+ 0.00	2C	13	N0942
WAST CON			NDD						+ 0.00	1C	13	N0942
WAST CON	45	41	001	23	3.03	1	118	2C	+ 0.00	2C	13	N0942
WAST CON			NDD						+ 0.00	1C	13	N0942
WAST CON	45	4E	NDD						+ 0.00	2C	13	N0942
WAST CON			001	12	0.93	1	102	1C	+ 0.00	1C	13	N0942
WAST CON	45	50	001	17	1.41	1	140	2C	- 0.20	2C	13	N0942
WAST CON			001	19	2.06	1	144	1C	+ 0.20	1C	13	N0942

Plant: Beaver Valley Unit 1
 Page: 9/89 PRE

Steam Generator: A

ALERT: TUBES INSPECTED WITH EDDY-360 WASTAGE CONTROL EXAMINATION

TEST	ROW	COL	IND	WTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
WAST CON	45	53	NDD					+ 0.00	2C	13	N0942	
WAST CON			DD1	18	1.85	1	122	1C	1C	13	N0942	
WAST CON	45	59	NDD					+ 0.00	2C	13	N0942	
WAST CON			NDD					+ 0.00	1C	13	N0942	
WAST CON	46	42	DD1	45	10.23	1	122	2C	2C	13	N0942	
WAST CON			NDD					+ 0.00	1C	13	N0942	

TOTAL TUBES FOUND * 37
 TOTAL INDICATIONS FOUND * 76
 TOTAL TUBES IN INPUT FILE * 3388

Plant: Beaver Valley Unit 1
Page: 9/89 PRE

Steam Generator: A

WJERT: EDDY-360 INDICATIONS WASTAGE CONTROL EXAMINATION >= 40% TW

TEST	ROW	COL	IND	NTW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
WAST	001	46	42	001	45	10.23	1	122 20	0.20	2C	13	N0942

TOTAL TUBES FOUND = 1
TOTAL INDICATIONS FOUND = 1
TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
 Page: 9/89 PRE

Steam Generator: A

QUERY: EDDY-360 INDICATIONS WASTAGE CONTROL EXAMINATION 20 TO 39% TW

TEST	ROW	CDL	IND	%TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
WAST CON	2	93	001	29	4.19	1	116	1C	- 0.20	1C	13	N0942
WAST CON	7	94	001	25	3.16	1	113	1C	- 0.20	1C	13	N0942
WAST CON	10	92	001	20	2.18	1	156	1C	- 0.10	1C	13	N0942
WAST CON	12	92	001	27	3.70	1	121	1C	- 0.20	1C	13	N0942
WAST CON	18	89	001	25	3.16	1	126	1C	- 0.10	1C	13	N0942
WAST CON	24	85	001	22	2.88	1	88	1C	- 0.10	1C	13	N0942
WAST CON	28	13	001	23	2.84	1	156	2C	- 0.10	2C	14	N0942
WAST CON	29	14	001	26	3.71	1	125	1C	- 0.20	1C	14	N0942
WAST CON	30	14	001	29	4.29	1	140	1C	- 0.20	1C	14	N0942
WAST CON	31	15	001	34	5.87	1	117	2C	- 0.10	2C	14	N0942
WAST CON			001	30	4.56	1	135	1C	- 0.10	1C	14	N0942
WAST CON	35	17	001	27	3.80	1	139	2C	+ 0.00	2C	14	N0942
WAST CON	37	19	001	24	3.14	1	113	2C	- 0.20	2C	14	N0942
WAST CON	37	23	001	22	2.66	1	127	1C	- 0.40	1C	14	N0942
WAST CON	41	27	001	24	3.25	1	133	1C	+ 0.10	1C	13	N0942
WAST CON	41	29	001	20	2.19	1	137	2C	+ 0.00	2C	14	N0942
WAST CON	42	29	001	26	3.78	1	136	2C	- 0.20	2C	13	N0942
WAST CON			001	32	5.36	1	82	1C	+ 0.10	1C	13	N0942
WAST CON	43	33	001	30	4.88	1	132	2C	- 0.10	2C	13	N0942
WAST CON	43	34	001	24	3.34	1	130	1C	+ 0.20	1C	13	N0942
WAST CON	43	35	001	33	5.63	1	118	2C	- 0.10	2C	13	N0942
WAST CON	44	53	001	20	2.25	1	94	1C	- 0.20	1C	13	N0942
WAST CON	45	41	001	23	3.03	1	118	2C	+ 0.00	2C	13	N0942

TOTAL TUBES FOUND = 21
 TOTAL INDICATIONS FOUND = 23
 TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
 Date: 9/89 PRE

Steam Generator: A

WATER: EDDY-360 INDICATIONS WASTAGE CONTROL EXAMINATION - 20% TW

TEST	ROW	COL	IND	%TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
WAST CON	2	93	001	17	1.47	1	138	2C	- 0.10	2C	13	N0942
WAST CON	12	92	001	10	0.76	1	142	2C	+ 0.00	2C	13	N0942
WAST CON	15	90	001	19	1.96	1	128	1C	+ 0.00	1C	13	N0942
WAST CON	30	14	001	9	0.65	1	159	2C	- 0.10	2C	14	N0942
WAST CON	37	19	001	11	0.84	1	136	1C	+ 0.00	1C	14	N0942
WAST CON	37	74	001	16	1.30	1	164	2C	- 0.30	2C	13	N0942
WAST CON			001	19	1.89	1	143	1C	+ 0.20	1C	13	N0942
WAST CON	38	23	001	18	1.74	1	152	1C	- 5.00	1C	14	N0942
WAST CON	41	29	001	19	2.09	1	149	2C	+ 0.00	2C	13	N0942
WAST CON			001	17	1.32	1	106	1C	+ 0.00	1C	14	N0942
WAST CON	42	59	001	17	1.59	1	112	2C	+ 0.30	2C	13	N0942
WAST CON			001	17	1.60	1	148	1C	- 0.10	1C	13	N0942
WAST CON	43	34	001	17	1.53	1	165	2C	- 0.10	2C	13	N0942
WAST CON	45	48	001	12	0.93	1	102	1C	+ 0.00	1C	13	N0942
WAST CON	45	50	001	17	1.41	1	140	2C	- 0.20	2C	13	N0942
WAST CON			001	19	2.06	1	144	1C	+ 0.20	1C	13	N0942
WAST CON	45	53	001	18	1.85	1	122	1C	- 0.10	1C	13	N0942

TOTAL TUBES FOUND = 13
 TOTAL INDICATIONS FOUND = 17
 TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
Date: 9/89 PRE

Steam Generator: A

WLEP: EDDY-360 INDICATIONS WASTAGE EXAMINATION -># 40% TW
.....

TOTAL TUBES FOUND * 0
TOTAL INDICATIONS FOUND * 0
TOTAL TUBES IN INPUT FILE * 3368

Plant: Beaver Valley Unit 1
Date: 9/89 PRE

Steam Generator: A

**** Page

QUERY: EDDY-360 INDICATIONS WASTAGE EXAMINATION 20 TO 39% TW

TEST	ROW	COL	IND	TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
WASTAGE	14	92	001	24	2.98	1	48	1C	+ 0.00	1C	12	NO942
WASTAGE	17	90	001	29	4.27	1	47	1C	- 0.50	1C	12	NO942
WASTAGE	21	88	001	24	2.92	1	42	1C	+ 0.10	1C	12	NO942
WASTAGE	25	11	001	24	2.94	1	91	1C	- 0.10	1C	12	NO942
WASTAGE	27	85	001	28	4.05	1	95	2C	+ 0.00	2C	12	NO942
WASTAGE			001	24	3.09	1	162	1C	+ 0.00	1C	12	NO942
WASTAGE	30	16	001	20	2.19	1	44	1C	- 0.30	1C	12	NO942
WASTAGE	31	16	001	26	3.61	1	134	1C	- 0.10	1C	12	NO942
WASTAGE	32	16	001	27	3.86	1	93	1C	- 0.20	1C	12	NO942
WASTAGE	34	17	001	25	3.27	1	113	1C	- 0.10	1C	12	NO942
WASTAGE	35	19	001	21	2.23	1	123	1C	- 0.10	1C	12	NO942
WASTAGE	36	22	001	29	4.42	1	54	1C	- 0.10	1C	12	NO942
WASTAGE	36	75	001	22	2.52	1	41	1C	+ 0.10	1C	12	NO942
WASTAGE	40	28	001	27	3.76	1	138	2C	- 0.10	2C	12	NO942
WASTAGE	42	28	001	23	2.83	1	125	2C	- 0.40	2C	12	NO942
WASTAGE	42	31	001	25	3.26	1	135	2C	- 0.10	2C	12	NO942
WASTAGE			001	33	5.46	1	59	1C	- 0.30	1C	12	NO942
WASTAGE	42	32	001	28	4.02	1	146	2C	- 0.30	2C	12	NO942
WASTAGE	42	34	001	21	2.34	1	70	1C	- 6.80	1C	12	NO942
WASTAGE	43	30	001	27	3.73	1	119	2C	- 0.20	2C	12	NO942
WASTAGE			001	20	2.08	1	109	1C	+ 0.30	1C	12	NO942
WASTAGE	43	31	001	23	2.81	1	141	2C	- 0.50	2C	12	NO942
WASTAGE			001	20	2.04	1	159	1C	- 0.10	1C	12	NO942
WASTAGE	44	60	001	27	3.76	1	59	1C	- 0.20	1C	12	NO942
WASTAGE	45	36	001	21	2.24	1	126	2C	- 4.00	2C	12	NO942
WASTAGE	45	45	001	27	3.93	1	132	2C	- 0.20	2C	12	NO942

TOTAL TUBES FOUND * 22
TOTAL INDICATIONS FOUND * 26
TOTAL TUBES IN INPUT FILE * 3388

Plant: Beaver valley Unit 1
 Date: 9/89 PRE

Steam Generator: A

QUERY: EDDY-360 INDICATIONS WASTAGE EXAMINATION < 20% TW

TEST	ROW	COL	IND	%TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
WASTAGE	17	90	001	18	1.76	1	77	2C	- 0.10	2C	12	N0942
WASTAGE	21	88	001	19	1.96	1	12	2C	- 0.10	2C	12	N0942
WASTAGE	25	11	001	12	0.87	1	124	2C	+ 0.10	2C	12	N0942
WASTAGE	28	85	001	17	1.47	1	61	2C	+ 0.20	2C	12	N0942
WASTAGE			001	17	1.48	1	136	1C	- 0.50	1C	12	N0942
WASTAGE	30	16	001	16	1.28	1	125	2C	- 0.30	2C	12	N0942
WASTAGE	31	16	001	17	1.38	1	52	2C	+ 0.10	2C	12	N0942
WASTAGE	32	16	001	14	1.02	1	166	2C	+ 0.10	2C	12	N0942
WASTAGE	33	79	001	14	1.03	1	135	2C	- 0.10	2C	12	N0942
WASTAGE			001	18	1.57	1	39	1C	- 0.40	1C	12	N0942
WASTAGE	34	16	001	17	1.38	1	80	2C	- 0.20	2C	12	N0942
WASTAGE			001	11	0.84	1	142	1C	+ 0.10	1C	12	N0942
WASTAGE			001	11	0.83	1	89	1C	+ 0.00	1C	12	N0942
WASTAGE	34	17	001	17	1.50	1	147	2C	- 0.30	2C	12	N0942
WASTAGE	35	18	001	18	1.66	1	60	2C	+ 0.30	2C	12	N0942
WASTAGE	36	20	001	19	1.94	1	34	1C	- 0.20	1C	12	N0942
WASTAGE	36	75	001	14	1.08	1	90	2C	- 0.20	2C	12	N0942
WASTAGE	38	21	001	15	1.09	1	71	2C	+ 0.10	2C	12	N0942
WASTAGE	39	26	001	18	1.55	1	33	1C	- 0.30	1C	12	N0942
WASTAGE	40	28	001	17	1.51	1	89	1C	+ 0.20	1C	12	N0942
WASTAGE	40	71	001	14	1.06	1	121	2C	+ 0.30	2C	12	N0942
WASTAGE	41	30	001	11	0.83	1	165	2C	+ 0.20	2C	12	N0942
WASTAGE	42	34	001	11	0.83	1	166	2C	+ 0.00	2C	12	N0942
WASTAGE	44	57	001	18	1.57	1	147	1C	- 0.10	1C	12	N0942
WASTAGE	44	60	001	19	2.00	1	163	2C	+ 0.40	2C	12	N0942
WASTAGE	44	62	001	19	1.91	1	161	2C	+ 0.00	2C	12	N0942
WASTAGE	45	39	001	16	1.64	1	156	2C	- 2.10	2C	12	N0942
WASTAGE			001	18	1.57	1	160	1C	- 0.30	1C	12	N0942
WASTAGE	45	45	001	16	1.17	1	127	1C	- 0.20	1C	12	N0942

TOTAL TUBES FOUND = 24
 TOTAL INDICATIONS FOUND = 29
 TOTAL TUBES IN INPUT FILE = 3388

Plant: Beaver Valley Unit 1
Date: 9/89 RES

Steam Generator: C

QUERY: TUBES INSPECTED WITH EDDY-360 CL DEPLUGGED TUBES EXAMINATION

TEST	ROW	COL	IND	%TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
CL PLUGP	1	62	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	1	66	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	2	71	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	10	60	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	11	47	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	11	92	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	24	85	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	24	87	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	30	16	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	31	14	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	31	15	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	31	16	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	31	82	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	32	78	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	35	76	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	37	22	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	41	28	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	43	32	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	44	40	NDD		+ 0.00				TSH	8	N0942	
CL PLUGP	45	49	NDD		+ 0.00				TSH	8	N0942	

TOTAL TUBES FOUND = 20
TOTAL INDICATIONS FOUND = 20
TOTAL TUBES IN INPUT FILE = 3388

ATTACHMENT V

Plant: BEAVER VALLEY UNIT 1

Steam Generator: A

Order: Sort by ROW, COL

Title: TUBES PLUGGED - 7TH REFUELING OUTAGE (9/89 OUTAGE)

NO.	ROW	COL
1.	1-	20
2.	1-	28
3.	1-	42
4.	1-	46
5.	1-	64
6.	1-	66
7.	1-	77
8.	1-	83
9.	2-	32
10.	2-	34
11.	2-	46
12.	2-	63
13.	3-	1
14.	3-	2
15.	3-	39
16.	3-	56
17.	3-	75
18.	3-	78
19.	4-	8
20.	4-	13
21.	4-	18
22.	4-	25
23.	4-	43
24.	4-	64
25.	5-	6
26.	5-	37
27.	5-	38
28.	5-	45
29.	6-	4
30.	6-	31
31.	6-	34
32.	6-	37
33.	6-	40
34.	6-	77
35.	7-	9
36.	7-	34
37.	7-	45
38.	7-	60
39.	8-	2
40.	8-	33
41.	10-	14
42.	10-	27
43.	10-	67
44.	11-	34
45.	11-	41
46.	11-	45
47.	12-	38
48.	12-	45
49.	14-	35
50.	15-	31

NO.	ROW	COL
51.	15-	56
52.	17-	59
53.	19-	14
54.	19-	63
55.	20-	25
56.	20-	28
57.	22-	74
58.	24-	72
59.	24-	76
60.	24-	85
61.	25-	18
62.	25-	30
63.	26-	59
64.	26-	62
65.	27-	34
66.	27-	72
67.	27-	74
68.	28-	19
69.	28-	26
70.	29-	20
71.	29-	24
72.	30-	36
73.	30-	43
74.	31-	18
75.	31-	73
76.	32-	42
77.	32-	67
78.	33-	32
79.	33-	77
80.	34-	37
81.	35-	30
82.	35-	31
83.	37-	23
84.	37-	25
85.	37-	32
86.	43-	38

Plant: BEAVER VALLEY UNIT 1

Steam Generator: B

Order: Sort by ROW, COL

Title: TUBES PLUGGED - 7TH REFUELING OUTAGE (9/89 OUTAGE)

NO.	ROW	COL
1.	1-	9
2.	1-	19
3.	1-	87
4.	1-	91
5.	2-	37
6.	2-	87
7.	3-	13
8.	3-	14
9.	3-	17
10.	3-	19
11.	3-	87
12.	4-	2
13.	4-	22
14.	4-	87
15.	5-	7
16.	5-	70
17.	5-	87
18.	6-	10
19.	6-	15
20.	6-	27
21.	6-	91
22.	7-	33
23.	9-	7
24.	9-	43
25.	9-	76
26.	10-	58
27.	11-	30
28.	12-	10
29.	12-	13
30.	12-	18
31.	14-	9
32.	15-	8
33.	16-	19
34.	19-	8
35.	21-	10
36.	21-	60
37.	21-	88
38.	25-	19
39.	29-	82
40.	31-	82
41.	32-	16
42.	33-	16
43.	33-	78
44.	34-	40
45.	46-	53

Plant: BEAVER VALLEY UNIT 1

Steam Generator: C

Order: Sort by ROW, COL

Title: TUBES PLUGGED - 7TH REFUELING OUTAGE (9/89 OUTAGE)

NO.	ROW	COL
1.	1-	3
2.	1-	4
3.	3-	1
4.	3-	2
5.	4-	51
6.	4-	53
7.	5-	2
8.	10-	57
9.	16-	3
10.	15-	6
11.	15-	59
12.	15-	70
13.	21-	21
14.	26-	10
15.	28-	15
16.	36-	53
17.	42-	66
18.	44-	55
19.	44-	56

ATTACHMENT VI

TABLE 1

EDDY-360 PLUG INDICATIONS
RSG-A INLET

NOTE: All plugs listed below were removed and replaced with heat Number 7042-2 plugs during this outage.

PLUG ID	TYPE IND.	TWD	IND LOC.	EXISTING PLUG INFO.	
				HEAT NO.	INSERTION DATE
1-9	IDI	82	HEEL	W-592-1	1/25/88
1-15	IDI	100	HEEL	W-592-1	1/25/88
1-25	IDI	99	HEEL	W-592-1	1/25/88
1-27	IDI	99	HEEL	W-592-1	1/25/88
1-29	IDI	90	HEEL	W-592-1	1/25/88
1-32	IDI	100	HEEL	W-592-1	1/25/88
1-35	IDI	100	HEEL	W-592-1	1/25/88
1-36	IDI	29	HEEL	W-592-1	1/25/88
1-37		*		W-592-1	1/25/88
1-39		*		W-592-1	1/25/88
1-40		*		W-592-1	1/25/88
1-44		*		W-592-1	1/25/88
1-48	IDI	91	HEEL	2848-2	1/25/88
1-50	IDI	51	HEEL	2848-2	1/25/88
1-52	IDI	100	HEEL	2848-2	1/25/88
1-55	IDI	99	HEEL	W-592-1	1/25/88
1-56	IDI	90	HEEL	W-592-1	1/25/88
1-58		NDD		W-592-1	1/25/88
1-68	IDI	95	HEEL	W-592-1	1/25/88
1-69	IDI	100	HEEL	W-592-1	1/25/88
1-72	IDI	98	HEEL	W-592-1	1/25/88
1-78	IDI	98	HEEL	W-592-1	1/25/88
1-79	IDI	99	HEEL	W-592-1	1/25/88
1-80	IDI	88	HEEL	W-592-1	1/25/88
1-81	IDI	39/100	TOE/HEEL	W-592-1	1/25/88
1-82	IDI	51/100	TOE/HEEL	W-592-1	1/25/88
2-41		*		W-592-1	1/25/88
2-49	IDI	84	HEEL	2848-2	1/25/88
10-43		*		2848-2	1/25/88
15-5	IDI	81/52	HEEL/HEEL	W-592-1	7/03/86
21-8	IDI	43	HEEL	W-592-1	7/03/86
24-37	IDI	100	HEEL	W-592-1	7/03/86
25-10	IDI	100	HEEL	2848-2	1/25/88
28-10		NDD		2848-2	1/25/88
29-11	IDI	100	HEEL	W-592-1	7/03/86
29-13		NDD		W-592-1	7/03/86
30-83		*		W-592-1	7/03/86
31-17		NDD		2848-2	1/25/88
33-42	IDI	100	HEEL	W-592-1	1/25/88
33-78		NDD		W-592-1	7/03/86

TABLE 1 (Cont'd)

EDDY-360 PLUG INDICATIONS
RSG-A INLET

NOTE: All plugs listed below were removed and replaced with heat Number 7042-2 plugs during this outage.

PLUG ID	TYPE IND.	% TWD	IND LOC.	EXISTING PLUG INFO.	
				HEAT NO.	INSERTION DATE
34-18	IDI	100	HEEL	2848-2	1/25/88
34-77	IDI	100	HEEL	W-592-1	7/03/86
37-21	IDI	100	HEEL	2848-2	1/25/88
42-30	IDI	100	HEEL	W-592-1	7/03/86
44-35	IDI	92	HEEL	W-592-1	7/03/86
44-56	IDI	100	HEEL	W-592-1	1/25/88
45-56	IDI	100	HEEL	W-592-1	7/03/86
46-48	IDI	82	HEEL	2848-2	1/25/88

TABLE 2

EDDY-360 PLUG INDICATIONS
RSG-B INLET

NOTE: All plugs listed below were removed and replaced with heat Number 7042-2 plugs during this outage.

PLUG ID	TYPE IND.	% TWD	IND LOC.	EXISTING PLUG INFO.	
				HEAT NO.	INSERTION DATE
1-8	IDI	65	HEEL	2848-2	2/08/88
1-12	IDI	87	HEEL	2848-2	2/08/88
1-22	IDI	21	HEEL	2848-2	2/08/88
1-36	IDI	65	HEEL	2848-2	2/08/88
1-39	IDI	82	HEEL	2848-2	2/08/88
1-46	IDI	62	HEEL	2848-2	2/08/88
1-58	IDI	75	HEEL	2848-2	2/08/88
1-69	IDI	78	HEEL	2848-2	2/08/88
1-77	IDI	86	HEEL	2848-2	2/08/88
2-20	IDI	55	HEEL	2848-2	2/08/88
2-59	IDI	74	HEEL	2848-2	2/08/88
4-1	IDI	71	HEEL	2848-2	2/08/88
4-20	IDI	45/77	HEEL	2848-2	2/08/88
5-1	IDI	95	HEEL	2848-2	2/08/88
5-9	IDI	54	HEEL	2848-2	2/08/88
5-23	IDI	67	HEEL	2848-2	2/08/88
15-90		NDD		W-592-1	6/16/86

TABLE 2 (Cont'd)

EDDY-360 PLUG INDICATIONS
RSG-B INLET

NOTE: All plugs listed below were removed and replaced with heat Number 7042-2 plugs during this outage.

PLUG ID	TYPE IND.	% TWD	IND LOC.	EXISTING PLUG INFO.	
				HEAT NO.	INSERTION DATE
18-6	IDI	74	HEEL	2848-2	2/08/88
22-7	IDI	88	HEEL	2848-2	2/08/88
23-87	IDI	72	HEEL	2848-2	2/08/88
25-9		NDD		W-592-1	6/16/86
25-11	IDI	19	HEEL	W-592-1	6/16/86
26-11		NDD		W-592-1	6/16/86
26-86		NDD		W-592-1	6/16/86
31-16	IDI	88	HEEL	2848-2	2/08/88
31-79		NDD		W-592-1	6/16/86
32-17	IDI	32	TOE	W-592-1	6/16/86
32-79		NDD		W-592-1	6/16/86
33-77		NDD		W-592-1	6/16/86
35-77	IDI	12/25	HEEL	NX2960 or 38347-1	9/83
36-77	IDI	83	HEEL	W-592-1	6/16/86
40-45		NDD		W-592-1	6/16/86
40-50	IDI	20/83	TOE/HEEL	W-592-1	6/16/86
40-51		NDD		W-592-1	6/16/86
45-48		NDD		W-592-1	6/16/86
46-54	IDI	24/55	HEEL/HEEL	NX2960 or 38347-1	9/83

TABLE 3

EDDY-360 PLUG INDICATIONS
RSG-C INLET

NOTE: All plugs listed below were removed and replaced with heat Number 7042-2 plugs during this outage.

PLUG ID	TYPE IND.	% TWD	IND LOC.	EXISTING PLUG INFO.	
				HEAT NO.	INSERTION DATE
1-57		*		2848-2	2/04/88
1-62		*		2848-2	2/04/88
1-66		*		2848-2	2/04/88
2-71		*		2848-2	2/04/88

TABLE 3 (Cont'd)

EDDY-360 PLUG INDICATIONS
RSG-C INLET

NOTE: All plugs listed below were removed and replaced with heat Number 7042-2 plugs during this outage.

PLUG ID	TYPE IND.	% TWD	IND. LOC.	EXISTING PLUG INFO.	
				HEAT NO.	INSERTION DATE
3-3		*			
4-54		*		2848-2	2/04/88
10-60		*		2848-2	2/04/88
11-47		*		2848-2	2/04/88
11-51		*		2848-2	2/04/88
11-52		*		2848-2	2/04/88
11-92		*		2848-2	2/04/88
12-51		*		2848-2	2/04/88
24-85		*		2848-2	2/04/88
24-87		*		2848-2	2/04/88
30-16		*		W-592-1	7/03/86
31-13		*		NX2960/38347-1	9/83
31-14		*		NX2960/38347-1	9/83
31-15		*		NX2960/38347-1	9/83
31-16		*		NX2960/38347-1	9/83
31-82		*		NX2960/38347-1	9/83
32-78		*		2848-2	2/04/88
35-76		*		W-592-1	7/03/86
37-22		*		2848-2	2/04/88
41-28		*		W-592-1	7/03/86
43-32		*		W-592-1	7/03/86
44-40		*		NX2960/38347-1	9/83
45-49		*		W-592-1	7/03/86
		*		W-592-1	7/03/86

LEGEND FOR TABLES 1 THROUGH 3

HEEL	=	HEEL TRANSITION OF THE PLUG (END CLOSEST TO THE TUBE END)
IDI	=	INSIDE DIAMETER INDICATION
IND.	=	INDICATION
LOC.	=	LOCATION
NDD	=	NO DETECTABLE DEGRADATION
% TWD	=	PERCENT THROUGH-WALL DEPTH OF THE INDICATION
TOE	=	TOE TRANSITION OF THE PLUG (END CLOSEST TO THE TOP OF THE TUBESHEET)
*	=	NOT INSPECTED DURING THIS OUTAGE

ATTACHMENT VII

Plant: Beaver Valley Unit 1
 Stage: 9/89 RES

Steam Generator: A

QUERY: TUBES INSPECTED WITH EDDY-360 DEPLUGGED CL TUBE EXAMINATION

TEST	ROW	COL	IND	%TW	VOLTS	CHN	DEG	LOCATION	EXTENT	TAPE	ANLST	COMMENTS
CL PLUGP	1	9	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	15	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	25	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	27	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	29	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	32	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	35	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	36	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	37	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	39	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	40	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	44	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	48	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	58	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	68	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	69	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	72	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	78	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	79	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	80	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	81	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	1	82	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	2	41	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	2	49	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	10	43	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	24	37	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	24	62	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	29	13	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	30	83	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	31	17	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	33	42	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	33	78	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	34	18	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	34	77	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	37	21	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	42	30	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	44	35	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	44	56	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	45	56	NDD		+ 0.00				TSC	11	L1107	
CL PLUGP	46	48	NDD		+ 0.00				TSC	11	L1107	

TOTAL TUBES FOUND = 40
 TOTAL INDICATIONS FOUND = 40
 TOTAL TUBES IN INPUT FILE = 3388