

GPU NUCLEAR CORPORATION  
OYSTER CREEK NUCLEAR GENERATING STATION


Facility Operating  
License No. DPR-16

---


Technical Specification  
Change Request No. 208  
Docket No. 50-219

---

Applicant submits, by this Technical Specification Change Request No. 208 to the Oyster Creek Nuclear Generating Station Technical Specifications, proposed changes to pages 2.3-2 and 4.3-1.

By   
J. J. Barton  
Vice President and Director  
Oyster Creek

Sworn and Subscribed to before me this 3<sup>rd</sup> day of March 1993.

  
A Notary Public of NJ

JUDITH M. CROWE  
Notary Public of New Jersey  
My Commission Expires 11/25/95

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the matter of )  
GPU Nuclear Corporation )


Docket No. 50-219

CERTIFICATE OF SERVICE

This is to certify that a copy of Technical Specification Change Request No. 208 for Oyster Creek Nuclear Generating Station Technical Specifications, filed with the U.S. Nuclear Regulatory Commission on March 3, 1993, has this day of March 3, 1993, been served on the Mayor of Lacey Township, Ocean County, New Jersey by deposit in the United States mail, addressed as follows:

The Honorable Louis A. Amato  
Mayor of Lacey Township  
818 West Lacey Road  
Forked River, NJ 08731

By

  
J. J. Barton  
Vice President and Director  
Oyster Creek

**OYSTER CREEK NUCLEAR GENERATING STATION**  
**Docket No. 50-219**  
**Technical Specification Change Request No. 208**

Applicant hereby requests the Commission to change Appendix A to the above captioned license as described below, and pursuant to 10 CFR 50.91 an analysis concerning the determination of no significant hazards considerations is also presented:

1.0 Section to be Changed

Sections 2.3 and 4.3.

2.0 Extent of Change

Reduces the setpoint of the ninth (highest) safety valve from 1230 to 1221 psig.

3.0 Changes Requested

The requested changes are shown on the attached Technical Specification pages 2.3-2 and 4.3-1.

4.0 Discussion

The purpose of this Technical Specification Change Request is to propose the reduction of the setpoint of the ninth (highest) safety valve from 1230 psig to 1221 psig. Oyster Creek has nine safety valves with setpoints as follows:

<u>Number of Valves</u>	<u>Technical Specification Setpoints (psig)</u>
4	1212 ± 12
4	1221 ± 12
1	1230 ± 12

The modification would change the setpoint to:

<u>Number of Valves</u>	<u>Technical Specification Setpoints (psig)</u>
4	1212 ± 12
5	1221 ± 12

Lowering the setpoint of the ninth safety valve would result in a reduced peak system pressure for transients. In addition, reducing the setpoint of the ninth safety valve would eliminate ordering and warehousing safety valves with three different setpoints. This would result in a significant cost and time savings in maintenance and surveillance testing.

License Basis Analysis

The safety valves are provided to satisfy the overpressure protection requirement of the ASME code. This system has no function during normal operation, and it is anticipated that there is a low probability of safety valve actuation since overpressure is relieved by the isolation condensers, the turbine bypass valves and the electromatic relief valves. A plant performance evaluation has been performed to demonstrate that there is an acceptably low probability of a safety valve opening as a result of an anticipated transient.

With the reduced setpoint of the highest safety valve, the margin of safety previously defined in the SAR would not be reduced because lowering the safety valve setpoint will result in lower peak pressures during abnormal transients/postulated accidents. The margin of safety defined in the SAR is contained in Chapter 15, Accident Analysis. These analyses demonstrate the ability of the plant to mitigate the consequences of postulated accidents and transients without undue hazard to the health and safety of the public. The safety result for transients/postulated accidents which would be affected by the reduction in safety valve setpoint is:

Reactor coolant system stresses will not exceed that allowed for accidents by applicable ASME and ANSI codes. This means limiting peak pressure in the reactor vessel to 110% of design pressure and to 115% of design pressure for the recirculation piping. The RPV design pressure is 1250 psig which requires the limit to be 1375 psig (1390 psia). The recirculation piping design pressure is 1200 psig which results in a limit of 1380 psig (1395 psia).

The most limiting overpressure event analyzed in the FSAR is the MSIV closure with scram on high neutron flux and failure of EMRVs, turbine bypass valves, isolation condensers and recirculation pump trip (RPT). This transient was analyzed with safety valve setpoints as follows:

<u>No. of Valves</u>	<u>Tech Spec Setpoints (psig)</u>	<u>Analysis Setpoints (psia)</u>
4	1212 ± 12	1240
4	1221 ± 12	1249
1	1230 ± 12	1257

A re-analysis of this transient for Cycle 13 with the single safety valve set at 1249 instead of 1257 psia resulted in a peak pressure at the bottom of the RV of 1383 psia which is below the code limit and lower than the peak pressure using a safety valve setpoint of 1257 psia (1384 psia). The peak pressure in the recirculation piping was 1391.5 psia which is also below the code limit.

Thus, with the proposed setpoint change of reducing the highest safety valve setpoint from 1230 psig to 1221 psig, the margin of safety in the SAR is not reduced. For the purposes of this evaluation, margin of safety is defined as the margin between the safety limit and fission product barrier failure. Because the event does not exceed the event limit (1375 psig), the margin of safety is not reduced.

Nuclear safety or safe plant operations will not be adversely affected. As mentioned previously, it is anticipated that the safety valves are unlikely to be actuated for normal (non-ATWS) anticipated events since overpressure is relieved by the isolation condensers, the turbine bypass valves and the electromatic relief valves. There has been no transient at Oyster Creek that has resulted in the opening of a safety valve.

Eliminating the third setpoint would minimize the potential for an incorrect setpoint of the ninth valve.

#### 5.0 Determination

The proposed Technical Specification Change Request does not involve a significant hazards consideration for the reasons as stated below:

1. Involve a significant increase in the probability or consequence of an accident previously evaluated:

The change in setpoint of the ninth safety valve will not increase the probability of occurrence or the consequences of an accident previously evaluated in the SAR because there is no change to the number or function of the nine safety valves. The only event initiator that involves a safety valve is a spurious valve opening which is not affected by the change in setpoint.

The activity will not increase the probability of occurrence or consequence of a malfunction of equipment important to safety previously evaluated in the SAR based on a reliability analysis of RPT, EMRVs and safety valves which shows that the likelihood of reactor vessel overpressure due to an ATWS remains very small.

2. Create the possibility of a new or different kind of accident from any accident previously evaluated.

The proposed activity does not create a possibility for an accident of malfunction of a different type than any previously identified in the SAR since existing safety valves remain unchanged, and no systems are affected by this modification. Analyses demonstrate that all of the appropriate event acceptance limits have been satisfied for the proposed new setpoint.

3. Involve a significant reduction in the margin of safety.

The margin of safety as presently defined in the basis for the Technical Specifications will not decrease as a result of this proposed change.

For the purposes of this evaluation, the margin of safety is defined as the margin between the safety limit and fission product barrier failure. Because the event does not exceed the event limit (1375 psig), the margin of safety is not reduced.

#### 6.0 Implementation

It is requested that the amendment authorizing this change become effective prior to the next refueling outage.