



SECY-00-0045
RIS 2000-17

NMP1L 3249
December 31, 2019

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Nine Mile Point Nuclear Station, Units 1 and 2
Renewed Facility Operating License Nos. DPR-63 and NPF-69
Docket Nos. 50-220 and 50-410

Subject: 2019 Summary of Regulatory Commitment Changes

There is one regulatory commitment change requiring NRC notification in accordance with the guidance contained in NEI 99-04, "Guidelines for Managing NRC Commitment Changes," Revision 0, for the period of October 1, 2018 to September 30, 2019. NEI 99-04 was approved by the NRC for licensee use via SECY-00-0045, "Acceptance of NEI 99-04, 'Guidelines for Managing NRC Commitments,'" and licensees were informed that NEI 99-04 was an acceptable process for control of regulatory commitments by the issuance of Regulatory Issue Summary (RIS) 2000-17, "Managing Regulatory Commitments made by Power Reactor Licensees to the NRC Staff," on September 21, 2000.

The attachment to this letter contains a Regulatory Commitment Change Summary.

This letter contains no NRC commitments. Should you have any questions regarding the information in this submittal, please contact me at (315) 349-7012.

Sincerely,

A handwritten signature in black ink, appearing to be "BKS", with a long horizontal line extending to the right.

Brandon K. Shultz
Manager Site Regulatory Assurance, Nine Mile Point Nuclear Station
Exelon Generation Company, LLC

BKS/RMD

cc: NRC Regional Administrator, Region I
NRC Resident Inspector
NRC Project Manager

ADD
NRR

Attachment

Regulatory Commitment Change Summary

Document Control Desk
December 31, 2019

The following commitment change was implemented during the period from October 1, 2018, to September 30, 2019.

Commitment change no. NL-2011-000008-021

Subject:

Commitment to enhance Boraflex Monitoring Program no longer necessary.

Statement of commitment:

The Boraflex Monitoring Program for Unit 1 will be enhanced to perform periodic in-situ neutron attenuation testing and measurement of boron areal density for those Boraflex racks that remain in use during the period of extended operation. It will also be enhanced to create a new activity which provides instruction for the trending of silica levels, coupon results, and the results of in-situ testing. Enhancements will be completed prior to the period of extended operation.

Change to commitment:

Commitment terminated with approval of Amendment 234.

Justification for change:

Approved License Amendment 234 Remove Boraflex Credit REDACTED

In the background of the LAR it states: "With the elimination of reliance on Boraflex for SFP reactivity control, the Boraflex Monitoring Program and the License Renewal commitment to enhance the program will no longer be necessary and will terminate with implementation of the approved license amendment."

In Section 3.1 of the amendment it states, "As a result, continued performance of the Boraflex monitoring program and the license renewal commitment to enhance the program will no longer be necessary. It is the licensee's intent to terminate the monitoring program with implementation of the approved license amendment."