

ORIGINAL

OFFICIAL TRANSCRIPT
PROCEEDINGS BEFORE

NUCLEAR REGULATORY COMMISSION

COMMISSION MEETING

PUBLIC MEETING

DKT/CASE NO.

TITLE

DISCUSSION AND POSSIBLE VOTE ON
SEQUOYAH HYDROGEN CONTROL

PLACE

Washington, D. C.

DATE

December 15, 1982

PAGES

1 - 108

B212220550 B21215
PDR ADOCK 05000327
T FDR

AR
ALDERSON REPORTING

(202) 628-9300
440 FIRST STREET, N.W.
WASHINGTON, D.C. 20001

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
DISCUSSION AND POSSIBLE VOTE ON SEQUOYAH
HYDROGEN CONTROL
PUBLIC MEETING

Nuclear Regulatory Commission
Room 1130
1717 H Street, N.W.
Washington, D.C.

Wednesday, December 15, 1982

The Commission met, pursuant to notice, at
10:05 a.m.

BEFORE:

NUNZIO PALLADINO, Chairman of the Commission
VICTOR GILINSKY, Commissioner
JOHN AHEARNE, Commissioner
THOMAS ROBERTS, Commissioner

STAFF AND PRESENTERS SEATED AT COMMISSION TABLE:

SAM CHILK
WALTER BUTLER
CARL STALL
ROGER MATTSON
HAROLD DENTON
BOB PURPLE
JOHN E. ZERBE
SHELDON L. TRUBATCH

AUDIENCE SPEAKERS:

CHARLES TINKLER
LARRY MILLS
JOHN RALSTON
DAVID BENFRO

DISCLAIMER

This is an unofficial transcript of a meeting of the United States Nuclear Regulatory Commission held on December 15, 1982 in the Commission's offices at 1717 H Street, N. W., Washington, D. C. The meeting was open to public attendance and observation. This transcript has not been reviewed, corrected, or edited, and it may contain inaccuracies.

The transcript is intended solely for general informational purposes. As provided by 10 CFR 9.103, it is not part of the formal or informal record of decision of the matters discussed. Expressions of opinion in this transcript do not necessarily reflect final determinations or beliefs. No pleading or other paper may be filed with the Commission in any proceeding as the result of or addressed to any statement or argument contained herein, except as the Commission may authorize.

P R O C E E D I N G S

1

2 CHAIRMAN PALLADINO: Good morning, ladies and
3 gentlemen.

4 We are meeting this morning with the staff to
5 discuss the permanent hydrogen mitigation system at the
6 Sequoyah facility. This system was required to be
7 installed when the Commission authorized the issuance of
8 a full power license for Unit 1 in September, 1980.

9 At that time, the Commission required an
10 interim system to be installed as reviewed and approved
11 by the staff, but reserved to itself the approval of the
12 final system.

13 The current license condition requires a
14 resolution of this issue before Sequoyah Unit 1 may
15 restart following the first refueling outage. The plant
16 is nearing completion of its first refueling and the
17 staff is here to request that the Commission confirm
18 that the system installed by the licensee provides
19 adequate hydrogen control features.

20 Before I turn the meeting over to staff, I
21 would like to note that representatives from the
22 Tennessee Valley Authority are with us today and are
23 ready to answer specific Commissioner questions about
24 their system. It would be useful if the staff would
25 introduce these representatives at the beginning of

1 their presentation.

2 One other point I would like to mention before
3 we get started is that at the conclusion of this
4 morning's meeting, I will be asking the Commissioners to
5 vote on whether the system installed by TVA satisfies
6 the conditions in the Sequoyah Unit 1 license.

7 Commissioner Gilinsky does plan to join us
8 somewhere around 10:30 and expects to be here for that
9 vote. Commissioner Asselstine, I understand, is still
10 on travel status.

11 Do any other Commissioners have opening
12 comments? If not, then I will turn the meeting over to
13 Mr. Denton.

14 MR. DENTON: Thank you, Mr. Chairman.

15 We are recommending that you approve the
16 installatin and operation of Sequoyah Unit 1 with the
17 permanent hydrogen mitigation system. As you observed,
18 they have operated during the first cycle with an
19 interim hydrogen ignition system.

20 Bob Purple has about a five-minute
21 presentation to cover the background and what has gone
22 on over the past couple of years on this issue.

23 Then Roger Mattson will discuss the results of
24 the staff's safety evaluation of the permanent system
25 and include the results of our meeting with the ACRS,

1 cover the items raised in their letter of December 13,
2 and introduce other members of the staff.

3 Bob, why don't you begin?

4 MR. PURPLE: Well, in response to your first
5 request, Mr. Chairman, perhaps I can get TVA to identify
6 the key individuals they have here today. Larry Mills
7 will introduce them.

8 MR. MILLS: Larry Mills, manager Nuclear
9 Laboratory, TVA; and we have John Ralston, our chief
10 nuclear engineer with us. We have George Dillworth,
11 assistant general manager, and David Renfro, nuclear
12 engineer from our Engineering Design organization.

13 MR. PURPLE: Thank you.

14 I will try to keep this to five or less
15 minutes because much of it is background you have
16 already heard. The staff is recommending approval of
17 the system that IVA proposed with two modifications that
18 Roger will get into with more detail in a few minutes.

19 The first viewgraph - please - will show the
20 briefing outline, Number 1. I will talk about the
21 chronology very briefly, of how we got to where we are
22 today, and from then on Roger Mattson will discuss our
23 safety review and conclusions.

24 Number 2, please. The key element here is
25 that the low power license was issued in February of '80

1 and it contained, as the chairman mentioned, a condition
2 dealing with both interim and permanent hydrogen control
3 systems. That subsequently got modified as time went
4 by, and I will show you that in the next couple of
5 viewgraphs.

6 One item not shown in the chronology in the
7 viewgraph that occurred just last week was an ACRS
8 meeting to discuss and consider the hydrogen control
9 system to which the ACRS has issued a letter just this
10 week, and we will discuss our reaction to that with you
11 in a few minutes.

12 CHAIRMAN PALLADINO: Is there a similar
13 condition for Unit 2?

14 MR. PURPLE: Yes, there is. Unit 2 would have
15 a need for a permanent hydrogen control system
16 acceptable to the Commission by the end of the first
17 refueling, which in that case would be September of '83.

18 CHAIRMAN PALLADINO: And you are not asking
19 for that today.

20 MR. PURPLE: That's correct.

21 MR. DENTON: Because we are asking for one
22 more type of test to be done and I thought it would be
23 best to await the results of that test and provide it to
24 the Commission before asking you do approve it for Unit
25 2. They would need approval by late next year for Unit

1 2.

2 MR. PURPLE: Number 3, please.

3 We do not need to dwell on the details. This
4 simply shows the original license condition that was in
5 the license when it was issued in February of '80, at
6 that time indicating that by January 31 of 1981 TVA
7 would still have the interim system in and that for
8 operation beyond January '82 the Commission had to
9 confirm that an adequate hydrogen control system had
10 been installed for permanent use.

11 During the course of the spring of '81 and in
12 meetings with the Commissioners with respect to Unit 2,
13 the decision was reached to extend the date for Unit 1
14 for meeting the permanent hydrogen control system until
15 the end of the first refueling outage of Unit 1, instead
16 of the January '82 date.

17 So, viewgraph 4(a) shows what is presently in
18 the license and the condition that had to be met prior
19 to startup following the first refueling outage, which
20 is what they are in right now. The Commission must
21 confirm, and that is why we are here.

22 The second item on there is simply a more
23 explicit statement of the type of research and test
24 activity that the staff felt was necessary.

25 That is a brief chronology.

1 COMMISSIONER AHEARNE: Can you say a few words
2 about II.A.4?

3 MR. PURPLE: Sure.

4 COMMISSIONER AHEARNE: What was your
5 interpretation of what was meant by that license
6 condition? You are asking for a new calculation.

7 MR. PURPLE: I guess I would like to ask Roger
8 to answer that.

9 MR. MATTSON: This was the question of doing
10 more refined local temperature calculations. You
11 recall, we had done some, let me call them "scoping
12 calculations" for a piece of equipment if I recall
13 correctly, about a year ago.

14 The idea was do do better CLASIX calculations
15 - which we are going to describe in a bit here - of the
16 general containment environment, and then having those
17 refined calculations to then even refine the local
18 temperature calculations.

19 This was a license condition upon them to
20 continue their work in that area.

21 COMMISSIONER AHEARNE: Well, this is now
22 looking for differences between the containment
23 temperature and the equipment temperature.

24 MR. MATTSON: Yes.

25 COMMISSIONER AHEARNE: Now, I did not go back

1 and look at what we had meant at the time, but are you
2 saying that what you meant by this was the containment
3 temperature was the cruder bulk calculation and the
4 equipment temperatures now, as a result of the detailed
5 improved code calculation?

6 MR. MATTSON: No, I am sorry I confused that
7 for you.

8 COMMISSIONER AHEARNE: I am not sure what you
9 mean by containment temperature.

10 MR. MATTSON: The containment temperature is
11 the bulk temperature calculated by the CLASIX code. Now
12 early versions of the code were used a year ago.
13 Refinements were made in the course of the last year and
14 better temperature calculations of the bulk containment
15 temperature were made.

16 COMMISSIONER AHEARNE: And then you are going
17 to go from that CLASIX calculation down to detailed
18 calculations.

19 MR. MATTSON: That is right. We had done some
20 early calculations of that sort a year or so ago, and we
21 had done more calculations and more refined calculations
22 of that trans-position or transfer of bulk to local
23 conditions.

24 CHAIRMAN PALLADINO: When you say "bulk," what
25 do you mean?.

1 MR. MATTSON: The temperature is in a
2 compartment where combustion is occurring. I do not
3 mean generally in the containment.

4 CHAIRMAN PALLADINO: In the atmosphere.

5 MR. MATTSON: Atmospheric temperature in a
6 compartment, yes.

7 MR. PURPLE: I guess there was one more slide
8 which simply is a continuation of this license
9 conditions, which would be IV.B.

10 COMMISSIONER ROBERTS: Well, what do you mean
11 in IIA-5?

12 MR. MATTSON: That is an interesting question.

13 COMMISSIONER ROBERTS: That is a catch-all for
14 anything.

15 MR. MATTSON: Well, it really is, and we are
16 going to get into one that showed up as anomalous. In
17 the testing of the Tayco igniters there are some -- I
18 guess anomalous is in the eye of the beholder - but some
19 results that we think require further testing. There
20 has been some controversy between us and the licensee as
21 to whether that further testing is really necessary.

22 But it was really a sort of catch-all, that if
23 something untoward appeared in the further confirmatory
24 testing and in the design development of the ignition
25 systems, being a new venture, a new type of safety

1 system, that we would evaluate and resolve any anomalous
2 results that showed up.

3 MR. DENTON: I think the origin of that,
4 Commissioner, as I remember it was --

5 COMMISSIONER ROBERTS: It is not what we would
6 do, it is what the licensee would do.

7 MR. DENTON: Yes.

8 COMMISSIONER ROBERTS: It is a condition that
9 you are imposing.

10 MR. DENTON: When we proposed this condition
11 there had been occasionally some anomalous test results
12 cropping up in the early program and this was, I guess,
13 an attempt to be sure that those were fully described
14 and evaluated as they developed - if they developed.

15 MR. MATTSON: Yes.

16 CHAIRMAN PALLADINO: Well, have the anomalies
17 been resolved?

18 MR. DENTON: I think they have satisfied all
19 these test conditions with the recommendations that we
20 make on the results of their program.

21 MR. PURPLE: Roger?

22 MR. MATTSON: Well, that brings us up to a
23 slide that is headed, "Permanent hydrogen mitigation
24 system." It is really an outline of the areas that I
25 want to touch on. But let me give a little bit of an

1 introduction of how the technical questions have been
2 addressed over the last two years.

3 CHAIRMAN PALLADINO: Do we have that?

4 MR. DENTON: Yes, you have Number 5.

5 MR. MATTSON: The one right after the license
6 conditions.

7 CHAIRMAN PALLADINO: I probably have it here,
8 yes. Excuse me.

9 MR. MATTSON: You recall that in the late fall
10 of 1980 TVA became the first utility to decide on a
11 distributed system of igniters for the Sequoyah plant.
12 And it was this system of igniters that was to provide
13 for hydrogen control for accidents beyond the design
14 basis.

15 The Commission had told TVA that it wanted
16 such control for smaller-sized containments like the ice
17 condenser and the MARC III because those containments
18 might not be capable of coping with the burning of
19 hydrogen in the amounts that had occurred in the
20 accident at Three Mile Island.

21 In the two years since, the Commission set
22 this general requirement for some sort of hydrogen
23 control system, and TVA decided upon the igniters.

24 There has been a learning process. It is
25 really a two-fold learning process. On the one hand it

1 is technical, having to do with how hydrogen is
2 produced, how it behaves and distributes itself; how it
3 is ignited; how much energy is produced in its ignition
4 in air and spray environments, some complicated
5 questions where we really had to push back the state of
6 knowledge in hydrogen. We could not go to standard
7 references on hydrogen burning and find answers to these
8 questions.

9 So, there has been some research and some
10 pushing back a frontier.

11 There was a second kind of question that this
12 portended for all of us and that was, what is the
13 regulatory basis for reviewing and approving a system
14 whose purpose lies beyond the design basis?

15 We have a number of systems and equipment that
16 are within the design basis - and we speak of equipment
17 important to safety, and safety grade; and there is a
18 set of regulations and a way of thinking where people
19 know what they are talking about.

20 When you go beyond the design basis it raised
21 questions that have caused some learning and some false
22 starts, perhaps, and it is in this area, I think, that
23 there remains some controversy.

24 I think when we get to the ACRS letter and
25 talk about the three points at issue between us and the

1 ACRS, you will see that they lie not necessarily in the
2 technical question but in the area of what level of
3 assurance is required for safety equipment beyond the
4 design basis. What level of assurance that will work,
5 and what degree of protection does it afford. How many
6 accident sequences beyond the design basis are you
7 trying to treat.

8 Now, in this briefing that I am going to give
9 on this slide you will see these recurring themes. Let
10 me try to summarize how I think we have come out on
11 those two general issues before I get down into the
12 details.

13 On the technical question I think there has
14 been a very thorough engineering design by TVA and a
15 thorough review by the staff.

16 One way to get a feel for that as you read the
17 safety evaluation in Supplement No. 6 is to keep track
18 of the list of firms that have been involved and the
19 places that engineering expertise has been brought to
20 bear on the question. That gives you a flavor of how
21 wide and deep the exploration has been.

22 You will see Sandia Labs played an important
23 role in the testing that was done for the staff. You
24 see Los Alamos National Laboratory involved in the
25 analysis. Brook Haven involved in sequence analysis.

1 Lawrence Livermore, Oakridge. You see private and
2 academic institutions like McGill University, White
3 Shell Labs, Factory Mutual, Acurex, Thinwall - these are
4 the names in the traditional engineering community of
5 expertise in hydrogen.

6 So, we have tapped a number of sources and so
7 has TVA in coming to this design. So, as we told you in
8 the briefing that Walt and I gave you more generally on
9 hydrogen a few weeks ago, there has been a lot of
10 learning.

11 Some of the things that we were worried about
12 two years ago we are not worried about so much today,
13 and we have significantly advanced the state of
14 technical understanding on our part and maybe the
15 general scientific community about hydrogen combustion.

16 I will get into those technical matters a
17 little more in a minute.

18 Now, on the regulatory question, the question
19 if how much assurance for what kind of events, let me
20 recall some conversations we had when the Commission had
21 a little bit different makeup. But when we were talking
22 about what we were supposed to be trying to do with this
23 safety equipment for beyond design basis accidents.

24 We were told by the Commission to require a
25 system for controlling hydrogen from degraded core

1 accidents - not from core-melt accident. That is,
2 accidents that went beyond the design basis and there
3 was some damage to the core and some large amount of
4 hydrogen generated, but the accident was terminated. We
5 did not specify in any particular or mechanistic way how
6 it was terminated, but it was terminated short of core
7 melt.

8 So, the way we described how it was
9 terminated, we said 75 percent metal-water reaction -
10 not a hundred, not a melt-down - but somehow the core
11 cooling was restored to limit metal-water reaction in
12 the neighborhood of 75 percent.

13 We were also told - and I think we encouraged
14 this kind of thinking - that we could be realistic in the
15 analysis beyond the design basis. We need not have the
16 degree of conservatism or the gold-plating of equipment,
17 if you will, that we traditionally apply for
18 safety-grade equipment within the design basis where
19 the purpose is to provide protection for more than the
20 specific design-basis accident you are treating.

21 Beyond the design basis, we acknowledged we
22 would not have to have all of that conservatism, we
23 could be more realistic.

24 To say that a little bit more informally, I
25 believe the objective was to bite off a large portion of

1 the risk to containment that was possible from hydrogen
2 burning, but to admit, going in, that we could not
3 provide a hundred percent assurance against all
4 sequences beyond the design basis; that we were to make
5 a reasonable attempt to deal with large amounts of
6 hydrogen but to recognize that there would always be a
7 residium of risk. There would always be some
8 uncertainty, some possibility of incompleteness.

9 I think we have done a good job of hitting
10 most of the risk from hydrogen burning causing a
11 containment failure for a degraded core accident, and we
12 will get into the sequences that have been covered. But
13 it is not a system that provides total assurance. That
14 is a difficult regulatory domain for you to operate in,
15 for us to operate in, and for TVA to operate in.

16 How much is enough? Where do you stop? You
17 will see that those are the areas that ACRS' questions
18 reside in.

19 CHAIRMAN PALLADINO: Can you just give a
20 little clue, are you talking about the fact that we are
21 limiting it to 75 percent, that is one state of
22 incompleteness?

23 MR. MATISON: Yes.

24 CHAIRMAN PALLADINO: Another is that maybe
25 there is no power back-up on the diesels; is that

1 another sense

2 MR. MATISON: That is another way to say one
3 of the limits. When we turn to that ACRS question we
4 will show you that the plant specific PRA that has been
5 done for Sequoyah shows that the loss of all A.C. power
6 is first of all not a dominant contributor to risk as it
7 was in the Surry plant in the WASH-14 study, that
8 Sequoyah has a factor of ten better reliability of A.C.
9 power than Surry.

10 And given that it is not a dominant
11 contributor, and given the fact that there is a very
12 short time between the onset of hydrogen production in a
13 station blackout and a total core melt-down - people
14 estimate it to be less than an hour, on the order of
15 half an hour - that gives you a feel for how long has
16 the operator has to interdict a degraded core event
17 before it turns into a core melt event.

18 If you remember, when we put out the second
19 interim hydrogen rule we said we were interested in
20 degraded core events that move slowly, that offered
21 some reasonable opportunity for the restoration of
22 equipment or the realization of a human error and its
23 correction, whatever; a change in the operation of the
24 plant to interdict that accident before total core
25 meltdown.

1 So, we chose accidents like the S-2-D
2 sequence, the small break LOCA with loss of emergency
3 core cooling, TMI-type sequence, and reasonable
4 permutations and combinations of parameters about that
5 accident, slow moving, reasonably interdictable degraded
6 core accidents that could be stopped short of core
7 meltdown.

8 PMLB prime, the loss of wall A.C. power fails
9 at Sequoyah on two tests. One, it is not a dominant
10 sequence and two, the time between the onset of hydrogen
11 production and total core slumping or loss of core
12 geometry is a very short time, on the order of half an
13 hour.

14 We will get back to that when we come to the
15 ACRS letter. We have a slide on it we can put up and
16 examine that further, if you would like.

17 CHAIRMAN PALLADINO: Just one more question on
18 the 75 percent. If this system works with 75 percent
19 hydrogen, why does it not work with 100 percent
20 hydrogen? You are trying to burn it as it comes off.

21 MR. MATTSON: It will depend on how it comes
22 off, absolutely. And to say that 75 percent is the
23 point that you aim at, that is a rather arbitrary
24 decision, to stop at 75. If you go back, there is a lot
25 of judgment in 75 percent. Why not the 50 percent that

1 we saw at TMI?

2 CHAIRMAN PALLADINO: The simpler question is,
3 if it works at 75 - or maybe it is not a simpler
4 question but I perceive it as such.

5 MR. MATTSON: It will work at less than 75, at
6 more than 75, depending on how the hydrogen comes off;
7 depending on how it burns. We are going to show you a
8 slide that shows quite a lot of margin between the
9 calculated pressures for sequences that produce in the
10 vicinity of 75 percent metal-water reaction - and there
11 is a lot of margin between these calculated pressures
12 and the strength of the containment.

13 So, clearly, you can take beyond 75 percent.

14 COMMISSIONER AHEARNE: I thought your point,
15 Roger, was that if you went to 100 percent hydrogen, the
16 kind of damage you would then be having is not the kind
17 of damage you would be expected to be able to mitigate
18 using the igniters.

19 MR. MATTSON: Well, it is the kind of damage
20 to the core you might not be able to mitigate with the
21 other systems for safety.

22 CHAIRMAN PALLADINO: Yes, I accept that.

23 MR. MATTSON: They do not fit.

24 CHAIRMAN PALLADINO: I just was thinking in
25 particular of a hydrogen --

1 COMMISSIONER AHEARNE: The accident sequence.

2 MR. MATTSON: Yes, that is right.

3 MR. DENTON: I do not think there are any
4 short cliffs if more hydrogen than 75 percent is evolved
5 and the core stays in the vessel.

6 MR. MATTSON: No, I was speaking more from a
7 need to keep some sense of continuity with the other
8 safety systems and their performance.

9 All right, now I will go back to the slide
10 that you have up in front of you.

11 I thought you might want to hold the two
12 igniters that we are going to be talking about today.
13 The big one is the Tayco igniter that is presently
14 installed in the permanent hydrogen mitigation system at
15 Sequoyah. The little one is the so-called GM Glow plug
16 that was in the interim hydrogen mitigation system at
17 Sequoyah and is in fact still in the systems at other
18 plants like McGuire and D. C. Cook.

19 COMMISSIONER ROBERTS: This is trivia, but
20 what does this cost?

21 MR. MATTSON: It is called a Tayco igniter.

22 COMMISSIONER ROBERTS: No, what does it cost?

23 MR. MATTSON: What does it cost? I am sorry,
24 \$300 a piece. These are 120 volt igniters, 120 volt
25 A.C. There are 64 of them presently installed in

1 Sequoyah. We will tell you, we think there ought to be
2 68 for reasons we will describe.

3 There are generally two in each compartment,
4 so there is some redundancy. So, if one would fail in a
5 compartment you would have another one to ignite the
6 hydrogen in that compartment.

7 They operate at about 48 watts per square
8 inch, they, the Taycos. That is less than the Glow
9 plugs which are about 200 watts per square inch. And
10 there is a reason why that is important, we will come
11 back to it later.

12 The Glow plug operates with a surface
13 temperature of about 1800 degrees Fahrenheit, and the
14 Tayco operates with a surface temperature of about 1700
15 degrees Fahrenheit.

16 COMMISSIONER AHEARNE: Roger, I am trying to
17 understand whether I should ask my question. Are you
18 going to later get into the question of why 31 and 32
19 have to be there for a liability and why TVA went to
20 Tayco over the Glow plug? If you ace, I will just hold
21 off.

22 MR. MATTSON: This is as good a time as any to
23 talk about the more reliable design.

24 COMMISSIONER AHEARNE: All right.

25 MR. MATTSON: Let me start and say some words

1 about that.

2 COMMISSIONER AHEARNE: In looking through the
3 SER, about the only arguments I could see - it is not
4 in here that says Tayco is worse - but the conclusions I
5 would reach are either the advantage of not having to
6 run a step-down and the main event there being, you got
7 rid of the transformer which was causing environmental
8 problems.

9 MR. MATTSON: On the surface, I believe that
10 is the principal difference. There are other reasons
11 why TVA wanted to go back to the interim system and
12 polish it up a little bit. It had been put in quickly.
13 If was off of its emergency lighting system so the light
14 bulbs had been taken out the locations where the
15 igniters has been put in.

16 (Laughter.)

17 MR. MATTSON: They wanted better cabling and
18 they wanted to improve those other features. But in
19 theory at least you could have done that to the Glow
20 plug system also.

21 So, the principal difference from where we sit
22 seems to be their conviction that the Tayco igniter was
23 good for the job and that the system that they would
24 install to power the Tayco igniters was a more reliable
25 system.

1 They are here and if they have things to add
2 to that, they ought to be given the --

3 COMMISSIONER AHEARNE: Larry, why did you go
4 to the Tayco igniter over the Glow plug?

5 MR. MILLS: The primary reason for that was
6 because we wanted to get rid of the transformers in the
7 Glow plug system.

8 COMMISSIONER AHEARNE: OK.

9 MR. MATTON: The second point on this
10 viewgraph is that there was quite a lot of research on
11 hydrogen control that went on. We are able to go into
12 the details of that today if you want but recall, we did
13 get into that at some length a couple of weeks ago.

14 Let me just quickly summarize to what your
15 appetite and you can lead us if you want to go deeper.

16 The research generally occurred in three
17 quarters, NRC's principally at Sandia; the Ice Condenser
18 Owners Group which paid for work in places like White
19 Shell and Hettel; and the EPRI work for industry
20 generally. EPRI was principally concentrating on
21 equipment survivability, which we are going to turn to
22 in a few minutes.

23 They looked at how combustion occurs for
24 various steam and air mixtures; they looked at how
25 mixing occurs for steam-air hydrogen mixtures; they

1 looked at the propensity for detonation, what it would
2 take to cause rapid burning; what kinds of igniters and
3 what kinds of mixtures.

4 As I have said several times already, there
5 has been a pushing back in the state of knowledge. We
6 have learned more about these things than was available
7 in the hydrogen literature.

8 COMMISSIONER ROBERTS: Is the EPRI work
9 complete?

10 MR. MATTSON: No. You recall, EPRI has a
11 major program about to take off which is the Nevada Test
12 Site, a 52-foot diameter vessel that is going to give an
13 ability to look at these scale questions where there can
14 be concentration gradients because of flowing air or
15 because of local letting loose of hydrogen and it has to
16 spread out somewhere. They are going to look at
17 equipment survivability in that kind of an environment.

18 So, EPRI has at least that major ones. Are
19 there others that EPRI is doing?

20 MR. STALL: That's it.

21 MR. MATTSON: Well, another aspect of our
22 review concentrated on what events, what accidents, are
23 we trying to cover with this igniter.

24 CHAIRMAN PALLADINO: Did the research program
25 confirm that these plugs in the expected atmospheres

1 worked to ignite the hydrogen?

2 MR. MATTSON: Yes, with one small area.

3 COMMISSIONER AHEARNE: Are you talking about
4 the plugs or the igniters, the Tayco?

5 CHAIRMAN PALLADINO: The Tayco.

6 MR. MATTSON: The research program confirmed
7 that you can put in a distributed ignition system and
8 control hydrogen. That you can count on it burning the
9 hydrogen at low concentrations even in steam-air
10 mixtures, so as to prevent the buildup of hydrogen,
11 which is the basic purpose of all this.

12 We are going to tell you about a small piece
13 that we think more ought to be done on in a minute, but
14 this SER is many pages long, and a lot of research
15 programs generated a lot of data that was not available
16 before, which confirmed that the igniters will work.

17 Now, there is this small piece we want to talk
18 about which we would do some additional testing because
19 of a narrow question.

20 CHAIRMAN PALLADINO: Is this on the spray
21 effect on the surface?

22 MR. MATTSON: Let me turn to that.

23 CHAIRMAN PALLADINO: Well, is it on that?

24 MR. MATTSON: Yes.

25 CHAIRMAN PALLADINO: Because I was going to

1 ask a question on that.

2 MR. MATTSON: That is on the next slide.

3 COMMISSIONER AHEARNE: Roger, I am not an
4 aficionado of SERs. The research program may have
5 generated a lot of data but not too much of it has made
6 it into the SER.

7 MR. MATTSON: When I said research is now, I
8 meant the research by Ice Condenser Owners Group, EPRI
9 and our research program. I think the things that
10 Sandia did for us and Los Alamos did for us that we used
11 are in the SER.

12 COMMISSIONER AHEARNE: I am not saying that
13 there are not some areas. I am just commenting that the
14 research program may have generated a lot of data and a
15 bunch of conclusionary statements rather than --

16 MR. MATTSON: You are saying that the data
17 themselves are not there.

18 COMMISSIONER AHEARNE: Yes.

19 MR. MATTSON: But there are references to
20 quite a number of reports that have that data in there.

21 Well, besides the investigation of these
22 physical parameters and what ought to be the inputs to
23 the codes and what ought to be the estimates of how the
24 combustion occurs. There has also been a lot of work on
25 what are the degraded core accidents and how do they

1 generate hydrogen, the accidents that we are trying to
2 protect against.

3 I said before that we concentrated on the
4 S-2-D sequence and we gave TVA and other licensees the
5 option of broadening to other sequences by one of two
6 other mechanisms. They could either take the S-2-D
7 sequence and do parameter variations, when pumps came
8 on; when pumps were turned off and that sort of thing,
9 or they could look at additional sequences. They can
10 look at not just small breaks and loss of ACCS, they
11 could look at intermediate breaks and loss of ACCS.

12 They could look at slow-moving transients
13 followed by loss of all feedwater, followed by loss of
14 ACCS.

15 TVA, in actuality, took both approaches. They
16 started with the S-2-D sequence and did parameter
17 variations about it, principally parameter variations on
18 the rate of hydrogen release into the containment. And
19 then they showed through examination of other sequences
20 that those parameter variations covered quite a range of
21 accidents.

22 If you look in thue plant specific
23 probabilistic risk assessment for Sequoyah, the RSSMAP
24 study, you will see some of the sequences that they used.

25 Now, the loss of all A.C. power was not one

1 that they included, and the reason they did not include
2 it - and it is a reason we agree with - is that it is
3 not the dominant contributor at this station.

4 In the containment hydrogen analysis area - we
5 already mentioned this briefly in the introductory slide
6 - there was quite a lot of change since last we told you
7 about TVA's state of knowledge on the ignition system,
8 the CLASIX code is the code by which you calculate the
9 pressure and temperature in the compartments of the ice
10 condenser when hydrogen burns in those compartments.

11 TVA did a lot of work refining the CLASIX
12 modeling and checking it against other codes by other
13 people in the business to see that their code did not
14 give anomalous results relative to these others.

15 We, too, reviewed the CLASIX code and then
16 took our containment model at Los Alamos, the compare
17 code, had it modified so it could handle hydrogen
18 combustion phenomena and did comparisons of the CLASIX
19 output with the compare output. The comparisons are
20 quite good.

21 So, we are able to say that we believe the
22 CLASIX code does a reasonable job, an acceptable job, of
23 estimating the containment pressure and temperature
24 within sub-compartments.

25 That, again, is the starting point for which

1 local temperature calculations are made to check whether
2 the critical equipment survives - essential equipment, I
3 guess we call it - and that is the pressure calculation
4 that you use to compare with the strength of the
5 containment to make sure the containment survives.

6 So, it is very important to have that
7 assurance on the containment hydrogen analysis model.

8 Another area - and here it is probably worth
9 putting up one of these backup slides. You have in
10 front of you a set of --

11 COMMISSIONER AHEARNE: A little over a year
12 ago, Roger, Sandia had got a European code, I thought it
13 was a German code. Did anything ever come from their
14 looking at that code?

15 MR. STALL: That is one of three codes that
16 are under consideration for further work. They are
17 continuing to use that code. It has its pluses and
18 minuses with respect to cost of running and accuracy. We
19 are still pursuing that through our Office of Research.

20 COMMISSIONER AHEARNE: But it is not something
21 that they or you went along with to say you would count
22 on its results or rely on its results?

23 MR. STALL: Well, I think we feel we would
24 need further comparisons of that with experimental data
25 to rely on it.

1 COMMISSIONER AHEARNE: Thank you.

2 MR. MATISON: The next area where there has
3 been some progress was in understanding the structural
4 capacity of the ice condenser containment.

5 In that set of backup slides, if you will turn
6 to B-4 - this very graphically shows you the range and
7 estimates. The three bars on the left-hand side are the
8 ultimate capability of the containment estimated by our
9 contractor at Ames Laboratory; TVA's estimate of the
10 ultimate capability, and an R&D Associates estimate.

11 In the first bar on the left you will notice
12 36 psig is in there by a dash line. That is a three
13 sigma margin on the 60 psig, ultimate capability that
14 our contractor estimated.

15 One advantage of our estimate is that we were
16 able to kind of normalize the input. Some of the
17 reasons for variation among these other sources of the
18 calculation is that they did not all start with the same
19 input, there was some change in understanding the
20 material properties.

21 It is that 36 psig, the three sigma lower
22 bound of the ultimate strength that we have used in
23 testing whether or not the containment survives for the
24 beyond design basis accidents that we have said are
25 important for the igniters to work. That is quite a

1 conservative --

2 COMMISSIONER AHEARNE: How does that statement
3 track with the one earlier when you started, Roger, you
4 mentioned -- talking about the criteria to use for
5 something beyond design basis. You said you would be
6 more realistic to use your regulatory conservatism.

7 MR. MATTSON: That is a good point.

8 In containment failure you get into a lot of
9 debates over, "What do you mean when you say containment
10 failure, how does it fail? Do you mean a pinhole; do
11 you mean a blow-out of a penetration; do you mean the
12 failure penetration by heat in addition to the failure
13 by pressure? What do you mean?"

14 As you well know, those discussions can be
15 endless. They are not ended yet and we will continue to
16 talk about them as research goes on. You recall, the
17 research program has some modeling of both steel and
18 concrete containments to do some over-pressure tests and
19 look at some of these failure modes and try to shed some
20 light on it.

21 So, rather than have that debate on a
22 licensing case, a very conservative approach was taken.

23 (Laughter.)

24 MR. MATTSON: Because we knew from the
25 calculations --

1 CHAIRMAN PALLADINO: Realistic.

2 MR. MATTSON: Sorry. This is not a
3 requirement. If you can show that with your realistic
4 calculations you are well below a very conservatively
5 set limit, then the debate is over and you do not have
6 to get into that area of discussion. That is the trick
7 that has been used here. We have not tried to conceal
8 it from you.

9 COMMISSIONER AHEARNE: I know.

10 MR. MATTSON: It is not the preferred way of
11 operating in this domain, you are absolutely right.

12 COMMISSIONER AHEARNE: It is just, I felt
13 uneasy when I read it primarily because it has the
14 character of, "We will be this conservative because we
15 know we can still get in underneath that limit."

16 MR. MATTSON: That is why we did it, and that
17 is why we said it that way to make sure people did not
18 try to apply it in the future saying, "Gee, you have a
19 three-sigma margin on that first case, you had better
20 put three sigma on all of this beyond design basis
21 stuff." That is not the intent.

22 Hopefully, we have made that clear in the
23 SER. If we have not made it clear, we will go back and
24 make it clearer.

25 COMMISSIONER AHEARNE: The logic does not hang

1 together in that it almost sounds like -- it is either
2 one of two things. It is either the three sigma is the
3 right thing to do or else, we will put on whatever limit
4 that is necessary to stay above what the calculation
5 says is the best estimate. I do not think either is
6 good.

7 CHAIRMAN PALLADINO: There are differences in
8 knowledge that develop.

9 COMMISSIONER AHEARNE: Yes.

10 MR. DENTON: I do not really think it is an
11 "either-or" situation. I think you have to look at
12 whether we should spend the regulatory staff time and
13 effort to pin it down in this case. If you are clearly
14 underneath the three sigma, then we do not have to worry
15 with it. If it got higher, then we call in more
16 consultants and we give them more accurate estimates.
17 So, it is a screening-kind of criteria.

18 MR. MATTSON: The second implication you have
19 is clearly right. The design pressure is 12 psi; the
20 hydrogen burn estimate, the best estimate is 11.

21 COMMISSIONER AHEARNE: That's right.

22 MR. MATTSON: The licensing is 19.

23 COMMISSIONER AHEARNE: The base case is 19.

24 MR. MATTSON: But Service Level C is 30.

25 COMMISSIONER AHEARNE: Yes.

1 MR. MATTSON: And Service Level A is 12.

2 COMMISSIONER AHEARNE: Right.

3 MR. MATTSON: And we are way down there below
4 36.

5 COMMISSIONER AHEARNE: Yes, but as you know,
6 the interim rule talks about Service Level C.

7 MR. MATTSON: Yes.

8 COMMISSIONER AHEARNE: Which is not that much
9 different than 36.

10 MR. DENTON: What do you recommend we use,
11 Commissioner?

12 MR. MATTSON: That is an interesting point.

13 COMMISSIONER AHEARNE: I am not recommending.
14 I read the SER, I am just responding that the only
15 inconsistency that I either saw there or heard today was
16 in this case we are going to be more realistic. We are
17 not going to apply the normal regulatory conservatisms.

18 MR. DENTON: Roger's statement is still valid
19 later on in the discussion.

20 MR. MATTSON: I think I understand something
21 different from what you are saying. You are saying, you
22 do not quarrel with being more realistic, the 36 being
23 three sigma is a lot of conservatism.

24 COMMISSIONER AHEARNE: Yes.

25 MR. MATTSON: And yet, it is still above

1 Service Level C by six pounds.

2 COMMISSIONER AHEARNE: That is fine. I would
3 have been a lot more comfortable had you said, "Our
4 current best estimate is" - and whether you took 45 or
5 60, that is your best estimate. And look, this is over
6 three sigma beyond. Just as a comment.

7 MR. MATTSON: I think the comment would say to
8 me that maybe Service Level C is too conservative for
9 the rule.

10 COMMISSIONER AHEARNE: Well, as you recall,
11 when we argued about Service Level C it was not over
12 objections to conservatism.

13 MR. MATTSON: Yes. This is an interesting
14 piece of information compared to that, though.

15 CHAIRMAN PALLADINO: Roger, is this based on
16 the seal breaking through, or from your penetrations, or
17 was this on the structural --

18 MR. MATTSON: The judgment that has been made
19 is that the seals won't fail first, penetrations won't
20 fail first. The failure occurs. Penetrations will not
21 fail first.

22 CHAIRMAN PALLADINO: I would have expected
23 some of the seals to go first.

24 MR. STALL: The point here is that these
25 penetrations are designed for containments that are set

1 for about 60 pounds gauge. Ther is no difference
2 between these penetrations and those that are used in
3 the large iries,, and the kinds of pressures --

4 MR. MATTSON: That is a design failure for
5 those penetrations. The penetrations might go first in
6 a large dry where the ultimate strength is 140 pounds.
7 There is still quite a lot of discussion, as I was
8 saying.

9 CHAIRMAN PALLADINO: So, you are saying these
10 are over-designed for this particular application.

11 MR. MATTSON: And that is why we are
12 comfortable with the judgment that the penetrations
13 don't fail first for this design.

14 CHAIRMAN PALLADINO: I still would have
15 thought it was penetrations, but I will accept your
16 judgment.

17 COMMISSIONER AHEARNE: Since we are talking
18 about this kind of stuff, what is the Van Mises criteria?

19 CHAIRMAN PALLADINO: What is what?

20 COMMISSIONER AHEARNE: The Van Mises criteria.

21 MR. MATTSON: It has something to do with
22 strength of materials.

23 (Laughter.)

24 MR. MATTSON: We do not have the Structural
25 Engineering Branch with us.

1 COMMISSIONER AHEARNE: I was just asking you.

2 MR. MATTSON: It is in the SER, I saw it
3 myself. It has to do with the strength of materials and
4 it is off --

5 COMMISSIONER AHEARNE: It almost sounds that
6 was the way you were normalizing your --

7 MR. MATTSON: Well, it is a standard strength
8 of materials thing, but TVA, can you help us? No, they
9 do not have their structural person either.

10 If you go to your strength of materials
11 elementary text, which we ought to be able to do here
12 but we can't -- it is in there, I remember it.

13 COMMISSIONER AHEARNE: On page 22-23 when you
14 normalize your ultimate capacity which looks to be the
15 chart that you are showing -- no, it is not.

16 MR. MATTSON: What is your problem?

17 COMMISSIONER AHEARNE: Well, I am looking on
18 page 22-23 of the SER, and I am looking at the
19 normalized ultimate capacity, all right?

20 MR. MATTSON: Yes.

21 COMMISSIONER AHEARNE: And this is where you
22 say you have normalized it using actual mean material
23 properties and Von Mises yield criterion.

24 MR. MATTSON: Yes.

25 COMMISSIONER AHEARNE: That is why I asked.

1 You list here TVA as 40, and just a minor point, here
2 you have 45 on your chart; then staff remain 60 and R&D
3 40. Just out of curiosity, which is correct?

4 MR. MATTSON: Yes, there is a five-pound
5 difference between the TVA value here and the TVA value
6 on the chart. I cannot explain it. Charlie, do you
7 know, is it a mistake on one or the other? The other
8 seem to compare well, but this one does not.

9 Well, it does not seem germane, I mean crucial
10 to the argument. We will decide which one is right.

11 COMMISSIONER AHEARNE: I was just trying to
12 understand.

13 MR. MATTSON: Pardon me?

14 MR. BUTLER: TVA says it is 45.

15 MR. MATTSON: TVA says it should be 45, so the
16 SER has got a typo in it.

17 The last point on that slide 5 that we had up
18 before from this package that came down originally was
19 the question of essential equipment survivability.

20 The approach that was taken here was to
21 identify the essential equipment and then to look at the
22 essential equipment and decide what were the most
23 sensitive components from a temperate point of view, and
24 then to calculate the local temperatures from the CLASIX
25 compartment scale temperature; and then to compare the

1 temperatures that were calculated locally for the
2 equipment with the temperatures for which that equipment
3 had been qualified under the normal EQ program.

4 As we expect it would be the case because
5 these flame temperatures are so transient in nature that
6 when you account for local heat transfer phenomenon the
7 temperature that is actually reached by the equipment is
8 significantly lower than the normal EQ temperature where
9 there is a soaking and an equilibrium condition obtains.
10 There is about a hundred degrees Fahrenheit difference.

11 The survivability question has very much
12 diminished since we were here a year ago, talking about
13 would this equipment really survive. It turned out to
14 be a rather small part of the question.

15 COMMISSIONER AHEARNE: And they also got rid
16 of the transformers.

17 MR. MATTSON: And they got rid of the
18 transformers.

19 COMMISSIONER GILINSKY: Let's see, what are
20 the key items?

21 MR. MATTSON: There is a list in the SER which
22 is -- somebody help me quickly with the page number.

23 COMMISSIONER GILINSKY: The recirculation must
24 be pretty --

25 MR. MATTSON: Pardon me?

1 COMMISSIONER GILINSKY: You have to make sure
2 your fans are operating.

3 MR. MATTSON: The fans. Yes, the list in the
4 SER has been criticized because it is incomplete. It
5 was attempting to speak to some examples. It is at page
6 38.

7 COMMISSIONER AHEARNE: Well, 38 is your most
8 sensitive equipment. You say, the most sensitive to
9 temperature change equipment. That, I thought, is your
10 list on 39.

11 MR. MATTSON: I did not understand your
12 question.

13 COMMISSIONER AHEARNE: On 39, I thought, your
14 list, you said that is the set of the ones that are
15 really most sensitive to temperature change. That is
16 true?

17 MR. MATTSON: That's right.

18 COMMISSIONER AHEARNE: And 38 was the larger
19 set of the ones that IVA had selected.

20 MR. MATTSON: There is a qualitative statement
21 that there is a larger set. It is in the SAR. The
22 smaller set, the stuff that is more sensitive and hence
23 was looked at in detail is in Table 22-3. Now, those
24 are statements of facts. Are there questions?

25 COMMISSIONER GILINSKY: Well, there are two

1 kinds of equipment, I would assume. One is, you would
2 like to make sure that the equipment makes this work is
3 used to operate.

4 MR. MATTSON: That's right.

5 COMMISSIONER GILINSKY: And there the fans are
6 important, I assume.

7 MR. MATTSON: Yes.

8 COMMISSIONER GILINSKY: Beyond that, I guess
9 you like other equipment.

10 MR. MATTSON: Let me see if I know what you --

11 COMMISSIONER GILINSKY: Survivable.

12 MR. MATTSON: The hot standby condition of
13 safe shutdown, that equipment, the valves and
14 instruments, things inside containment that could be
15 exposed to the flame that have to provide that safe
16 shutdown function were included in the list of the
17 essential equipment by TVA.

18 COMMISSIONER GILINSKY: And what assurance is
19 there that will in fact survive the burn?

20 MR. MATTSON: They looked at -- the equipment
21 is surveyed to see what is the most sensitive ones. And
22 the most sensitive ones have specific detailed checks to
23 make sure that the local temperature is below the EQ
24 temperature.

25 Given that that was fairly easy to show on all

1 of that equipment, then there is a judgment made that
2 all of the equipment will survive because that equipment
3 all has environmental qualifications for its normal
4 design-basis purposes. Have I stated that correctly?

5 So, there is assurance that it is qualified to
6 survive the burn environment. It is not done. It is an
7 economy to avoid doing these detailed calculations for
8 each an every piece of equipment. You look at the ones
9 that are most sensitive and which there is any question
10 in your mind about whether they would survive or not,
11 and then you do the calculation and you show on the
12 order of a hundred degrees margin - even for the most
13 sensitive pieces of equipment.

14 That supports the judgment that it will all
15 survive for the hot standby.

16 COMMISSIONER GILINSKY: When you say a hundred
17 degrees margin, is that a lot or a little --

18 MR. MATTSON: That is a lot.

19 COMMISSIONER GILINSKY: -- given the
20 uncertainties?

21 MR. MATTSON: No, that is a lot of margin.

22 COMMISSIONER GILINSKY: What are the
23 calculations, roughly speaking?

24 MR. MATTSON: Tens of degrees, not on the
25 order of a hundred degrees.

1 CHAIRMAN PALLADINO: Must the fans be running
2 to assure survivability?

3 MR. MATTSON: The performance of the ignition
4 system is based upon the fans running. We have not
5 designed and reviewed an ignition system without fans
6 running. That enters arguments about where you locate
7 the igniters and when they burn, and flame
8 acceleration. All those questions are tied up in whether
9 the thing is mixed or not.

10 CHAIRMAN PALLADINO: I gather there were some
11 tests done at Hettel that were inconclusive.

12 MR. STALL: There were mixing tests done at
13 Hettel and the conclusions there were that there was
14 very good mixing in that the concentration --

15 CHAIRMAN PALLADINO: This is without
16 circulation?

17 MR. STALL: This is with the fans.

18 CHAIRMAN PALLADINO: But there were some tests
19 with no forced recirculation and they said they were not
20 conclusive. I was just wondering why the tests were
21 done. Or was that to see whether or not you had to have
22 the fans?

23 MR. STALL: Well, you know, with respect to
24 the fans in the real containment, analyses were done
25 with the fans turned off just to see what the

1 consequences are. And it turns out that the pressures,
2 the burn pressures for the case with fans turned off is
3 substantially higher than with the fans on.

4 And our design basis, therefore, is that the
5 fans will stay on with these igniter systems.

6 COMMISSIONER GILINSKY: Now, how vulnerable
7 are the fans themselves to a burn?

8 MR. STALL: That matter has been reviewed by
9 our EQ - Equipment Qualification - people and they are
10 satisfied that those fans will survive the transients,
11 the pressures and temperatures associated with these
12 burns.

13 COMMISSIONER GILINSKY: What are the
14 especially vulnerable parts of them, what are the
15 margins that you see? It looks as if the fans are
16 critical not only for the functioning of the hydrogen
17 control system but for protecting the rest of the
18 equipment.

19 MR. STALL: The things we looked at were the
20 Delta P across the fans. Maybe at this point we can ask
21 TVA to help us.

22 COMMISSIONER GILINSKY: Sure.

23 MR. DENTON: Let me volunteer an experience
24 that does not apply to this plant, but the motors have
25 to be looked at, and it tends to be access of moisture

1 in the containment to the bearings, or to the
2 insulation. Many motor failures ultimately are traced
3 back to moisture.

4 The motors themselves are rather big and bulky
5 and therefore I do not think their temperature would
6 heat up very much due to a flash and burn.

7 COMMISSIONER GILINSKY: But it does look as
8 though everything depends on these fans operating.
9 Please?

10 MR. RENFRO: David Renfro from TVA.

11 We looked at the effects of pressure and
12 temperature on the fans. The fans weigh about 1300
13 pounds. We evaluated the temperature rise due to their
14 bulk and it was not too significant. It was less than
15 the qualification temperatures for the fans.

16 We looked at the pressure effect on the fan
17 blades, took a very conservative approach and posed a
18 static pressure of about 50 pounds on the fan blades,
19 and they were shown to survive by the manufacturer.

20 So, we have looked at both pressure and
21 temperature.

22 COMMISSIONER GILINSKY: And that applies to
23 all electrical equipment on which the fans depend as
24 well, switches and relays, and whatever else there may
25 be? The answer, I assume, is yes?

1 (Laughter.)

2 MR. MATTSON: If you look at the list of most
3 sensitive equipment, that is the thing that tends to
4 show up because it is small and does not have the bulk
5 to heat up. It can get to a higher temperature faster.

6 COMMISSIONER AHEARNE: Going from, as I
7 understood, your SER, you have checked TVA, but TVA
8 essentially went through their systems, came up with a
9 list which they called essential equipment; is that
10 correct?

11 MR. MATTSON: Yes.

12 COMMISSIONER AHEARNE: And then you agreed
13 with that.

14 MR. MATTSON: Yes, that is how we do it on EQ
15 also.

16 COMMISSIONER AHEARNE: And then, rather than
17 going through the detailed calculations which are the
18 items on this list of essential equipment, they chose
19 those now, by analysis of which ones they felt would be
20 most sensitive.

21 MR. MATTSON: It is my understanding they did
22 it by inspection.

23 MR. STALL: Yes, just by judgment. And then
24 the staff also took a few of these things, such as the
25 Barton transmitter, and did audit computations of the

1 heat-up.

2 MR. MATTSO: It is a big, bulky piece of
3 equipment that has all of its internal shielded from the
4 flame, and it is fairly sound ground to say the
5 temperature transient is not going to reach the complex
6 interior and heat it up, and cause it to fail.

7 If it is an exposed wire or exposed
8 transmitter, or an exposed thermo-couple or valve
9 operator, then the judgment is a little harder, and that
10 is the kind of thing you concentrate on, the sensitive
11 equipment.

12 COMMISSIONER AHEARNE: Did you do any checks
13 on other -- for example, the flanges, the valves which
14 do not show up on that list of most sensitive, did you
15 do any audit check on that to just see whether you
16 agreed that they are not classed most sensitive?

17 MR. STALL: The answer is no. The one I am
18 aware of is the Barton transmitter.

19 COMMISSIONER AHEARNE: Well, that one they
20 already put in their most sensitive. What I was asking
21 is, they had a list of this list of equipment and you
22 said, yes --

23 MR. MATTSO: We had each of the systems
24 branches way back in the beginning of this review
25 collaborate in what constitutes the essential equipment

1 for safe shutdown.

2 COMMISSIONER AHEARNE: Yes. That is not the
3 issue I am asking about. The issue I am asking about,
4 they then went, according to the SER, they went from
5 that list of essential equipment to a set of five which
6 turned out to be only four because the Barton
7 transmitter is no longer there.

8 MR. MATTSON: Did we look at the difference
9 between the two lists?

10 COMMISSIONER AHEARNE: Yes.

11 MR. MATTSON: We had to, they are both before
12 us.

13 COMMISSIONER AHEARNE: Yes.

14 MR. MATTSON: Did we add anything?

15 COMMISSIONER AHEARNE: No.

16 MR. MATTSON: I think he said no.

17 COMMISSIONER AHEARNE: No, that is not the
18 question. The question is, did you then audit any of
19 the things, looked at any of the ones that they did not
20 put on the most sensitive and say, yes, you agreed?

21 Another way of asking the question, it appears
22 to me that what ended up being analyzed in detail was
23 TVA's list of most sensitive and we agree with it.

24 MR. MATTSON: Our best judgment is they
25 probably did not, but they are not here today, that is

1 the Environmental Qualifications Branch. So, we cannot
2 say for certain.

3 COMMISSIONER GILINSKY: Are you done?

4 COMMISSIONER AHEARNE: Yes.

5 COMMISSIONER GILINSKY: Let me just pursue
6 this point of the fans. I am pleased to have gotten an
7 answer from TVA. But I am a little concerned that you
8 did not seem to have an independent view of it.

9 Have we checked this carefully?

10 MR. DENTON: We checked fans earlier. You
11 know, the EQ looks at a lot of stuff, not just here. I
12 can remember calculations on fan motors a year ago, and
13 we had retained Los Alamos to help us check.

14 So, we have a lot of work on the effect of
15 flame fronts on equipment.

16 MR. MATTSON: The fans are all on the normal
17 EQ list. A review is done of the normal EQ list.

18 COMMISSIONER GILINSKY: Well, but I thought up
19 to now we had not been reviewing against burnings.

20 MR. DENTON: No, but we had begun to look
21 against burns when this review first kicked off. I
22 remember seeing calculations done just for fan motors
23 against hydrogen burn.

24 MR. MATTSON: That is one of the things I
25 remember Vollmer and Rubinstein specifically looking at.

1 MR. DENTON: And we had it done by a
2 laboratory like Los Alamos to give us an independent
3 check of the adequacy of some of those calculations.
4 So, I do not know on this particular list --

5 COMMISSIONER GILINSKY: I guess these are
6 rather large fans.

7 MR. MATTSON: They are.

8 COMMISSIONER GILINSKY: And it sounds like
9 this has not been touched experimentally. Is that
10 impractical, do you think, considering the number of
11 plants we are going to be involved in?

12 MR. STALL: These are very large fans and they
13 are very heavy fans. I think it is impractical to fit
14 them through the manholes. The biggest test facility is
15 this 50-foot diameter one at NCS and I believe their
16 manholes are about 18 inches across. I believe these
17 motors are larger than that.

18 COMMISSIONER AHEARNE: It is almost like
19 shipping bombs.

20 MR. MATTSON: Well, there might be equipment
21 that is somehow close to what you are worried about.
22 John Larkin is in the audience. Do we know of any
23 large-scale equipment like that, that is going in the
24 EPRI test?

25 MR. LARKIN: No.

1 MR. MATTSON: No, sorry.

2 MR. STALL: But you see, the fan here is
3 sensitive. The concern here is the pressure of the
4 Delta P rather than the temperature. We feel rather
5 confident that because of the bulkiness of it that the
6 temperature response would not be severe.

7 The question at hand is whether the Delta P
8 that develops across the fans might cause them to warp
9 or change configuration.

10 COMMISSIONER GILINSKY: Are you going to say
11 anything about power supply, was there another point on
12 that?

13 MR. STALL: Mr. Tinkler will augment the
14 response on the fans.

15 COMMISSIONER GILINSKY: They do seem to be a
16 pretty critical component.

17 MR. STALL: Yes.

18 MR. TINKLER: I would just like to make a few
19 remarks about the concern over the viability of fans.
20 The staff has assured itself, and did as early as the
21 interim evaluation, that the air return fans would
22 function in this environment.

23 But I would like to point out that the
24 earliest concern over survivability of fans was
25 heightened by preliminary calculations performed by TVA,

1 I believe, that demonstrated that without the fans
2 operating containment pressures could reach very high
3 levels. I believe they were on the order of 90 psia.

4 It is our opinion that one should not
5 attribute too much significance to those particular
6 early preliminary calculations. Those calculations were
7 performed with earlier versions of the code which did
8 not credit operation of various igniters at strategic
9 locations such as the upper plenum.

10 Those calculations, in addition to
11 conservatively assuming no operating of fans, imposed
12 conservative ignition assumptions in the upper
13 compartment of the containment.

14 It may very well be that if one only had to
15 deal with failure of the air return fans, that pressures
16 would still be below the pressure capacity of the
17 Sequoyah containment.

18 COMMISSIONER GILINSKY: What was that point,
19 only had to deal with air return?

20 MR. TINKLER: If we only had to deal with
21 failure of the air return fans.

22 COMMISSIONER GILINSKY: Oh, I see.

23 MR. TINKLER: Now, I am not imposing
24 additional failures like sprays and so forth. One
25 could reasonably expect that the pressures would remain

1 below the Sequoyah pressure capacity.

2 Now, detailed calculations of that sort have
3 not been performed from a best estimate viewpoint with
4 combustion assumptions. But I would just like to point
5 out that that original concern was heightened by some
6 very conservative calculations.

7 COMMISSIONER GILINSKY: But to sum up, you
8 assured yourself that we can be reasonably confident the
9 fans would operate in that environment.

10 MR. MATTSON: Well, a corollary to what
11 Charlie said, the staff has been aware for two years it
12 was important to have fans working. The Environmental
13 Qualification Branch has reviewed what TVA says it has
14 done.

15 TVA says it assured the EQ branch and the
16 staff that it was OK. We just do not happen to have the
17 people here who can jump up and swear and declare they
18 did it; an oversight.

19 COMMISSIONER GILINSKY: Have you discussed the
20 question of power supplies, the point raised in the ACRS
21 letter?

22 MR. MATTSON: No, we have not. If we could
23 move on, we could talk about some of these open issues.

24 COMMISSIONER AHEARNE: Let me just ask one
25 question. Harold, could you ask someone from the EQ

1 Branch to send me a note, give me a call, and tell me
2 about this, what they have done to go from the essential
3 list to the most sensitive?

4 MR. DENTON: Yes.

5 MR. MATTSON: The next slide talks about two
6 open issues that the staff had identified. I do not
7 mean to be ducking your question, Commissioner
8 Gilinsky. The third one will be power supplies when I
9 get to the ACRS letter.

10 CHAIRMAN PALLADINO: Which set are we looking
11 at?

12 MR. MATTSON: We are looking at the original
13 set, the slide, the sixth one down that says, "Open
14 Issues." It has two bullets on it.

15 One question that we had as an open issue in
16 our draft SER that we sent down to you and that we sent
17 to the ACRS was the question of performance of the Tayco
18 igniters in the upper compartment in the presence of
19 sprays.

20 We had said early that we thought we ought to
21 have some tests of the temperature of the igniters in
22 the spray environment because at the last minute in this
23 year of testing and review we had seen some tests that
24 showed a decrease in the temperature of the igniter in
25 the presence of sprays. The sprays were not typical of

1 the operating characteristics.

2 TVA's response to that anomalous result - if I
3 can call it that - was to say, "We will put a better
4 shield over it, we will seal it so that it does not see
5 the vertical component of the spray."

6 We felt a little uncomfortable with that
7 because with the movement of air there is a lateral
8 component to the spray and there is no shield for
9 protecting the igniter.

10 Well, that was our position going in to the
11 ACRS subcommittee review last week. The ACRS
12 subcommittee had retained two knowledgeable and
13 respected experts in this field, Drs. Catton and
14 Zufans. Zufans from Franklin Research, and Catton from
15 UCLA, people we respect in the thermal-hydraulics
16 business and that we have dealt with at the ACRS level
17 for some years.

18 They caused us to rethink the question of the
19 conditions for this test. They pointed out to us that
20 we were relying on analysis to make the conclusion that
21 ignition would occur in the presence of this lateral
22 spray component, that it was bigger than a question of
23 temperature. You might have a temperature that would
24 not support combustion because the air-steam mixture was
25 unique, in addition to the temperature being unique.

1 That there was a synergism between these two effects of
2 sprays.

3 We thought about that and decided they were
4 right, and went to the full committee and said we had
5 changed our minds, we wanted ignition tests, not just
6 temperature measurement tests in the present of a spray,
7 a lateral spray component.

8 The ACRS listened to the same consultants and
9 concluded that that was unnecessary. Of course, TVA's
10 position has been that no more testing was necessary,
11 that the simple improvement of the spray shield for the
12 vertical component was enough.

13 So, you have three points of view on this
14 issue. The recommendation we make is that there be
15 additional testing. That it is confirmatory in nature.
16 That there is no crisis that it be done overnight, that
17 there are several facilities doing hydrogen testing - in
18 our research program; in EPRI's research program. TVA
19 be allowed to figure out what is the most cost-effective
20 way to supply this data.

21 There has been some argument over, we did not
22 know how to end the testing and that there was no limit
23 to what we wanted. We have on one of the backup slides
24 specified what we think a very simple limit. We do not
25 have any intent to keep this thing going forever and

1 ever. We think it is reasonable to ask for this
2 confirmatory information.

3 There have also been people - one more point -
4 who said that this is not just a Tayco problem and they
5 are right, it is not just a Tayco problem. It is a
6 problem we will have to address for the GM Glow plugs
7 when we get around to the McGuire final SER. The
8 one-year period, remember, applied both to the McGuire
9 and the Sequoyah review. And since they have kept the
10 Glow plugs, we will have to address this question for
11 them also.

12 CHAIRMAN PALLADINO: Now, so far as
13 temperature is concerned, though, not thinking about the
14 synergistic effect, tests showed that these temperatures
15 came down 16 degrees, depending on whether the fan was on
16 or off. Aside from the synergistic effect, could the
17 Tayco igniters still function, did they function? Would
18 that reduce temperature?

19 MR. MATTSON: In my understanding, that test
20 did not have combustion in it. It is our judgment that
21 the Tayco igniter will function, that it is adequate,
22 this is confirmatory.

23 CHAIRMAN PALLADINO: But even with that
24 reduced temperature, surface temperature?

25 MR. MATTSON: Yes.

1 COMMISSIONER AHEARNE: It was not clear from
2 the SER why you concluded 1500 degrees was the critical
3 temperature.

4 MR. MATTSON: Charlie? You want to, Walt?

5 MR. TINKLER: The ability of the igniters to
6 ignite various air-steam mixtures has been investigated
7 by measuring Glow plug surface temperatures or Tayco
8 surface temperatures and determining the surface
9 temperature at the time of ignition of various
10 mixtures. And for mixtures up to those required to
11 inert with steam, surface temperatures, the maximum
12 surface temperature required was on the order of 1500
13 degrees Fahrenheit for very high steam traction.

14 COMMISSIONER AHEARNE: What was that, do you
15 recall?

16 MR. TINKLER: What was?

17 COMMISSIONER AHEARNE: What was the condition,
18 how unusual was the condition where you required 1500
19 degrees, where you needed 1500 degrees?

20 MR. TINKLER: 1500 degrees was the temperature
21 required of the GM Glow plug.

22 COMMISSIONER AHEARNE: Not of the igniter?

23 MR. TINKLER: Not of the Tayco igniter, but of
24 the GM Glow plug on the order of 50 percent.

25 COMMISSIONER AHEARNE: And do you believe that

1 there is an equivalent temperature requirement from the
2 Glow plug in the igniter?

3 MR. TINKLER: The testing performed by TVA
4 indicates that the surface temperature need not be that
5 high for the Tayco coil igniter. We have pursued that
6 matter to determine if we could resolve specifically why
7 the Tayco coil igniter ignites at a lower surface
8 temperature.

9 COMMISSIONER AHEARNE: And your SER mentions
10 you think perhaps the internal gets higher.

11 MR. TINKLER: It may be that air within the
12 coil is heated to higher temperatures and the concern is
13 that if the mixture which flows past the igniter is
14 flowing rapidly enough the residence time of air in that
15 coil is not too terribly long and that you may not see
16 that benefit.

17 COMMISSIONER AHEARNE: So, am I correct in
18 saying that you are choosing 1500 degrees as the
19 critical temperature because you have Glow plug results
20 that require 1500 degrees for some very high steam
21 traction mixtures, and you do not have any evidence that
22 the Tayco igniter would work in that same fraction at a
23 lower temperature, and you think that that fraction is
24 sufficiently within the scenario calculation you want to
25 require that ought to be used.

1 MR. TINKLER: We do have evidence that the
2 Tayco coil igniter would function in that environment
3 with a lower temperature. As I said, the concern is
4 that we are not persuaded that we can explain why, that
5 it may be a result of that particular test.

6 CHAIRMAN PALLADINO: Commissioner Roberts?

7 COMMISSIONER ROBERTS: Yes. On the additional
8 testing under the spray condition - I am reading from
9 the SER 22-47, "Staff will require the TVA to complete
10 certain additional tests to verify that the Tayco
11 igniter will maintain ... This work can be performed at
12 the Nevada Test Site."

13 Then you say, "The staff will require the
14 installation of four additional igniters in the upper
15 compartment, and TVA has indicated its willingness to
16 comply with this requirement."

17 Now, does TVA's willingness to comply relate
18 to the four additional igniters, or does it also apply
19 to the additional testing?

20 MR. MATTSON: There are a couple points in
21 this SER that have been clarified and this is one of
22 them, the connection between the testing and the four
23 additional. It is just because of time that it did not
24 get said very well.

25 If I can characterize what I think TVA feels,

1 and then maybe they should speak. I think they feel
2 they will put in the four extra Glow plugs, if that is
3 necessary, with reluctance but not a big fight.

4 On the additional testst they feel that they
5 are not necessary and they would like to see them not
6 required. So, there is a difference, they are not quite
7 as strong on the four as they are on the additional
8 tests. But maybe they ought to speak to the question.

9 MR. RALSTON: I am John Ralston from TVA.

10 I think Roger correctly characterized our
11 position on the four igniters. We do not feel they are
12 essential. We feel what we proposed is adequate, but we
13 are willing to put them in at the next refueling outage.

14 The aspect of the spray test, I think we have
15 done some significant tests, we feel, at our Singleton
16 Laboratory where we sprayed water on both the Tayco and
17 the Glow plug. We feel these have demonstrated the
18 ability of the Tayco to withstand a spray environment
19 and still maintain a rather high temperature.

20 The test we did was without a shield. We
21 sprayed water on it from a nozzle. We varied the mass
22 flux across the Tayco igniter and we showed that with 20
23 percent of the vertical component that you would see in
24 the actual containment environment we maintained 1500
25 degrees. That is 20 percent of that actually impinging

1 on the igniter.

2 At 60 percent, we maintained the 1350 degrees
3 which our testing program has shown it reliably ignited
4 hydrogen. In a 40-percent steam environment, there is
5 six volume percent hydrogen.

6 So, we feel that, when we combined it with
7 this larger rain shield - and we are only talking about
8 six igniters which are in the upper compartment and
9 below the spray ring - that when we combine that with
10 this larger rain shield which protected it so that
11 really you had to have a turbulence that came through
12 there at an angle that was greater than 50 degrees from
13 the vertical.

14 What we are saying basically is that you could
15 withstand upwards of 60 percent of the vertical rain
16 shower blowing across the igniter at a greater than 50
17 degree angle, and you still maintain the 1350 degrees.

18 COMMISSIONER AHEARNE: Now, do you believe
19 that the 60 percent or 50 percent steam fraction is not
20 a necessary condition? I gathered what the staff was
21 talking about was that 1500 degrees was needed for that
22 high a percentage.

23 MR. RALSTON: All I can say is that our test
24 showed that we can burn it at 40 percent steam
25 environment at a lower temperature.

1 COMMISSIONER AHEARNE: Yes, you did not go to
2 the higher steam.

3 MR. TINKLER: Can I?

4 COMMISSIONER AHEARNE: Yes.

5 MR. TINKLER: 15 degrees was required with the
6 GM Glow plug at high steam fractures; the Tayco igniter
7 was ignited at high steam fractions at lower
8 temperatures.

9 (Simultaneous conversations.)

10 COMMISSIONER AHEARNE: In your test that you
11 are reporting, Mr. Ralston, was there any
12 cross-streaming - the question that staff had raised -
13 the possibility it works at 1350 surface temperature
14 because the inside is really the higher temperature and
15 if you have enough turbulence you may not be able to
16 have sufficient dwell time inside?

17 MR. RALSTON: The one I referred to did not.
18 We ran an earlier test where we had the spray shield
19 that originally was proposed with a fan that blew across
20 it, and we got, I would say, similar kinds of results.

21 MR. DENTON: I think our view was that it will
22 work. I mean, our gut engineering feel is that they
23 will ignite. But this is an existing facility, they can
24 run the additional test. Questions have been raised and
25 we are at a very early stage in the hydrogen.

1 So, I thought it would be better to go ahead
2 and approve this in Unit 1, run this one more test and
3 just be sure we covered all bases if there are any
4 doubts among the technical people.

5 CHAIRMAN PALLADINO: What you say in your
6 proposed licence condition, one of your slides, seems to
7 be different.

8 MR. MATTSON: It is different, I should have
9 pointed that out to you. The license condition on the
10 last slide was sent down to meet your one-week
11 requirement before we changed our minds as a result of
12 Catton's and Zudans' pointing out this small disconnect.

13 CHAIRMAN PALLADINO: Even here it says,
14 "Additional tests shall be performed on the Tayco
15 igniters to demonstrate that the igniters will maintain
16 an adequate surface temperature."

17 MR. MATTSON: That's right.

18 CHAIRMAN PALLADINO: I think that is to
19 initiate --

20 MR. MATTSON: We would change that license
21 condition to say, "initiate combustion." We want
22 hydrogen burning in the test, not just surface
23 temperature.

24 COMMISSIONER AHEARNE: But I thought Mr.
25 Ralston was just talking about some tests that seemed to

1 have a combination of both the spray and the air
2 turbulence.

3 MR. MATTSON: We had evidently considered and
4 dismissed that argument before the ACRS meeting.
5 Charlie, do you want to say why? Would you like to hear
6 the rebuttal to that?

7 MR. TINKLER: TVA performed numerous tests of
8 the Tayco igniter. A group of tests were performed to
9 determine requisite surface temperatures for
10 combustion. These tests involved hydrogen air-steam and
11 induced turbulence via fan.

12 Those tests did not involve sprays. They also
13 performed surface temperature tests with sprays without
14 hydrogen.

15 COMMISSIONER AHEARNE: OK, can I just intepret
16 it? Mr. Ralston, then I misunderstood. Your test was
17 not a test with the spray, the fan, and combustion.

18 MR. RALSTON: No. We did not have combustion.

19 COMMISSIONER AHEARNE: OK.

20 MR. RALSTON: In fact, one of the concerns we
21 have expressed to the staff is, we do not know where we
22 can run a test like this. Now, the Nevada facility that
23 was referred to has some limitations on the amount of
24 water that one can put in there as it is designed right
25 now. We do not know that we could get enough water in

1 there to simulate the spray.

2 The Sandia facility has similar kinds of
3 problems with what you see there. So, we are not aware
4 of where such a test can be run.

5 COMMISSIONER AHEARNE: Your concern then, are
6 you saying that your concern with this license condition
7 is not that you do not think -- you are not objecting
8 primarily because you feel that it is not necessary and
9 it might take you months to do it, but you do not know
10 where you can do it.

11 MR. RALSTON: Well, it is a combination. We
12 do not think it is necessary, for sure. We do not know
13 where we could do it, and we are not sure we can reach
14 good, sound agreement on what the acceptance criteria
15 are and what the real test ought to be.

16 You are really trying to approximate the
17 turbulence inside a condenser with a spray going, and
18 that is a nebulous thing to agree, you have approximated
19 it.

20 I think the test we did, I hope you understand
21 was, the turbulence is in my mind not really an issue
22 because we had the bare igniter sticking out there with
23 a rain shower falling on it. So, it was as wet as it
24 will ever get.

25 (Laughter.)

1 COMMISSIONER AHEARNE: The turbulence issue
2 though, I gather, was not so much whether that would put
3 water over it. The turbulence question is, is the
4 igniter mechanism working because of a heatup inside the
5 igniter coil. If you have enough turbulence you may not
6 have enough dwell for the hydrogen inside that coil.

7 MR. RALSTON: OK.

8 MR. MATTSON: You have a very graphic example
9 now before you. I think you understand it very well
10 what I meant when I said, "What degree of assurance do
11 you want."

12 COMMISSIONER AHEARNE: Yes.

13 MR. MATTSON: The judgment is, it will work in
14 this environment.

15 COMMISSIONER AHEARNE: Roger, has the staff
16 looked at -- in the SER you seem to imply that they
17 could run the tests at Nevada.

18 COMMISSIONER ROBERTS: They say they can.

19 COMMISSIONER AHEARNE: Mr. Ralston said they
20 cannot.

21 MR. MATTSON: Let me see if I can shed some
22 light on that. His statement seems at odds with
23 Harold's statement.

24 COMMISSIONER AHEARNE: It is at odds with the
25 statement here --

1 COMMISSIONER ROBERTS: Can be done.

2 COMMISSIONER AHEARNE: At the Nevada Test Site
3 in early 1983.

4 MR. MATTSON: There are facilities of
5 sufficient size to do this work. He is probably right
6 that if you look at the details of how they are
7 presently designed and configured, you would have to
8 make some changes.

9 It is our judgment that the changes in these
10 exiting facilities would not be large, would not cost
11 enormous sums of money.

12 COMMISSIONER ROBERTS: Are we asking TVA to
13 solve a generic problem?

14 (Laughter.)

15 COMMISSIONER ROBERTS: I have problems with
16 that.

17 MR. MATTSON: Wait a minute. No, I do not
18 think so. TVA is the only company that is using Tayco
19 and the residence time inside that little coil is the
20 issue. So, no, I do not believe we are.

21 Now, there may be a similar question for the
22 Glow plug that the Ice Condensers Owners Group will have
23 to resolve when we turn to McGuire in two months. But
24 for that igniter, this company is the only one that has
25 it.

1 CHAIRMAN PALLADINO: Was that your question,
2 Tom?

3 COMMISSIONER ROBERTS: Yes. I have more.

4 COMMISSIONER AHEARNE: Then you are saying
5 that the SER statement, "This work can be performed at
6 the Nevada Test Site in early 1983," it is really the
7 staff's judgment. Early 1983 is within four months.

8 MR. MATTSON: Again, bear with us. This is
9 something that is happening in the last three or four
10 days. So, we are not going to press that this stuff has
11 to be run in the early spring. The tests that we had
12 thought we were interested in when we wrote this SER
13 were different tests than what we would now require.

14 Our judgment as to how long it might take to
15 change a facility and get into the facility, perform the
16 test, it is a little longer.

17 COMMISSIONER AHEARNE: So, in other words, not
18 only then are you going to be proposing a change in what
19 the tests were to show, but you have here the test shall
20 be completed by September '83. Are you going to change
21 that, also?

22 MR. MATTSON: We were going to leave September
23 the way it is. When we discuss this among ourselves
24 within the last few days the question of, "Why
25 September" the answer, "Well, let's tie it to Unit 2 and

1 it would be nice to have this cleared up so it was not
2 still hanging out when Unit 2 finished its first
3 refueling."

4 That is a good reason. In terms of a risk
5 basis for that reason, there is not any. If they would
6 come in and say, "We can get into this facility in
7 eleven months and run the test, will it resolve it,"
8 clearly, I think we would say yes.

9 COMMISSIONER GILINSKY: I wonder if we could
10 extract ourselves from this --

11 MR. MATTSON: I would encourage you to.

12 (Laughter.)

13 CHAIRMAN PALLADINO: Commissioner Roberts?

14 COMMISSIONER ROBERTS: Yes, let me ask you a
15 question. I am reading from the SER, this is page 22-5,
16 "Installation of additional igniters in the upper
17 compartment will provide greater margin of safety."
18 What is the incremental margin that this is going to
19 provide?

20 MR. MATTSON: You are switching a little bit
21 from the spray tests.

22 COMMISSIONER ROBERTS: Yes.

23 MR. MATTSON: OK. We have two backup slides
24 that show where these things go, and it is from those
25 slides that you can understand the increment that you

1 are interested in.

2 Charlie, do you just want to start with B-6
3 and B-7, can you put them up on the screen, please? B-6
4 first, and point out where the additional ones go, and
5 then show how they provide this staggered coverage?

6 CHAIRMAN PALLADINO: Why you are putting them
7 in.

8 MR. MATTSON: Why don't you just step up there
9 so you can point exactly to which ones you are talking
10 about.

11 MR. TINKLER: Depicted on this is the general
12 layout of the Sequoyah containment and the distribution
13 of igniters. This represents, this boundary here,
14 represents divider -- which separates the upper
15 compartment and the lower compartment.

16 This section here is the ice condenser. The
17 upper plenum is the region above the top of the ice
18 condenser.

19 The staff has proposed that four additional
20 igniters be located in the upper compartment at this
21 approximate location, if I can have B-7.

22 This viewgraph illustrates those igniters that
23 are presently installed as parts of PHMS below the spray
24 header.

25 The staff has proposed that four additional

1 igniters be located in those approximate locations.

2 CHAIRMAN PALLADINO: Why is that, what leads
3 you to say they ought to be there, or they ought to be
4 added?

5 MR. TINKLER: The motivation for increasing
6 the number of igniters and at those specific locations
7 is to improve coverage of the central core of the upper
8 compartment.

9 As they are located now it is our feeling that
10 most of the igniters are on the periphery. They are
11 either located against the containment shell side, there
12 are two igniters above the air return fans or in the
13 case of these igniters, on the inside of the containment
14 wall below the position of the top deck blankets.

15 MR. MATSON: There are really two general
16 concerns. One is that the four might not be enough to
17 cover the geometry of this large upper compartment, so
18 that there could be concentration gradients in the upper
19 compartment that could lead to less control of the
20 hydrogen as is being burned. You might end up with
21 burning large concentrations instead of small
22 concentrations. That is one kind of concern.

23 Another kind of concern is with just a small
24 number in the upper compartment, you really want to burn
25 up there. That is a good place to burn. Four of them

1 that are already there are located in such a way that
2 when the blanket blows off the ice condenser - although
3 it looks like it will not interfere with them - there is
4 a small possibility that it could interfere with those
5 igniters.

6 So, the four additional igniters give you some
7 assurance there. The primary reason is this geometric
8 arrangement. It is clearly an inspection type
9 engineering judgment as to how many and where to put
10 them in a large open space where you have got air moving
11 in order to keep it uniformly mixed, and you have to
12 reach some judgment as to how many does it take before
13 you are confident that you won't have bad concentration
14 gradients, to benchmark --

15 COMMISSIONER GILINSKY: How many are up there
16 ;now?

17 MR. MATTSON: In the interim system they had
18 16 in the upper plenum. They came back with the final
19 system with ten. In the interim system they had 16
20 igniters.

21 COMMISSIONER AHEARNE: The previous backup
22 shows 16 in the upper plenum.

23 MR. TINKLER: In the upper compartment.
24 Previously there were 16 in the upper compartment.

25 MR. MATTSON: I am sorry, I forgot there is a

1 difference; 16 in the upper compartment. They now
2 changed it to ten in the upper compartment. We would
3 bring that back to 14.

4 The increment is a judgment increment.

5 COMMISSIONER AHEARNE: Now, I gather that you
6 were unable to convince the ACRS at the moment.

7 MR. MATTSON: The ACRS was kind of like TVA,
8 they may not be necessary but --

9 COMMISSIONER AHEARNE: But they won't do any
10 harm.

11 MR. MATTSON: They won't do any harm.

12 COMMISSIONER GILINSKY: The ACRS now.

13 MR. MATTSON: And as long as we did not tell
14 them they had to do it and delay startup, they would put
15 them in, I guess is their position.

16 CHAIRMAN PALLADINO: Will the installation of
17 those be a factor in startup?

18 MR. MATTSON: No, we have agreed they can put
19 them in at the next opportunity of sufficient duration
20 which, I gather, will be in this next startup, next
21 refueling.

22 If I could go to slide 7 quickly. I am still
23 delaying your power thing.

24 CHAIRMAN PALLADINO: That is not a basic part
25 of the decision of whether or not this is inadequate.

1 MR. MATTSON: No, no. We think it is adequate
2 for restart, with 64. We put 68 in, given that there
3 are many years left in the operation of this plant and
4 it is not a big expenditure, and it can be done.

5 COMMISSIONER AHEARNE: You say it is an --
6 system, and let me go back to the "radical" that Vic
7 mentioned.

8 The test that you are asking them to do on the
9 spray, I gather your conclusion is that it does not give
10 you enough uncertainty to raise in your mind the
11 question of, is it really adequate enough to have the
12 plant restart.

13 MR. MATTSON: That is right, it does not raise
14 that question.

15 COMMISSIONER AHEARNE: Yet, you don't really
16 know where the test can be done, but you want to put on
17 a September '83 licensing condition that it has to be
18 done by.

19 MR. MATTSON: For reasons I said had to do
20 with bureaucratic efficiency more than anything else.

21 COMMISSIONER GILINSKY: Well, it does seem
22 like a good idea to have it done before the next plant
23 starts operating. If it turns out that it is absolutely
24 impossible to get it done, reach some fair, common-sense
25 accomodation.

1 MR. MATTSON: Yes. That is also what I said.
2 If it turns out that September is unreasonable and
3 December is reasonable, all they have to do is tell us
4 that. There is no reason not to --

5 COMMISSIONER GILINSKY: And we also assume
6 they make a reasonable effort --

7 COMMISSIONER ROBERTS: They better keep a
8 transcript.

9 COMMISSIONER GILINSKY: -- to meet the
10 September --

11 MR. MATTSON: That is right. And these test
12 facilities, the EPRI facilities, we are a partner in the
13 EPRI facility, and we all have some control over
14 scheduling and we have a voice in when schedules get set.

15 COMMISSIONER AHEARNE: But it is correct that
16 you have looked at the facility and you have reached the
17 conclusion that it could be used. TVA has looked at the
18 facility and has concluded it cannot be used. So, is
19 that correct?

20 COMMISSIONER GILINSKY: Probably neither have
21 looked that hard at it.

22 MR. MATTSON: Neither have looked that hard at
23 it, that is the answer. We have looked at the tests we
24 think we would like to see, and it seems reasonable that
25 those tests can be performed, given our understanding of

1 the vessels available in the United States, especially
2 the one at Nevada, to modify one and get it done in a
3 reasonable period of time, like a year.

4 COMMISSIONER AHEARNE: The SER statement is a
5 little bit strong; is that right?

6 MR. MATTSON: Yes. Well, it was for a
7 different test that we thought could be run rather
8 straightforward, not involving combustion.

9 The next slide, Slide 7, the SER points out
10 that there are on-going programs --

11 CHAIRMAN PALLADINO: Of the first set?

12 MR. MATTSON: The first set, yes, sir; not the
13 backup, the first set, Slide 7.

14 There are on-going programs in industry and
15 government that will provide us confirmatory
16 information, stuff that if we had today it would be nice
17 to say we had it and use it support our conclusions.

18 It is not there today. We will keep track of
19 that as it becomes available. If anything untoward
20 occurs, of course, we will bring it to your attention.

21 This is a kind of a not license condition on
22 the applicant, it is a condition on the staff. We will
23 keep track and make sure these things confirm what we
24 think the judgments are.

25 COMMISSIONER GILINSKY: Let's see, if you have

1 local detonations up there, how confident are you that
2 detonations will not take place?

3 MR. MATTSON: Well, the SER goes into some
4 description about the work the TVA has done to assure
5 themselves. We have reviewed that and we agree with
6 them within the existing state of knowledge.

7 There are continuing experiments at Sandia
8 dealing with local detonations. We are going to push
9 the forefront of knowledge back in that area. We think
10 it is OK, but it is a research program. If it tells us
11 we did something wrong, we would have to factor it back
12 in here.

13 We think it will confirm that the analysis
14 that has been done so far is right.

15 CHAIRMAN PALLADINO: You had an earlier
16 question.

17 MR. MATTSON: I want to turn now to a backup
18 slide that summarizes the ACRS letter on Sequoyah, dated
19 day before yesterday, December 13. It is backup slide
20 B-8, it should be next to the last one in your backup
21 package.

22 The bottom line, the ACRS agreed that this was
23 an adequate hydrogen mitigation system, provides
24 adequate safety margins. So, to interpret that in our
25 decision here today, that means that they have removed

1 the license condition.

2 On the matters of further work, the ACRS
3 brought up three points. Two we have already talked
4 about, four more igniters in the upper compartment.
5 They do not hurt anything but they may not be necessary.

6 Ignition testing with sprays, we talked at
7 length about that.

8 Then this question of loss of A.C. power.
9 This really goes to the point of what accident sequences
10 beyond the design basis are you designing this system
11 for. I have already said that we were trying to get the
12 bulk of the risk to containment from hydrogen generation
13 beyond the design basis, but we have to acknowledge it
14 would not be all of it.

15 One way to answer the question of, where does
16 the bulk of the risk reside is in risk assessment,
17 probabilistic risk assessment. Which events are more
18 likely to cause hydrogen in a way that could be stopped
19 short of core meltdown where this system would give you
20 some help.

21 Loss of all A.C. power for this plant is an
22 insignificant contributor to overall risk and to that
23 domain.

24 COMMISSIONER AHEARNE: ACRS actually talks
25 about station blackout.

1 MR. MATTSON: That is the same thing, loss of
2 all A.C. and station blackout are in the jargon the same
3 thing.

4 COMMISSIONER AHEARNE: You don't count loss of
5 diesels also?

6 MR. MATTSON: Loss of all A.C. means loss of
7 diesels and offsite, that is the jargon.

8 The ACRS letter, I must say, can be misread.
9 The ACRS letter says we should write some procedures to
10 fix this problem, and procedures don't fix this
11 problem. You have to have a piece of equipment to do
12 what the ACRS tells us outside of the letter what they
13 really mean.

14 The chairman of the subcommittee is Carson
15 Marck. Carson has said to the staff that what he means
16 is by "procedures" a way to hook up a portable gas
17 generator that most plants might have around.

18 Now, there is no license condition that there
19 be a portable gas generator at any plant. I am told
20 that at some plants they have them sometimes to pump
21 water if they get a flood or to just have handy in case
22 of this or that need in the normal functioning of the
23 plant.

24 They are not a safety requirement. There is
25 nothing in our regulations that goes beyond the diesel

1 generator on site power kind of requirement.

2 So, first of all, it is not just procedures
3 that would fix the problem.

4 Second of all, it is not just igniters that
5 will solve the problem. We have already talked about
6 the importance of the air fans and making some assurance
7 that the system works.

8 Now, Charlie says - and rightfully so - that
9 we may be overly sensitized because those early
10 calculations had a lot of conservatism in them.

11 Nevertheless, the judgment we are reaching and
12 the recommendations we are giving you are based on the
13 assumption that the fans and the igniters go together in
14 supplying the assurance that we are supplying, and to
15 provide backup power for the igniters would not supply
16 backup power for the fans.

17 Now, there is an "out" to his question. I
18 think you can get out of this rabbit hole, to use your
19 expression. And that is A.44. You have an unresolved
20 safety issue on station blackout.

21 Now, it looks generally at, should you do more
22 to prevent station blackout, should you do more to
23 mitigate station blackout, where should you put your
24 bucks? Should you put them on hydrogen control? Should
25 you put them on more water to the core? Should you, for

1 example, put them on a seal coolant steam-driven system
2 as some of the advanced reactors in some of the other
3 countries are choosing to do? That might be a much
4 better thing to do with your dollars than put them in
5 igniters.

6 We would argue to not study this problem on
7 Sequoyah, it is a use of their resources and a use of
8 our resources we can better spend on the unresolved
9 safety issue A.44 and decide on a more general plane
10 what is the right thing to do on station blackout.

11 CHAIRMAN PALLADINO: Would A.44 have to be
12 modified to make sure it includes consideration of the
13 igniter question?

14 MR. DENTON: We would want to make sure that
15 it does, now that it has been flagged specifically and
16 there are questions about what would you do if you lost
17 power and then it came on again, would you want the
18 igniters to come on automatically if you did not know
19 what the concentrations were. Maybe you would want to
20 measure the hydrogen concentration first.

21 So, we will certainly add it in there. And I
22 think there are some unique features of Sequoyah that
23 mitigate against making this the area to look into.

24 Actually, loss of all A.C. power at a site is
25 a rather severe case, but we do think at Sequoyah that

1 most likely when the igniters are called upon to work,
2 there will be plenty of power available and it will be
3 not because of a loss of A.C. power, it will be some
4 other accident scenario.

5 CHAIRMAN PALLADINO: I gather from what Roger
6 said earlier that this facility fares better on loss of
7 A.C. power than other facilities.

8 MR. MATTSON: Yes, roughly a factor of ten
9 better than the Surry plant, and the reason is because
10 of a lot of inner ties offsite, it has a reliable grid,
11 and because it has better diesels and a better diesel
12 loading sequence on site.

13 COMMISSIONER GILINSKY: You mean, there is
14 less likelihood to lose all A.C. power.

15 MR. MATTSON: Less likely to lose offsite, and
16 if it loses offsite, less likely to lose diesels.

17 MR. DENTON: This is based on the results of
18 the RSSMAP study which is available for this facility.

19 COMMISSIONER AHEARNE: How many diesels do
20 they have?

21 MR. MATTSON: Two per unit, and I believe they
22 are adding a fifth, I was told today.

23 MR. DENTON: I guess I did want to point out
24 too, we do have these three areas of differences. I
25 think we have come an awful long way of getting

1 agreement among everybody in a very complex area to only
2 end up with these three loose ends on hydrogen.

3 We were not able -- the three in the ACRS
4 letter up there, the number of the test and the question
5 of the power supply between us.

6 CHAIRMAN PALLADINO: Which slide are you on?

7 MR. MATTSON: B-8. Igniters in the upper
8 compartment, the ignition testing with sprays, and
9 whether we should continue to study the need for backup
10 A.C. power for the station blackout.

11 COMMISSIONER GILINSKY: Earlier you talked
12 about the question whether you want to turn the igniters
13 back on. You may have covered this in the beginning,
14 but why is this a manual system as opposed to an
15 automatic system? As I understand it, you want it to go
16 on every time safety injection goes on.

17 MR. MATTSON: But it takes a long time, these
18 are slow-moving sequences, before you depend on it. And
19 using the standard approach to allowing manual action,
20 it is a simple action; there is plenty of time to
21 perform it in. If you forget to do it, it meets the
22 test of a manual action.

23 If you automate the things it has to happen
24 quickly and in a confusing environment. This is a
25 fairly simple action, it is on the prompt signals, they

1 prompt things to do.

2 COMMISSIONER GILINSKY: But if there are no
3 exceptions to the rule that you turn it on, then it
4 would seem to me to make sense to make it automatic. If
5 there was a situation in which you would want the
6 operator to exercise judgment.

7 MR. MATTSON: There is something in the SER
8 about that. Even though I have said we would not do any
9 more for station blackout, it is really because you
10 cannot do it procedurally.

11 There are some procedures you might write,
12 however, for station blackout or for extreme cases
13 beyond the basis that we have used for this system,
14 inadequate core cooling parts of emergency procedures,
15 for example.

16 COMMISSIONER GILINSKY: Well, I was not
17 thinking of a station blackout.

18 MR. MATTSON: Well, let me take the station
19 blackout because it is the only example that I know.

20 COMMISSIONER GILINSKY: Harold mentioned it.
21 But what about just the basic turning on of the igniters?

22 MR. MATTSON: Because operators cannot really
23 tell, really, in an event what the event is. That says
24 you would like them to turn them on for all approaches
25 to abnormal conditions. Because it takes long time to

1 generate hydrogen, you do not need to automate it.

2 There may be conditions where, after a long
3 period of time, if something has happened that is not
4 within the design basis for these igniters, you might
5 want to tell them to turn them off. Station blackout is
6 one that we are going to do some more thinking about
7 that one in the inadequate core cooling guidelines.

8 There might be some advantage to having a
9 caution in inadequate core guidelines, inadequate core
10 cooling guidelines that where you got down to a very
11 degraded situation where you have had a station blackout
12 you know you have caused severe damage to the core. You
13 cannot measure how much and you cannot do anything about
14 it because your safety equipment has lost . . . of its
15 power - that is what a station blackout is.

16 And then you restore power. Grid comes back
17 on, or you get a diesel started. At that point you will
18 be able to measure hydrogen and you will know the status
19 of equipment and you will know the status of the core.

20 There is some discussion yet about whether it
21 is better to quickly turn the igniters on, or whether it
22 would have been better to turn them off so that they do
23 not come immediately on in that situation. There may
24 need to be judgments for such, in extreme degraded
25 situations, about containment venting or other ways to

1 deal with that hydrogen.

2 COMMISSIONER AHEARNE: Are you saying form
3 that that you are still considering whether or not
4 require them to be automatic?

5 MR. MATSON: No. He asked whether there was
6 guidance of conditions where the operator might want to
7 do more than a blind switching on. My answer is, we
8 always want him to blindly switch them on, but later on
9 there might be extreme situations where you tell him to
10 do something a little different.

11 COMMISSIONER AHEARNE: But what you seem to be
12 saying is that in answer to, should they be on
13 automatically, that there might be a situation where you
14 would not want them to turn them back on. And you are
15 analyzing that further.

16 But that sort of sounds like your conclusion
17 would be, yes, it ought to be automatic except you have
18 this one hesitation which you are looking at.

19 COMMISSIONER GILINSKY: Well, no, it sounds
20 like it ought to be automatic but you ought to be able
21 to turn it off, and then there is some question about
22 whether you want to turn it back on.

23 MR. MATSON: I did not say it ought to be
24 automatic. I said it ought to always be turned on once
25 you start down the path.

1 COMMISSIONER GILINSKY: That says to me it
2 ought to be automatic.

3 MR. MATTSON: That is not the criterion we use
4 nor that our regulations require.

5 COMMISSIONER GILINSKY: It does seem to me a
6 common-sense criterion.

7 MR. MATTSON: Well, then we would automate a
8 number of things that are not automated now.

9 COMMISSIONER GILINSKY: Well, maybe we ought
10 to deal with them today.

11 It seems to me you are answering a question, a
12 rather more sophisticated question than I was asking.
13 But it does seem to me that if there are no exceptions
14 to turning them on it ought to be automatic. And from
15 what you say, you ought to be able to turn it off, as
16 with a lot of other equipment so we can have some
17 flexibility later on.

18 MR. DENTON: I think our first judgment was
19 that manual was adequate, and it would be more reliable
20 if you made it automatic.

21 MR. MATTSON: We talked about this question at
22 some length with the interim system where they had to go
23 outside of the control room to turn them on.

24 COMMISSIONER GILINSKY: Through two locked
25 doors, as I remember.

1 MR. MATTSON: Yes, you remember the discussion
2 quite well.

3 Now we have it in the control room where it is
4 quite accessible.

5 COMMISSIONER GILINSKY: No, I think that is a
6 great improvement.

7 MR. MATTSON: There are a couple of switches
8 and we do it manually because there is time to get it
9 done.

10 COMMISSIONER GILINSKY: Well, I suggest you
11 think about whether or not it ought to be automatic. It
12 does seem to me that if there are no exceptions to the
13 rule, then we ought to just take it off the operator's
14 agenda, that is just one less thing --

5 CHAIRMAN PALLADINO: What tells the operator
16 he should or should turn it on?

17 MR. DENTON: I think it is the SFAS signal.

18 MR. MATTSON: If he gets a safety injection
19 signal we tell him to manually actuate the igniter.

20 COMMISSIONER AHEARNE: Would you ever have any
21 criterion which would say don't turn it on?

22 COMMISSIONER GILINSKY: When that other signal
23 goes in it.

24 COMMISSIONER AHEARNE: Yes. I guess I am sort
25 of with Vic on this. If the procedures always do

1 something it is not clear why it should not be automatic.

2 MR. MATTSON: Well, I encourage you to think
3 about that criterion because that is rather new and
4 interesting to control rooms today. It is a problem.

5 (Laughter.)

6 COMMISSIONER GILINSKY: I guess we have some
7 homework.

8 (Laughter.)

9 CHAIRMAN PALLADINO: Is that a technical
10 decision?

11 COMMISSIONER GILINSKY: No. I do think that --

12 COMMISSIONER AHEARNE: I would like them to go
13 back and come back.

14 MR. MATTSON: That is just kind of a generic
15 question, though. I think that we will get with the
16 Division of Human Factors and talk a little bit about
17 what other things might fall in that same package.

18 COMMISSIONER AHEARNE: Yes, but just to this
19 one particular area, look at that a little bit again. If
20 you want the operator always to do that I don't
21 understand why it should not be automatic.

22 CHAIRMAN PALLADINO: Well, I would suggest
23 that we make it that the staff should review that
24 question.,

25 COMMISSIONER AHEARNE: Yes.

1 CHAIRMAN PALLADINO: Or investigate that
2 question, explore it and then come back.

3 COMMISSIONER AHEARNE: Yes.

4 MR. MATTSON: Let's see, "always" we
5 understand to be always when there is a safety injection
6 thing, and we just always flip it on when he hears the
7 safety injection signal. You do understand that.

8 COMMISSIONER AHEARNE: Yes.

9 CHAIRMAN PALLADINO: Any more questions?

10 COMMISSIONER GILINSKY: Well, I have just one
11 general question, how does this affect other ice
12 containment plans and MARC-3s, where does it lead us
13 with respect to everything else?

14 MR. MATTSON: Yes. Generally, we are moving
15 along at a rather fast pace towards approving
16 distributed ignition systems. They have panned out,
17 they work. There was some question two years ago
18 whether that would be true and I think those questions
19 are largely put to bed.

20 We have plant specific detail to work out.

21 COMMISSIONER AHEARNE: This was the lead.

22 MR. MATTSON: This is the lead. You have not
23 seen the MARC-3 yet. When we come to you on Grand Gulf
24 for full power you will first see that.

25 CHAIRMAN PALLADINO: I am trying to recall our

1 last meeting. I thought we had some agreement that the
2 distributed systems were going to be used in ice
3 condenser.

4 MR. MATTSON: Let me back up a little. They
5 have been used in ice condenser now for two years.
6 There are no MARC-3s yet in operation, Grand Gulf will
7 be the first one. So, there are several kinds now of
8 distributed ignition systems, one for the MARC-3s, one
9 for McGuire and TVA - if I can throw them in the same
10 group - and then the Tayco that is being used by TVA.

11 All three distributed ignition systems appear
12 to be valid ways to deal with hydrogen up to the 75
13 metal-water reaction, and we are getting down to the
14 fine points and putting most questions to rest, in our
15 judgment. It is just a few more months, maybe a year
16 or so with Grand Gulf to put all these things to rest,
17 and we will be done with the degraded core cooling
18 hydrogen question for this size containment.

19 Now, we have already put it to bed for the
20 very small BWR containments by inserting the MARC-1s and
21 MARC-2s, and then what remains is hydrogen control for
22 large dries which you remember in our discussion we put
23 over into the severe accident considerations for trying
24 to conclude in calendar '83 through the IDCOR analysis
25 and our own analysis that nothing more needs to be done

1 to those, which will be the likely outcome.

2 COMMISSIONER GILINSKY: Well, what about, say,
3 D.C. Cook, will they follow one of these models?

4 MR. MATTSON: Yes. I think D.C. Cook is most
5 patterned after McGuire, and McGuire is our next thing
6 to move to. I believe it is sort of a proforma
7 write-off on D.C. Cook once we have completed the
8 McGuire.

9 (Simultaneous conversation.)

10 COMMISSIONER AHEARNE: Are any of the other
11 companies switching from the Glow plug to the Tayco?

12 MR. MATTSON: Not to our knowledge, no. They
13 are staying with th Glow plugs.

14 COMMISSIONER AHEARNE: Since in voting on this
15 we are essentially accepting the SER, I have a couple of
16 questions on the SER.

17 MR. MATTSON: OK.

18 COMMISSIONER AHEARNE: Ob 22-5 you say, "The
19 procedures call for the system to remain actuated until
20 the unit reaches safe cold shutdown."

21 MR. MATTSON: I do not believe it said safe
22 cold shutdown. Where does it say that?

23 COMMISSIONER AHEARNE: At 22-5.

24 MR. DENTON: That is a long time.

25 COMMISSIONER AHEARNE: Well, not only is it a

1 long time, many times safety injection does not lead
2 going to safe cold shutdown.

3 MR. DENTON: That is a good point.

4 MR. MATTSON: But notice, at the bottom of the
5 page that we do acknowledge a tie-in of the procedures
6 for this piece of equipment to the 82-111 emergency
7 procedure guideline review.

8 So, whatever is the right thing will get done
9 there. We had to make a choice for now. I think the
10 choice is probably a proper one. But there is an
11 opportunity for further reflection.

12 COMMISSIONER AHEARNE: If you put those in the
13 procedures, are you saying that the operator must leave
14 those on until the plant goes to a safe cold shutdown,
15 and they should not take it to, say, cold shutdown and
16 get it back up, they have to stay on.

17 MR. MATTSON: That is the judgment that has
18 been made, yes.

19 COMMISSIONER AHEARNE: Even when it is in
20 normal operation, it would still have to be on.

21 MR. MATTSON: Well, there is some limit to it.

22 COMMISSIONER AHEARNE: That is what it says.

23 MR. MATTSON: I see your point.

24 MR. DENTON: We will fix that.

25 COMMISSIONER AHEARNE: On pages 20-20 and then

1 22-19 you are talking about some of the calculations
2 that were done. At the bottom of 22-19 it talks about a
3 TVA calculation in which they ended up getting - and
4 this is talking about detonation - they ended up having
5 a safety factor of three before material yield.

6 You then, on 22-20, the second paragraph
7 talked about subsequent calculations Sandia performed
8 which indicated the containment would survive the
9 detonation.

10 The wording leads me to conclude that you got
11 nothing like the factor three the TVA did.

12 MR. MATTSON: My reading said the same thing,
13 but I did not bother to ask anybody if that was true.
14 Wait?

15 MR. STALL: Yes, that is true. But the
16 postulated cloud that was detonated was much larger in
17 the subsequent calculations.

18 COMMISSIONER AHEARNE: Sandia's calculations?

19 MR. STALL: Yes.

20 COMMISSIONER AHEARNE: And that was because
21 you thought that was a more realistic calculation or a
22 more conservative calculation?

23 MR. STALL: Because it was more conservative.
24 The assumption made by TVA was that there was a six-foot
25 diameter ball.

1 COMMISSIONER AHEARNE: Right.

2 MR. STALL: Which we felt was unduly small,
3 and we asked the TVA to take a look at a different one
4 with a larger detonation.

5 MR. MATTSO: Sandia, you mean.

6 MR. STALL: Sandia, and they took the entire
7 upper plenum of the ice condenser, which in our view is
8 a pretty large detonation.

9 COMMISSIONER AHEARNE: True.

10 (Laughter.)

11 COMMISSIONER AHEARNE: I am glad Roger pointed
12 out in the beginning --

13 MR. MATTSO: You know, there is a difference
14 between an SER written during a shutdown when the data
15 comes in, some of it very late; and one written at
16 anormal OL.

17 COMMISSIONER AHEARNE: Yes.

18 On the top of page 22-22 you say, "The staff
19 has compared the release rates chosen by TVA to those
20 suggested in the proposed rule." Now, the release rate
21 that TVA calculated, you say in here, was six pounds per
22 second. But in looking at the proposed rule suggests
23 rates were up to a thousand.

24 MR. MATTSO: Is that the same units?

25 COMMISSIONER AHEARNE: A thousand pounds per

1 minute.

2 MR. MATTSON: Three-hundred sixty versus a
3 thousand. Six per second.

4 COMMISSIONER AHEARNE: Yes.

5 COMMISSIONER AHEARNE: That is factor three
6 difference.

7 MR. MATTSON: But the 360 is the base case.

8 MR. STALL: No. It is much higher than the
9 base case.

10 COMMISSIONER AHEARNE: The base case was a
11 third of a pound a second, according to page 22-21.

12 MR. MATTSON: I guess that the weight of the
13 evidence must be from our own assessment as to what can
14 be expected for these slow-moving transients. If it is
15 one pound per second and they use six, that looks pretty
16 good.

17 COMMISSIONER AHEARNE: Yes.

18 MR. MATTSON: And if the rule says a thousand
19 and they do 360, that is pretty close.

20 COMMISSIONER AHEARNE: So, you are saying the
21 factor of three was not important.

22 MR. STALL: I think our judgment is that a
23 thousand pounds per minute is a horrendously rapid
24 release.

25 COMMISSIONER AHEARNE: Of course, I am not

1 even saying it is realistically even conservative. I am
2 just trying to understand if I endorse the SER, what am
3 I endorsing. And I find this --

4 MR. MATTSON: If the SER is not an adequate
5 representation, then maybe we ought to elaborate this a
6 little and put the two numbers side by side, 360 versus
7 1,000. When the thousand was picked, there had been no
8 such calculations of this sort by anyone, and it was in
9 our judgment today a very conservative number.

10 It is the second one we found so far today,
11 and I think the Research people who are putting that
12 rule in form for final action, we probably better get
13 these points to them. The intent of that rule is not to
14 have this kind of conservatism.

15 COMMISSIONER AHEARNE: On page 22-30, the top
16 of the page, as I read it you are saying that the base
17 case that was used had a flame speed of six feet per
18 second, but the test data and literature have speeds
19 between one and three feet per second at the eight
20 percent hydrogen concentration which is around the
21 hydrogen concentration you talk about used in the system.

22 Is this another case of conservatism in the
23 calculation?

24 MR. MATTSON: That is what it says here.

25 COMMISSIONER AHEARNE: I am just trying to

1 verify it.

2 MR. MATTSON: "The assumptions of ignition at
3 the higher concentrations with a faster flame speed
4 result in a greater amount of energy being released
5 over a shorter period of time, and thus are
6 conservative."

7 COMMISSIONER AHEARNE: Yes.

8 MR. MATTSON: We tried to point those out as
9 we go along, so people know where to pick up the next
10 time around.

11 COMMISSIONER AHEARNE: Just as an aside, I was
12 surprised, given what I thought, there is still a fair
13 amount of uncertainties in some of the calculations that
14 the code runs, to see the the three significant figures
15 of pressures that you calculate. That is just a comment.

16 On 22-42 I am puzzled by that statement in the
17 middle of the paragraph, and it looks like the third
18 sentence.

19 You say, "Because the actual temperature
20 reached by the tested equipment during these tests was
21 not measured and qualification temperature was the
22 temperature of thermal environment to which the test
23 equipment was exposed, there is no direct way to
24 determine the actual qualification temperature reached
25 by limiting components."

1 And then you go on to say, TVA claims that
2 something should be true.

3 Now, I know that on the next page what you end
4 up doing is, it seems to me essentially what you are
5 saying is that the temperature difference is so big that
6 one has in this situation, that the fact that you did
7 not get the actual temperature measurement is not
8 important.

9 Is that the base of your argument?

10 MR. MATTSON: I believe it is.

11 MR. STALL: Could you restate the question,
12 sir?

13 COMMISSIONER AHEARNE: Well, the way the
14 phrasing in the SER is given, it is a little disturbing
15 because, you see, you are going on to say that the
16 acceptance criteria is based on the qualification
17 temperature of the equipment and the duration for which
18 the temperature is maintained.

19 Then you go on to say, the actual temperature
20 reached by the tested equipment was not measured in the
21 test you ran.

22 Now, my point is that it seems to me what you
23 are saying is that the maximum temperature calculated is
24 so much lower than the qualification temperature, that
25 the fact that you did not actually measure the

1 temperature in that test --

2 MR. MATTSON: Means you can be off by a long
3 ways in the analysis. That is how I read it.

4 COMMISSIONER AHEARNE: Yes.

5 MR. MATTSON: You want us to confirm that and
6 clarify it, if I understand the thrust of your comment.

7 COMMISSIONER AHEARNE: Yes.

8 And the last question on 22-44, the second
9 paragraph. You point out, you say, "The test conducted
10 by the licensee was performed in a relatively small
11 oven. Sandia has stated that scaling may be a
12 significant factor in analyzing the survivability of
13 equipment." And then you go on to say that Sandia is
14 going to be performing some additional tests to address
15 this concern.

16 I gather that the fact that the Sandia --
17 either the significant factor that Sandia is talking
18 about is not factors of two to three or four because
19 then that would push you over the boundary of your
20 difference; or you feel that they are going to be able
21 to address the answer rapidly enough under your program
22 so you did not need to discuss that as either a license
23 condition or get TVA involved in looking at those
24 questions.

25 MR. MATTSON: I think it is more in the vein

1 of a research group saying that we probably ought to do
2 some research in this area because it may be bigger. I
3 do not think they have said it is any factor.

4 COMMISSIONER AHEARNE: Well, no. At At least
5 it says here that Sandia has stated that scaling may be
6 a significant factor. At least to me it concluded that
7 you had just previously said two things.

8 First, you are going to count on the
9 temperature of the certain piece of equipment being
10 lower than the environmental qualification temperature.

11 MR. MATTSON: Yes.

12 COMMISSIONER AHEARNE: Second, you were not
13 able, or the test did not measure the temperature of
14 this equipment. However, the calculation is
15 sufficiently large that you don't have any problem.

16 Third, the tests that the licensee actually
17 did do for the temperature qualification were in a small
18 oven and Sandia has said, well, maybe when you scale it
19 you can get significantly different results.

20 I am not sure what the chain is there, but it
21 is just unsettling. I would like to at least understand
22 why I should not be disturbed by that.

23 MR. DENTON: We will have someone get in touch
24 with you. I guess what we are relying on is the
25 reviewer's bottom line that this equipment passes

1 muster. Maybe he has not explained himself that well.

2 MR. MATTSON: My interpretation is, he is
3 skeptical, but there is work going on and if it turns
4 out to be the other way --

5 COMMISSIONER AHEARNE: But you see, in earlier
6 places where the staff is skeptical you have ended up
7 both putting a license condition on and requiring TVA to
8 do something. In this case the skepticism, the level of
9 skepticism --

10 MR. MATTSON: There is a difference between
11 our skepticism as the people who have to sign on the
12 line that it is adequate for public health and safety,
13 and the skepticism of a research contractor. There is a
14 difference, and that is reflected in our calling some
15 things confirmatory items and other things license
16 conditions.

17 COMMISSIONER AHEARNE: So, you are saying that
18 this represents Sandia's skepticism and not the
19 staff's. Well, you are the sponsor of the SER.

20 MR. MATTSON: Well, you have asked for several
21 things from the EQ people who are not here today, and by
22 that oversight we owe you a little response. We will
23 make sure that we are right on that one.

24 COMMISSIONER AHEARNE: Thank you.

25 CHAIRMAN PALLADINO: Commissioner Roberts?

1 COMMISSIONER ROBERTS: No questions.

2 COMMISSIONER AHEARNE: Which version of the
3 license condition are we voting on?

4 CHAIRMAN PALLADINO: Well, I was going to vote
5 that the question be, does the Commission approve the
6 hydrogen control system being installed by TVA as an
7 adequate hydrogen control system for their plant.

8 COMMISSIONER AHEARNE: With no licensing
9 conditions.

10 COMMISSIONER AHEARNE: We did not say if there
11 are license conditions.

12 COMMISSIONER AHEARNE: But if we vote that if
13 it is adequate, then that sounds like there is no
14 condition on it.

15 CHAIRMAN PALLADINO: I am just looking at what
16 the Commission said back in, what was it, 1980, that had
17 to be done by this time. They said, must confirm that
18 an adequate hydrogen control system for the plant is
19 installed and will perform a synthetic function in a
20 manner that provides adequate safety margins.

21 COMMISSIONER GILINSKY: But I think John was
22 asking where we stand on the igniters and the research
23 program.

24 COMMISSIONER AHEARNE: It is just that the
25 staff has propped two license conditions and I was not

1 sure whether Joe was saying, "Well, let's not --

2 CHAIRMAN PALLADINO: No, I was leaving it to
3 the staff whether to add four or six. But if that
4 sharpens the issue, I am quite happy to add that license
5 condition.

6 Now, I think there were the ones --

7 COMMISSIONER GILINSKY: Whether there are four
8 igniters in the research program.

9 CHAIRMAN PALLADINO: Yes. I would say the
10 possible license conditions are four additional igniter
11 units shall be installed in their Sequoyah Unit 1 upper
12 containment compartment, in locations acceptable to the
13 NRC staff for startup following the second -- and then
14 the next one being, additional tests shall be performed
15 on the Tayco igniters to demonstrate that the Tayco
16 igniters initiate combustion in a spray environment such
17 as that expected in the upper compartment of the ice
18 condenser containment.

19 I hate to make a date, however, a part of our
20 conditions. I would leave that to be worked out with
21 the staff.

22 COMMISSIONER AHEARNE: Yes, the date, I think,
23 had better we worked out.

24 CHAIRMAN PALLADINO: Yes, the date could be
25 worked out.

1 So, now I propose we vote on, does the
2 Commission approve the hydrogen control system being
3 installed by TVA on Sequoyah Unit 1 as adequate for that
4 plant, with the conditions outlined on one slide, with
5 the modification I indicated.

6 All those in favor indicate by saying aye.

7 COMMISSIONER GILINSKY: I want to make a
8 comment on that.

9 CHAIRMAN PALLADINO: Go ahead.

10 COMMISSIONER GILINSKY: I am inclined to adopt
11 the proposition with the more severe conditions on TVA.
12 At the same time I want to say that I think we would
13 never have gotten to this place if TVA had not exercised
14 leadership on this problem. They could have taken the
15 easy way out and just said there is no problem.

16 They did not do that and confronted the thing
17 head-on. I think Dave Freeman had a great deal to do
18 with that. He was Chairman at the time. I think we
19 would not be here today if TVA had not taken that
20 approach.

21 So, I vote to all that condition, but at the
22 same time I do want to express that view about the way
23 TVA has approached this problem.

24 COMMISSIONER AHEARNE: I would agree with
25 Vic's comments., I like Dave Freeman a great deal. I

1 do not know whether he is the key, but he could well
2 be. I would certainly agree that TVA has done a great
3 job and I accept that condition.

4 CHAIRMAN PALLADINO: Tom?

5 COMMISSIONER ROBERTS: I am not persuaded that
6 on-going research is necessary.

7 CHAIRMAN PALLADINO: So, you take exception
8 with the research that is suggested here. You accept
9 the research?

10 COMMISSIONER AHEARNE: Yes.

11 CHAIRMAN PALLADINO: You accept the research.

12 COMMISSIONER GILINSKY: Yes.

13 CHAIRMAN PALLADINO: I accept the research.

14 So, I accept the conditions set forth here.

15 Let me make sure now, we still have three
16 people voting for approving this system for Sequoyah
17 Unit 1 with the conditions set forth by the staff with
18 the words, "initiate combustion" in place of "maintain
19 adequate surface temperature" when talking about the
20 additional tests.

21 COMMISSIONER AHEARNE: As I understand it,
22 Tom, you accept the system.

23 COMMISSIONER ROBERTS: Yes.

24 CHAIRMAN PALLADINO: So, as far as accepting
25 the system, the four of us vote on the same side. So

1 far as the conditions are concerned, you do not feel
2 that the research program is necessary.

3 COMMISSIONER ROBERTS: I don't say it is
4 unnecessary.

5 CHAIRMAN PALLADINO: All right, that concludes
6 our business on this subject now. Any questions by the
7 staff?

8 MR. DENTON: No.

9 CHAIRMAN PALLADINO: All right, thank you very
10 much.

11 (Whereupon, at 12:15 p.m. the meeting of the
12 Commission was adjourned.)

13

14

15

16

17

18

19

20

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

COMMISSION MEETING

in the matter of: PUBLIC MEETING - Discussion and Possible Vote on
- Sequoyah Hydrogen Control

Date of Proceeding: December 15, 1982

Docket Number: _____

Place of Proceeding: Washington, D C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

M. E. Hansen

Official Reporter (Typed)

M. E. Hansen

Official Reporter (Signature)

BRIEFING OUTLINE

- I. CHRONOLOGY
- II. REVIEW OF PERMANENT HYDROGEN
MITIGATION SYSTEM
- III. OPEN ISSUES
- IV. CONFIRMATORY ITEMS
- V. LICENSE CONDITIONS

CHRONOLOGY

SER ISSUED

MARCH 1979

LOW POWER LICENSE ISSUED

FEBRUARY 29, 1980

FULL POWER LICENSE ISSUED

SEPTEMBER 17, 1980

TVA EXECUTIVE SUMMARY

REPORT ISSUED

SEPTEMBER 27, 1982

SSER #6 ISSUED

DECEMBER 1982

ORIGINAL LICENSE CONDITION

HYDROGEN CONTROL MEASURES (SECTION 22.2, II.B.7)

- (1) BY JANUARY 31, 1981, TVA SHALL BY TESTING AND ANALYSIS SHOW TO THE SATISFACTION OF THE NRC STAFF THAT AN INTERIM HYDROGEN CONTROL SYSTEM WILL PROVIDE WITH REASONABLE ASSURANCE PROTECTION AGAINST BREACH OF CONTAINMENT IN THE EVENT THAT A SUBSTANTIAL QUANTITY OF HYDROGEN IS GENERATED.
- (2) FOR OPERATION OF THE FACILITY BEYOND JANUARY 31, 1982, THE COMMISSION MUST CONFIRM THAT AN ADEQUATE HYDROGEN CONTROL SYSTEM FOR THE PLANT IS INSTALLED AND WILL PERFORM ITS INTENDED FUNCTION IN A MANNER THAT PROVIDES ADEQUATE SAFETY MARGINS.
- (3) DURING THE INTERIM PERIOD OF OPERATION, TVA SHALL CONTINUE A RESEARCH PROGRAM ON HYDROGEN CONTROL MEASURES AND THE EFFECTS OF HYDROGEN BURNS ON SAFETY FUNCTIONS AND SHALL SUBMIT TO THE NRC QUARTERLY REPORTS ON THAT RESEARCH PROGRAM.

CURRENT LICENSE CONDITION

HYDROGEN CONTROL MEASURES (SECTION 22.2.11.B.7)

- (1) PRIOR TO STARTUP FOLLOWING THE FIRST REFUELING OUTAGE, THE COMMISSION MUST CONFIRM THAT AN ADEQUATE HYDROGEN CONTROL SYSTEM FOR THE PLANT IS INSTALLED AND WILL PERFORM ITS INTENDED FUNCTION IN A MANNER THAT PROVIDES ADEQUATE SAFETY MARGINS.
- (2) DURING THE INTERIM PERIOD OF OPERATION, TVA SHALL CONTINUE A RESEARCH PROGRAM ON HYDROGEN CONTROL MEASURES AND THE EFFECTS OF HYDROGEN BURNS ON SAFETY FUNCTIONS AND SHALL SUBMIT TO THE NRC QUARTERLY REPORTS ON THAT RESEARCH PROGRAM.
 - (A) TVA SHALL AMEND ITS RESEARCH PROGRAM ON HYDROGEN CONTROL MEASURES TO INCLUDE, BUT NOT BE LIMITED TO, THE FOLLOWING ITEMS:
 - 1) IMPROVED CALCULATIONAL METHODS FOR CONTAINMENT TEMPERATURE AND ICE CONDENSER RESPONSE TO HYDROGEN COMBUSTION.
 - 2) RESEARCH TO ADDRESS THE POTENTIAL FOR LOCAL DETONATION.
 - 3) CONFIRMATORY TESTS ON SELECTED EQUIPMENT EXPOSED TO HYDROGEN BURNS.
 - 4) NEW CALCULATIONS TO PREDICT DIFFERENCES BETWEEN EXPECTED EQUIPMENT TEMPERATURE ENVIRONMENTS AND CONTAINMENT TEMPERATURES.

5) EVALUATE AND RESOLVE ANY ANOMALOUS RESULTS OCCURRING DURING THE COURSE OF ITS ONGOING TEST PROGRAM.

(B) A SCHEDULE FOR CONFIRMATORY TESTS SHALL BE PROVIDED BY TVA CONSISTENT WITH THE REQUIREMENT TO MEET SECTION (22)D.(2) OF THE LICENSE.

PERMANENT HYDROGEN MITIGATION
SYSTEM

PRINCIPAL REVIEW AREAS

- o PHMS DESIGN
- o HYDROGEN CONTROL RESEARCH
 - COMBUSTION
 - MIXING
 - DETONATIONS
- o DEGRADED CORE ACCIDENTS & HYDROGEN GENERATION
- o CONTAINMENT HYDROGEN ANALYSIS
- o SEQUOYAH STRUCTURAL CAPACITY
- o ESSENTIAL EQUIPMENT SURVIVABILITY

OPEN ISSUES

- o PERFORMANCE OF TAYCO IGNITERS IN
CONTAINMENT UPPER COMPARTMENT
- o NUMBER AND LOCATION OF IGNITERS IN
UPPER COMPARTMENT

CONFIRMATORY ITEMS

ANALYTICAL

LOCAL DETONATIONS

CLASIX/COMPARE CODE WORK

EXPERIMENTAL

EQUIPMENT SURVIVABILITY

COMBUSTION EFFECTS AT LARGE SCALE

COMBUSTION PHENOMENA

PROPOSED LICENSE CONDITIONS

FOR UNIT 1

FOUR (4) ADDITIONAL IGNITER UNITS SHALL BE INSTALLED IN THE SEQUOYAH UNIT 1 CONTAINMENT UPPER CONTAINMENT COMPARTMENT IN LOCATIONS ACCEPTABLE TO THE NRC STAFF PRIOR TO STARTUP FOLLOWING THE SECOND REFUELING OUTAGE.

ADDITIONAL TESTS SHALL BE PERFORMED ON THE TAYCO IGNITER TO DEMONSTRATE THAT THE IGNITERS WILL MAINTAIN AN ADEQUATE SURFACE TEMPERATURE IN A SPRAY ENVIRONMENT SUCH AS THAT EXPECTED IN THE UPPER COMPARTMENT OF THE ICE CONDENSER CONTAINMENT. THESE TESTS SHALL BE COMPLETED BY SEPTEMBER 1983.

IMPORTANT FINDINGS OF
UTILITY RESEARCH PROGRAM

- o CONFIRMATION OF RELIABLE IGNITION OF LEAN H₂ - AIR - STEAM MIXTURES
- o TURBULENCE PROMOTES EFFICIENT COMBUSTION AT LOW H₂ CONCENTRATIONS (6%)
- o NO DETONATIONS OR UNEXPECTED PRESSURE EFFECTS OBSERVED
- o POST-ACCIDENT CONTAINMENT ATMOSPHERE WELL-MIXED
- o ANALYSIS DEMONSTRATES ADEQUACY OF PHMS FOR THE CONTROL OF H₂, WITH MARGINS:
- o PEAK ATMOSPHERE BURN PRESSURE BELOW SEQUOYAH PRESSURE CAPACITY FOR SPECTRUM OF DEGRADED CORE ACCIDENTS
- o EQUIPMENT TEMPERATURE RESPONSE WELL BELOW EQUIPMENT QUALIFICATION TEMPERATURE OR TESTED TEMPERATURE

DEGRADED CORE ACCIDENT SCENARIOS


		PEAK HYDROGEN RELEASE RATE (LB/MIN)	PEAK CONTAINMENT PRESSURE (PSIG)
S ₂ D	- SMALL BREAK LOCA, LOSS OF ECCS	65	18.7 (LC)
SENSITIVITY CASE 1	- 3 X S ₂ D HYDROGEN RELEASE RATE	192	19.1 (LC)
SENSITIVITY CASE 2	- 3 X S ₂ D HYDROGEN RELEASE RATE WITH 6 LB/SEC SPIKE	360	18.8 (UC)
S ₁ D	- INTERMEDIATE BREAK LOCA, LOSS OF ECCS	78	--
S ₂ G	- SMALL BREAK LOCA, LOSS OF CONTAINMENT HEAT REMOVAL	0*	--
T _B B ₂	- LOSS OF MAIN FEEDWATER AND ALL AC	3.6	--
T _B LD	- LOSS OF MAIN FEEDWATER, AUX. FEEDWATER, AND ECCS	2.9	--

* OVER 120,000 SEC PERIOD

LOWER COMPARTMENT PRESSURE

RESPONSE --- BASE CASE SEQUOYAH

DESIGN PRESSURE: 12 PSIG/27 PSIA
PRESSURE CAPACITY: 36 PSIG/51 PSIA
BURN PRESSURE: 19 PSIG/33 PSIA



SEQUOYAH CONTAINMENT MARGINS WITH THE PHMS






TABLE 22.4 COMPARISON OF ANALYTICALLY CALCULATED THERMAL RESPONSES
DURING HYDROGEN BURN AND QUALIFICATION TEMPERATURES

COMPONENT	MAXIMUM TEMP., °F (CALCULATED),	DESIGN/TEST TEMP., °F
IGNITER (USED IN IDIS)		
INTERIOR BOX AIR	227	428 (TRANSFORMER)
CABLE	171	
TRANSFORMER CORE	157	
BARTON TRANSMITTER		
INTERIOR AIR	231	310
CASE SURFACE	245	
CABLE IN CONDUIT (USED IN IDIS)		
COPPER	251	TESTED TO 700
INSULATION	260	
CONDUIT SURFACE	332	
THERMOCOUPLE CABLE INSULATION		
		1126
RTD CABLE INSULATION		
		1013

IGNITER LOCATIONS IN CONTAINMENT



LOCATION OF ADDITIONAL IGNITERS



⊗ - PHMS IGNITERS
× - ADDITIONAL IGNITERS

ACRS LETTER ON SEQUOYAH
(DATED DECEMBER 13, 1982)

- o CONCLUDES: PHMS PROVIDES ADEQUATE SAFETY MARGINS
- o ACRS IS NOT FULLY PERSUADED THAT ADDITIONAL STAFF REQUIREMENTS ARE WARRANTED
 - o 4 MORE IGNITERS IN UPPER COMPARTMENT
 - o IGNITION TESTING WITH SPRAYS
- o ACRS RECOMMENDS MORE CONSIDERATION BE GIVEN TO IGNITER POWER SUPPLY DURING TOTAL LOSS OF A.C. POWER

TAYCO IGNITER TESTING

OBJECTIVE: CONFIRM THAT TAYCO IGNITERS RELIABLY IGNITE
LEAN H_2 - AIR - STEAM MIXTURES IN THE SPRAY
ENVIRONMENT OF THE SEQUOYAH UPPER COMPARTMENT

ELEMENTS:

- o TEST ENVIRONMENT WITH SPRAY DROPLET DENSITY EQUIVALENT
TO UPPER COMPARTMENT
- o DROPLETS AT TERMINAL VELOCITY
- o SUFFICIENTLY UNIFORM DROPLET MIXTURE
- o LEAN H_2 CONCENTRATIONS (APPROXIMATELY 5-7%)



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DEC 8 1982

MEMORANDUM FOR: Chairman Palladino
Commissioner Gilinsky
Commissioner Ahearne
Commissioner Roberts
Commissioner Asselstine

FROM: William J. Dircks
Executive Director for Operations

SUBJECT: SEQUOYAH SER SUPPLEMENT ON HYDROGEN MITIGATION SYSTEM

Enclosed are copies of the proposed Supplement to the Sequoyah Safety Evaluation Report which updates the staff's evaluation of issues related to the hydrogen mitigation system for Units 1 and 2. Subject to the satisfactory resolution of two issues dealing with the TAYCO igniter surface temperature and the number of units in the upper compartment, we conclude that the license condition on hydrogen control is satisfactorily resolved.

The system, designated by TVA as their permanent hydrogen mitigation system, is being installed in Unit 1 and is to be installed in Unit 2 during the first refueling outage of that unit. Briefing slides are included for a forthcoming meeting on this subject matter.

Also, copies of the TVA Executive Summary Report are enclosed which sets forth the basis for TVA concluding that the system will perform its interded function in a manner that provides adequate safety margin.

(Signed) William J. Dircks

William J. Dircks
Executive Director for Operations

cc w/enc1
SECK
PE
GC

Safety Evaluation Report

related to the operation of
Sequoyah Nuclear Plant,
Units 1 and 2

Docket Nos. 50-327 and 50-328

Tennessee Valley Authority

**U.S. Nuclear Regulatory
Commission**

Office of Nuclear Reactor Regulation

November 1982



ABSTRACT

Supplement No. 6 to the Safety Evaluation Report related to the operation of the Tennessee Valley Authority's Sequoyah Nuclear Plant, Units 1 and 2, located in Hamilton County, Tennessee, has been prepared by the Office of Nuclear Reactor Regulation of the U. S. Nuclear Regulatory Commission. The purpose of this supplement is to update the staff's evaluations of the issues related to the hydrogen mitigation system identified in the SER and previous supplements as needing resolution.

TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT.....	iii
1 INTRODUCTION.....	1-1
22 TMI REQUIREMENTS.....	22-1
II.B.7 Analysis of Hydrogen Control.....	22-1
1 Background.....	22-1
2 System Description.....	22-2
3 Combustion/Igniter Testing.....	22-6
3.1 The Whiteshell Test Program.....	22-7
3.2 The Factory Mutual/Acurex Test Program.....	22-10
3.3 Tayco Igniter Testing.....	22-12
3.4 Staff Conclusions Regarding Testing.....	22-14
4 Hydrogen Mixing and Distribution.....	22-15
5 Detonations.....	22-17
6 Degraded Core Accidents and Hydrogen Generation.....	22-20
7 Sequoyah Containment Structural Capacity.....	22-22
8 Containment Analysis.....	22-24
8.1 Containment Codes.....	22-24
8.2 Containment Pressure and Temperature Calculations.....	22-29
8.3 Confirmatory Analysis and Conclusion.....	22-35
9 Survivability of Essential Equipment.....	22-37
9.1 Essential Equipment.....	22-37
9.2 Thermal Environment Response Analysis.....	22-39
9.3 Pressure Effects.....	22-45
9.4 Staff Conclusions Regarding Equipment Survivability...	22-45
10 Overall Conclusions.....	22-46
APPENDIX A CONTINUATION OF CHRONOLOGY OF NRC STAFF RADIOLOGICAL SAFETY REVIEW OF SEQUOYAH STATION	
APPENDIX B BIBLIOGRAPHY	

LIST OF TABLES

22.1 Internal static pressure capacity for hydrogen burning, psig.....	22-23
22.2 Containment sensitivity studies.....	22-32
22.3 Essential equipment.....	22-38
22.4 Comparison of analytically calculated thermal responses during hydrogen burn with qualification temperatures.....	22-43

1 INTRODUCTION

The purpose of this Supplement 6 to the Sequoyah Safety Evaluation Report (SER) is to update the staff's evaluation of the issues related to the hydrogen mitigation system that is being installed in Unit 1 and is to be installed in Unit 2 during the first refueling outage of that unit. Except where noted, the material herein supplements the information that has been reported previously. The following sections of this supplement are numbered to correspond to those in the SER and earlier supplements.

This supplement provides the basis for the staff's concluding that sufficient information is available to permit the installation and operation of a modified hydrogen mitigation system for Sequoyah Unit 1.

22 TMI-2 REQUIREMENTS

II.B.7 Analysis of Hydrogen Control

1 Background

The staff's licensing requirements relative to the provisions for hydrogen control beyond those prescribed in 10 CFR 50.44 have evolved from numerous deliberations among the Nuclear Regulatory Commission (Commission), the Advisory Committee on Reactor Safeguards (ACRS), the NRC staff, and applicants and licensees. In summary, the Commission's requirement for ice condenser containments is that a supplemental hydrogen control system be provided so that the consequences of the hydrogen release generated during the more probable degraded core accident sequences do not involve a breach of containment nor adversely affect the functioning of essential equipment.

In Supplements 4 and 5 to the Sequoyah SER (NUREG-0011), the staff concluded that the interim distributed ignition system (IDIS) installed at Sequoyah Units 1 and 2 is acceptable as an interim hydrogen control measure for degraded core accidents. However, the staff recommended that the detailed review of the distributed ignition system continue, so that a number of issues related to degraded core hydrogen control could be more thoroughly investigated before it endorsed a long-term commitment to deliberate ignition. These issues included items related to combustion phenomena as well as further consideration of a spectrum of degraded core accident sequences.

Based on these recommendations, the operating licenses of Sequoyah Units 1 and 2 were conditioned to require that the licensee, the Tennessee Valley Authority (TVA), continue research programs on hydrogen control measures and the effects of hydrogen-burn safety functions during the interim period of operation. The research program was to include: (1) improvement of calculational methods for containment temperature and ice condenser response to hydrogen combustion, (2) research to address the potential for local detonation, (3) confirmatory tests

on selected equipment exposed to hydrogen burns, (4) new calculations to predict differences between expected equipment temperature environments and containment temperatures, and (5) evaluation and resolution of any anomalous results occurring during the course of the test program. The license condition required that TVA, by the end of the first refueling outage, provide the bases for a Commission determination that an adequate hydrogen control system for the plants is installed and will perform its intended function in a manner that provides adequate safety margins.

As part of its research activities, TVA in cooperation with Duke Power and American Electric Power (AEP) continued to investigate alternative measures of hydrogen control. As a result of continued studies, TVA has concluded that a deliberate ignition system, similar to the IDIS, provides adequate safety margins in controlling the consequences of degraded core accidents. The new system, designated the permanent hydrogen mitigation system (PHMS), is to be installed in Sequoyah Unit 1. The PHMS is identical in concept to the interim system but provides system design improvements. A detailed discussion of the PHMS is provided below.

The approach taken by TVA for establishing that the PHMS provides adequate safety margins relies on analytical modeling of the containment and equipment response to the degraded-core event. Because the models involve simplifying assumptions and input parameters describing such complex phenomena as containment mixing, flame speeds, and equipment heatup, the utility research program serves to verify key assumptions in the analyses.

2 System Description

The PHMS is a system of igniters and ancillary equipment TVA has installed within the containment of Sequoyah Units 1 and 2. The igniters are designed to ensure a controlled burning of hydrogen in the unlikely event that excessive quantities of hydrogen, well beyond the design bases required by 10 CFR 50.44, are generated as a result of a postulated degraded core accident. The PHMS is designed to promote the combustion of hydrogen in a manner such that containment integrity is maintained.

TVA has selected and tested a 120-V ac hermetically sealed thermal igniter manufactured by Tayco Engineering as the igniter to be installed in the PHMS. The heating element is formed into a cylindrical coil approximately 1.75-in. long and 0.75-in. in diameter. Power is supplied directly to the igniter at 120 V ac. The igniter is mounted in a National Electrical Manufacturers Association (NEMA) Type 4 enclosure with the heating element protruding. This enclosure is designed to remain watertight under various environmental conditions, including exposure to water jets. A spray shield is provided above the igniter to protect it from a direct spray.

The igniters in the PHMS are equally divided into two redundant groups, with 16 separate circuits per group, each with an independent circuit breaker and two igniters per circuit. Each group has independent and separate control, power, and igniter locations that ensure adequate coverage even in the event of a single failure. Manual actuation capability for each group is provided in the main control room (one switch per group), along with the status (on-off) of each group.

The igniters are powered from Class 1E power panels that have normal and alternate power supply from offsite sources. In the event of a loss of offsite power, the igniters would be powered from the emergency diesel generators. Group A igniters receive power from the train A diesels, and group B igniters from the train B diesels. In addition, the igniters will be seismically supported.

The permanent hydrogen mitigation system installed in Sequoyah Units 1 and 2 consists of 64 igniter assemblies distributed throughout the upper, lower, and ice condenser compartments. Following a degraded core accident, any hydrogen that is produced would be released into the lower compartment. To cover this region, 22 igniters (equally divided between trains) will be provided. Eight of these will be distributed on the reactor cavity wall exterior and crane wall interior at an intermediate elevation. Two igniters will be located at the lower edge of each of the five steam generator and pressurizer enclosures, two in the top of the pressurizer enclosure, and another pair above the reactor vessel in the cavity.

Any hydrogen not burned in the lower compartment would be carried up through the ice condenser and into its upper plenum. Because steam would be removed from the mixture as it passes through the ice bed, thus concentrating the hydrogen, mixtures that were nonflammable in the lower compartment would tend to become flammable in the ice condenser upper plenum. This phenomenon is supported by the CLASIX containment analysis code, discussed later in this SSER, which predicts that more sequential burns will occur in the upper plenum than in any other region. Controlled burning in the upper plenum is preferable because upper plenum burns involve smaller quantities of hydrogen and allow for the expansion of the hot gases into the upper compartment, thereby reducing the peak pressure.

TVA has chosen to take advantage of the beneficial characteristics of combustion in the upper plenum by distributing 16 igniters around it. The igniters are located on the containment shell side of the upper plenum at 16 equally spaced azimuthal locations. To handle any accumulation of hydrogen in the upper compartment, four igniters will be located in the upper compartment dome. Additional igniters are located at lower elevations in the upper compartment to take advantage of upward flame propagation at lower hydrogen concentrations; specifically, four igniters are located near the top inside of the crane wall, and one is located above each of the two air return fans. The air return fans provide recirculation flow from the upper compartment through the dead-ended volume and back into the lower compartment. To cover the deadended region, there will be a pair of igniters in each of the eight rooms through which the recirculation flow passes.

The staff has reviewed the number and locations of igniters provided in the PHMS and finds the system layout acceptable. The staff notes, however, that the PHMS would be improved by locating the upper plenum igniters alternately between the containment shell side and the crane wall side of the upper plenum in a staggered fashion, and locating additional igniters at lower elevations in the upper compartment. Installation of upper plenum igniters in a staggered arrangement will further reduce the likelihood of flammable mixtures bypassing the igniters, while additional upper compartment igniters would provide added assurance that any burning in the upper compartment will occur as discrete

burns at low hydrogen concentrations characterized by upward flame propagation, rather than as a global burn. TVA is unable to relocate upper plenum igniters or add more upper compartment igniters during this refueling of the Sequoyah Unit 1. The staff may require TVA to relocate the upper plenum igniters in a staggered arrangement before restart following the next refueling for Sequoyah Unit 1 depending on the outcome of certain confirmatory testing as detailed in Section 10. The staff considers the present igniter locations to be acceptable for operation during the next cycle. However, installation of additional igniters in the upper compartment will provide greater margin of safety from events that could result in releases of hydrogen to the upper compartment. TVA has indicated a willingness to install four additional igniters in the upper compartment. The adequacy of the number and locations of the upper compartment igniters will be confirmed on the basis of certain large-scale confirmatory tests to be conducted at the Nevada Test Site in early 1983 as part of a joint Electric Power Research Institute (EPRI)/NRC hydrogen research program. These tests will include dynamic simulations of degraded core accidents at a scale comparable to the actual containment building, and will serve to identify scale effects on combustion phenomena. Upon completion of those tests, the staff will provide recommendations regarding the adequacy of the upper compartment igniter coverage and any required design enhancements.

With respect to operating procedures, the TVA emergency operating instructions direct the operator to actuate the PHMS following any reactor trip or safety injection initiation. These directions are included in the immediate actions of the diagnostic procedure used following reactor trip or safety injection, and actuation of the PHMS is verified in the procedure for responding to a loss-of-coolant accident (LOCA). Thus, the operator will have sufficient time to actuate the PHMS manually for any event in which it would be required. As recommended in SSER 5, the air handling units used for normal refrigeration in the ice condenser will be tripped for both units for accidents in which the PHMS is actuated. The procedures call for PHMS to remain actuated until the unit reaches safe cold shutdown and any threats as a result of hydrogen release are eliminated. The staff concludes that these procedural instructions are adequate for actuation and termination of the PHMS. In addition, the emergency operating instructions will be upgraded in response to TMI Action Plan Item I.C.1 and Commission Action on SECY-82-111. The upgraded instructions

will address operation of hydrogen mitigation systems based on inadequate core cooling symptoms and containment pressure and hydrogen concentrations. The Tayco igniters have been subjected to endurance testing for a period of approximately 2 weeks.

To ensure that the PHMS will function as intended, TVA has proposed a preoperational and surveillance testing program similar to that performed for the IDIS. Preoperational testing, to be performed before restart after refueling, will verify that the current drawn by each group of igniters is within tolerance, and that the temperature of the igniter is at least 1700°F. During the preoperational tests the current in each circuit will be measured and the results used as the baseline for future surveillance tests. The igniter system will be subjected to periodic surveillance testing; this testing will consist of energizing the PHMS in the main control room and taking current readings of the circuits. If the current readings do not compare favorably with current measurements taken during preoperational testing, all igniters will be individually inspected to ensure their operability. The staff will also require that igniter temperatures be measured at specified intervals.

The operability of at least 31 of the 32 igniters per train will maintain an effective coverage throughout the containment, if there are no inoperable igniters on corresponding redundant circuits that provide coverage for the same region. The two trains of igniters should be operable during operational modes 1 and 2.

3 Combustion/Igniter Testing

In support of the IDIS, TVA, Duke Power, and AEP conducted two testing programs to obtain information pertinent to the performance characteristics of the glow plug igniters. Preliminary screening and qualification testing was performed at TVA's Singleton Laboratory. Combustion tests using the glow plugs were performed by Fenwal, Inc. to study igniter performance under various environmental conditions (Cross, 1980; Mills, 1981). Based on the results of these programs, the staff concluded in Sequoyah SSER 4 that the glow plug igniter would perform its intended function under various conditions.

During the past 2 years, to evaluate further the efficacy of ignition systems and to investigate possible enhancements to proposed deliberate ignition systems, the ice condenser utility owners and the Electric Power Research Institute (EPRI) have sponsored several test programs. This work is summarized in the TVA Executive Summary Report dated September 27, 1982. Basic combustion and igniter studies were conducted in a test program conducted at the Whiteshell Nuclear Research Establishment to evaluate the glow plug and Tayco igniters, along with testing to investigate the following items: lean mixture combustion, rich mixture deflagrations, fan- and obstacle-induced turbulence, and the effects of a compartmentalized geometry. To determine if a water spray/fog consisting of smaller water droplets than conventional containment spray systems would improve the overall performance of deliberate ignition systems, the utilities sponsored testing with the Factory Mutual Corporation and Acurex Corporation. Factory Mutual investigated, in a small-scale facility, the pressure suppression effects of a small droplet spray/fog. Acurex addressed the same phenomenon, as well as the effects of igniter location, in a larger scale vessel.

3.1 The Whiteshell Test Program

The experimental program carried out at Whiteshell consisted of small-scale igniter testing and large-scale combustion testing (Mills, 1982a, b, c; Kammer, 1982).

Small-scale tests were performed in a 17-liter vessel to investigate the effect of igniter surface temperature and type on the lower flammability limits of lean hydrogen-air-steam mixtures. The small-scale test program consisted of three phases. Data on the lower flammability limit were obtained in Phases 1 and 2 using a GMAC-7G glow plug operating at 14 and 12 V, respectively. In Phase 3 tests were repeated using the Tayco igniter. Hydrogen concentrations were varied between 4 and 15%, and steam concentrations varied between 0 and 60% in all three phases.

Evaluation of the experimental data indicates that for quiescent mixtures, ignition occurs below hydrogen concentrations of 8.0% for steam concentrations

of up to 30%. Consistent with other test data for steam concentrations above 30%, the flammability limit was shifted upward to higher hydrogen concentrations. The igniter consistently initiated combustion of mixtures with steam concentrations up to approximately 60%. Experimental results showed reliable ignition of turbulent mixtures with hydrogen concentrations of 5%, even for steam concentrations up to 40%.

The surface temperature of the igniter at the time of ignition was measured for each test. For dry mixtures, the Tayco igniter surface temperature at ignition was approximately 1200°F. Test data show that the igniter surface temperature at the time of ignition increases with steam concentration. This is consistent with the trend observed for GM glow plug igniters.

The large-scale tests were performed at Whiteshell using a 7.5-ft diameter sphere. The purpose of the tests was to investigate four different items: lean mixture combustion, rich mixture deflagrations, fan- and obstacle-induced turbulence, and compartmentalized geometry effects. Spark ignition was used in these tests.

In Phase 1 of the program, lean mixture tests were performed in the sphere to investigate the combustion phenomena under various conditions of steam and fan-induced turbulence. Hydrogen concentrations were varied from approximately 5 to 10 volume percent, and steam from 0 to 30%. Fans were activated in several of the tests.

Test results for quiescent mixtures with bottom ignition indicate that combustion was initiated at a 5 volume percent hydrogen concentration. Only about 20% of the hydrogen was burned at this concentration. For an 8% hydrogen concentration, virtually complete combustion was observed. These results are in general agreement with previously published data on the flammability of lean mixtures. Tests with steam present show that the addition of 15% steam does not have a significant effect on the completeness of burn.

Results obtained with fans activated confirm that turbulence enhances the rate and completeness of combustion. An increase in peak pressure to the

corresponding adiabatic value was also observed. These findings corroborate the results of tests at Fenwal (Cross, 1980; Mills, 1981), Lawrence Livermore National Laboratory (LLNL) (NUREG/CR-2486), and Sandia National Laboratory (Roller and Falacy, 1982), but more importantly they indicate that turbulent plant conditions will promote burning at relatively lean concentrations.

During Phase 2 of the Whiteshell program, a series of rich mixture deflagration tests was performed to supplement existing knowledge of combustion of hydrogen-steam-air mixtures at high hydrogen concentrations and to confirm that detonations would not result. For these tests, hydrogen concentrations were varied from 10 to 42 volume percent, and steam from 0 to 40 volume percent. Fans were activated in several tests.

Complete combustion was achieved in nearly all tests, including those with a quiescent mixture of 10% hydrogen and 40% steam. For both dry mixtures and mixtures with steam present, the measured pressure was always less than the theoretical adiabatic pressure. This same result was observed in Sandia combustion tests conducted as part of the NRC research program. Furthermore, no detonations were observed even at stoichiometric and higher concentrations of hydrogen which are classically considered to be detonable. The absence of detonations is attributed to the fact that the energy release rate of the igniter is significantly less than that required to initiate a detonation.

In Phase 3 of the Whiteshell test program, the effects of turbulence induced by fans and gratings on the extent and rate of combustion were investigated. Hydrogen concentrations ranged from 6 to 27 volume percent in these tests. Results show that for rich mixtures, forced turbulence increases the rate of pressure rise but does not increase the peak pressure. With regard to the effect of gratings, the test results indicated that in lean mixtures without fans, the presence of gratings tended to increase the magnitude and rate of pressure rise. At high concentrations or with fans, the gratings reduced both the magnitude and rate of pressure rise by acting as heat sinks. In summary, the Phase 3 results indicate that no unanticipated pressure effects result from forced turbulence, even at high concentrations of hydrogen.

In the fourth and final phase of the Whiteshell program, compartmentalized geometry effects were investigated. Two connected compartments were simulated by attaching a 20-ft long, 1-ft-diameter pipe to the 7.5-ft-diameter sphere. The effects of igniter location and unequal concentrations in each vessel were investigated for hydrogen concentrations ranging from 6 to 25 volume percent. Two igniter locations were used, one at the end of the pipe and the other at the center of the sphere. For all tests, no detonations occurred, and the observed peak pressures were less than the calculated adiabatic values. With regard to tests with unequal concentrations, no significant effects of propagating flames between two connected vessels were observed.

3.2 The Factory Mutual/Acurex Test Program

To determine whether a water spray consisting of droplets smaller than conventional spray systems would improve the overall performance of a deliberate ignition system, a two-part experimental program was carried out under the sponsorship of EPRI. The Factory Mutual Corporation (FM) project was the first of the two-part program (Mills, 1982a). The purpose of the FM project was to evaluate the effects of water fog density, droplet diameter, and temperature on the lower flammability limit of hydrogen-air-steam mixtures. The FM work also served to identify a set of nominal conditions for the intermediate-scale hydrogen combustion studies dealing with the pressure-suppressant effects of fog. The intermediate scale studies were conducted by the Acurex Corporation (ibid) and were the second part of the two-part program.

The FM tests were conducted in a plexiglass tube approximately 3.5-ft long and 6-in. in diameter. A 2.8-Joule spark served as the ignition source. Several tests were also conducted with a GMAC-7G glow plug as the ignition source to verify the applicability of these tests to the installed distributed ignition systems. Five different spray nozzles were used to obtain different fog conditions (i.e., different characteristic droplet sizes and densities). Mean droplet sizes from approximately 10 to 150 microns were investigated at fog concentrations up to 0.1 volume percent. Tests were conducted at water temperatures of 20°C (69.8°F), 50°C (122°F), and 70°C (158°F), and hydrogen concentrations ranging from approximately 4 to 12 volume percent.

Results of the FM tests confirmed the analytical prediction that increased fog densities are required to achieve a given level of fog inerting when the characteristic droplet size is increased. Test results showed that at ambient temperature, visually dense water fogs had only a marginal effect on the hydrogen lower flammability limit. At higher fog temperatures, somewhat larger increases in the flammability limit were observed. TVA reported favorable agreement between the FM experimental data and theoretical models used to describe the effect of fog on hydrogen combustion.

As a follow-on to the small-scale FM tests, the effects of fogs and sprays on the characteristics of deflagration were investigated in larger scale tests conducted by Acurex. A 630-ft³ vessel approximately 17 ft high and 7 ft in diameter was used for all tests. The tests were carried out in two phases.

All Phase 1 tests were dynamic tests with the glow plug preenergized. Tests were conducted with hydrogen injection, hydrogen/steam injection, and hydrogen/steam injection with water spray present. These tests investigated the effect of igniter location with igniter assemblies located near the top, at the center, or near the bottom of the test vessel. The results of the Phase 1 Acurex tests suggest that lowering the igniter location produces milder pressures during hydrogen combustion. This appears to be a result of increasing the fraction of the vessel volume exposed to upward propagating flames in lean hydrogen concentrations. For these dynamic tests, repeated burns were produced with pressure increases of 1 to 6 psi; for several tests without sprays, the pressure rises were higher, with a maximum increase of 28 psi. Because the Phase 1 tests were transient in nature, combustion parameters such as hydrogen concentration at ignition and completeness of burn were not conclusively determined.

During Phase 2 of the project, Acurex investigated the effects of a water fog on the pressure rise that accompanies a deflagration. Quiescent tests were conducted without water fog and with water fog at two different droplet sizes and concentrations. Dynamic tests were conducted with hydrogen injection and with hydrogen/steam injection. The igniter assembly was located near the bottom of the vessel for all tests.

For the transient tests conducted in Phase 2, the pressure increases from the repeated burns varied from 1 to 5 psi. The small pressure rises are attributed to ignition occurring at lower hydrogen concentrations. This conclusion is consistent with the Whiteshell findings that increased turbulence promotes ignition at lower hydrogen concentrations. Because the containment post-accident environment would resemble the transient test conditions, the pressure rises associated with hydrogen combustion in containment are expected to be relatively benign, as observed in the transient tests.

3.3 Tayco Igniter Testing

As discussed in previous supplements, the effectiveness and durability of the GM glow plug under endurance, cycling, and hydrogen combustion conditions has been demonstrated in testing conducted at Whiteshell and Singleton. To show that the Tayco model igniter is comparable to the GM glow plug, tests have been performed on the Tayco igniter at Whiteshell and Singleton.

Tests of the Tayco igniter conducted as Phase 3 of the small-scale igniter test program at Whiteshell show that the Tayco igniter was as effective at igniting lean mixtures as the GM glow plug. The results of the igniter surface temperature tests suggest that the Tayco igniter is capable of igniting mixtures at surface temperatures 125°F to 200°F less than the GM glow plug. This could be attributed to the helical geometry of the Tayco igniter, which may promote higher local gas temperatures within the coil.

Tests were conducted at Singleton to assess the durability of the Tayco igniters when they are subjected to endurance and cycling operations at minimum and maximum voltages and to hydrogen combustion. To summarize, four Tayco igniters were subjected to a series of five tests. These tests consisted of a 24-hour break-in at 120 V, continuous operation for 7 days at 120 and 135 V, and on/off cyclic operation at 120, 125, 130, and 135 V. Igniter surface temperature was monitored for the duration of the tests. The steady-state surface temperature remained above 1700°F through out the test series. The igniters were energized for a total of approximately 370 hours each. All Tayco igniters performed successfully during the tests except for one which failed

after 340 hours of operation. Operation for 340 hours is considered acceptable because it is in excess of the expected period for which igniter performance will be required.

Tests were also conducted in which the igniter was exposed to hydrogen combustion in flowing mixtures with entrance conditions ranging from 4 to 12 volume percent. The Tayco igniter initiated combustion and survived the burn environment in all cases.

At the staff's request, additional tests were conducted at TVA's Singleton Laboratory to ensure that the Tayco igniter would operate as intended in a spray environment such as that in the upper compartment. Tests were conducted using a single hollow cone spray nozzle of the same type used in Sequoyah and in the Fenwal spray tests for the glow plug igniter. The nozzle was oriented vertically downward and was located 3 ft directly above the igniter. The igniter was oriented horizontally and was mounted under a horizontal spray shield of the same configuration as those on the igniter assemblies to be installed in Sequoyah.

Igniter performance was assessed on the basis of measured surface temperatures for four different environmental conditions: natural and fan-induced circulation, with and without spray. In tests without sprays, the igniter surface temperature remained above 1700°F at all times. When the spray nozzle was activated, the igniter temperature dropped to 1650°F and 1600°F with the fan off and on, respectively.

Although the 1600°F surface temperature is above the maximum surface temperature required for ignition as determined by Whiteshell, the staff considered the drop in surface temperature significant, and requested that TVA provide additional assurance that the Singleton test conditions were representative of those expected in the plant. Further TVA analysis of the Singleton test data showed that the spray density through the horizontal plane at the igniter elevation was approximately equivalent to that which would be provided by operation of one of the two spray trains in the Sequoyah plant. Moreover, because the majority of the spray flow with the hollow cone nozzle is concentrated at the periphery of the cone, the spray density directly below the

test nozzle (i.e., at the location of the igniter assembly), would be even less than expected in Sequoyah with one spray train operating. Therefore, in the view of the staff, these Singleton spray tests did not adequately represent the containment spray environment.

In response to a staff request, TVA has performed a number of subsequent tests using a solid cone spray nozzle. In one test the nozzle was located between the igniter and the fan such that the edge of the spray cone just intersected the edge of the igniter spray shield. The height of the nozzle was adjusted to provide a spray density at the horizontal plane of the igniter equivalent to operation of both spray trains in Sequoyah. With the fan energized, an igniter surface temperature of approximately 1500°F was measured. The staff notes that while this test represents containment spray conditions better than the previous spray tests, vertical droplet velocities in the test were higher than expected in containment and would tend to underestimate spray transport across the igniter in the horizontal direction, even with the fan on. Some impingement of spray droplets on the igniter is expected in containment due to the presence of convective currents with velocities on the order of the droplet terminal velocity.

The staff has indicated to TVA that additional spray tests are needed to confirm satisfactory operation of the Tayco igniter in a spray environment. These tests must ensure that the Tayco igniter will reliably initiate combustion in a spray environment similar to that expected in containment. Satisfactory igniter operation can be confirmed by verifying experimentally that the igniter will sustain a surface temperature sufficient to initiate combustion in lean mixtures, or by demonstrating by test that combustion will occur. The minimum surface temperature for reliably initiating combustion is considered by the staff to be 1500°F. The staff will require that such tests be completed to its satisfaction before it grants final approval of the Tayco igniter.

3.4 Staff Conclusions Regarding Testing

The staff has reviewed the combustion testing programs conducted as part of the TVA research effort and concludes that the results support the use of a distributed ignition system for post-accident hydrogen control. Specifically, the

results of tests conducted at Whiteshell show that thermal igniters will reliably initiate combustion for a wide range of hydrogen-steam-air mixtures. Tests conducted at higher hydrogen concentrations illustrate the difficulty in initiating detonations, even at stoichiometric and higher concentrations.

Also, the observed effects of steam, induced turbulence, connected geometries, and unequal concentrations on the nature of hydrogen combustion confirm the staff's previous understanding. Tests conducted at Factory Mutual and Acurex provide additional information on the pressure-suppression and inerting effects of sprays and fogs. Similarly, none of the results obtained in these studies would support a negative finding relative to the use of deliberate ignition system. With regard to the Tayco igniter, a number of tests remain to be completed to provide further confirmation that the igniter will operate as intended in a spray environment. However, igniter tests conducted to date provide a basis for concluding that the GM and Tayco igniters are equivalent.

4 Hydrogen Mixing and Distribution

Analyses discussed in SSER 3 have indicated that hydrogen released during a postulated degraded core accident could be expected to be reasonably well mixed by the time it leaves the lower compartment. Adequate mixing, in conjunction with ignition of lean mixtures, would effectively preclude the formation of detonable concentrations. However, previous containment mixing analyses were cursory in nature, and did not attempt to characterize quantitatively hydrogen mixing and distribution within the ice condenser containment. A series of large-scale tests were, therefore, conducted by the Hanford Engineering Development Laboratory (HEDL) as part of the EPRI research program to provide additional assurance that large hydrogen concentration gradients will not occur (Mills, 1982a).

The mixing tests were conducted at HEDL's Containment Systems Test Facility (CSTF). This facility has a vessel that is 67 ft tall, with a diameter of 25 ft. Because the upper compartment of the ice condenser containment will be well mixed by the sprays, the lower compartment region was chosen for modeling emphasis in the facility. The interior of the CSTF was modified to represent a

divider deck, reactor cavity, refueling canal, the air return fans, and ice condenser lower inlet doors. For the purposes of these tests, geometric similarity was retained between the test compartment and the lower compartment of an ice condenser containment. Hydrogen and steam release rates used in tests were scaled to model the base case S₂D loss-of-coolant accident (LOCA)*. Helium was used to simulate hydrogen in most of the tests because of site safety considerations. Atmospheric temperatures, velocities, and gas concentrations were measured at several distributed points during the tests. The test matrix for the HEDL program was designed to characterize hydrogen distribution for two release scenarios: (1) a 2-in. pipe break with a horizontal orientation and (2) a 10-in. pressurizer-relief tank rupture disc opening with a vertically upward orientation. Two different release rates were investigated. The test program included tests with and without air return fans.

The results of the HEDL tests show that good mixing in the lower compartment can be expected if the air return fans remain operational throughout the accident. The air recirculation fans minimize both the peak helium concentration and the maximum helium concentration difference between points in the test compartment. In all cases with forced air recirculation, which included the two jet orientations and two different release rates, the maximum helium concentration difference between all points in the test compartment was less than 3 volume percent at all times and was generally on the order of 2%. These concentration differences had stopped increasing even before the release period was over and were less than 1 volume percent within 5 minutes after stopping the source gas.

The HEDL tests with no forced recirculation (air return fans inoperative) were inconclusive. During the helium-steam release for these tests, the maximum concentration difference between all measurement points in the test compartment was 2 volume percent. Following the helium-steam release, however, the test compartment developed a vacuum as the steam in the compartment condensed. This reverse migration coupled with the lack of a mixing mechanism from either the fans or the jet itself created a concentration difference of as much as 7

*A single degraded core accident designated as S₂D in WASH-1400 (NUREG-75/014); it is a small-break LOCA accompanied by the failure of emergency core cooling injection.

volume percent helium. Although the later portion of the test may in no way be prototypical of the plant, as TVA contends, neither does it support a conclusion that adequate mixing will occur without forced circulation by the air return fans. In assessing mixing in the latter portion of the test, however, it should be noted that for tests both with and without forced recirculation, the test compartment volume is well mixed with less than 1 volume percent concentration difference between points within 20 minutes after stopping the hydrogen-steam or helium-steam source.

Based on review of the HEDL results, the staff concludes that the formation of significant hydrogen concentration gradients in containment is unlikely if the air return fans survive the accident environment. The operation of the deliberate ignition system near the lower hydrogen flammability limit in conjunction with the mixing by the air return fans ensures that hydrogen concentrations at or below the flammability limit will be maintained throughout containment for the duration of the accident. In this regard, the formation of detonable pockets of hydrogen is precluded.

5 Detonations

The TVA position regarding detonation is that detonation is not a credible phenomenon in the containment because: (1) there would be no rich concentrations throughout the containment because the distributed igniters would initiate combustion as the mixture reached the lower flammability limit and because effective mixing would occur; (2) there are no high-energy sources to initiate a detonation; and (3) there are no areas of the containment with sufficient geometrical confinement to allow for the flame acceleration necessary to yield a transition to detonation.

The staff agrees with the TVA position. Because of the well-mixed atmosphere in containment, as confirmed by the HEDL mixing tests, the potential for localized accumulation of significant concentrations of hydrogen is unlikely. Even given that a high concentration might be formed locally, detonation of the cloud is extremely remote because this would require that the cloud encounter an ignition source of sufficiently high energy to initiate a detonation before

it passes through a region in which an igniter is located or before combustion is initiated. The staff concluded in SSER 5 that the energy level of the thermal igniter is not sufficient to initiate a detonation. This conclusion is supported by test data, including several of the tests recently conducted at Whiteshell and LLNL. Although these tests do not show conclusively that detonation or transition to detonation cannot occur, they do illustrate the difficulty involved in producing the phenomenon even using stoichiometric hydrogen-air mixtures such as those present in tests.

In the staff's view, the only scenario in which large concentrations of hydrogen might accumulate is one in which all igniters in a given region fail, along with the air return fan. TVA has provided redundant igniters on separate power trains in each region of the containment to preclude such an occurrence. The staff thus concludes that detonation of local pockets of hydrogen is extremely unlikely.

Another concern related to the detonation issue is that of flame acceleration. The phenomenon of flame acceleration as a possible mechanism for producing a detonation or large overpressures in containment was discussed in SSERs 4 and 5. The concern, expressed by Sandia National Laboratory, was that obstructions in the ice condenser region of the plant may serve to accelerate combustion to the point that a transition to detonation would occur. Utility consultants previously concluded and still contend that there are no areas in the containment that provide sufficient geometrical confinement to allow for the extreme flame acceleration necessary to result in a transition to detonation. For example, the vertical ice baskets in the ice condenser are not sufficiently confined radially and the circumferential upper plenum above the ice condenser is not sufficiently confined for transition to detonation to occur.

With regard to the ice condenser region of containment, the utility consultant's view was that, for an S₂D-type scenario, the upper plenum igniters would ignite the mixture as it first becomes flammable; then, as a richer mixture is vented to the upper plenum, the igniters will produce a horizontal standing flame. If the mixture is further enriched, the flame will propagate downward into the ice bed until it settles to an equilibrium point where sufficient steam has

been condensed. TVA concluded that even if an inerted mixture with a high hydrogen concentration were introduced to the ice bed, which is highly unlikely because of operation of the lower compartment igniters and the air return fans, the flame front would simply propagate to an equilibrium elevation where sufficient steam was condensed to support combustion. The flame propagation will not allow the hydrogen-steam-air mixture to dry out to the point where detonable mixtures would develop. The staff previously considered these matters, as discussed in SSER 5, and concluded that a transition to detonation in the ice condenser region was not likely.

Results of recent research conducted at McGill University as part of the NRC Hydrogen Research Program support the TVA position that flame acceleration will not occur in an ice condenser containment. In laboratory-scale studies of flame propagation through obstacle fields, McGill researchers have investigated the rate of flame acceleration as a function of obstacle configuration and hydrogen concentration in dry air. In these tests, noticeable flame acceleration and transition to detonation were observed only at hydrogen concentrations in excess of 13 to 15 volume percent. This limit is lower than the often-quoted value of 18%, but is still well above the concentration expected in the containment building. The requisite concentration may shift upward if steam is added to the mixture. Furthermore, Sandia tests have confirmed that confinement of the gas mixture is a requisite condition for producing a transition to detonation. The composite evidence of these relatively recent tests has led Sandia to conclude that a transition to detonation in the upper plenum region is unlikely. The McGill findings are preliminary in nature, and additional tests are planned at both McGill and Sandia to address the effects of steam addition and scaling on the requisite concentration for flame acceleration. However, the staff believes that the preliminary findings by McGill will not be significantly altered by additional tests and that they provide an adequate basis for licensing decisions.

Although the potential for detonation and flame acceleration is extremely remote, TVA has calculated the response of the containment shell to a postulated local detonation of a 6-ft-diameter gas cloud and showed that a margin of safety of 3 exists before material yield would be reached. The results of this analysis were reported in SSER 4. At that time, further studies were thought

to be necessary to bound the variation in pulse shapes to confirm the TVA findings. TVA was therefore required by license condition to address the potential for local detonation. TVA has considered the potential and has concluded, based on the results of its research program, that detonations and transitions to detonations are not credible in Sequoyah. TVA thus considers further studies of containment response to detonations unwarranted. The staff agrees with TVA that detonations are extremely unlikely in Sequoyah and therefore feels the TVA position is reasonable for the licensing decisions related to the PHMS.

Even though the staff's view is that sufficient information exists for closure of the detonation issue, the staff, with the support of Sandia, has initiated an independent calculation of containment response to postulated local detonations. Sandia, using the CSQ computer code in conjunction with a simple structural failure criterion, has calculated the effects of various postulated local detonations on the containment structure. Results of early calculations for the upper plenum of an ice condenser plant indicate that containment integrity can be threatened if the requisite conditions for detonations were attained. As previously stated, however, it is the view of the staff that the conditions that must prevail to produce detonations are extremely unlikely. Moreover, even with the presence of detonable mixtures, as assumed in the Sandia analysis, there has been no demonstration that a detonation would occur. Subsequent calculations performed by Sandia using a detailed structural model indicated the containment would survive upper plenum detonations.

The Sandia investigation, which is not yet complete, is viewed by the staff as a confirmatory item to provide further insight into the consequences of local detonations. The results of this effort are not expected to alter the staff's findings on the hydrogen control capability at Sequoyah for the aforementioned reason.

6 Degraded Core Accidents and Hydrogen Generation

As discussed in SSER 4, a small-break LOCA followed by a failure of emergency core cooling (ECC) injection (S₂D) was selected by TVA as the base case for

evaluation of the hydrogen mitigation system. Hydrogen release rates are a time-varying function whose average is of the order of 20 lbs per minute. The staff considered these rates to be representative of releases that might be encountered in typical degraded core accidents less severe than total core melt or vessel failure, and considered them an acceptable upper limit basis for use in the interim evaluation; however, several concerns remained open. Among these were: (1) the possibility that other scenarios might present schedules of steam and hydrogen release not covered by the analysis chosen; (2) that steam inerting might occur at some time during the sequence allowing large concentrations of hydrogen to develop; (3) that the recovery period might produce an exceptional burst of steam or hydrogen; or (4) that hydrogen might be released after the loss of the ice heat sink. TVA was therefore asked to broaden the studies of steam and hydrogen releases.

In the follow-on CLASIX studies that were submitted by the applicant, steam and hydrogen releases were varied to correspond to higher release rates and releases after the ice had melted. It was shown that a representative selection of scenarios would be bounded by the calculated release rates, and thus it was claimed that a satisfactory group of alternative scenarios had been encompassed by the calculations. TVA states that the scenarios encompassed included an intermediate-break LOCA with a loss of ECC (S_1D), a small-break LOCA with a loss of containment heat removal (S_2G), a transient loss of main feedwater and loss of all ac power ($T_B B_2$), and a transient loss of main feedwater, loss of auxiliary feedwater, and loss of the ECC ($T_B LD$).

The staff has compared the release rates and sequences used in TVA's calculations to those developed in an independent study of degraded core accidents in ice condenser plants carried out at Brookhaven National Laboratory (Yang and Pratt, 1982). It is clear from this comparison that TVA's choices of hydrogen and steam release rates do indeed cover the above range of accident scenarios. The highest rate of hydrogen release calculated by Brookhaven was of the order of 1 lb per second. The Brookhaven calculations did not indicate that these rates would be exceeded during quenching or recovery from the degraded core conditions as well as in the initial core uncover phase. On the other hand, TVA has calculated the effect of hydrogen release rates as 6 lb per second under representative steam conditions, with and without ice.

In addition, the staff has compared the release rates chosen by TVA to those suggested in a proposed rule ("Notice of Interim Requirements Related to Hydrogen Control" (46 FR 62281)). In this comparison, the release rates used by TVA were again found to be an adequate representation of the scenarios considered important in these degraded core situations.

The licensee's core reflood studies using MARCH, WFLASH, and LOCTA did not disclose any conditions that would be more adverse than the high release rates used in CLASIX.

The staff therefore finds TVA's treatment of scenarios to develop steam/hydrogen source terms in conformance to the requirements of existing hydrogen degraded core rules acceptable.

7 Sequoyah Containment Structural Capacity

In support of the initial licensing of the plant, the ultimate pressure-retaining capacity of the Sequoyah steel containment was calculated by five different investigators. These pressures ranged from a low of 27 psig to a high of 50 psig, as listed in column 2 of Table 22.1. The variation was the result of the difference in the material properties used in the analysis, the stress limit criteria, and the manner of incorporating the horizontal and vertical stiffeners. When the material properties and the stress limit criteria are normalized to actual mean material properties and Von-Mises criteria, respectively, to form a uniform basis for comparison, the ultimate capacity then varies from a low of 40 psig to a maximum of 60 psig as listed in column 3 of Table 22.1. To provide an adequate safety margin, the staff reduced its ultimate mean value of 60 psig by 3 standard deviations. The standard deviation computation incorporated the variations in the material properties, material sizes and thicknesses, stiffener spacing, and containment shell diameter. The standard deviation of the containment pressure was calculated to be 8 psig. Therefore the ultimate capacity of the containment adopted by the staff was 36 psig, which represents a lower bound value. An assessment of the containment penetrations was also made at the initial licensing stage and showed that the penetrations were not the controlling item for the containment ultimate pressure capacity, as reported in SSERs 3 and 4.

Table 22.1 Internal static pressure capacity for hydrogen burning, psig

Investigator	Column 1, Service Level C*	Column 2, Reported ultimate capacity**	Column 3, Normalized ultimate capacity†
TVA		38	40
Staff (Ames Laboratory)	30.0	36††	60
Franklin Research		30	51
Offshore Power		50	53
R&D Associates		27	40

*Based on ASME Code methods and Code allowables; 1/2-in. steel plate controls.

**Reported by individual investigators and summarized in NUREG/CR-1891.

†Capacity values normalized using actual mean material properties instead of Code values and Von-Mises yield criterion.

††Based on actual material properties and Von-Mises yield criterion; this value is the mean value minus 3 standard deviations.

The proposed rule, "Interim Requirements Related to Hydrogen Control," was published after these analyses. The proposed rule would require that the hydrogen control system perform its function without loss of containment structural integrity. For the PHMS installed at Sequoyah, the rule would require that the

containment pressure throughout the accident transient remain at or below that which corresponds to Service Level C limits of the Boiler and Pressure Vessel Code of the American Society of Mechanical Engineers (ASME Code).

The staff's consultant, Ames Laboratory, computed the value of the internal pressure that would produce stresses in the steel shell corresponding to Service Level C Limits as specified in the ASME Code, Section VI, Division 1. This value is 30 psig and is shown in column 1 of Table 22.1. This value is based on the finite element analysis model used in computing the containment ultimate capacity reported earlier. The limiting section in the Ames Laboratory analyses is the 1/2-in. thick cylindrical plate between elevations 756 ft 3 in. and 810 ft 3 in. The staff agrees with the Ames estimated pressure retention capability for ASME Boiler and Pressure Vessel Code Service Level C limits is 30 psig with all of the inherent safety margins of the code implied.

TVA has also made an evaluation of the reinforced concrete floor that divides the upper and lower compartments. This evaluation showed the reinforced concrete floor differential pressure capacity to be equal to or greater than the containment shell capacity.

8 Containment Analysis

8.1 Containment Codes

Calculations of containment atmospheric pressure and temperature have been performed using the CLASIX computer code developed by Westinghouse Offshore Power Systems (Westinghouse OPS-36A31). Descriptions of the earlier version of CLASIX have been previously reported in SSERs 3, 4, and 5. As noted in SSER 5 and as part of the license condition, the staff asked TVA to provide improved calculational methods for containment pressure and temperature response to hydrogen combustion. Specifically, TVA was to refine CLASIX to permit the addition of structural heat sinks and the separate modeling of the upper plenum. In addition, TVA was to provide additional verification of the CLASIX code by comparison with results from other accepted codes and combustion tests. The present and latest version of CLASIX incorporates those changes requested by the staff.

The CLASIX code is a multivolume containment code that calculates the containment pressure and temperature response in the separate compartments. CLASIX has the capability to model features unique to an ice condenser plant--including the ice bed, recirculation fans, and ice condenser doors--while tracking the distribution of the atmosphere constituents--oxygen, nitrogen, hydrogen, and steam. The code also has the capability of modeling containment sprays. Unlike the earlier version, the present version of CLASIX includes heat sinks and models the upper plenum as a separate model. Mass and energy released to the containment atmosphere in the form of steam, hydrogen, and nitrogen is input to CLASIX. The burning of hydrogen is calculated in the code with provisions to vary the conditions at which the burn initiates and propagates to other compartments.

CLASIX input for each compartment consists of the net free volume, temperature, contents by constituent, burn control parameters, and passive heat sink data. The burn control parameters include the hydrogen concentration and oxygen concentration required for ignition, the hydrogen concentration for propagation, the hydrogen fraction burned, and the minimum oxygen concentration required to support combustion and the burn time. The flow area, flow loss coefficient, and propagation delay time for each intercompartment flow path is also required. Additional input data are supplied to describe the ice condenser, fans, and sprays.

The major difference between the present and earlier version of CLASIX is in the heat sink model. The analytical model of the structural heat sinks represents all heat sinks as multilayered slabs. Heat transfer to the exposed surfaces by both convection and radiation is modeled. Radiation is assumed to occur only between the water vapor in the containment atmosphere and the surface of the heat sinks. A conventional finite difference formulation is used to model internal heat transfer.

The staff, with the support of Los Alamos National Laboratory (LANL), has completed a preliminary assessment of the CLASIX code. This assessment involved an evaluation of the validity and adequacy of the assumptions and models employed and review of the TVA-supplied comparisons between CLASIX results and those for other containment codes and combustion experiments.

A number of technical concerns were identified during the code review. With regard to the CLASIX radiation model, the staff requested that TVA clarify the expression used to compute the net radiant heat exchange. Specifically, the staff questioned the inclusion of gas and wall emissivities as multipliers on the temperature terms. TVA has reviewed the development of the radiation model and has concluded that use of the emissivities is inappropriate. However, TVA notes that use of the emissivities results in an underestimate of radiant heat flux to the walls and, thus, leads to conservative containment temperature and pressure predictions. Based on an independent review and on the TVA clarification provided, the staff and LANL concur in the TVA finding that CLASIX underpredicts the radiation heat transfer.

LANL, as part of its review, also identified a number of questions regarding the fluid flow equations used in the code. LANL's concerns centered on the use of (1) steady-flow equations to describe the transient phenomena and (2) constant loss coefficients for subsonic flows. The rationale provided by TVA for the CLASIX flow equations is that the Mach number for all CLASIX cases analyzed to date has been less than the commonly accepted criteria for assuming incompressible flow. On this basis, the staff and LANL agree that the CLASIX approach is valid.

To increase the level of confidence in the CLASIX code, TVA has validated CLASIX by comparing calculated results with the calculated results of the Westinghouse COCOCLASS9 code (Westinghouse, 1981), the Westinghouse Transient Mass Distribution (TMD) code (WCAP-8077,-8078), and the measured results of selected Fenwal and LLNL tests.

COCOCLASS9 is based on the NRC-accepted code COCO (WCAP-8326, 8327), and has been used in support of licensing activities for dry containments. The COCOCLASS9 analytical model has the capability to simulate heat transfer to passive heat sinks and containment sprays as well as high enthalpy water mass and energy addition. However, the COCOCLASS9 model provides only a single volume representation of containment, and does not allow spray evaporation as CLASIX does. Also COCOCLASS9 does not have the capability to model the addition of hydrogen during a burn. This limitation precludes comparison of a transient burn case.

Comparative runs were made with CLASIX and COCOCLASS9 assuming no heat sinks, heat sinks, and heat sinks with radiation. The comparison indicates that despite the previously cited discrepancy in the CLASIX radiation model, the two codes produced almost identical results for all cases considered. TVA attributes the excellent agreement to the use of a similar heat transfer model in COCOCLASS9.

The TMD program was developed for analyses of the ice condenser containment response during the initial few seconds following the onset of a design-basis LOCA. TMD contains a multicompartment analytical model but does not include models for containment sprays, air return fans, heat sinks, or hydrogen addition. Therefore, the comparison of CLASIX and TMD results is limited to multicompartment pressure and temperature responses to high enthalpy water mass and energy addition. This comparison provides verification of CLASIX pressure and temperature response calculations, flow path calculations, and certain aspects of the ice condenser model.

Four CLASIX-TMD comparison runs were made covering the anticipated range of the blowdown energy from saturation to superheat conditions. A containment similar to the Sequoyah ice condenser plant was modeled in all cases. Direct comparisons were made between the calculated temperature and pressure responses. Comparisons indicate that the two programs are in excellent agreement with the CLASIX-calculated values for both temperature and pressure being generally more conservative. CLASIX is expected to be conservative relative to TMD because of differences in the treatment of breakflow as the flow enters containment.

For the final part of the verification, CLASIX was used to model hydrogen combustion experiments conducted at Fenwal and LLNL. These comparisons provide limited verification for such features in CLASIX as the hydrogen burn model, the models for hydrogen and high enthalpy water mass and energy addition, and to some extent the passive heat sink and containment spray models. The approach taken to establish CLASIX input data for the experimental simulation was to utilize to the fullest extent possible all reported test measurements for the selected experiments. This included the CLASIX initial conditions as well as burn parameters such as the fraction of hydrogen burned and the burn time.

A total of 17 tests were selected for CLASIX verification. These included six dry tests and nine steam tests reported by Fenwal and LLNL. Hydrogen concentrations for both the dry and steam tests ranged from 8 to 15 volume percent. Steam concentrations for the latter tests ranged from 5 to 10 volume percent. In addition, one transient test and one test with spray were analyzed. Comparison of CLASIX-calculated results with those measured in the tests indicated that CLASIX predictions for peak pressure are consistently higher than those measured in the tests. Temperature comparisons were not attempted because of the slow response time of the thermocouples used in the tests. Only in a few cases were the CLASIX-calculated pressures higher than those measured. This was attributed to inaccuracies or inconsistencies in the estimated burn fractions.

In addition to its limited assessment of the CLASIX code and the TVA-supplied comparative runs, the staff directed its contractor, LANL, to develop the capability to model containment response to degraded core accidents independently. The ultimate purpose of the LANL effort was to perform confirmatory calculations for Sequoyah and other ice condenser plants; however, comparison of the models and results for the LANL-developed code with those for CLASIX provides an additional basis for evaluating the adequacy of the CLASIX code.

A modified version of the NRC COMPARE code was developed by LANL to model containment response to degraded core accidents. COMPARE was previously developed to perform confirmatory subcompartment analyses, and included capabilities required to analyze ice condenser containments, heat transfer to passive heat sinks, and the thermodynamics of atmospheres composed of steam, water, and ideal gases. To apply the COMPARE code to the analysis of hydrogen burning in containments, several capabilities were added, specifically a new ice condenser door model, a fan cooler model, a sump recirculation heat exchanger model, and a hydrogen burn model. A complete and total evaluation of the hydrogen burn version of COMPARE was not performed during the LANL effort. However, the applicability of the COMPARE code for the performance of subcompartment analyses has been evaluated rather extensively. Verification of the models added to the subcompartment version of COMPARE was performed by LANL. These

evaluations show that the models provided results that are consistent with the original objective of the model.

A verification of the hydrogen burn analysis capabilities of the hydrogen burn version of COMPARE is also provided by the comparisons of calculated results with those obtained using the CLASIX code. These comparisons, discussed below, indicate that similar calculated values of pressure and temperature are obtained even though the codes were developed independently and utilize different models.

Based on its assessment of models used in the CLASIX code, a review of comparative runs provided by TVA, and the reasonable agreement found between CLASIX and the hydrogen burn version of COMPARE, the staff concludes that use of the CLASIX code to predict ice condenser response to a degraded core accident is acceptable, if appropriate input values are used. Approval of the CLASIX code for application to this particular class of accidents does not, however, constitute NRC endorsement of CLASIX for applications involving other classes of accidents, or variations of CLASIX to model other containment types. The staff will continue to assess the adequacy of the CLASIX code as part of its ongoing confirmatory effort.

8.2 Containment Pressure and Temperature Calculations

The approach taken by TVA to establish the acceptability of the hydrogen control system was to select an accident sequence based on its significance and characteristics from the standpoint of hydrogen threat, and to then parametrically vary key aspects of the containment analysis. As in previously reported analyses, a small-break LOCA with failure of safety injection, the S₂D event was chosen as the base case.

TVA has performed calculations of the containment pressure and temperature response to the base case scenario using the latest version of CLASIX and the releases calculated from the MARCH code. For the base case calculation, TVA assumed a lower flammability limit of 8 volume percent hydrogen, a burn fraction of 85%, and a flame speed of 6 fps. Test data from Fenwal and Whiteshell,

as well as the literature on combustion, indicate that ignition in the turbulent post-accident environment will occur around 5 volume percent hydrogen, with a burn completeness of 30 to 40%. Test data and the literature also show that at an 8% hydrogen concentration flame speeds are between 1 and 3 fps rather than 6 fps. The assumptions of ignition at the higher concentrations with a faster flame speed result in a greater amount of energy being released over a shorter period of time, and thus are conservative. Another conservatism in the CLASIX analysis is the assumption that ignition will occur simultaneously at all igniter sites in a compartment. This assumption will act to further increase the calculated pressures and temperatures.

The results of the CLASIX base case analysis indicate that the hydrogen will be ignited in a series of 7 burns in the lower compartment and 30 burns in the upper plenum. The burns occur over a 2500-second interval, with the 7 lower compartment burns intermixed, some concurrently, with 15 upper plenum burns over the first half of the interval. The peak calculated containment pressures and temperatures are 18.7 psig and 1245°F for the lower compartment, 18.1 psig and 257°F for the dead-ended region, 13.1 psig and 1220°F for the upper plenum, and 10.4 psig and 163°F for the upper compartment. The pressure in containment before the first burn was approximately 5 psig.

As a result of the action of engineered safety features such as the ice condenser, air return fans, and upper compartment spray, the pressure and temperature spikes were rapidly attenuated between burns. After the last hydrogen burn, which occurs at approximately 7100 seconds into the accident, roughly 780,000 lbs of ice are calculated to remain in the ice condenser section (representing at least 110×10^6 BTUs in remaining heat removal capacity).

In summary, the results of the TVA base case analysis show an increase in containment pressure as a result of hydrogen burns on the order of 13 psi, with the containment remaining well below the lower bound ultimate capacity of 36 psig. The analysis predicts the burning will occur in the lower compartment and upper plenum, thereby gaining the advantage of heat removal by the ice bed and venting to the large upper compartment volume. It should also be noted that each burning cycle involved the combustion of only 30 lbs of hydrogen, or

roughly 2×10^6 BTUs of energy addition. By burning at a given concentration in the lower compartment (and upper plenum), there is also the advantage of burning less total hydrogen at a time because the combined volumes account for less than one-third of the total containment volume.

To assess the efficacy of the PHMS more realistically, a best estimate calculation was performed by TVA assuming a lower flammability limit of 6 volume percent, a burn fraction of 60%, and a flame speed of 3 fps. The best estimate case results in a peak containment pressure of 10.6 psig, which is below the 12 psig containment design pressure.

TVA has also performed sensitivity studies to determine the effects of CLASIX burn parameters, safeguards performance, and reduced igniter performance on the containment response. To bound reported data regarding hydrogen combustion, a number of cases were analyzed in which burn parameters such as hydrogen concentration for ignition, burn completeness, and flame speed were varied either throughout containment or in selected compartments. Ignition criteria analyzed ranged from ignition at 4% hydrogen with 40% burn completeness, to complete combustion at 10% hydrogen. Flame speeds were varied from 1 to 12 fps. Additional cases were run to assess the effects of partial operation of the containment air return fans and sprays, heat removal by ice, and hydrogen release rates. In some of these cases several parameters were varied simultaneously such as a case with partial fan and spray operations, and modified ignition criteria (see Table 22.2). Finally, there were investigations of the effects of such postulated phenomena as fogging reducing the burn completeness in the upper plenum and steam inerting the lower compartment.

As discussed in SSER 5, the staff requested that TVA quantitatively assess the formation of fog and its effect on the performance of the igniter system. With regard to the effect of fogs and sprays on combustion, analytical studies of the requisite fog density and droplet size for inerting have been conducted by Westinghouse, Sandia, and others. Based on considerations of the heat of combustion and fog/spray droplet vaporization, these studies show that to fog inert an otherwise flammable mixture, two conditions must exist simultaneously:

Table 22.2 Containment sensitivity studies*

	Calculated peak pressure (psig)		Calculated peak temperature (°F)	
	LC	UC	LC	UC
Base case	18.7 (14.2)	10.4 (14.4)	1245 (1262)	163 (236)
<u>Ignition criteria</u>				
All ignition at 6% H ₂ , 60% burned	12.8	8.9	805	148
All ignition at 10% H ₂ , 100% burned	8.0 (8.6)	9.7 (8.9)	214 (237)	171 (175)
<u>Flame speed</u>				
1 fps flame	10.1	9.6	884	150
12 fps flame	23.5 (12.4)	10.8 (13.2)	1306 (1243)	182 (205)
<u>Safeguards</u>				
1 fan, 1 spray operational, UC and DE ignition at 6% H ₂ , 60% burned	17.6	18.0	1159	606
No ice, UC ignition at 6% H ₂ , 60% burned	22.8 (18.3)	26.9 (25.3)	1132 (1236)	548 (575)
<u>Hydrogen release</u>				
3 x base case H ₂ release rate	19.1	15.3	1578	498
Same as above with 6 lbs/sec spike, no ice	24.9	25.3	1310	542
<u>Reduced igniter performance</u>				
UP ignition at 8% H ₂ , 40% burn	17.6	10.5	1284	157
No LC ignition	7.8	9.2	214	153
<u>LANL mechanistic burn model</u>				
Conservative (see text)	(26.1)	(24.2)	(1585)	(513)
Best estimate (see text)	(18.5)	(20.0)	(1382)	(360)

*LC = Lower compartment; UC = upper compartment; DE = dead-ended region; UP = upper plenum

All cases assume base case parameters except as noted;
() = results predicted by LANL using hydrogen burn version
of COMPARE.

the fog density must be sufficiently high and the droplet diameter sufficiently small. The requisite fog density increases approximately as the square of the droplet diameter. Both of these parameters vary as a function of the hydrogen concentration of the mixture. In general, fog droplets on the order of 10 microns or less in diameter are capable of vaporizing completely in the flame front and quenching the flame. However, if the majority of the droplets in the population are larger than 10 microns, the fog is not expected to significantly influence the flame structure and may in fact exhibit beneficial effects such as the suppression of combustion pressure and any detonation waves.

To determine the significance of fog with regard to the PHMS installed in Sequoyah, TVA conducted a study to identify the major fog formation and removal mechanisms within an ice condenser containment. Analysis revealed that the upper and lower compartments maintained lower fog concentrations than the upper plenum. When the hydrogen concentration reached the lower flammability limit in the lower and upper compartments, the calculated fog concentrations were well below the calculated inerting limit. For the upper plenum, the fog is predicted to increase the flammability limit slightly. When the hydrogen concentration reaches 8.0 to 8.5 volume percent hydrogen in the upper plenum, the calculated fog concentration is two times smaller than the required concentration for inerting.

The staff has reviewed the TVA analysis and the results of the fog/spray tests conducted in support of the deliberate ignition system. Based on the information provided as a result of these investigations, the staff concludes that the presence of fogs and sprays in a post-accident atmosphere may affect the operation of the PHMS by increasing slightly the concentration at which ignition is initiated, but will not preclude satisfactory operation of the PHMS, because ignition is still expected to occur with acceptable consequences. The staff notes that even though there is still reasonable assurance that reliable ignition will be achieved with the PHMS, reduced igniter performance has been assumed by TVA in CLASIX containment analysis, and the results have been found acceptable.

After the issuance of SSER 4, TVA performed sensitivity studies of the hydrogen release rates and has computed the hydrogen release rates for a number of other accident sequences using the MARCH code. Two different sensitivity cases were considered. In the first, a hydrogen release rate three times that of the base case was assumed for the period up to and including the maximum release rate (spike). To provide equivalent hydrogen mass additions, the duration of blow-down following the spike was correspondingly decreased. For conservatism, the steam releases were not changed, because additional steam would act as a burn heat sink. In the second case, the hydrogen release rate was similarly assumed to be three times the base case; however, a maximum release rate of approximately six times the base case value was assumed.

The CLASIX code was used to analyze the containment response for the two cases: first assuming ice to be present, and assuming all the ice melted. The highest peak pressure predicted by CLASIX for all the sensitivity runs was 27 psig. This pressure is well below the lower bound pressure capacity for the Sequoyah containment.

The results of selected CLASIX sensitivity analyses are summarized in Table 22.2, along with the results predicted by LANL using the hydrogen burn version of the COMPARE code. Comparison of the CLASIX and COMPARE results indicates excellent agreement between the two codes. The peak containment pressures calculated by COMPARE are consistently lower than comparable CLASIX values, illustrating the conservatism in CLASIX. The peak temperatures calculated by COMPARE are generally equivalent to those calculated by CLASIX but in some cases are slightly higher.

In conclusion, the results of the CLASIX sensitivity analyses demonstrate that (1) the effect of ignition criteria on containment pressure is dominated by the corresponding changes in burn location and sequence, but within the parameter ranges considered it does not result in peak pressures significantly greater than for the base case; (2) flame speed has a considerable effect on containment pressure but does not pose a threat to containment integrity even for conservative flame speeds; (3) partial versus full operation of the air return fans makes little difference in the calculated results; (4) ice condenser heat

removal is effective in reducing containment pressure; (5) the rate of hydrogen release has little effect on the peak containment pressure; and (6) even with reduced igniter efficiency or lower compartment inerting, the PHMS will continue to perform its intended function. It should be noted that the cases with no ice are not mechanistic, i.e., they are not representative of the S₂D scenario. However, these cases importantly demonstrate that, even without ice, the containment pressure with the assumed igniter operation remains below the containment pressure capacity. This serves to indicate some insensitivity to whatever accident scenario is chosen.

8.3 Confirmatory Analysis and Conclusion

At the request of the staff, LANL has performed confirmatory analyses for the base case and several other cases using the hydrogen burn version of COMPARE. Code input equivalent to that for the CLASIX code was used in the confirmatory analyses with one exception. In the LANL analyses, the ice condenser section was represented by four separate nodes each accounting for one-fourth of the ice condenser volume; this is a finer model representation of the ice bed than used in CLASIX. The hydrogen burn parameters for the ice condenser and lower plenum nodes were specified to preclude the initiation of independent burns but to permit burning by propagation if the hydrogen concentration exceeded 8 volume percent.

Agreement between COMPARE and CLASIX was quite good, with COMPARE predicting peak pressures throughout containment of 14 psig. The mass of ice left in the ice condenser after the last burn is estimated at 289,000 lbs. This value is less than predicted by CLASIX because more burning in the ice bed region is predicted by COMPARE, but is not a safety concern because the remaining ice represents adequate heat removal capacity.

The TVA sensitivity studies indicate that containment integrity will be maintained for the base case and all sensitivity variations considered; however, upper compartment burns occurred in only two of the TVA cases. The subject of burning in the upper compartment was previously identified as a staff concern. Staff interest in this area lies in the fact that ignition in the large, relatively open upper compartment conceivably represents the largest energy release

rate by combustion and thus the greatest threat to containment. Although the TVA upper compartment burns did not result in excessive pressures, the staff asked LANL to investigate this phenomenon further.

In response to the NRC request, LANL performed a number of additional sensitivity analyses using the modified COMPARE code. The approach taken by LANL was to identify the combination of burn parameters required to produce a maximum containment pressure, and then to assign parameter values based on a mechanistic burn model that is substantiated by test. Independent burn initiation in the upper compartment was identified as necessary to produce maximum pressures.

The model used by LANL to establish parameter values for the COMPARE containment analyses is based on estimates of turbulence levels and fluctuations and their relationship to eddy diffusivity and burn velocity. The controlling rate mechanism for the transport of the hydrogen from its source to an igniter can, in general, be estimated by using turbulence theory. The rate of burning for the lean mixtures under consideration is also controlled by the turbulence level. The level of turbulence is estimated by summing all of the dissipation sources (sprays, fans, jets, natural convection, etc.) and by using a formulation that relates the turbulent kinetic energy, mixing length, and eddy diffusivity to the rate of dissipation of kinetic energy. The turbulence model was used to estimate the mean concentration at the initiation of burning and the flame speed for the ice condenser containment burn analyses in which the first burn occurred in the upper compartment.

Two COMPARE calculations were performed to assess the significance of upper compartment burning. Burn parameters for these runs were specified so that burning could only initiate in the upper compartment, but could propagate into any compartment in which the hydrogen concentrations is greater than 4.1 volume percent. The first COMPARE run conservatively assumed ignition at 5% hydrogen with 40% burn completion, and a flame speed of 30 fps. The second run assumed the best estimates for these parameters based on the mechanistic burn model, i.e., ignition at 4.2% hydrogen with 10% burn completion, and a flame speed of 16 fps. Results of these calculations, summarized in Table 22.2, show that for both cases peak pressures will remain below the estimated failure pressure.

The staff concludes that the CLASIX containment analysis performed by TVA and confirmed in part by LANL provides an adequate basis for concluding that hydrogen combustion associated with the operation of the PHMS will not pose a threat to the integrity of the Sequoyah containment. While concluding that the use of CLASIX to predict ice condenser response to a degraded core accident is acceptable, the staff will continue the effort as part of its ongoing code assessment work.

9 Survivability of Essential Equipment

By letters dated June 2, 1981, December 1, 1981, and November 29, 1982, TVA submitted an evaluation of survivability of the essential equipment exposed to the thermal environment postulated in the containment during hydrogen burns initiated by the PHMS. Although this system was designed to prevent high hydrogen concentration buildup by deliberate ignition of relatively low concentrations of hydrogen in hydrogen-air-steam mixtures, the resulting release of thermal energy may still be sufficient to increase the temperature of the equipment located in the containment significantly. Because some of this equipment is needed to ensure maintenance of a safe shutdown condition and containment integrity, TVA was required to demonstrate that the essential equipment located inside the containment will survive the hydrogen burn environment resulting from operation of the PHMS. TVA determined analytically and experimentally the thermal response of selected pieces of essential equipment exposed to a hydrogen burn environment. Comparing the resulting temperatures with the qualification temperatures for this equipment, TVA provided information to demonstrate the survivability of the equipment.

9.1 Essential Equipment

The selection of equipment that must survive a hydrogen burn was based on its function during and after an accident. In general, all the equipment in the following four categories of systems located in the containment was considered to be essential for safety of the plant:

- (1) systems mitigating the consequences of the accident
- (2) systems needed for maintaining integrity of the containment pressure boundary
- (3) systems needed for maintaining the core in a safe condition
- (4) systems needed for monitoring the course of the accident

TVA's selection of safety-related equipment was based on the shutdown and safety function diagrams (letter from R. T. Cross, TVA, to R. L. Tedesco, December 15, 1980). The list of safety-related equipment is in Table 22.3.

Table 22.3 Essential equipment

-
1. Mitigating Systems
 - 1.1 Hydrogen igniters
 - 1.2 Air return fan
 - 1.3 Associated power and control cables
 - 1.4. Hydrogen recombiner
 2. Systems Maintaining Containment Pressure Boundary
 - 2.1 Air locks and equipment hatches
 - 2.2 Containment isolation valves including hydrogen sample valves
 - 2.3 Electrical penetrations
 - 2.4 Gaskets and seals for flanges
 - 2.5 Electrical boxes
 3. Systems Maintaining Core Safety
 - 3.1 Reactor vessel vent valves (PORV)
 4. Monitoring Systems
 - 4.1 Steam generator, pressurizer and sump water level transmitters
 - 4.2 Core exit thermocouples
 - 4.3 Reactor coolant system pressure transmitter
 - 4.4 Hot leg RTD
 - 4.5 Cold leg RTD
 - 4.6 Reactor vessel level system
 - 4.7 Associated cables (in conduits and exposed)
 - 4.8 Junction boxes
 - 4.9 Operators on solenoid valves
 - 4.10 Hydrogen analyzer
-

TVA restricted the survivability evaluation to the equipment which is most sensitive to temperature change. This reduced considerably the number of thermal response analyses and/or experiments that had to be performed. The following equipment items were selected for an evaluation of their thermal response to the hydrogen burn environment:

- (1) igniter assembly
- (2) Barton transmitter
- (3) igniter power cable in conduit
- (4) thermocouple cable
- (5) resistance temperature detector (RTD) cable

The staff has compared TVA's list of equipment selected for survivability evaluation with the lists of essential equipment prepared independently by the staff, and finds that the TVA list contains the equipment essential for safe operation of the plant under accident condition. The staff has also reviewed the criteria used by TVA in selecting the equipment for analytical and experimental investigations. Determination of the survivability of these pieces of equipment will be sufficient for establishing survivability of all the equipment listed in Table 22.3, provided these pieces of equipment have been included in the TVA equipment qualification (EQ) program. For pieces of equipment that are not in the EQ program, TVA has provided separate bases for the survivability finding.

9.2 Thermal Environment Response Analysis

The thermal environment for evaluating equipment survivability was determined by the CLASIX computer code. It corresponded to energy release from burning hydrogen which was generated during the accident resulting from a small-break LOCA with a loss of emergency core coolant injection (S₂D sequence), but with both trains of sprays and air return fans operating. The hydrogen was assumed to be ignited by the PHMS when it reached 8 volume percent concentration, with each burn being 85% complete. It was further assumed that the flame propagated throughout the containment with a velocity of 1 fps and its temperature remained constant at the adiabatic flame temperature of 1400°F. The CLASIX

code predicted 6 burns in the lower compartment and 26 burns in the upper plenum of the ice condenser for this scenario. No burns were predicted in the upper compartment. The average time between the burns in the lower compartment is about 200 seconds, and the highest temperature reached by the gas is 884°F. In the upper plenum, the average time between burns is about 90 seconds and the highest temperature reached by the gas is 1114°F. In addition, for the analysis to demonstrate thermal stability of the ice condenser foam insulation, the licensee has referenced the Duke Power Company's analysis (Parker, 1981) in which it was assumed that hydrogen was burning continuously for 45 minutes at the midpoint of the ice condenser baskets; the resulting flame was conservatively assumed to be 1-in. thick with a temperature of 1600°F.

The thermal responses of the igniter assembly, Barton transmitter, and igniter power cable in conduit were analytically predicted for the thermal environment described in the previous section. The igniter assembly was analyzed using the upper plenum temperature profile that is considered to be the most severe thermal environment for igniters. It should be noted that the TVA analysis was done for the igniter assembly used for the IDIS. TVA has now decided to use a different igniter assembly for the PHMS, one that does not employ a transformer. Because the transformer was the most sensitive component of the previous igniter assembly, the staff concludes the same analysis could be applied to the new igniter assembly. The Barton transmitter was analyzed using the lower compartment temperature profile, and the igniter power cable in conduit was analyzed for both the upper plenum and the lower compartment temperature profiles. The staff has reviewed and concurs with this choice of thermal profiles for analysis, because these profiles conservatively represent the thermal environments to which the given equipment would be exposed during an accident.

The analytical models used in predicting thermal responses of equipment considered thermal energy transfer from the moving flame by radiation and from the hot gases by natural convection only.

Standard heat transfer equations were used to calculate this heat transfer. The heat transfer inside the equipment was determined by TVA using the HEATING

5 computer code (ORNL). This code was applied to solve heat transfer equations for two-dimensional models of different components. Therefore, these components had to be represented by relatively simple geometries. TVA prepared such simplified models which, despite their simplicity, included significant heat transfer characteristics.

The models used in the analysis were verified by comparing calculated results with the results derived from other accepted computer programs or obtained experimentally. The validity of the pressure transmitter model was determined by comparing its response to the results of the temperature transient analysis performed for equipment qualification using the COCO computer program (WCAP-8936). This program was previously verified by the staff. The agreement between temperature responses predicted by these two programs is satisfactory. TVA verified the model for thermal response of thermocouple cable by comparing it to the results of the test performed by Fenwal (Fenwal, 1980). Analytical results predicted the melting of the teflon insulation that was observed in the experiments. The staff has reviewed the methodology used by TVA and finds that in general the models conservatively overestimate heat transfer from the flame because it is assumed to move in the containment with an artificially slow velocity and at an adiabatic temperature, despite its loss of energy to different heat sinks. On the other hand, the transfer of heat by radiation from the hot gases was neglected by the licensee. The staff's consultant, Sandia, performed independent verification of TVA's analyses (McCulloch, 1982) and concluded that although they do not reflect true mechanisms of energy transfer for the hydrogen burn environments used, they yield conservative results.

Thermal responses for the thermocouple and RTD cables were determined experimentally at TVA's Singleton Laboratory. The cables were exposed to the simulated hydrogen burn environment in a Lindberg Tube furnace, and the temperatures reached by cable insulation were measured. The cables were exposed to 1400°F for five 30-second cycles. Between the cycles (170-second period), the temperature was reduced to 300°F. The staff concluded that this environment conservatively represents the condition existing in the lower compartment during hydrogen burn.

Thermal response of the igniter cable used in the IDIS was determined experimentally at Singleton Laboratory. The cable was placed in a conduit with both ends sealed. The cable in the conduit was placed in a Blue M oven and was exposed to about 700°F for about 45 minutes. The staff concluded the environment conservatively represents the condition existing in the lower compartment or in the upper plenum of the ice condenser. The IDIS cable was not part of the NUREG-0588 qualification program, although the cable used for PHMS is qualified to meet NUREG-0588 requirements. Also, the materials used in the construction of the IDIS cable are more sensitive to heat than the materials used in the PHMS cable.

The acceptance criterion used for evaluating survivability of essential equipment is based on the qualification temperature of the equipment and the duration for which the temperature is maintained. The equipment located in the containment will survive the hydrogen burn if the temperature reached by its most sensitive component will not exceed the temperature reached by this component during qualification tests. Because the actual temperature reached by the tested equipment during these tests was not measured and qualification temperature was the temperature of thermal environment to which the test equipment was exposed, there is no direct way to determine the actual qualification temperature reached by the limiting components. However, TVA claims that environmental qualification tests are typically conducted for extended periods of time and the equilibrium surface temperature should achieve thermal equilibrium with the test chamber during the tests. Because of several conservative assumptions in the thermal response analysis, the staff is of the opinion that use of the qualification temperature by TVA as a criterion for evaluating the survivability of limiting components is acceptable. To confirm equipment survivability at elevated temperatures, TVA has performed tests in Singleton Laboratory in which the igniter power cable in conduit was exposed to 700°F for 45 minutes. Although some degradation of the insulation was observed, the cable qualified in the subsequent high voltage test.

The analytically calculated thermal responses during hydrogen burn are compared with the qualification temperatures in Table 22.4. In all cases, the qualification temperatures are not exceeded. It is the opinion of the staff that this equipment will survive a hydrogen burn.

The survivability of thermocouple and RTD cables was determined experimentally by actually verifying their behavior in a simulated hydrogen burn environment. The temperatures reached by the cable insulation are listed in Table 22.4. Only slight degradation of cable insulation was observed. Both cables successfully passed high voltage tests.

All equipment except the core exit thermocouple, reactor vessel level thermocouple, and vessel vent valves has been included in the TVA EQ program. The core exit thermocouples are located inside the vessel head and are not exposed to the hydrogen burn environment. The reactor vessel level thermocouple and vent valves will be included in the EQ program when they are added to the plant.

Table 22.4 Comparison of analytically calculated thermal responses during hydrogen burn and qualification temperatures

Component	Maximum temp, °F (calculated)	Design/test temp, °F
Igniter (used in IDIS)		
Interior box air	227	428 (transformer)
Cable	171	
Transformer core	157	
Barton transmitter		
Interior air	231	310
Case surface	245	
Cable in conduit (used in IDIS)		
Copper	251	tested to 700
Insulation	260	
Conduit surface	332	
Thermocouple cable insulation		1126
RTD cable insulation		1013

In a submittal dated November 29, 1982, TVA stated that all the equipment listed in Table 22.3--except for thermocouple and RTD cable--reaches the equilibrium temperature during the qualification testing. Based on this statement and the experimental verification of RTD and thermocouple cables, the staff concludes that all the equipment listed in Table 22.3 will survive the hydrogen burn environment.

It should be noted, however, that the tests conducted by the licensee were performed in a relatively small oven. In NUREG-CR/2730, the staff's contractor (Sandia) has stated that on the basis of some preliminary test results, scaling (volume of containment building vs. volume of the test chamber) may be a significant factor in analyzing the survivability of the equipment. During fiscal year 1983, Sandia will be performing some additional confirmatory tests to address this concern. But, based on the conservative assumptions and available margins in the work done to date, the staff finds that the essential equipment will survive the hydrogen burn environment. The results from Sandia's upcoming tests will be relied on to confirm the findings made above.

Secondary fires in the Sequoyah plant may originate either when combustible materials located in the containment reach their ignition temperature or when the insulation on the ice condenser cooling ducts is heated to the point at which polyurethane foam starts to decompose and emit combustible gases. After reviewing different possible sources of combustible materials, TVA identified organic cable insulation as the only significant source. In most cases, however, cables are completely enclosed in conduits or cable trays, and are not directly exposed to the hydrogen burn. Those cables that have exposed insulation have been tested to ensure their flame resistance. In evaluating the thermal stability of insulation at ice condenser cooling ducts, TVA referenced the analysis performed by Duke Power Company for the McGuire plant (Parker, 1981). Because the ice condenser designs are similar in both plants, the analysis performed for McGuire is applicable to Sequoyah. This analysis indicates that the polyurethane foam will not reach temperatures at which pyrolysis could generate combustible gases. The staff has reviewed this analysis and concurs with TVA's conclusion.

9.3 Pressure Effects

For the pressure profile inside the containment during the hydrogen burn, the conservative pressure profile was obtained from the CLASIX analysis with a 12 fps flame speed. This analysis is identified in TVA's submittal of December 1, 1981.

With the PHMS, the highest predicted pressure in the containment does not exceed the pressures used during the qualification testing of equipment. However, a pressure differential could be developed between the lower and upper compartments of the containment that could strain the blades of the air return fans. TVA has indicated that the fans are protected by backdraft dampers; hence this pressure differential would not affect their performance. In addition, TVA performed a structural analysis that indicates that the fans could take static loads in excess of those produced by the predicted pressure differential.

9.4 Staff Conclusions Regarding Equipment Survivability

After reviewing TVA's analysis and/or experimental investigation of equipment survivability, the staff concludes that TVA has provided sufficient evidence that all the equipment required to ensure safe shutdown conditions and containment integrity will survive the environment created by burn of the hydrogen generated during a postulated accident. This conclusion is based on the following:

- (1) The list of equipment provided in the submittal included all the essential equipment.
- (2) The equipment selected for the analytical and experimental investigations adequately characterizes the essential equipment on the list.
- (3) The analytical methods used by the applicant adequately calculate thermal response of equipment, based on the postulated thermal environment.

- (4) The comparison of analytically determined thermal responses to the corresponding qualification temperatures for some sample components has indicated that these temperatures will not be exceeded during a hydrogen burn.
- (5) Experimental determination of survivability of the thermocouples, RTD cables, and igniter cable in conduit in the test chambers conservatively predicts their behavior in a hydrogen burn environment.
- (6) It was satisfactorily demonstrated that burning hydrogen will not initiate secondary fires in the containment by igniting combustible materials by generating combustible gases from the decomposition of polyurethane foam insulation.

10 Overall Conclusions

The operating licenses for Sequoyah Units 1 and 2 contain a condition requiring that, "prior to startup following the first refueling outage, the Commission must confirm that an adequate hydrogen control system for the plant is installed and will perform its intended function in a manner that provides adequate safety margins." The licenses include another condition dealing with the TVA research program which provides, among other things, that "...TVA shall...evaluate and resolve any anomalous results occurring during the course of its ongoing test program."

The staff has concluded its review of the matter of hydrogen control for postulated degraded core accidents at the Sequoyah plant. The staff finds that (1) four additional igniters must be installed in the upper compartment in locations satisfactory to the staff prior to restart after the second refueling of Unit 1, and (2) certain additional testing of the Tayco igniter in a simulated spray environment is required by September 1983. Subject to the satisfactory resolution of the above contingencies, the staff finds that

- The peak pressures as a result of igniter-induced burns will be less than the containment pressure capacity. The results of many accident analyses suggest that the peak containment atmosphere pressure will be close to the

design pressure of 12 psig. Even considering a broad range of accident scenarios and combustion assumptions that is more conservative, it is expected that the containment pressure will remain below 30 psig. With adequate margins, the containment pressure capacity is 36 psig.

- The essential equipment has been identified and the peak temperatures during a hydrogen burn for the most sensitive piece of equipment have been shown to be less than its qualification temperature.

The contingencies identified in the above findings deal with design features of the PHMS. Specifically, they concern the capability of the Tayco igniter to maintain (1) a surface temperature sufficient to initiate combustion in a spray environment and (2) the density of the igniters in the upper containment to ensure favorable consequences of the hydrogen burns in the upper compartment. Recent tests conducted by TVA indicate that the igniters will function as intended. However, the temperature margin provided by the igniters appears to be small under spray condition. The staff will require that TVA complete certain additional tests to verify that the Tayco igniter will maintain an adequate surface temperature in a spray environment such as that expected in the upper compartment of the ice condenser containment. This work can be performed at the Nevada Test Site in early 1983, as part of the EPRI/NRC hydrogen research program. The staff will require the installation of four additional igniters in the upper compartment at locations satisfactory to the staff, and TVA has indicated its willingness to comply with this requirement.

As part of its PHMS evaluation, the staff also identified a number of technical concerns that it intends to investigate further as confirmatory items. The confirmatory items are

- local detonations
- CLASIX/COMPARE code work
- equipment survivability for a spectrum of accidents
- combustion effects at large scale
- combustion phenomena including flame acceleration in the upper ice bed

The subject of local detonations in confined regions of the containment is currently under investigation at Sandia under a staff technical assistance contract. This work is considered confirmatory in nature because: (1) mixing of the containment atmosphere, in conjunction with igniter operation at low hydrogen concentrations, will preclude the formation of detonable mixtures, and (2) recent analyses performed by Sandia using the CSQ code and a refined structural analysis indicate that the Sequoyah containment can withstand the postulated detonation of a 20 volume percent hydrogen mixture in the upper plenum of the ice condenser. The Sandia investigation should be completed by mid-1983.

The staff will continue to assess the adequacy of the CLASIX code as part of its technical assistance program with the Los Alamos National Laboratory. This containment code work is considered to be confirmatory in light of the staff's findings regarding the adequacy of the CLASIX models and the reasonable agreement obtained between CLASIX and the hydrogen burn version of COMPARE. The code work will be an ongoing effort.

The staff will also continue to investigate equipment survivability for a spectrum of degraded core accidents. This investigation will be carried out as part of the NRC Hydrogen Burn Survival Program already in place at Sandia. The results of the hydrogen release rate sensitivity analyses and the substantial margins between predicted and qualification temperatures for the more temperature-sensitive pieces of equipment provide the bases for classifying this item as confirmatory.

The staff will monitor the results of other ongoing NRC and EPRI hydrogen research programs to: (1) confirm the adequacy of the number and location of igniters in the upper compartment of containment; and (2) confirm the lack of significant flame acceleration at large scale. Research programs to address these concerns will be performed at the Nevada Test Site and the Sandia FLAME facility, respectively. These programs are considered confirmatory because similar test programs have been completed at smaller scale with acceptable results.

Accordingly, subject to satisfactory resolution of the open item dealing with the Tayco igniter surface temperature, the staff finds the license conditions

dealing with hydrogen control during postulated degraded core accidents to be satisfactorily resolved.

APPENDIX A

CONTINUATION OF CHRONOLOGY OF NRC STAFF
RADIOLOGICAL SAFETY REVIEW OF SEQUOYAH STATION

APPENDIX A

CONTINUATION OF CHRONOLOGY OF NRC STAFF RADIOLOGICAL SAFETY REVIEW OF SEQUOYAH STATION

May 5, 1981	Letter from licensee concerning program for training for mitigating core damage.
May 15, 1981	Letter from licensee concerning survivability of hydrogen recombiners and containment temperature profile.
May 18, 1981	Letter from licensee concerning EPRI hydrogen research program.
June 1, 1981	Letter to licensee concerning conceptual design for mitigating effects of potential core-melt accident.
June 2, 1981	Letter from licensee forwarding nonproprietary version of "Resolution of Equipment Survivability Issues for Sequoyah Nuclear Plant."
June 16, 1981	Letter from licensee forwarding "Research Program on Hydrogen Combustion and Control, Quarterly Progress Report 3."
July 1, 1981	Letter from licensee forwarding "Selection of Permanent Hydrogen Mitigation System for Sequoyah Nuclear Plant."
July 8, 1981	Letter to licensee requesting additional information on hydrogen control.
July 17, 1981	Letter to licensee forwarding agenda for July 23 hydrogen control/combustion meeting to review R&D programs.
July 14, 1981	Letter from licensee concerning research project regarding conceptual design for mitigation of effects of potential core-melt accidents.
August 17, 1981	Letter from licensee advising that TVA is replacing interim distribution system with permanent hydrogen mitigation system.
August 27, 1981	Letter to licensee requesting information regarding equipment temperature response to hydrogen burns.
September 22, 1981	Letter from licensee forwarding "Research Program on Hydrogen Combustion and Control, Quarterly Progress Report 4."

October 1, 1981	Letter from licensee forwarding additional hydrogen control information.
October 29, 1981	Letter to applicant forwarding "Evaluation of Quarterly Progress Report 3, Research Program on Hydrogen Combustion and Control."
November 30, 1981	Letter from licensee forwarding comments on R. Strehlow's August 17 report on hydrogen control and combustion.
December 1, 1981	Letter from licensee responding to request for information regarding hydrogen control and equipment temperature response to hydrogen burns.
January 22, 1981	Letter from licensee forwarding "Research Program on Hydrogen Combustion and Control, Quarterly Progress Report 5."
January 29, 1982	Letter to licensee extending date by which NRC must confirm that adequate hydrogen control system is installed and functioning.
February 12, 1982	Letter to licensee concerning delay in submitting R&D program on hydrogen control and combustion.
February 12, 1982	Letter to licensee requesting additional information regarding hydrogen control.
February 25, 1982	Letter from licensee responding to request for information on hydrogen control and combustion.
April 6, 1982	Letter from licensee responding to request for information on hydrogen control.
April 13, 1982	Letter to licensee requesting summary report regarding adequacy of hydrogen control measures within 60 days of completion of ice condenser owners' group hydrogen control R&D program.
April 23, 1982	Letter from licensee forwarding "Combustion Studies at High Hydrogen Concentrations, Effect of Obstacles on Combustion."
May 17, 1982	Letter to licensee forwarding R. Strehlow's report regarding hydrogen control system.
June 14, 1982	Letter from licensee forwarding "Summary of Testing to Determine Suitability of Tayco Igniter for Use in Permanent Hydrogen Mitigation System."
July 12, 1982	Letter to licensee forwarding agenda for August 4, 1982 meeting concerning R&D program for hydrogen control and combustion in ice condenser plants.

July 28, 1982 Letter from licensee forwarding quarterly progress report on R&D program for hydrogen combustion and control.

September 17, 1982 Letter to licensee requesting additional information regarding hydrogen control.

September 27, 1982 Letter from licensee forwarding "Executive Summary Report on Adequacy of Permanent Hydrogen Mitigation System for Sequoyah Nuclear Plant."

October 1, 1982 Letter to licensee requesting additional information on equipment temperature response to hydrogen burns.

November 1, 1982 Letter from licensee responding to request for information on hydrogen control.

APPENDIX B
BIBLIOGRAPHY

American Society of Mechanical Engineers, "Boiler and Pressure Vessel Code," Section VI, Division 1.

Berman, M., Sandia, letter to J. T. Larkins, NRC, enclosing April and May 1982 status reports for the Sandia Hydrogen Programs, July 20, 1982.

Cross, J. L., TVA, letter to R. L. Tedesco, "Sequoyah Nuclear Plant Hydrogen Study, Volume II, Revision in Response to NRC Questions," December 11, 1980.

Fenwal Laboratory, "Sequoyah Nuclear Plant Core Degradation Program, Volume 2, Report on Safety Evaluation of the Interim Distributed Ignition System," December 15, 1980.

Kammer, D. S., letter to E. Adensam, NRC, "Seventh Quarterly Research Report," July 28, 1982.

McCulloch, W. H., Sandia, letter to K. Parczewski, NRC, dated October 29, 1982.

Mills, L. M., TVA, letter to A. Schwencer, "Second Quarterly Research Report," March 16, 1981.

---, letter to E. Adensam, NRC, "Fifth Quarterly Research Report," January 22, 1982a.

---, letter to E. Adensam, NRC, "Sixth Quarterly Research Report," April 23, 1982b.

---, letter to E. Adensam, NRC, "Summary of Testing to Determine Suitability of Tayco Igniter for Use in the Permanent Hydrogen Mitigation System at Sequoyah and Watts Bar Nuclear Plants," June 14, 1982c.

Oak Ridge National Laboratory (ORNL), "HEATING 5, an IBM 360 Heat Conduction Program," ORNL/CSD/TM-15.

Parker, W. O., Duke Power Co., letter to H. Denton, NRC, dated December 31, 1981, transmitting "Analysis of Hydrogen Control Measures at McGuire Nuclear Station," Vol. II, dated October 1981.

Roller, S. F, and S. M. Falacy, Sandia, "Medium-Scale Tests of H₂: Air: Steam Systems," paper prepared for NRC for submittal to the Second International Workshop on the Impact of Hydrogen on Water Reactor Safety," Albuquerque, October 3-7, 1982.

U.S. Nuclear Regulatory Commission, "Notice of Interim Requirements Related to Hydrogen Control," 46 FR 62281.

---, NUREG-75/014, "Reactor Safety Study, "October 1975.

---, NUREG-0588, "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," December 1979.

---, NUREG/CR-1891, "Reliability Analysis of Containment Strength--Sequoyah and McGuire Ice Condenser Containment," Ames Laboratories, August 1982.

---, NUREG/CR-2486, "Final Results of the Hydrogen Igniter Experimental Program," Lawrence Livermore National Laboratory, February 1982.

---, NUREG/CR-2730, "Hydrogen Burn Survival Thermal Model and Test Results," Sandia, August 1982.

Westinghouse Electric Corporation, "Zion Probabilistic Safety Study," Module 4, Section 4, 1981.

---, WCAP-8077, "Ice Condenser Containment Pressure Transient Analysis Methods" (Proprietary Class 2), March 1973; WCAP-8078 (Proprietary Class 3), March 1973.

---, WCAP-8326 (Proprietary Class 3), F. M. Bordelon and E. T. Murphy, "Containment Pressure Analysis (COCO)," July 1974; WCAP-8327 (Proprietary Class 2), July 1974.

--- WCAP-8936, "Environmental Qualification Instrument Transmitter Temperature Transient Analysis."

Westinghouse Offshore Power Systems, OPS-36A31; "The CLASIX Computer Program for the Analysis of Reactor Plant Containment Response to Hydrogen Release and Deflagration" (non-proprietary; OPS-0735, proprietary).

Yang, J. W., and W. T. Pratt, "A Study of Hydrogen Combustion During Degraded Core Accidents in PWR in Condenser Plant." Brookhaven National Laboratory, Department of Nuclear Energy, prepared for NRC under Interagency Agreement DE-AC02-76CH00016, January 1982.

400 Chestnut Street Tower II

September 27, 1982

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensan, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensan:

In the Matter of) Docket Nos. 50-327
Tennessee Valley Authority) 50-329

Enclosed is our response to R. L. Tedesco's April 13, 1982 letter to H. G. Parris regarding the request for a summary report on the adequacy of the hydrogen control measures required by operating license conditions 2.C.(22).D (unit 1) and 2.C.(16).h for the Sequoyah Nuclear Plant. This response also represents the final quarterly report required by the above operating license conditions.

As stated in the enclosed report, we have concluded that the permanent hydrogen mitigation system, described in the enclosed report, is an adequate hydrogen control system that will perform its intended function in a manner that provides adequate safety margins.

If you have any questions concerning this matter, please get in touch with J. E. Mills at FTS 358-2633.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills
L. M. Mills, Manager
Nuclear Licensing

Sworn to and subscribed before me
this 27th day of Sept. 1982

Buriant M. Lowery

Notary Public

My Commission Expires 4/8/86

BHS:JEW:LHB
Enclosure

cc: U.S. Nuclear Regulatory Commission (Enclosure)
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

cc: See page 2

DUPE 8210120284

ENCLOSURE
EXECUTIVE SUMMARY REPORT
ON THE ADEQUACY OF THE
PERMANENT HYDROGEN MITIGATION SYSTEM
FOR THE
SEQUOYAH NUCLEAR PLANT

SEPTEMBER 1982

TENNESSEE VALLEY AUTHORITY

I. Introduction

This report is an executive summary whose purpose is to provide an overview of the Tennessee Valley Authority's (TVA) position that the Permanent Hydrogen Mitigation System (PHMS) is an adequate hydrogen control system for the Sequoyah Nuclear Plant and would perform its intended function in a manner that provides adequate safety margins. Highlights of the PHMS design and supporting analyses and research are presented. A more comprehensive technical summary is provided as an attachment to this report.

II. Permanent Hydrogen Mitigation System (PHMS) Description

TVA has selected the concept of controlled ignition using thermal igniters for the PHMS at the Sequoyah Nuclear Plant. Briefly, the concept is to reliably ignite lean hydrogen-air mixtures throughout the containment to achieve periodic or continuous burning. This moderated energy addition rate would allow the containment heat sinks to absorb the heat of combustion more effectively and reduce the overall containment pressurization. This selection was made after a number of alternatives were thoroughly evaluated.

In early 1980, the TVA Board of Directors requested the TVA staff to investigate potential mitigation systems for degraded core accidents at Sequoyah. An intensive study was undertaken of concepts to prevent or minimize the effects of hydrogen combustion as well as concepts to increase containment capacity for overpressure events. After evaluating each of these strategies, the TVA staff recommended the implementation of a controlled ignition system. This concept was the basis for the Interim Distributed Ignition System (IDIS) installed at Sequoyah in the summer of 1980. Beyond this commitment to the IDIS, TVA, together with Duke Power and American Electric Power (AEP), continued to investigate alternative methods of hydrogen control. After completing these evaluations and comparing the alternatives, TVA selected controlled ignition for the PHMS.

A durable thermal igniter capable of maintaining an adequate surface temperature was specified for the PHMS. An igniter developed by Tayco Engineering to operate at a standard plant voltage of 120V ac was selected and has been shown to be capable of maintaining an adequate surface temperature for extended periods, initiating combustion, and continuing to operate in various combustion environments. To assure adequate coverage, a total of 64 igniters will be distributed throughout the major regions of containment in which hydrogen could be released or to which it could flow in significant quantities (see figure in attachment). There will be at least two igniters, controlled and powered redundantly, located in each of these regions.

The PHMS components inside containment will maintain their functional capability under the effects of postaccident conditions including combustion. In addition, the PHMS components will be seismically supported.

The igniters in the PHMS are equally divided into two redundant groups to ensure adequate coverage even in the event of a single failure. Manual control and status indication of each group will be provided in the main control room. The system would be energized manually following the start of any accident which indicates inadequate core cooling without waiting for any hydrogen buildup. Separate trains of power will be provided for each group of igniters and will be backed by automatic loading onto the diesel generators upon loss of offsite power.

In addition, appropriate surveillance testing requirements and technical specifications have been provided.

We conclude that the PHMS design, as described here, is adequate and that the system would perform its intended function in a manner that provides adequate safety margins.

III. Supporting Analyses

Numerous analyses have been performed by TVA and its subcontractors during the past two years to study the effects of mitigating hydrogen by controlled ignition on ice condenser containment structures and equipment during selected degraded core accidents.

Calculations of containment atmospheric pressure and temperature have been performed using the CLASIX computer code developed by Westinghouse Offshore Power Systems. The CLASIX code results have been compared favorably to results from other containment codes. The code also has been shown to conservatively predict the response from several experiments. For input to the CLASIX code, values for combustion parameters were obtained from the literature and values for hydrogen and steam release rates were calculated with the NRC-funded MARCH code. Enough sensitivity studies were performed on containment parameters, combustion parameters, and release rates to reasonably bound the expected response. The calculated peak containment pressure for the base case set of parameters was 19 psig while the highest pressure calculated in the sensitivity studies was less than 28 psig.

The response of the containment shell and internal structures to these static pressure loads has been evaluated. The minimum calculated structural capacity at yield of 45 psig bounds these calculated internal pressures with considerable margin.

Our analyses and research have indicated that dynamic loads from a detonation do not have to be considered because detonation is not a credible phenomenon in the containment. Briefly, this is because: (a) there are no high-energy sources to initiate a detonation, (b) there would be no rich concentrations throughout the containment because the distributed igniters would initiate combustion as the mixture reached the lower flammability limit and because effective mixing would occur, and (c) there are no areas of the containment with sufficient geometrical confinement to allow for the flame acceleration necessary to yield a transition to detonation. However, at the NRC's request, TVA has calculated the response of the containment shell to an impulse pressure from a hypothetical local detonation. The results showed that a margin of safety of three existed before material yield would be reached.

The survivability of key equipment has been evaluated for the calculated atmospheric pressure and temperature profiles augmented by radiative flame effects. The equipment temperature response was calculated using the NRC-funded HEATING5 code and the results were compared with the original qualification temperatures. This comparison showed that the key equipment would survive under postaccident conditions including combustion.

In summary, these analyses have demonstrated that the containment structures and key equipment would survive the effects of selected degraded core accidents when mitigated by the PHMS and continue to remain intact and operational. We conclude that the PHMS, as supported by the analyses described here, is adequate and would perform its intended function in a manner that provides adequate safety margins.

IV. Supporting Research

Extensive research has been sponsored by TVA, Duke, AEP, and Electric Power Research Institute (EPRI) during the past two years to study hydrogen combustion, distribution, and mitigation. The research programs were designed to be confirmatory in nature. They were necessarily limited in scope and depth due to time constraints imposed by the Sequoyah operating license conditions and the availability of test facilities. The programs focused on the engineering applications of hydrogen combustion technology in support of a mitigation system.

TVA, Duke, and AEP sponsored combustion experiments at Fenwal Incorporated to investigate the ignition characteristics and reliability of the General Motors (GM) igniter used in the Interim Distributed Ignition System. TVA, Duke, AEP, and the EPRI sponsored an integrated research program at Whiteshell Nuclear Research Establishment, Factory Mutual Research Corporation, Acurex Corporation, and Hanford Engineering Development Laboratory. In one phase of the Whiteshell tests, the lean ignition limits and minimum surface temperatures were determined for both the GM and Tayco igniter. In other tests at Whiteshell, the extent of reaction of lean mixtures, the behavior of deflagrations in rich mixtures, the effects of fan- and obstacle-induced turbulence, and the behavior in an extended vessel geometry were each investigated. At Factory Mutual, the pressure suppression effects of a water micro-fog were studied in small scale. In the intermediate-scale tests at Acurex, the effects of igniter location within the test vessel and the presence of a water micro-fog were both investigated. Simulation of postaccident conditions in an ice condenser lower compartment was performed at Hanford to study the potential for hydrogen pocketing or nonuniform distribution. TVA also conducted experiments at its Singleton Laboratory on the survivability of electrical cables and the durability of igniters under cycling, endurance, and combustion conditions.

The original research programs have been successfully concluded and the data have been submitted to the NRC. The tests showed no unexpected results and confirmed the judgments made in the design and analysis supporting the PHMS. Both types of igniters were shown to be reliable and effective under a wide range of conditions. In general, the combustion parameter results agreed with values from the literature. In particular, the transient tests exhibited sequential combustion accompanied by relatively mild pressure rises which are characteristic of the behavior calculated with the CLASIX code. No detonations were ever observed even at high concentrations of hydrogen or in an extended vessel geometry. The micro-fog was ineffective as a heat sink for pressure suppression during combustion. The Hanford simulation showed good mixing with no pocketing of hydrogen.

We conclude that the PHMS, as supported by the research here, is adequate and would perform its intended function in a manner that provides adequate safety margins.

V. Conclusions

TVA has designed a Permanent Hydrogen Mitigation System employing controlled ignition to mitigate the effects of hydrogen during potential degraded core accidents at the Sequoyah Nuclear Plant. The system is redundant, capable of functioning in a postaccident environment, seismically supported, capable of actuation from the main control room, and has an ample number of igniters distributed throughout the containment. The containment structures and key equipment have been shown by analysis or testing to survive the pressure and temperature loads from selected degraded core accidents and to continue to function. An extensive research program has confirmed our analytical assumptions, demonstrated equipment survivability and shown that controlled ignition can indeed mitigate the effects of hydrogen releases in closed vessels. We conclude that the PHMS is an adequate hydrogen control system that would perform its intended function in a manner that provides adequate safety margins.

ATTACHMENT TO ENCLOSURE
TECHNICAL SUMMARY REPORT
ON THE ADEQUACY OF THE
PERMANENT HYDROGEN MITIGATION SYSTEM
FOR THE
SEQUOYAH NUCLEAR PLANT

SEPTEMBER 1982

TENNESSEE VALLEY AUTHORITY

TABLE OF CONTENTS

- I. Introduction
- II. Permanent Hydrogen Mitigation System Description
- III. Supporting Analyses
 - A. Structures
 - B. Equipment
- IV. Supporting Research
 - A. Fenwal Incorporated
 - B. Whiteshell Nuclear Research Establishment
 - C. Factory Mutual Research Corporation
 - D. Acurex Corporation
 - E. Hanford Engineering Development Laboratory
 - F. TVA Singleton Materials Engineering Laboratory
- V. Conclusions
- VI. References

I. Introduction

This report is a technical summary whose purpose is to substantiate the Tennessee Valley Authority's (TVA) position that the Permanent Hydrogen Mitigation System (PHMS) is an adequate hydrogen control system for the Sequoyah Nuclear Plant and would perform its intended function in a manner that provides adequate safety margins. The report draws from and references the many technical reports that have been submitted by TVA to the NRC over the past two years. First, the criteria and final design for the PHMS is described. Next, a discussion is provided of the numerous analyses performed to determine the effects on key structures and equipment of mitigating degraded core accidents with the PHMS. Last, the research program conducted to confirm our understanding of hydrogen combustion control is reviewed. Throughout this report, resolution of the various technical issues that have been raised (containment capability, equipment survivability, local detonation, etc.) is provided and application of the test data and analyses is made in support of the adequacy of the PHMS.

II. Permanent Hydrogen Mitigation System (PHMS) Description

TVA has selected the concept of controlled ignition using thermal igniters for the PHMS at the Sequoyah Nuclear Plant. Briefly, the concept is to reliably ignite lean hydrogen-air mixtures throughout the containment to achieve periodic or continuous burning. This moderated energy addition rate would allow the containment heat sinks to absorb the heat of combustion more effectively and reduce the overall containment pressurization. This selection was made after a number of alternative concepts were thoroughly evaluated and compared. In early 1980, the TVA Board of Directors requested the TVA staff to investigate potential mitigation systems for degraded core accidents at Sequoyah. An intensive study was undertaken of concepts to prevent or minimize the effects of hydrogen combustion such as preinerting with nitrogen, postinerting with Halon, or controlled ignition. Also investigated were concepts to increase containment capacity for overpressure events such as augmented atmospheric cooling or various forms of containment venting. Each of these mitigation strategies was evaluated based on their effectiveness, technical feasibility, additional risk, reliability, and cost. The report recommended the implementation of a controlled ignition system. This concept was the basis for the Interim Distribution Ignition System (IDIS), installed at Sequoyah in the summer of 1980.

Beyond this commitment to the IDIS, TVA, together with Duke Power and American Electric Power (AEP), continued to investigate alternative methods of hydrogen control. The potential electromagnetic interference effects of spark igniters were examined. A conceptual design study for a postaccident Halon 1301 injection system was commissioned. The corrosive effects on stainless steel of Halon decomposition products were later demonstrated by TVA at its Singleton Materials Engineering Laboratory. Bench-scale tests on controlled combustion with catalytic combustors were performed and the effects of catalyst poisoning by fission products were investigated. TVA also evaluated controlled ignition enhanced with spray fogging, oxygen removal with a gas turbine, and postaccident inerting with carbon dioxide. After completing all these evaluations and comparing the alternatives, TVA selected controlled ignition for the PHMS. Brief descriptions are provided below of the PHMS and its design criteria, operating procedure, surveillance testing, and technical specifications.

To assure that hydrogen would be ignited at any containment location as soon as the concentration exceeded the lower flammability limit, a durable thermal igniter capable of maintaining an adequate surface temperature was specified. An igniter developed by Tayco Engineering was selected for use in the PHMS since it operates at a more standard plant voltage of 120V ac than the lower voltage required by the General Motors (GM) glow plug used in the IDIS at Sequoyah. The Tayco model igniter has been shown by experiment to be capable of maintaining surface temperatures in excess of the required minimum for extended periods, initiating combustion, and continuing to operate in

various combustion environments. Information on such proof testing is included in sections IV.B and IV.F of this summary report.

To assure adequate spatial coverage, a total of 64 igniters will be distributed throughout the major regions of containment in which hydrogen could be released or to which it could flow in significant quantities (see figure). There will be at least two igniters, controlled and powered redundantly, located in each of these regions. Following a degraded core accident, any hydrogen which is produced would be released into the lower compartment inside the crane wall. To cover this region, 22 igniters (equally divided between trains) will be provided. Eight of these will be distributed on the reactor cavity wall exterior and crane wall interior at an intermediate elevation to allow the partial burning that accompanies upward flame propagation. Two igniters will be located at the lower edge of each of the five steam generator and pressurizer enclosures, two in the top of the pressurizer enclosure, and another pair above the reactor vessel in the cavity. These 22 lower compartment igniters would prevent flammable mixtures from entering the ice condenser. Any hydrogen not burned in the lower compartment would be carried up through the ice condenser and into its upper plenum. Since steam would be removed from the mixture as it passed through the ice bed, thus concentrating the hydrogen, mixtures that were nonflammable in the lower compartment would tend to become flammable in the ice condenser upper plenum. This phenomenon is supported by the CLASIX containment analysis code (discussed in section III.A of this summary report) which predicts more sequential burns to occur in the upper plenum than in any other region. Controlled burning in the upper plenum is preferable since the amount of hydrogen consumed in each lean-limit burn is so low due to the relatively small volume of the region that the energy addition rate to the containment is moderated. We also conclude, based on the expert opinion of Dr. Bernard Lewis and Bela Karlovitz, that there is no realistic potential for a transition to detonation in the upper plenum because the available ignition strength is weak, the entering mixtures will be just-flammable, and the plenum does not have sufficient geometrical confinement above or below the region of combustion. Therefore, we have chosen to take advantage of the beneficial combustion characteristics of the upper plenum by distributing 16 igniters equally around it. Four igniters will be located around the upper compartment dome, four more around the top inside of the crane wall, and one above each of the two air return fans. The air return fans provide recirculation flow from the upper compartment through the 'dead-ended' volume and back into the main part of the lower compartment. To cover this region, there will be a pair of igniters in each of the rooms (a total of 16 igniters) through which the recirculation flow passes.

The PHMS components inside containment will maintain their functional capability under postaccident conditions. These components will survive the effects of multiple hydrogen burns and will be protected from spray impingement and flooding. In addition, the PHMS components will be seismically supported.

The igniters in the PHMS are equally divided into two redundant groups, each with independent and separate controls, power, and locations, to ensure adequate coverage even in the event of a single failure. Manual control of each group of igniters will be provided in the main control room and the status (on-off) of each group will be indicated there. The system would be energized manually following any accident upon the occurrence of any condition which indicates inadequate core cooling without waiting for a potential hydrogen buildup. Separate trains of Class 1E 480V ac auxiliary power will be provided for each group of igniters and will be backed by automatic loading onto the diesel generators upon loss of offsite power. Each individual circuit will power two igniters and have a design voltage of 120V ac.

Surveillance testing proposed for the PHMS will consist of energizing the system from the main control room and taking voltage and current readings from each circuit at the distribution panels located in the auxiliary building. These readings can then be compared to ones taken during preoperational testing of the system to indicate whether or not both igniters on each circuit are operational without requiring containment entry. The operability of at least 31 of the 32 igniters per train would conservatively guarantee an effective coverage throughout the containment. Appropriate technical specifications on test intervals and restoration to operable status have previously been proposed.

We conclude that the PHMS design, as described here, with igniter type and locations, redundancy, capability of functioning in a postaccident environment, seismic support, main control room actuation, and remote surveillance is adequate and the system would perform its intended function in a manner that provides adequate safety margins.

III. Supporting Analyses

Numerous analyses have been performed by TVA and its contractors during the past two years to study the effects of mitigating hydrogen by controlled ignition on ice condenser containment structures and equipment during selected degraded core accidents. Calculations of containment atmospheric pressure and temperature during these accidents have been performed using the CLASIX code. The response of the containment shell and internal structures to the peak calculated pressures has been evaluated. The response of the containment shell to an impulse pressure from a hypothetical local detonation has been calculated. The survivability of key equipment has been evaluated for the calculated atmospheric pressure and temperature profiles augmented by radiative flame effects. The analyses have demonstrated that the containment structures and key equipment would survive the effects of selected degraded core accidents when mitigated by the PHMS and continue to remain intact and operational. We conclude that the PHMS, as supported by the analyses described below, is adequate and would perform its intended function in a manner that provides adequate safety margins.

A. Structures

Containment atmospheric pressure loadings on the shell and internal structures during degraded core accidents including hydrogen combustion have been calculated using the CLASIX containment analysis code written by Offshore Power Systems (OPS), a division of Westinghouse. The expertise developed over the years in writing and verifying NRC-accepted design basis containment analysis codes was used as a basis for this effort. The ice condenser containment was modeled in CLASIX using such standard assumptions as homogeneous volume nodes. Extensions to this traditional methodology were included in the code to account for the effects of degraded core accidents such as hydrogen combustion. Hydrogen combustion was represented by a simple model that added the heat released during burning to the surroundings when flammability criteria were met in that region. The CLASIX code has been compared by OPS to TMD, an NRC-accepted subcompartment ice condenser analysis code, and to COCOCLASS9, a degraded core accident containment analysis code based on the NRC-accepted COCO code. The comparisons showed good agreement. The CLASIX code was also used to model hydrogen combustion experiments conducted at Fenwal Incorporated and Lawrence Livermore National Laboratory. The code conservatively overpredicted the pressure and temperature response measured during the tests. We conclude that the CLASIX code is adequate to use for conservative prediction of the ice condenser containment response to degraded core accidents including hydrogen combustion.

The CLASIX input required to model the Sequoyah containment response to such an event consisted largely of physical parameters such as volumes, areas, and material properties that have been used previously in design basis licensing analyses. Several of these parameters, including containment spray flow rate, initial ice mass, and air return fan flow rate, were varied in sensitivity

studies. In addition, several hydrogen combustion parameters were specifiable in the input to allow for a wide range of sensitivity studies. These include the lower flammability limit (LFL), the fraction of burn completeness, and the burn duration. The burn duration actually represents the pressure rise time based on flame propagation at a constant speed after simultaneous ignition at all igniters located in that volume. In our latest studies, the conservative assumptions used in the base case calculation were an LFL of 8 volume percent, a burn fraction of 85 percent, and a flame propagation speed of 6 ft/sec. The parameters assumed in the best estimate calculation were an LFL of 6 volume percent, a burn fraction of 60 percent, and a propagation speed of 3 ft/sec. In the various sensitivity studies, the LFL was varied between 4 and 10 volume percent, the burn completeness fraction between 40 and 100 percent, and the burn duration based on flame speeds between 1 and 12 ft/sec. These value ranges are supported by numerous references in the literature for turbulent combustion in lean-limit mixtures. Results from the recent Electric Power Research Institute (EPRI) -utility lean-limit hydrogen combustion experiments validated the use of these value ranges. Information and conclusions from this combustion research is included in sections IV.E, IV.C, and IV.D of this summary report. In further comparisons to actual data, as stated above, the CLASIX code was able to conservatively overpredict experimental pressures measured at two different facilities. The parameter sensitivity studies were performed to bound reported data and to account for such postulated phenomena as steam inerting the lower compartment or fogging reducing the burn completeness in the upper plenum. We conclude that the combustion parameter input, including sensitivity variations, is adequate to be used in the CLASIX code for conservative prediction of containment response.

Another set of CLASIX input parameters required to model a degraded core event included the hydrogen and steam release rates into the containment. Allowances were made in the CLASIX code for these input parameters to be varied over a wide range since they would be dependent on the accident sequence being studied. A small-break LOCA with failure of safety injection (S₂D) was chosen as the base case for analysis because it is similar to the TMI-2 class of accidents. The S₂D event is also an appropriate selection because it is believed to be the most probable accident sequence that would result in core damage at Sequoyah. Recovery of core cooling was assumed to occur prior to core slump and the cladding reaction was terminated at a conservative level of 75 percent. In addition, a review of other probable scenarios shows the S₂D transient results in more than twice as much hydrogen generation prior to core slump as was found in the other scenarios. Beyond the S₂D base case, sensitivity studies were performed to evaluate the effects of increasing the hydrogen release rate throughout the event by as much as a factor of three and increasing the rate in a 'spike' fashion over a segment of the event. In addition, the hydrogen release rates from analyses (using the MARCH computer code) of a number of other accident sequences were reviewed and found to be bounded by either the S₂D base case or the sensitivity studies. The S₂D base case release rate used in the TVA analysis also bounded the release rates presented in NUREG/CR-2540, 'A

Method for the Analysis of Hydrogen and Steam Releases to Containment During Degraded Core Cooling Accidents.' Since the PHMS is intended to mitigate degraded core events which are terminated prior to core slump, the release rates during the core recovery phase were calculated and also found to be less than already covered by the studies. We conclude that the hydrogen and steam release rate input, including sensitivity variations, is adequate to use in the CLASIX code for conservative prediction of containment response.

The CLASIX code calculations for the base case set of input parameters described above resulted in a peak containment pressure of 19 psig. The best estimate case resulted in a peak pressure of less than 12 psig, the containment design pressure. The highest peak pressure that resulted from any of the numerous sensitivity studies was less than 28 psig. As described below, the Sequoyah containment yield strength has been calculated to be at least 45 psig.

Structural analyses have been performed to determine the static pressure capability of the containment and internal structures. The pressure rise resulting from a hydrogen deflagration is slow enough to be treated as a static pressure load in the analysis. The associated temperature effects were found to be negligible. An elastic-plastic analysis was performed by TVA using a finite element model of the limiting section (1/2' cylindrical plate between elevations 756' 3" and 810' 3") of the steel containment shell. All other containment boundary components were evaluated and it was determined that this shell section was limiting in terms of containment yield strength. Using the actual minimum yield strength of the plate material, the yield pressure of this shell section was found to be at least 45 psig. Other independent structural evaluations have been made that confirmed this minimum capacity. An evaluation was also made of the concrete divider deck (the main internal structure between the upper and lower compartment) that revealed its differential pressure capacity to be equal to or greater than the containment shell capacity. We conclude that the capability of the containment shell and internal structures is adequate to withstand the static pressure loads during hydrogen combustion in the degraded core accidents studied.

In addition to these analyses of static pressure capability, TVA has performed an analysis of the dynamic response of the containment to an impulse load from a hypothetical local detonation. Development of the impulse load and the structural analysis was requested by the NRC, although our analyses and research have indicated that local detonation is not a credible phenomenon in the containment. To briefly review, several factors affect the potential for a detonation including ignition strength, hydrogen concentration, and geometrical confinement. Addressing these factors individually, the thermal igniters used for controlled ignition are considered by experts, including Dr. Roger Strehlow (an NRC consultant), to be 'soft' or 'weak' sources of ignition and as such are not likely initiators of detonation. Second, rich concentrations of hydrogen will not be present

throughout large regions of the containment because the PHMS igniters will initiate combustion near the LFL. This has been demonstrated on numerous occasions (see sections IV.A, IV.B, IV.C, and IV.D) including tests in the presence of steam or spray. In addition, isolated rich concentrations away from the source due to extreme hydrogen gradients or pocketing will not occur. This has been confirmed by results from the mixing tests in the simulated ice condenser containment at Hanford Engineering Development Laboratory (see section IV.E). Third, we have identified no areas of the containment with sufficient geometrical confinement to allow for the extreme flame acceleration necessary to yield a transition to detonation. For example, the vertical ice baskets in the ice condenser are not sufficiently confined radially and the circumferential upper plenum above the ice condenser is not sufficiently confined above or below for a transition to detonation to occur (see section II). Even if rich mixtures were postulated to exist in a confined geometry, it is improbable that a detonation would result. Illustrating this fact are two of the tests conducted at Whiteshell Nuclear Research Establishment that failed to produce a detonation when igniting a stoichiometric (about 29.5 volume percent hydrogen) mixture in an enclosed sphere or even when igniting a 25 volume percent mixture in a pipe attached to the sphere in a configuration more conducive to a transition to detonation. For more information see section IV.B of this summary report. We conclude that detonation is not a credible phenomenon in the ice condenser containment. However, as stated above, TVA has developed an impulse load from a hypothetical local detonation and analyzed the dynamic containment response. The hypothetical load was based on the detonation of a six-foot diameter spherical cloud with wave speeds (to calculate the pressure rise time) and peak overpressures obtained from the literature. The impulse was assumed to act at the center of the same critical containment shell section used for the static analysis. The results showed that a margin of safety of three existed before material yield would be reached. We conclude that the containment shell could survive even such a hypothetical local detonation.

Based on the above analyses, we conclude that the containment structures would survive the effects of selected degraded core accidents when mitigated by the PHMS and continue to remain intact.

B. Equipment

Containment atmospheric pressure and temperature loadings on key equipment in the containment have been calculated using the CLASIX code discussed above in section III.A. The parameters assumed previously for the base case were used again except that the burn duration was based on a low flame speed of one ft/sec chosen at the NRC's request to enhance the heat contribution from the flame. To account for these flame effects, the CLASIX temperature transient in each of the regions containing key equipment selected for analysis was augmented by a radiative heat flux term. The radiative heat flux was imposed during each burn and was based on a conservative adiabatic flame temperature of 1400^oF. This

combined temperature load was imposed on the equipment in an analysis using the standard HEATINGS thermal code which was developed with NRC funding. The equipment was initially assumed to be in equilibrium at the highest preburn atmospheric temperature resulting from the postulated degraded core accident. The thermal analysis was extended until well after all the temperature peaks associated with burns had passed.

Key equipment inside containment essential for safe shutdown of the plant was identified. That subset of equipment either considered to be potentially sensitive to temperature or located in regions of numerous burns such as the ice condenser upper plenum was then selected. This subset would bound the remaining key equipment items for the evaluation of temperature survivability. The pressure capability of the key equipment was judged to be controlled by the limiting containment shell section pressure capability described above in section III.A. The subset of key equipment included the exposed incore thermocouple cable and hot and cold leg RTD cable, the Interim Distributed Ignition System (IDIS) igniter assembly, the igniter assembly power cable in conduit, and a transmitter assembly representative of the types installed in the plants. The decision was made to test the exposed cables rather than attempting to analyze them due to the potential for changing surface properties (see section IV.F). Thermal analyses were performed on the remaining key components.

The igniter assembly analysis was performed on a Sequoyah IDIS assembly which should conservatively bound the PHMS assembly response. It showed that the core of the transformer inside the igniter assembly would reach 157°F while the transformer windings were designed to operate at up to 428°F. Analysis also showed that the conduit for the igniter assembly power cable would reach 332°F (and the interior even less) while tests conducted at TVA's Singleton Laboratory showed the cable in conduit would function without degradation up to 600°F. The transmitter analysis resulted in a casing surface temperature of 245°F (and the interior even less) while the transmitter has been qualified to operate at 320°F. This thermal analysis methodology was compared to an NRC-accepted Westinghouse equipment thermal qualification model and showed good agreement. In addition, the methodology was applied to sample Fenwal test data and found to conservatively overpredict thermal response.

In addition to the key subset described above, the effects of temperature and pressure were evaluated for other key equipment such as the air return fans. No burns were predicted by CLASIX to occur in the upper compartment for the base case parameter assumptions. However, even for those sensitivity studies which resulted in upper compartment burns, the atmosphere only very briefly exceeded the elevated temperatures at which the fans were designed to operate in an emergency. In addition, the massive fan motor and casing (weighing approximately 1300 lbs.) have a significant amount of thermal inertia. The backdraft dampers above the fans avoid pressure loads on the fans during lower compartment pressurization. Again, no upper compartment burns are predicted for the base case. However, the fan blades have been

structurally analyzed to take a static load (in addition to the normal operating stresses) greater than even the maximum peak differential pressure predicted in the sensitivity studies discussed in section III.A.

In addition to analyzing the survivability of the key equipment described above, special areas such as the foam insulation around the ice condenser were evaluated for temperature effects. A thermal analysis using the HEATING code mentioned above was performed by Duke Power to evaluate whether heat from combustion in the ice condenser could decompose the foam to form flammable products. The analysis showed that even the heat flux from a constant band of flame applied locally for 45 minutes to the ice condenser walls would not be sufficient to elevate the foam behind it to its pyrolysis temperature.

Based on the above analyses and tests, we conclude that the containment key equipment would survive the effects of selected degraded core accidents when mitigated by the PHMS and continue to remain operational.

IV. Supporting Research

Extensive research has been sponsored by TVA, Duke, AEP, and EPRI during the past two years to study hydrogen combustion, mitigation, and distribution. The research programs were designed to be confirmatory in nature. They were necessarily limited in scope and depth due to time constraints imposed by the Sequoyah operating license conditions and the availability of test facilities. The programs focused on the engineering applications of hydrogen combustion technology in support of a mitigation system. TVA, Duke, and AEP sponsored combustion experiments at Fenwal Incorporated. TVA, Duke, AEP, and EPRI sponsored research at Whiteshell Nuclear Research Establishment in combustion and igniter development, at Factory Mutual Research Corporation in combustion and mitigation, at Acurex Corporation in combustion and mitigation, and at Hanford Engineering Development Laboratory in distribution. TVA conducted experiments at its Singleton Laboratory in equipment survivability and igniter development. The original research programs have been successfully concluded and the data have been submitted to the NRC. To summarize, the tests showed no unexpected results and confirmed the judgments made in the design and analysis supporting the PHMS. We conclude that the PHMS, as supported by the research described here, is adequate and would perform its intended function in a manner that provides adequate safety margins.

A. Igniter Performance Testing - Fenwal, Incorporated

A two-phase experimental program was undertaken at Fenwal to investigate the ignition characteristics and reliability of the General Motors (GM) igniter. The test vessel was a 134 ft³ steel sphere that was heated and insulated. Phase 1 consisted of a series of premixed combustion tests with hydrogen concentrations at 8, 10, and 12 volume percent. The effects of fan-induced turbulence and steam addition were investigated in several tests. The performance of the GM igniter in igniting hydrogen mixtures was demonstrated to be reliable. In addition, comparison of such test results as pressure rises and ignition limits with previously published information showed good agreement.

The Phase 2 follow-on tests consisted of further premixed tests with hydrogen concentrations between 5-10 volume percent, tests where hydrogen was continuously injected into the test vessel, and a series of tests using water sprays. The most important result of the Phase 2 program was the ability of the igniter to reliably ignite lean hydrogen mixtures under adverse conditions, including the presence of steam and water sprays, and to continue to operate. The minimal pressure rises experienced during the continuous injection tests indicated the igniter's capability to initiate local combustion of hydrogen-air mixtures just as they became flammable. The series of sequential burns that occurred during the continuous injection tests were characteristic of the behavior predicted with the CLASIX code (section III.A). No detonations were ever observed even when pure hydrogen was being admitted to the vessel during the transient tests.

B. Hydrogen Combustion Phenomena - Whiteshell Nuclear Research Establishment

The experimental program at Whiteshell consisted of a small-scale igniter testing segment and a multifaceted large scale segment aimed at enhancing our understanding of basic combustion phenomena. The results of this program are summarized below.

Small-scale tests were performed in a 17-liter vessel to provide further evidence of the capability of both GM and Tayco thermal igniters to reliably ignite lean hydrogen mixtures. Numerous tests were conducted to determine the lower ignition limits and corresponding igniter surface temperatures in various premixed hydrogen-air-steam mixtures. Hydrogen concentrations were varied between 4-15 volume percent and steam concentrations varied between 0-60 volume percent. The measurement of igniter surface temperature required for ignition showed that the igniter at its normal operating temperature has considerable margin even for high steam concentrations.

The larger-scale tests were performed in the Whiteshell Containment Test Facility using a 223 ft³ heated and insulated metal sphere and, for some tests, a 20-foot long by 1-foot diameter attached pipe. These tests were grouped into four principal areas:

- (a) Extent of reaction of lean mixtures
- (b) Laminar spherical deflagration
- (c) Effects of fan- and obstacle-induced turbulence
- (d) Extended geometry (sphere and attached pipe)

The lean mixture tests were performed in the sphere to investigate the extent of reaction under various conditions of steam and fan-induced turbulence. Hydrogen concentrations were varied between 5-11 volume percent and steam between 0-30 volume percent. Fans were activated in several of the tests. Results were in agreement with previously-published data on the flammability of lean mixtures. Results also showed that the addition of relatively large (over 30 volume percent) amounts of steam reduced the pressure rise following burns due to the added heat capacity. This indicates that pressure rise data from dry tests may be overconservative for application to plant environments with high steam concentrations. Results also showed that turbulence increased the rate and magnitude of pressure rise for a given concentration by increasing the burn completeness, thus corroborating the Fenwal results. This indicates that burning at relatively lean concentrations would be promoted by the turbulent plant conditions.

The laminar spherical deflagration tests were performed in the sphere to compare the actual pressure rises with the corresponding theoretical adiabatic pressure rises and to confirm that no detonations would result even at high concentrations of hydrogen. Hydrogen concentrations were varied between 10-42 volume percent and steam between 0-40 volume percent. Fans were activated in several tests. Results again showed that the addition of large amounts of steam reduced the pressure rise following burns. The

actual pressure was always less than the theoretical pressure and the margin increased as the hydrogen concentration was increased. No detonations were observed even at stoichiometric and higher concentrations of hydrogen which are classically considered to be detonable.

The turbulence tests were performed in the sphere to investigate the effects of turbulence induced by fans and gratings on the extent and rate of combustion. In these tests, hydrogen concentrations varied between 6-27 volume percent. One test was run with 10 volume percent steam. Results showed that for rich mixtures, forced turbulence did not increase the overall pressure rise but did increase the rise rate slightly. In lean mixtures without fans, the presence of gratings tended to increase the magnitude and rate of pressure rise. At high concentrations or with fans, the gratings reduced both the magnitude and rate of pressure rise by acting as heat sinks. These results indicate that no unanticipated pressure effects result from forced turbulence even at high concentrations of hydrogen.

The extended geometry tests were performed by attaching the pipe to the side of the sphere. The effects of varying igniter location, fans, and unequal concentrations in each vessel were investigated. The hydrogen concentration varied between 6-25 volume percent. All of these tests were run without adding steam. Results of varying the igniter locations between the end of the pipe and the center of the sphere confirmed that lean mixtures propagate a flame more readily in the upward than horizontal direction and in the presence of turbulence. Although the burst disc initially separating the mixtures in the pipe and sphere induced local turbulence which enhanced the rate and extent of reaction, no significant effects of propagating flames between unequal concentrations were observed. Even in a long, narrow pipe, at high concentrations of hydrogen with no steam present, no detonation occurred.

The Whiteshell tests investigated a number of parameters related to the potential hydrogen combustion phenomena inside the containment. Based on their results, we conclude that the GM and Tayco igniters would reliably ignite lean mixtures of hydrogen in a postaccident environment. We also conclude that the observed effects of steam, induced turbulence, connected geometries, and unequal concentrations on the nature of hydrogen combustion have confirmed our previous understanding. None of the results would preclude the application of distributed ignition for postaccident hydrogen control. In particular, the tests are important for what they did not show, the occurrence of a detonation even in the presence of extremely severe conditions.

C. Water Micro-Fog Inerting - Factory Mutual Research Corporation

The Factory Mutual project was the first of a two-part experimental program to investigate the pressure suppressant effects of a water micro-fog. The purpose of the Factory Mutual project was to experimentally identify in small scale a set of nominal micro-fog conditions for investigation in the Acurex

intermediate scale hydrogen combustion studies (Section IV.D). Since the interest was in the pressure suppressant effects of a water micro-fog, the Factory Mutual project was necessary in order to avoid inadvertently inerting the Acurex test vessel. Therefore, the approach taken by Factory Mutual to achieve the project objective was to experimentally determine the water micro-fog requirements for inerting hydrogen-air mixtures and then simply recommend to Acurex a set of micro-fog conditions that did not meet those requirements. Emphasis was placed on visually dense fogs with number mean droplet sizes between 1-100 microns.

Tests were conducted in a plexiglas tube approximately 3.5 feet long with a 6 inch inner diameter. A 2.8 Joule spark served as the ignition source. Several tests were also conducted with a GM glow plug as the ignition source to verify the applicability of these tests to installed distributed ignition systems. Thermocouples were used to determine the presence of combustion. Five different spray nozzles were used in order to obtain different fog conditions, i.e., a characteristic droplet size and density. Varying the pressure drop across each spray nozzle also allowed different fog conditions to be obtained. Additionally, the micro-fog temperature and hydrogen concentration were varied.

Test results showed that at ambient conditions, visually dense water micro-fogs only marginally increase the hydrogen lower flammability limit. Additionally, as the characteristic droplet size is increased, the fog density required to maintain the same level of inerting is significantly increased. It was also demonstrated that increasing the micro-fog temperature increases the effect on the hydrogen lower flammability limit. Finally, the Factory Mutual tests showed that a glow plug and a strong spark source performed with no noticeable difference in combustion results.

D. Hydrogen Combustion Control Studies - Acurex Corporation

The Acurex project consisted of two phases. Phase 1 investigated the effect of igniter location within an enclosed compartment, while Phase 2 was the second of the two-part water micro-fog program (see Section IV.C). Quiescent tests have been conducted by other organizations where the ignition source location was varied. However, conditions inside the containment during a degraded core accident cannot be considered quiescent. Thus, the purpose of the Phase 1 test program was to qualitatively address the importance of igniter location during transient conditions. The purpose of the Phase 2 test program was to experimentally investigate the pressure suppressant effects of the two water micro-fog conditions recommended by Factory Mutual in both transient and quiescent tests.

Tests were conducted in a 17-foot high vessel with a 7-foot inner diameter. The total free volume was approximately 630 ft³. Thermocouples were used to detect flame front location and vessel atmosphere temperature. Strain gauge and piezoelectric pressure transducers were used to measure the vessel atmospheric pressure. Transient tests were conducted in Phases 1 and 2 with a continuous

injection of either hydrogen or a hydrogen-steam mixture. The hydrogen and hydrogen-steam flow rates used in the tests were calculated by applying the volume ratio of the test vessel and the combined lower and 'dead-ended' plant compartments to the average release rates calculated with the MARCH Code for an S₂D accident sequence. An igniter assembly supplied by Duke Power was preenergized for all transient tests. In the Phase 1 tests, the igniter was located either near the top, at the center, or near the bottom of the test vessel. Some Phase 1 tests were conducted with water sprays present. Phase 2 tests were conducted both with and without two separate micro-fog conditions and with various hydrogen concentrations. The Phase 2 transient tests were conducted with the bottom igniter location.

Results of the Phase 1 tests indicated that igniter location has some effect on combustion characteristics. This effect was shown to depend on: (1) whether the test was quiescent or transient, (2) the location of the igniter relative to the hydrogen source, and (3) the amount of turbulence present. The tests showed that, during transient injection periods, the pressure rise was less when the igniter was located near the region where the entering hydrogen mixed and first became flammable. The location of this region within containment would be determined by the geometry of each plant compartment, the hydrogen entry location and velocity, and the presence of turbulence within the compartment. Since these tests have demonstrated the desirability of near-limit combustion, we conclude that igniters should be located in the ice condenser upper plenum to allow near-limit combustion to occur as the hydrogen exits from the ice condenser. The Phase 1 tests also indicated that the potential for a larger pressure rise existed when the hydrogen source jet continued to bypass the igniter until the bulk of the vessel had reached a flammable concentration. This would tend to support locating igniters in the upper portion of the lower compartment to preclude the source jet from potentially bypassing nearby igniters. It is important to note that multiple igniters were located throughout the containment regions at various elevations to ensure near-limit combustion (see Section II). In addition, it is noteworthy that the Hanford tests (described in Section IV.E) demonstrated that the lower compartment region would be well-mixed, which, according to the Acurex tests, tends to reduce the significance of igniter location relative to the inlet mixing region. The Phase 1 tests also confirmed previous findings on the pressure mitigative effects of steam and water sprays due to turbulence-induced mixing.

Results of the Phase 2 tests showed that a water micro-fog had no pressure mitigative effect during hydrogen combustion in quiescent mixtures. This indicated that the dominant effect of the fog droplets was not as a heat sink. The pressure mitigative effect of micro-fogs in the transient tests seemed to be due to induced turbulence similar to the effect of sprays in some of the Phase 1 tests. This induced turbulence promoted mixing which enhanced the potential for near-limit combustion of the entering hydrogen.

Since an ice condenser containment would be sufficiently turbulent to ensure good mixing during a degraded core accident (see Section IV.E for a discussion of the Hanford tests), we conclude that inducing additional turbulence with micro-fogging would be unnecessary.

In addition to the above conclusions based on the test objectives, an evaluation of the tests revealed additional information from which conclusions were drawn. The GM igniter assemblies, identical to those in Duke Power's McGuire Nuclear Station and very similar to those used in the TVA IDIS, survived over five cumulative hours of exposure to combustion test environments. The assembly and power cable continued to operate without failure. The second additional conclusion dealt with estimated flame speeds. Although the test was not specifically instrumented to obtain flame speeds, it was possible to calculate 'average' flame speeds from the pressure rise data of several transient and quiescent tests. The calculated flame speeds in the transient tests varied from 1-2 ft/sec with steam present and either top or bottom ignition to 4 ft/sec with no steam present and bottom ignition. Flame speeds from the quiescent tests varied from 3-8 ft/sec as the hydrogen concentration was increased from 5 to 11 volume percent. Thus, we conclude that these data support the flame speed ranges used in the CLASIX analyses (see Section III.A). Another important result of the transient test series was that the nature of combustion was always deflagrative instead of detonative even when a hydrogen-rich mixture was entering the vessel. Perhaps the most significant observation was the extreme contrast in pressure rise between quiescent and transient combustion tests. The pressure rises during all of the transient tests in both Phase 1 and 2 was dramatically less than during the quiescent tests (with the exception of one very lean mixture quiescent test). From this contrast, we conclude that caution must be used in the direct application of data from quiescent tests to the investigation of transient conditions. A final conclusion is that since the expected containment postaccident environment would more closely resemble the transient test conditions, it follows that the pressure rises from sequential combustion should be relatively benign.

E. Hydrogen Distribution - Hanford Engineering Development Laboratory

Tests were conducted at Hanford to investigate the potential for nonuniformities or gradients in the distribution of hydrogen during a degraded core accident in an ice condenser containment. The purpose was twofold: (1) to investigate whether the potential existed for pocketing of rich mixtures that could lead to a local detonation and (2) to determine whether the well-mixed nodalization assumptions in the containment analysis were valid. The effects of temperature, forced circulation, and jets were studied. The emphasis was placed on representing a small break LOCA in the ice condenser containment since that was the base case used for design and analysis of the ignition system.

The Hanford Containment Systems Test Facility was selected because its relatively large volume (30,000 ft³) reduced scaling effects and because its interior could be customized to represent the structures of an ice condenser containment. Helium was used as a simulant for hydrogen in most of the tests due to site safety regulations.

Since the upper compartment of the ice condenser containment is well mixed by the sprays, the lower compartment region was chosen for modeling emphasis in the facility. A divider deck, reactor cavity, refueling canal, the air return fans and ice condenser lower inlet doors were all represented. The hydrogen (helium)/steam release was scaled from small break LOCA calculations using the MARCH computer code. Two release scenarios were modeled: (1) a 2' pipe break with a horizontal orientation and (2) a 10' pressurizer relief tank rupture disc opening with a vertically upward orientation. Atmospheric temperatures, velocities, and gas concentrations were measured at several distributed sample points during the tests.

The test results showed that mixing was very good, even without forced circulation by the air return fans. The maximum hydrogen concentration difference at any time during the release between any two sample points in the lower compartment was 2-3 volume percent. In addition, these concentration differences had stopped increasing even before the release period was over. We conclude that there is no potential for pocketing of rich mixtures and that the well-mixed assumptions in the containment analysis were justified.

F. Cable Survivability and Igniter Durability - TVA Singleton Materials Engineering Laboratory

Tests were conducted at Singleton to demonstrate the survivability of electrical cable and the durability of both GM and Tayco igniters. Samples of the exposed incore thermocouple and hot and cold leg RTD cables and the igniter assembly power cable in conduit were subjected to temperatures conservatively higher than calculated containment atmospheric temperature profiles during hydrogen burns. In a separate test series, the GM and Tayco igniters were subjected to durability testing consisting of thermal cycling, endurance, and combustion.

Since surface temperature effects could be important to the survivability of exposed thermocouple and RTD cable in the containment, tests were conducted at Singleton in lieu of analysis. A transient temperature profile that conservatively bounded the calculated transient atmospheric profile of the lower compartment (where the thermocouple and RTD cables are located) was imposed on the exposed cables in an oven. An indication of the conservatism of the test was the fact that the measurement thermocouple placed inside an outer cable jacket showed temperatures during the test even higher than the peak calculated atmospheric temperature in containment. In another test, a constant temperature profile that conservatively bounded the integrated heat flux from the calculated transient atmospheric

profile of the upper plenum (where the igniter power cable would be exposed to the most burns) was imposed on the cable in conduit in an oven. The fact that the cable reached and maintained internal temperatures during the test well above the calculated cable temperature is evidence of the conservatism of this test. Following each of the tests, all the cable insulation successfully passed visual inspection and a resistance check for breakdown under high voltage. We conclude that both the exposed cable and cable in conduit would survive a degraded-core accident that included hydrogen combustion.

Durability tests were performed at Singleton on both the GM and Tayco igniters. The thermal cycling tests consisted of repeated activations in air at several constant voltages. The endurance tests consisted of activation at several constant voltages for extended periods of up to one week. The combustion tests consisted of activations in both a pressurized closed vessel and in a flowing mixture in an open combustion tube. Each of the igniter types continued to operate satisfactorily during all of these tests and successfully passed posttest visual inspections. We conclude that either the GM or Tayco igniter is sufficiently durable to provide controlled ignition in a degraded core accident.

V. Conclusions

TVA has designed a Permanent Hydrogen Mitigation System employing controlled ignition to mitigate the effects of hydrogen during potential degraded core accidents at the Sequoyah Nuclear Plant. The system is redundant, capable of functioning in a postaccident environment, seismically supported, capable of actuation from the main control room, and has an ample number of igniters distributed throughout the containment. The containment structures and key equipment have been shown by analysis or testing to survive the pressure and temperature loads from selected degraded core accidents and to continue to function. An extensive research program has confirmed our analytical assumptions, demonstrated equipment survivability and shown that controlled ignition can indeed mitigate the effects of hydrogen releases in closed vessels. We conclude that the PHMS is an adequate hydrogen control system that would perform its intended function in a manner that provides adequate safety margins.

VI. References

Section II

- Sequoyah Nuclear Plant Hydrogen Study, Volume I (letter from L. M. Mills to A. Schwencer dated September 2, 1980)
- Second Quarterly Research Report (letter from L. M. Mills to A. Schwencer dated March 16, 1981)
- Third Quarterly Research Report (letter from L. M. Mills to E. Adensam dated June 16, 1981)
- Selection of the Permanent Hydrogen Mitigation System for the Sequoyah Nuclear Plant (letter from M. R. Wisenburg to E. Adensam dated July 1, 1981)
- Fourth Quarterly Research Report (letter from L. M. Mills to E. Adensam dated September 22, 1981)
- Response to Additional NRC Questions on Hydrogen Control System (letter from L. M. Mills to E. Adensam dated December 1, 1981)

Section III.A

- Sequoyah Nuclear Plant Hydrogen Study, Volume II, Revision in Response to NRC Questions (letter from J. L. Cross to R. L. Tedesco dated December 11, 1980)
- Additional Information Requested by NRC (letter from J. L. Cross to R. L. Tedesco dated December 17, 1980)
- Resolution of Equipment Survivability Issues for the Sequoyah Nuclear Plant (letters from L. M. Mills to E. Adensam dated June 2, 1981, and June 3, 1981)
- CLASIX Topical Report (letter from L. M. Mills to E. Adensam dated December 1, 1981)
- Response to Additional NRC Questions on Hydrogen Control System (letters from L. M. Mills to E. Adensam dated December 1, 1981, and January 5, 1982)

Section III.B

- Sequoyah Nuclear Plant Hydrogen Study, Volume II, Revision in Response to NRC Questions (letter from J. L. Cross to R. L. Tedesco dated December 11, 1980)
- Additional Information Requested by NRC (letter from J. L. Cross to R. L. Tedesco dated December 17, 1980)
- Resolution of Equipment Survivability Issues for the Sequoyah Nuclear Plant (letters from L. M. Mills to E. Adensam dated June 2, 1981, and June 3, 1981)

- Response to NRC Request for Information on Equipment Survivability for Sequoyah (letter L. M. Mills to E. Adensam dated December 1, 1981)
- Response to Additional NRC Questions on Hydrogen Control System (letter from L. M. Mills to E. Adensam dated December 1, 1981)

Section IV.A

- Sequoyah Nuclear Plant Hydrogen Study, Volume II, Revision in Response to NRC Questions (letter from J. L. Cross to R. L. Tedesco dated December 11, 1980)
- Second Quarterly Research Report (letter from L. M. Mills to A. Schwencer dated March 16, 1981)

Section IV.B

- Fifth Quarterly Research Report (letter from L. M. Mills to E. Adensam dated January 22, 1982)
- Sixth Quarterly Research Report (letter from L. M. Mills to E. Adensam dated April 23, 1982)
- Summary of Testing to Determine Suitability of Tayco Igniter for Use in the Permanent Hydrogen Mitigation System at Sequoyah and Watts Bar Nuclear Plants (letter from L. M. Mills to E. Adensam dated June 14, 1982)
- Seventh Quarterly Research Report (letter from D. S. Kammer to E. Adensam dated July 28, 1982)

Section IV.C

- Fifth Quarterly Research Report (letter from L. M. Mills to E. Adensam dated January 22, 1982)

Section IV.D

- Fifth Quarterly Research Report (letter from L. M. Mills to E. Adensam dated January 22, 1982)


Section IV.E

- Fifth Quarterly Research Report (letter from L. M. Mills to E. Adensam dated January 22, 1982)

Section IV.F

- Sequoyah Nuclear Plant Hydrogen Study, Volume II (letter from L. M. Mills to A. Schwencer dated September 2, 1980)
- Sequoyah Nuclear Plant Hydrogen Study, Volume II, Revision in Response to NRC Questions (letter from J. L. Cross to R. L. Tedesco dated December 11, 1980)

- First Quarterly Research Report (letter from J. L. Cross to R. L. Tedesco dated December 11, 1980)
- Second Quarterly Research Report (letter from L. M. Mills to A. Schwencer dated March 16, 1981)
- Resolution of Equipment Survivability Issues for the Sequoyah Nuclear Plant (letters from L. M. Mills to E. Adensam dated June 2, 1981, and June 3, 1981)
- Fourth Quarterly Research Report (letter from L. M. Mills to E. Adensam dated September 22, 1981)
- Response to Additional NRC Questions on Hydrogen Control System (letter from L. M. Mills to E. Adensam dated December 1, 1981)
- Response to NRC Request for Information on Equipment Survivability for Sequoyah (letter from L. M. Mills to E. Adensam dated December 1, 1981)



ICE CONDENSER CONTAINMENT ELEVATION VIEW
 SHOWING RELATIVE PHMS IGNITER LOCATIONS

12/81

POP
L PDR
CF
NTIS
NSIC

TRANSMITTAL TO:



Document Control Desk,
016 Phillips

ADVANCED COPY TO:



The Public Document Room

DATE:

12/17/82

cc: OPS File

From: SECY OPS Branch

C&R (Natalie)

Attached are copies of a Commission meeting transcript/s/ and related meeting document/s/. They are being forwarded for entry on the Daily Accession List and placement in the Public Document Room. No other distribution is requested or required. Existing DCS identification numbers are listed on the individual documents wherever known.

Meeting Title: Dis & Pass Vote on Research - Hydrogen Control

ITEM DESCRIPTION:	Open <input checked="" type="checkbox"/>		DCS COPIES:		
	Closed <input type="checkbox"/>		(1 of each Checked)		
	Copies Advanced To PDR:	*	* Original Document	May be Dup*	Duplicate Copy*
1. <u>Transcript</u> <u>(w/ piein graphs</u> <u>attached)</u>	<u>1</u>	*	<u>1</u>	—	—
2. <u>Memo Dircks</u> <u>to Commission</u> <u>dated 12/8/82 (w/</u> <u>dirreg-0011, sup. 6</u> <u>attached)</u>	<u>1</u>	*	—	<u>1</u>	—
3. <u>Letter JVA to NRC</u> <u>dated 9/27/82</u>	<u>1</u>	*	—	<u>1</u>	—
4. _____	—	*	—	—	—
5. _____	—	*	—	—	—

(PDR is advanced one of each document, two of each SECY paper.)

*Verify if in DCS, and change to "PDR available."