CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 TNSNP1 (2) 00-00000-00 (3) 41111 (4) (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 REPORT SOURCE L (6) 05000327 (7) 031831 (8) 042983 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 Unit 1 in mode 1 at 100% power. During review of maintenance requests, it was
03 discovered that on 3/19/83 steam generator blowdown isolation valve 1-FCV-1-14
04 would not stay open and after repair that the surveillance instruction SI-166.6
05 post maintenance stroke test was not accomplished. This caused entry into LCO 3.6.3.1.
06 There was no effect on public health or safety. Previous occurrences - none.
07
08
7 8 9

09 SYSTEM CODE HI (11) CAUSE CODE E (12) CAUSE SUBCODE F (13) COMPONENT CODE VALVOP (14) COMP. SUBCODE F (15) VALVE SUBCODE Z (16)
7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER: EVENT YEAR 83 — SEQUENTIAL REPORT NO. 053 / OCCURRENCE CODE 03 REPORT TYPE L — REVISION NO. 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN A (18) FUTURE ACTION G (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0000 (22) ATTACHMENT SUBMITTED N (23) NPRD-4 FORM SUB. N (24) PRIME COMP. SUPPLIER N (25) COMPONENT MANUFACTURER A499
33 34 35 36 37 40 41 42 43 44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The solenoid valve 1-FSV-1-14 (ASCO air solenoid valve, Model #206 381-3RVF) was not
11 holding air and caused 1-FCV-1-14 inoperability. The solenoid valve was replaced.
12 The post maintenance test was not done because of surveillance instruction (SI-166.6)
13 misinterpretation. The valve was satisfactorily tested and declared operable within
14 2 hours after discovery. SI-166.6 will be revised for clearer understanding of post
7 8 9 maintenance requirements. 80

15 FACILITY STATUS E (28) % POWER 100 (29) OTHER STATUS NA (30) METHOD OF DISCOVERY A (31) DISCOVERY DESCRIPTION (32) Maintenance Request Review
7 8 9 10 12 13 44 45 46 80

16 ACTIVITY RELEASED Z (33) CONTENT OF RELEASE Z (34) AMOUNT OF ACTIVITY NA (35) LOCATION OF RELEASE NA (36)
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER 000 (37) TYPE Z (38) DESCRIPTION (39) NA
7 8 9 11 12 13 80

18 PERSONNEL INJURIES NUMBER 000 (40) DESCRIPTION (41) NA
7 8 9 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY (43) TYPE Z (42) DESCRIPTION NA
7 8 9 10 80

8305050128 830429
PDR ADOCK 05000327
S PDR

20 PUBLICITY ISSUED N (44) DESCRIPTION (45) NA
7 8 9 10 68 69 NRC USE ONLY

Name of Preparer: A. M. Carver /M. R. Harding Phone: (615) 751-0349