

MISSISSIPPI POWER & LIGHT COMPANY Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 12, 1983

JAMES P. McGAUGHY, JR VICE PRESIDENT

> Office of Inspection & Enforcement U. S. Nuclear Regulatory Commission Region II 101 Marietta St., N.W., Suite 2900 Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station Unit 1 Docket No. 50-416 License No. NPF-13 File 0260/L-835.0 Division I Chlorine Detection System Surveillance Requirements Not Met LER 83-046/03 L-0 AECM-83/0277

On April 12, 1983, it was discovered that the monthly functional surveillance for the "A" Division I Chlorine Detection System had not been performed by its late date of April 10, 1983. Action (a) of Technical Specification 3.3.7.8 was entered. The event is reported pursuant to Technical Specification 6.9.1.13.b.

Yours truly,

LADal For J. P. M. Gangly

JPM: sap Attachment

cc: Mr. J. B. Richard (w/a)

Mr. R. B. McGehee (w/o)

Mr. T. B. Conner (w/o)

Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a) Office of Inspection & Enforcement U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Document Control Desk (w/a) U. S. Nuclear Regulatory Commission Washington, D. C. 20555