

JUN 1 6 1983

DCS
MS 016

MEMORANDUM FOR: Patricia M. Kreutzer, Licensing Assistant
Operating Reactors Branch #3
Division of Licensing

FROM: Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE - NOTICE
OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE AND PROPOSED NO SIGNIFICANT HAZARDS
CONSIDERATION DETERMINATION AND OPPORTUNITY FOR A HEARING

Portland General Electric Company, Docket No. 50-344, Trojan Nuclear Plant
Columbia County, Oregon

Date of amendment request: March 30, 1983

Description of amendment request: The amendment would add new requirements for operability, visual inspections and periodic testing of mechanical snubbers to ensure that these devices are operable. Snubbers are attached to piping and equipment to provide restraint during a seismic or other event which initiates dynamic loads, yet allow slow motion such as that produced by thermal expansion. The amendment would also make minor revisions to the requirements for testing and inspection of hydraulic snubbers, such as including large-capacity snubbers (which can now be tested) in the functional test program, and more clearly defining the acceptance criteria for visual inspection and functional testing.

Basis for proposed no significant hazards consideration determination. The Commission has provided guidance concerning the application of the standards for determining whether license amendments involve no significant hazards considerations by providing certain examples which were published in the FEDERAL REGISTER on April 6, 1983 (48 FR 14870). One of the examples of actions involving no significant hazards consideration is a change that constitutes an additional limitation, restriction, or control not presently included in the technical specifications: for example, a more stringent surveillance requirement.

8306160645 830610
PDR ADOCK 05000344
P PDR

| | | | | | | | |
|---------|--|--|--|--|--|--|--|
| OFFICE | | | | | | | |
| SURNAME | | | | | | | |
| DATE | | | | | | | |

The amendment request, discussed above, fits this example. On this basis, the Commission proposes to determine that the amendment involves no significant hazards consideration.

Local Public Document Room location: Multnomah County Library, 801 S.W. 10th Avenue, Portland, Oregon

Attorney for licensee: J. W. Durham, Senior Vice President, Portland General Electric Company, 121 S.W. Salmon Street, Portland, Oregon 97204

NRC Branch Chief: Robert A. Clark

Original signed by:

Original signed by:

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

cc: Project Manager
Licensing Assistant

Docket File
PDR
ORB#3 Rdg
Memo File
PKreutzer
CTrammell
RAClark

| | | | | | | | |
|---------|-----------|-----------|----------|-----------|------------|--|--|
| OFFICE | ORB#3:DL | ORB#3:DL | ORB#3:DL | AD:OR:DL | OELD | | |
| SURNAME | PKreutzer | CTrammell | RAClark | GCLaginas | G. JOHNSON | | |
| DATE | 5/27/83 | 5/31/83 | 5/31/83 | 5/31/83 | 6/6/83 | | |

*This is not considered
an amendment or deficiency
of basis for purposes
of NRC pending*