



MATERIAL TRANSMITTED HEREWITH
CONTAINS 2790 INFORMATION
UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

APR 27 1983

Report No. 70-1201/83-03

Docket No. 70-1201

License No. SNM-1168

Safeguards Group No. III

Licensee: Babcock and Wilcox Company
Power Generation Division
Commercial Nuclear Fuel Plant
Lynchburg, VA 24505

Date of Inspection: February 28, 1982, through March 4, 1983

Type of Inspection: Unannounced Material Control and Accountability

Inspector: DW Jones
for E. L. Day, Safeguards Engineer

4/26/83
Date Signed

Approved by: EJ McAlpine
E. J. McAlpine, Chief, Material Control and
Accountability Section, Safeguards Branch
Division of Emergency Preparedness and
Materials Safety Programs

4/27/83
Date Signed

Inspection Summary

Areas Inspected: MC-85206 Measurements and Statistical Controls (NDA Waste Measurements System)

The inspection involved 39 inspection hours on site by one NRC inspector and was begun during the regular hours.

Results: The licensee was found to be in compliance with NRC requirements in the area examined during the inspection except for the following items:

1. Failure to review and audit all aspects of the measurement programs on an annual basis.
2. Failure to perform acceptable NDA measurements of waste containers.

MATERIAL TRANSMITTED HEREWITH
CONTAINS 2790 INFORMATION

8307010003 830427
PDR ADOCK 07001201
C PDR

IE03 11/1
~~IE03~~
JK