

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N | Y | J | A | F | I | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 30 37 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T
0 1 | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 3 | 3 | 7 | 0 | 6 | 1 | 0 | 7 | 8 | 3 | 8 | 0 | 6 | 1 | 6 | 8 | 3 | 9
7 8 60 61 68 69 74 75 80
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | "Interim Report"--During the performance of Local Leak Rate Testing (LLRT) _____
0 3 | Containment Spray, penetration X-39A was found with leakage that may exceed the _____
0 4 | limit of 0.6La contained in Technical Specifications 4.7.A.2.b.2. _____
0 5 | _____
0 6 | _____
0 7 | _____
0 8 | _____

0 9 | S | D | 11 | E | 12 | X | 13 | V | A | L | V | E | X | 14 | E | 15 | D | 16 |
9 10 11 12 13 18 19 20
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
17 | 8 | 3 | 21 | 22 | 0 | 2 | 2 | 24 | 26 | / | 0 | 3 | 28 | 29 | L | 30 | 31 | 0 | 32 |
LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
X | 18 | B | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | 22 | N | 23 | Y | 24 | A | 25 | V | 0 | 8 | 5 | 26 |
33 34 35 36 37 40 41 42 43 44 47
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Cause of the leakage has not been determined. Additional Local Leak Rate Testing _____
1 1 | remains incomplete at this time. Additional valves may require repairs. Details _____
1 2 | will be provided 30 days after the completion of the "1983" Refueling Outage. _____
1 3 | _____
1 4 | _____

1 5 | H | 28 | 0 | 0 | 0 | 29 | NA | 30 | B | 31 | Surveillance | 32 |
7 8 9 10 12 13 44 45 46
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
1 6 | Z | 33 | Z | 34 | NA | 35 | NA | 36 |
7 8 9 10 11 44 45
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
1 7 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39 |
7 8 9 11 12 13
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
1 8 | 0 | 0 | 0 | 40 | NA | 41 |
7 8 9 11 12
PERSONNEL INJURIES NUMBER DESCRIPTION
1 9 | Z | 42 | NA | 43 |
7 8 9 10
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
2 0 | N | 44 | NA | 45 |
7 8 9 10
PUBLICITY ISSUED DESCRIPTION
8307010060 830616
PDR ADOCK 05000333
S PDR

James A. FitzPatrick
Nuclear Power Plant
P.O. Box 41
Lycoming, New York 13093
315 342.3840



June 16, 1983
JAFF-83-0632

James M. Allan, Acting Regional Administrator
United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, Pa. 19406

REFERENCE: DOCKET NO. 50-333 Licensee Event Report: 83-022

Dear Mr. Allan:

We have enclosed the referenced Licensee Event Report in accordance with Section 6.0 of Technical Specifications and USNRC Regulatory Guide 1.16.

If there are any questions concerning this report, please contact Mr. Hartford N. Keith at (315) 342-3840, Extension 230.

Very truly yours,

A handwritten signature in black ink, appearing to read 'Corbin A. McNeill, Jr.', with a long horizontal flourish extending to the right.

CORBIN A. McNEILL, JR.
RESIDENT MANAGER

CAM/HNK/cm
Enclosure

CC: USNRC Document Control Desk (1)
Asst. Director of Operating Reactors,
USNRC Directorate of Licensing (1)
INPO Records Center, Atlanta, Georgia (1)
Internal Power Authority Distribution
NRC Resident Inspector
Document Control Center
LER/OR File

IE22
11