

JUN 29 1983

Docket No. 50-329

Docket No. 50-330

Consumers Power Company

ATTN: Mr. D. Miller

Site Manager

P. O. Box 1963

Midland, MI 48640

Dear Mr. Miller:

The NRC has completed a review of the Zack Company welding procedures and welder performance testing.

This review, which was conducted by the Senior Resident Inspector, consisted of the following:

- (1) A review of the welding procedures to assure compliance with the American Welding Society Standards
- (2) Observation of a representative sample of welders performing welding activities in the shop and field to those procedures
- (3) A review of the result of the destructive testing of the welding specimens

Based on the results of this review you are authorized to proceed with the fabrication and welding of Heating, Ventilation, and Air Conditioning (HVAC) systems.

Should you have any questions do not hesitate to contact me.

Sincerely,

Original signed by
J. J. Harrison
for J. J. Harrison, Chief
Midland Section

cc: See attached distribution
list

8307050053 830629
PDR ADOCK 05000329
A PDR

IED
11/2

| | | | | | | | |
|---------|------------|----------|---------|--|--|--|--|
| OFFICE | RIII | | | | | | |
| SURNAME | Gardner/ls | Harrison | Warnick | | | | |
| DATE | 6/28/83 | 6/28/83 | 6/28/83 | | | | |

Consumers Power Company

- 2--

JUN 29 1983

cc: James W. Cook, CPCo
Resident Inspector, RIII
The Honorable Charles Bechhoefer,
ASLB
The Honorable Jerry Harbour,
ASLB
The Honorable Frederick P. Cowan,
ASLB
The Honorable Ralph S. Decker,
ASLB
William Paton, ELD
Michael Miller
Ronald Callen, Michigan
Public Service Commission
Myron M. Cherry
Barbara Stamiris
Mary Sinclair
Wendell Marshall
Colonel Steve J. Gadler (P.E.)
Howard Levin, TERA
Billie P. Garde, Government
Accountability Project
Lynne Bernabei, Government
Accountability Project

| | | | | | | | |
|-----------|--|--|--|--|--|--|--|
| OFFICE ▶ | | | | | | | |
| SURNAME ▶ | | | | | | | |
| DATE ▶ | | | | | | | |