

7/6/83

GPU 2425

C-E Power Systems
 Combustion Engineering Inc.
 1000 Prospect Hill Road
 Windsor, Connecticut 06095

Tel 203/661-1011
 Telex 90297

**CE POWER
 SYSTEMS**

**CONFIDENTIAL
 COUNSEL ONLY**


Enclosure (1) provides generic design differences between a typical C-E operating plant and B&W Three Mile Island Unit 2 (TMI). We are providing this material as background, knowing of your need to respond to regulatory inquiries. Since this information is generic and was gathered from services at Windsor, we recommend that you check the specific validity with respect to your unit.

Part a of Enclosure (1) provides a listing of design features of C-E operating plants which would tend to mitigate an event similar to the Loss of Feedwater Event which occurred at TMI. Such design features in conjunction with improved operating and emergency procedures will give confidence that an incident similar to the TMI event has a very low probability of occurrence at a C-E designed operating unit. C-E will continue to evaluate pertinent design features and promptly recommend any design modifications and/or procedural changes which enhance operating plant safety.

Part b of Enclosure (1) provides system descriptions which form the basis for the conclusions stated in Part a. Part c of Enclosure (1) provides a C-E engineering evaluation of the sequence of events which would transpire if an event similar to the TMI Loss of Feedwater incident were to occur on a C-E operating plant. Part c of Enclosure (1) is a generic description of expected C-E plant response to events similar to those experienced at TMI.

Combustion Engineering stands ready to assist you in responding to I.E. Bulletin 79-05. If you should require such assistance from C-E, please contact me.

Sincerely,



P. W. Krue
 Manager, Engineering Services

PHN:mtm

ENCLOSURE (1)

C-E/B&W

PRELIMINARY GENERIC PLANT COMPARISON

The information presented in this enclosure is based on preliminary information concerning the nuclear incident at Three Mile Island Nuclear Power Plant Number 2. The results stated in this enclosure are based on C-E engineering judgement of events which transpired during the accident. The information and material discussed and presented by C-E with respect to the Three Mile Island Nuclear Power Plant design has been obtained from the Preliminary and Final Safety Analysis reports and personal knowledge.

GENERIC DESIGN FEATURES WHICH DIFFER BETWEEN C-E AND TMI-2

DESIGN FEATURE

COMMENT

a) C-E plants have a low steam generator water level RPS trip. For a loss of feedwater, B&W plants trip on high primary system pressure. The B&W trip signal also lifts the pressurizer relief valves.

The combination of a low steam generator water trip and higher steam dump capacity prevent significant primary system pressure excursions on C-E plants.

b) C-E plants have 40% steam dump/turbine bypass capacity. B&W plants have 15% steam dump/turbine bypass capacity.

C-E steam generators have a larger secondary water inventory than the TMI steam generators.

There is more time available to establish emergent feedwater after loss of main feedwater in the C-E system and less likelihood of lifting a primary relief valve.

C-E core elevation is relatively lower in the NSSS layout than TMI core.

Only 20-25% of RCS fluid is needed to cover C-E core vs 40-45% of RCS fluid for TMI.

C-E steam generator elevation does not form a cold leg loop seal.

A significant fraction of the TMI RCS fluid, once there is void in the RCS, will collect in the steam generator/cold leg loop seal.

C-E steam generator elevation is higher than TMI steam generator.

The higher elevations result in a better potential to initiate and maintain natural circulation.

C-E U-tube steam generator design vs TMI once through straight tube (OTSG) design.

U-tube steam generator design allows reflux condensation of RCS fluid in hot leg vs only cold leg return of condensed RCS fluid for OTSG design. U-tube steam generator also allows more water inventory.

TMI steam generators have more primary side water inventory than the C-E steam generators.

There is more potential for water retention in the TMI SGs with consequent unavailability of the water to cool the core.

The TMI design has a loop seal in the pressurizer surge line. The C-E design has no loop seal.

A surge line loop seal allows water or two-phase fluid retention in the pressurizer with the primer system voided. This will produce an indication the reactor vessel is not voided based on a false pressurizer level indication. The C-E system without the surge line loop seal is less susceptible to this false indication.

DISCUSSION

9. The C-E pressurizer is at a higher elevation than the TMI pressurizer.
10. The C-E HPSI shutoff head is lower than the TMI HPSI shutoff head.

CONCLUSION


The increased elevation increases the likelihood of draining the pressurizer when the hot leg is voided.

The lower shutoff head will not result in lifting the pressurizer relief or safety valves if the HPSI pumps are left on.

Plant D

B & W
Three Mile Island

CE



Core Power
Steam Pressure
Total Reactor Flow

2772 H.P.
910 psig
428,425 gpm

Reactor Coolant Volume

Reactor Vessel
Steam Generator
Pressurizer
Other
Total


4310 ft³
2017 ft³
1523 ft³
225 ft³
10,875 ft³

Design Pressure
Operating Pressure
Design Temperature
Operating Temperature

2425 psig
2325 psig
625°F
550°F

Inlet
Outlet

550°F
550°F



Core Power
Steam Pressure
Total Reactor Flow

2570 H.P.
820 psig
359,516 gpm

Reactor Coolant Volume

Reactor Vessel
Steam Generator
Pressurizer
Other
Total

3652 ft³
2053 ft³
1523 ft³
1513 ft³
9213 ft³

Design Pressure
Operating Pressure
Design Temperature
Operating Temperature

2425 psig
2325 psig
625°F
550°F

Inlet
Outlet



550°F
550°F

E


247

DEW
THREE MILE ISLAND

C-E




NOTE: DRAWN TO SAME RELATIVE SCALE



210 ft. 3	48 ft. 3	314 ft. 3	370 ft. 3	232 ft. 3	652 ft. 3
					1728 ft. 3

CE

Quench Tank



Quench Tank

Design 100 psig/350 °F
Volume 1000 ft.
Normal 327.022 f/hr. 0.515 psi
Relief 342.022 f/hr. 0.515 psi

POXY

Capacity 131.022 f/hr. (min)
Type Solenoid Operated


Safety

Capacity 327.022 f/hr. 0.515 psi accumulation
Type Spring loaded

B&W

Three Mile Island

RC Drain Tank



Quench Tank (B & W "RC Drain Tank")

Design 100 psig/350 °F
Volume 1000 ft.
Normal 327.022 f/hr. 0.515 psi
Relief 342.022 f/hr. 0.515 psi


POXY

Capacity 131.022 f/hr. (min)
Type Solenoid Operated

Safety


Capacity 327.022 f/hr. 0.515 psi accumulation
Type Spring loaded

THREE MILE ISLAND FEEDWATER SYSTEM





Steam Generator Pressure	1000 psia
Feedwater Rate	12×10^6 lbs/hr
Feed Rate for Steam Generator	8×10^6 lbs/hr
Feed Pump Rate	8×10^6 lbs/hr
Feed Pump Rate as Percent of Full Flow Steam Rate	88
Number of Feed Pumps	2
Steam Lines	2

FEEDWATER SYSTEM




Steam Generator Pressure	920 psia
Feedwater Rate	11.2×10^6 lbs/hr
Feed Rate for Steam Generator	7.8×10^6 lbs/hr
Feed Pump Rate	7.8×10^6 lbs/hr
Feed Pump Rate as Percent of Full Flow Steam Rate	88
Number of Feed Pumps	2
Steam Lines	2

U. S. N.
Three Mile Island

[illegible]


Value	Parameter	Value
0.205 ± 10^{-3}	Temperature^{12}	100000
0.000000	Bridge resistance (10 m. Ω)	0.00
0.000000	Open pressure, kg/cm^2	0.000 ± 10^3
0.00	Open elements (at 0.10 m/sec) each, mV	0.00
0.00	Open elements (at 0.10 m/sec) mV	0.00
0.00 ± 10^3	Inductance temperature at full pressure, mV	0.00
0.00	Inductance temperature, single element, mV	0.00
0.00	Overall mV temperature (inductance) (single mV)	0.00
0.00	Inductance single each at 0.00 p. v. (mV)	0.00

Three Mile Island



EMERGENCY FEEDWATER


ACTUATED BY:	LOSS OF ALL MCP'S LOSS OF BOTH MAIN FEEDWATER PUMPS LOSS OF FEED-STEAM DIFFERENTIAL PRESSURE
CONTROLLED BY:	INTEGRATED CONTROL SYSTEM (IF AVAILABLE) MANUAL
EMERGENCY FEED PUMPS:	1 TURBINE DRIVEN 2 MOTOR DRIVEN
CAPACITY:	TURBINE DRIVEN - 100% DECAY HEAT MOTOR DRIVEN - 50% DECAY HEAT (U.S.N.)
SOURCES OF SUCTION:	CONDENSATE PUMPS (IF OPERATING) CONDENSATE STORAGE TANKS
EMERGENCY POWER:	YES
SECURITIC IS:	YES



AUXILIARY FEEDWATER

ACTUATED BY:	PARTIAL
CONTROLLED BY:	PARTIAL
AUXILIARY FEED PUMPS:	1 TURBINE DRIVEN 2 MOTOR DRIVEN
CAPACITY:	TURBINE DRIVEN - 100% DECAY HEAT MOTOR DRIVEN - 50% DECAY HEAT (Each)
SOURCES OF SUCTION:	CONDENSATE STORAGE TANKS
EMERGENCY POWER:	YES
SECURITIC IS:	NOT SPECIFIED

LL




Shutdown Cooling Initiation Temperatures:

Temperature, °F
Pressure, psig

Design Basis:

Cool down PCS from 200 °F to 120 °F in 21.5 hours, starting 5 hours after shutdown.

B & W
Three Mile Island



Shutdown Cooling Initiation Temperatures:



Temperature, °F
Pressure, psig


Design Basis:

Cool down PCS from 210 °F to 140 °F in 16 hours, starting 5 hours after shutdown.

247

E





Low Pressure Safety Injection Pump Pressure

Shutdown Cooling System Component Data

Low Pressure Safety Injection Pumps

Quantity	2
Type	Single stage, vertical centrifugal
Quality group class	Class 2
Code	ASME III, Class 2
Design pressure	500 psig
Design temperature	350 °F
Design flow/head	3000 gpm/250 ft.
Material	304 SS
Motor horsepower	400 HP

Shutdown Cooling Heat Exchangers


Quantity	2
Type	Shell and tube, horizontal
Service transfer rate	250 Btu/hr.-sq.-ft.
Heat transfer area/sq.	500 sq. ft.
Tube sizes	1/2 in.
Fluid	Reactor coolant
Design pressure	500 psig
Design temperature	350 °F
Material	Austenitic stainless steel

Shell and Tube

Quantity	2
Type	Shell and tube, horizontal
Service transfer rate	250 Btu/hr.-sq.-ft.
Heat transfer area/sq.	500 sq. ft.
Tube sizes	1/2 in.
Fluid	Reactor coolant
Design pressure	500 psig
Design temperature	350 °F
Material	Austenitic stainless steel

Design Cases

Tube side temperature	350 °F
Shell side temperature	350 °F



Shutdown Cooling System Component Data

Decay Heat Removal Pumps

Quantity	2
Type	Single stage, centrifugal
Quality group class	Class 2
Code	ASME III, Class 2
Design pressure	500 psig
Design temperature	350 °F
Design flow/head	3000 gpm/250 ft.
Material	304 SS
Motor horsepower	400 HP

Decay Heat Removal Coolers

Quantity	2
Type	Shell and tube
Service transfer rate	250 Btu/hr.-sq.-ft.
Heat transfer area	500 sq. ft.
Tube sizes	1/2 in.
Fluid	Reactor coolant
Design pressure	500 psig
Design temperature	350 °F
Material	Austenitic stainless steel


Shell and Tube

Quantity	2
Type	Shell and tube
Service transfer rate	250 Btu/hr.-sq.-ft.
Heat transfer area	500 sq. ft.
Tube sizes	1/2 in.
Fluid	Reactor coolant
Design pressure	500 psig
Design temperature	350 °F
Material	Austenitic stainless steel

Design Cases


Tube side temperature	350 °F
Shell side temperature	350 °F

D & H Three Mile Island



PUMP DISCHARGE SYSTEM COMPONENTS


- PUMP PUMPS**
1. Physically Actuated, 100 gpm each
 2. Low Level Interlock Stops Pumps
- ISOLATION VALVES**
1. ES/SAS Actuated (One Closes on SAS, One on CIAM), Solenoid Operated
 2. 5000 gal each, ASME Section VIII, Solenoid Category 1, 15 psig Design Pressure, 150°F Design Temperature, ASME A - 182
- MISCELLANEOUS LIQUID HOLDUP TANKS**



MISCELLANEOUS WASTE SYSTEM COMPONENTS


- PUMP PUMPS**
1. Receive ES/S Signal, 200 gpm each
 2. Motor Operated, Receive ES Signal
- ISOLATION VALVES**
1. One, 2534 ft³ (-18214 gal.), Solenoid Category 1, ASME III - C Class 1, 20 psig Design Pressure, 150°F Design Temperature
- MISCELLANEOUS LIQUID HOLDUP TANK**

Three Mile Island



Pressurizer Loop Parameters

Number	Design pressure	Design temperature	Operating pressure	Operating temperature	Total volume
1	210 psig	200 °F	215 psig	170 °F	2019 ft. ³
2	210 psig	200 °F	215 psig	170 °F	2019 ft. ³
3	210 psig	200 °F	215 psig	170 °F	2019 ft. ³
4	210 psig	200 °F	215 psig	170 °F	2019 ft. ³





Core Flooding Tank Parameters

Number	Design pressure	Design temperature	Operating pressure	Operating temperature	Total volume
1	200 psig	200 °F	200 psig	170 °F	1410 ft. ³
2	200 psig	200 °F	200 psig	170 °F	1410 ft. ³
3	200 psig	200 °F	200 psig	170 °F	1410 ft. ³
4	200 psig	200 °F	200 psig	170 °F	1410 ft. ³



B & W Three Mile Island

C-E



Parameter	Particulate	HEPA
Quantity	1	1
Type	Glass Fiber	High Efficiency Particulate Air
Efficiency (%)	20	99.97
Pressure Drop (in. W.G.)	0.1	0.3
Capacity (CFM)	22,000	22,000

FILTERS



Parameter	Supply Air	Pre-filter	Exhaust Filter	Exhaust Filter
Quantity	1	2	30/Assembly	30/Assembly
Type	Automatically Advanced Rolled Media	Automatically Advanced Rolled Media	High Efficiency Particulate Air (HEPA)	Activated Charcoal
Size	19'-0" x 11'-0"	10'-0" x 10'-4" 2" Media	24'-24" 11 1/2" Media	24'-24" 8" Media
Differential Pressure (in. W.G.)	0.16	0.16	1.2	1.0
Capacity (CFM)	22500	22500	22500	22500

Part C

GENERIC RESPONSE OF AN OPERATING C-E PLANT TO LOSS OF FEEDWATER OR A STUCK PRESSURIZER RELIEF/SAFETY VALVE

In the event of a complete loss of feedwater, the immediate response of a C-E NSSS would be a decrease in steam generator level. The loss of subcooled feedwater flow would result in a moderate reduction in steam generator heat removal capability and a slow rise in reactor coolant system (RCS) pressure and temperature. Within 15 to 40 seconds, a reactor trip signal will be produced by low steam generator level, resulting in a reactor trip and a turbine trip (for a plant with a manually initiated auxiliary feedwater system). After trip, the dump and bypass (if in the normal automatic mode) will regulate steam generator and RCS pressure and temperature to hot standby conditions and the power operated relief valve would not open.

The steam generator pressure will stabilize within a couple of minutes; decay heat will be removed through the dump and bypass. This condition could exist for 10 to 20 minutes before the heat transfer capability would start to decrease due to an excessively low steam generator level, thereby resulting in an increase in RCS temperature and pressure. If auxiliary feedwater is initiated within this time period, the power operated relief valve will not open.

For an event which does open the power operated relief or safety valve and which is followed by the unanticipated failure of a pressurizer relief or safety valve to reseal, the RCS will rapidly depressurize. If the relief valve does not reseal, the downstream isolation valve could be manually closed once the RCS pressure drops below the relief valve closing setpoint. If the valve is not, or cannot be isolated, the depressurization will continue. In this situation, the pressurizer surge tank rupture disk will fail, releasing fluid to the containment and the pressurizer bubble may be lost, resulting in liquid relief through the valve. The release of significant RCS fluid to the containment would result in a containment isolation signal.

Before the RCS pressure approaches the saturation pressure of the hot leg, a safety injection signal will occur, automatically starting the high pressure safety injection (HPSI) pumps. If the flow of the HPSI pump is sufficient to increase RCS pressure, there is no incentive for the operator to turn off these pumps to prevent overpressurization since the HPSI shutoff head is below the power operated relief valve setpoint.* If only minimum safeguards are available (i.e., one HPSI pump) due to loss of offsite power and a failure of a diesel or HPSI pump to start, the HPSI flow will be adequate to keep the core cooled. If the reactor coolant pumps are tripped, the core will be adequately cooled as long as the ECCS flow is maintained and the steam generators continue to remove decay heat. The layout of the RCS enhances core cooling because the core is essentially at the lowest elevation of the system, thereby, requiring less than 25% of the RCS inventory to keep the core covered.

*This statement does not apply to Maine Yankee which has high shutoff head pumps.

Kindly

Subsequent cooldown of the RCS must be regulated within rates specified by existing procedures, by manual control of auxiliary feedwater flow, and dump valve flow. The cooldown must not be so rapid as to also cause a depressurization below the saturation pressure of the hot leg.

Depressurization must be controlled within the appropriate existing pressure-temperature guidelines by balancing of the ECCS flow with the stuck pressurizer valve flow and other flows out of the RCS, as well as the shrinkage of the RCS as it cools down; again, to assure that the RCS pressure remains above the hot leg saturation pressure.

Handwritten: 1402.567

2781
E