NRC FORM 366 (12-81) 10 CFR 50	LICENSEE EVENT REPORT	APPROVED BY OMB
CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)		
0 1 A L J M F 2 2 0	0 - 0 0 0 0 - 0 0 3 4 1	1 1 1 1 0 0 57 CAT 58 5
CON'T 0 1 REPORT L 6 0 5 0 0 0 3 6 4 7 0 5 2 8 8 3 8 0 6 2 2 8 3 9 7		
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) O 2 At 0030 on 5/28/83 during performance of FNP-2-STP-612.0 (Reactor Coolant Pump		
Bus Reactor Trip Undervoltage Relay Calibration), 2A reactor coolant pump under-		
0 4 voltage relay 27-3 was declared inoperable due to its out of Spec. condition (69.8		
o 5 volts actual vs 75.43 volts required). Tech. Spec. 3.3.1 and 3.3.2, in part, re-		
o 6 quires the relay to be operable. Tech. Spec. action statement requirements were		
o 7 met. Health/safety of the public was not affected. A similar occurrence was re-		
O 8 ported in LER 82-026/03L-0 (Unit 2).		
I A T E	12 A 3 RELLAYX ODE	1 (5) Z (6)
TO REPORT BUENT YEAR	SEQUENTIAL OCCURRENCE REPORT NO.	REVISION NO.
TAKEN ACTION ON PLANT ME	TEOWN HOURS 22 ATTACHMENT NPRO-4 THOU BY SUBMITTEL FORN SUB. Z 29 29 30 TEOWN NPRO-4 THOURS 22 ATTACHMENT FORN SUB. Z 29 29 30 TEOWN NPRO-4 TEOWN SUBMITTEL FORN SUB. Z 20 0 0 0 0 0 0 N 23 Y 20 TEOWN SUBMITTEL FORN SUB.	PRIME COMP. COMPONENT (26) 1 N (25) G 0 8 0 4 44 44 47
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27 This event was attributed to setpoint drift. Following adjustment of the relay		
setpoint, 2A reactor coolant pump undervoltage relay was declared operable at		
1 2 0045 on 5/28/83.		
1 3		
1 4		80
FACILITY	NA B (31) Surveillance T	RY DESCRIPTION (32)
7 8 9 10 12 13 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF AC	CTIVITY (35) LOCATION	OF RELEASE (36)
1 6 Z 33 Z 34 NA	NA	80
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 1 7 0 0 37 7 38	.(39 NA	
7 8 9 11 12 13 PERSONNEL INJURIES		80
1 8 0 0 0 40	NA	
LOSS OF OR DAMAGE TO PACILITY 43	8307120590 830622 PDR ADOCK 05000348	80
7 8 9 10 PUBLICITY ISSUED DESCRIPTION 45	PDR	NRC USE ONLY
2 0 N 44 10	NA	53 59 80
NAME OF PREPARER W.	G. Hairston, III PHONE	(205) 899-5156

.