

JUL 29 1983

Docket No. 50-461

Illinois Power Company
ATTN: Mr. W. C. Gerstner
Executive Vice President
500 South 27th Street
Decatur, IL 62525

- References:
1. Ltr J. G. Keppler to W. C. Gerstner dtd September 1, 1982
 2. Ltr D. P. Hall to R. L. Spessard dtd November 10, 1982
 3. Ltr R. L. Spessard to W. C. Gerstner dtd December 2, 1982
 4. Ltr R. L. Spessard to W. C. Gerstner dtd December 20, 1982
 5. Ltr D. P. Hall to J. G. Keppler dtd June 24, 1983

Gentlemen:

This letter acknowledges your letter dated June 24, 1983, requesting concurrence in your plans for lifting Stop Work Order 016 on electrical conduit installation. Based on our continuing review and site inspection on July 26-27, 1983, we have determined that you have accomplished specific prerequisites outlined in References 1, 2, and 4. Based on our review and inspection, we concur in your lifting Stop Work 016. Results of your efforts pertaining to Reference 3 have been reviewed, are satisfactory and will be documented in Inspection Report 50-461/83-12.

It is our understanding that for all seismic Category I conduits, you will rework and reinspect as necessary all vaulted conduit travelers that were not part of Phases I, II, and III of the Stop Work 016 Recovery Plan. Those 367 conduits originally included in Phase IV of the Recovery Plan have been incorporated into the Level III scheduling system and will be routinely inspected when required.

JUL 29 1983

As discussed at the exit meeting on July 27, 1983, it is our understanding that you have completed, but not documented, your comparison of conduit installation job instructions, and QC instructions and checklists with appropriate QA verification checklists and specifications to assure that the installer, QC inspector and QA inspector use compatible requirements, tolerances and acceptance criteria. When you have documented the results, please forward them to our resident inspector for review. We will gladly discuss any questions you have concerning these matters.

Sincerely,

"Original signed by A.B. Davis"

James G. Keppler
Regional Administrator

cc w/ltr dtd 6/24/83:
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Phyllis Dunton, Assistant
Attorney General
Reed Neuman, Esq., Assistant
Attorney General
Gary N. Wright, Manager
Nuclear Facility Safety
Jean Foy, Prairie Alliance

RIII

Jablonski/db
07/28/83

RIII

Hayes

RIII

Knop

RIII

Norelius

RIII

Williams

~~RIII~~

~~Lewis~~

RIII

Davis

RIII

for Keppler

7/29 7/29