

CONTROL BLOCK: [ ] [ ] [ ] [ ] [ ] [ ] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[01] S C V I C S [1] [2] 0 0 - 0 0 0 0 0 - 0 0 [3] 4 1 0 0 0 [4] [ ] [5]

CON'T [01] REPORT SOURCE [L] [6] 0 5 0 0 0 3 9 5 [7] 0 7 0 3 8 3 [8] 0 8 0 4 8 3 [9]

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[02] At 2353 hours, July 3, 1983, with the Plant in Mode 3, Emergency Feedwater Valve IFV-3536 to "A" Steam Generator tripped shut on high flow and failed to reset. [03] Subsequently the valve was declared inoperable and Action Statement (a) of [04] Technical Specification 3.7.1.2, "Emergency Feedwater System," was entered. [05] There were no adverse consequences due to this event. A Motor Driven Emergency Feedwater Pump and Emergency Feedwater Valve IFV-3531 were operable to supply [06] "A" Steam Generator. [07] [08]

[09] SYSTEM CODE [C H] [11] CAUSE CODE [E] [12] CAUSE SUBCODE [G] [13] COMPONENT CODE [I N S T R U] [14] COMP. SUBCODE [X] [15] VALVE SUBCODE [Z] [16] [17] LER/RO REPORT NUMBER [8 3] [21] SEQUENTIAL REPORT NO. [0 7 5] [24] OCCURRENCE CODE [0 3] [28] REPORT TYPE [L] [30] REVISION NO. [0] [32] ACTION TAKEN [A] [18] FUTURE ACTION [Z] [19] EFFECT ON PLANT [Z] [20] SHUTDOWN METHOD [Z] [21] HOURS [0 0 0] [22] ATTACHMENT SUBMITTED [N] [23] NPRO-4 FORM SUB. [N] [24] PRIME COMP. SUPPLIER [N] [25] COMPONENT MANUFACTURER [W I 2 0] [26]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[10] The cause of this event was due to failure of the signal comparator card. [11] The card was replaced, the applicable surveillance test procedures were [12] performed, and the system was declared operable at 1345 hours, July 4, 1983. [13] No further corrective action is planned. [14]

[15] FACILITY STATUS [D] [28] % POWER [0 0 0] [29] OTHER STATUS [N/A] [30] METHOD OF DISCOVERY [A] [31] DISCOVERY DESCRIPTION [Operator Observation] [32]

[16] ACTIVITY CONTENT RELEASED OF RELEASE [Z] [33] [Z] [34] AMOUNT OF ACTIVITY [N/A] [35] LOCATION OF RELEASE [N/A] [36]

[17] PERSONNEL EXPOSURES NUMBER [0 0 0] [37] TYPE [Z] [38] DESCRIPTION [N/A] [39]

[18] PERSONNEL INJURIES NUMBER [0 0 0] [40] DESCRIPTION [N/A] [41]

[19] LOSS OF OR DAMAGE TO FACILITY TYPE [Z] [42] DESCRIPTION [N/A] [43] B308080416 830801 PDR ADOCK 05000395 S PDR

[20] PUBLICITY ISSUED [N] [44] DESCRIPTION [N/A] [45] NRC USE ONLY

NAME OF PREPARER [R. J. Bouknight] PHONE: (803) 345-5209

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE 764

COLUMBIA, SOUTH CAROLINA 29218

O. W. DIXON, JR.  
VICE PRESIDENT  
NUCLEAR OPERATIONS

August 1, 1983

Mr. James P. O'Reilly  
Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region II, Suite 2900  
101 Marietta Street, N.W.  
Atlanta, Georgia 30303


SUBJECT: Virgil C. Summer Nuclear Station  
Docket No. 50/395  
Operating License No. NPF-12  
Thirty Day Written Report  
LER 83-075

Dear Mr. O'Reilly:

Please find attached Licensee Event Report #83-075 for Virgil C. Summer Nuclear Station. This Thirty Day Report is required by Technical Specification 6.9.1.13.(b) as a result of entry into Action Statement (a) of Technical Specification 3.7.1.2, "Emergency Feedwater System," on July 4, 1983.

Should there be any questions, please call us at your convenience.

Very truly yours,



O. W. Dixon, Jr.

RJB:OWD/mac/fjc  
Attachment

cc: V. C. Summer	C. L. Ligon (NSRC)
E. H. Crews, Jr.	G. J. Braddick
T. C. Nichols, Jr.,/O. W. Dixon, Jr.	J. C. Miller
E. C. Roberts	J. L. Skolds
H. N. Cyrus	J. B. Knotts, Jr.
Group/General Managers	I&E (Washington)
O. S. Bradham	Document Management
R. B. Clary	Branch
C. A. Price	INPO Records Center
A. R. Koon	NPCF
D. A. Lavigne	File (Lic./Eng.)
J. L. Heilman	

OFFICIAL COPY  
IE 22

11