



Carolina Power & Light Company

LAP-83-304

**AUG 10 1983**

Director of Nuclear Reactor Regulation  
Attention: Mr. D. B. Vassallo, Chief  
Operating Reactors Branch No. 2  
Division of Licensing  
United States Nuclear Regulatory Commission  
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 AND 2  
DOCKET NOS. 50-325 AND 50-324  
LICENSE NOS. DPR-71 AND DPR-62  
SUPPLEMENTAL REQUEST FOR LICENSE AMENDMENT  
MISCELLANEOUS PLANT MODIFICATIONS

Dear Mr. Vassallo:

SUMMARY

In accordance with the Code of Federal Regulations, Title 10, Parts 50.90 and 2.101, Carolina Power & Light Company (CP&L) hereby requests a revision to the Technical Specifications (TS) for the Brunswick Steam Electric Plant, Unit No. 1 (Brunswick-1). The revision supplements our June 16, 1982 and April 28, 1983 submittals concerning miscellaneous TS revisions.

DISCUSSION

On June 16, 1982, CP&L submitted a request for TS revisions to address the deletion of certain safety-related hydraulic snubbers and the installation of several other miscellaneous plant modifications. All of these modifications were scheduled to be completed during the Brunswick-1 Reload 3 outage. Due to delays in beginning this outage, the lengthy duration of the outage, and changes in the work scope of the outage, CP&L found it necessary to revise the proposed TS revisions provided in our June 16, 1982 submittal (refer to CP&L's supplemental request for TS revisions dated April 28, 1983, Serial No. LAP-83-100).

Enclosure 1 of CP&L's April 28, 1983 request provides the background information for TS revisions relating to the implementation of certain NUREG-0619 requirements for Brunswick-1. During the Brunswick-1 Reload 3 outage, CP&L partially removed the control rod drive (CRD) return line and installed a temporary cap. This CRD return line removal resulted in the deletion of only four hydraulic snubbers instead of five snubbers as stated in our April 28, 1983 request. Accordingly, CP&L herein encloses a revised TS page 3/4 7-12 for Brunswick-1 that reflects the deletion of the correct number of CRD return line snubbers.

8308150272 830810  
PDR ADOCK 05000325  
P PDR


A001  
11

ADMINISTRATIVE INFORMATION

The enclosed TS page supersedes the same numbered page provided in our April 28, 1983 submittal. The revisions on the enclosed TS page are indicated by vertical lines in the right-hand margin. Since this request is a supplement to our April 28, 1983 and June 16, 1982 requests, we have determined that no additional license amendment fee is required.

Should you have any questions concerning this submittal, please contact our staff.

Very truly yours,




P. W. Howe  
Vice President  
Brunswick Nuclear Project

WRM/lcv (7323WRM)

Enclosure

P. W. Howe, having been first duly sworn, did depose and say that the information contained herein is true and correct to his own personal knowledge or based upon information and belief.



Notary (Seal)

My commission expires: 3-22-87

cc: Mr. Dayne H. Brown  
Radiation Protection Branch  
Division of Facility Services  
Department of Human Resources  
Mr. D. O. Myers (NRC-BSEP)  
Mr. J. P. O'Reilly (NRC-RII)  
Mr. S. D. MacKay (NRC)