

AUG 23 1983

Docket No. 50-412

Duquesne Light Company
ATTN: Mr. E. J. Woolever
Vice President
Nuclear Construction
Robinson Plaza Building No. 2
Suite #210, PA Route 60
Pittsburgh, Pennsylvania 15205

Gentlemen:

Subject: Inspection 50-412/83-07

This refers to your letters dated July 12 and July 20, 1983, in response to our letter dated June 10, 1983.

Thank you for informing us of the corrective and preventive actions documented in your letters. As discussed with Mr. Siegel of your staff by Mr. L. Tripp of this office during the July 27, 1983 onsite meeting, we expect the final corrective actions involving the reanalysis and redesign of the diesel exhaust piping to be summarized in a subsequent submittal. Also, in the July 27 meeting, Duquesne Light committed to submit the results of the benchmark piping analyses and conclusions regarding the generic influences of heavy wall fittings at a later date. These actions will be examined during future inspections of your licensed program.

Your cooperation with us is appreciated.

Sincerely, Original Signed By:

for R. W. Starostecki
Richard W. Starostecki, Director
Division of Project and Resident
Programs

cc:
E. Ewing, Quality Assurance Manager
R. J. Washabaugh, Project Manager
E. F. Kurtz, Jr., Manager, Regulatory Affairs
H. M. Siegel, Manager, Engineering
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Commonwealth of Pennsylvania

8309090457 830823
PDR ADDOCK 05000412
Q PDR

*IEO1
1/1*

OFFICE					
SURNAME					
DATE					

Duquesne Light Company

2

AUG 23 1983

bcc:
Region I Docket Room (with concurrences)
DPRP Section Chief
J. Grant, DPRP

OFFICE	RI: DPRP	RI: DPRP	RI: DPRP	RI: DPRP			
SURNAME	Walton/mec	Tripp	Keimig	Starostecki			
DATE	8/22/83	8/22/83	8-23-83	8-23-83			