NRC FORM 366 (12-81) 10 CFR 50

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

APPROVED BY OMB 3150-0011

CONTROL BLOCK: ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Entry
0 1	Licensee Code ②	A L J M F 2
	License Number ③	0 0 - 0 0 0 0 0 - 0 0
	License Type ④	4 1 1 1 1
	CAT ⑤	
CON'T 0 1	Report Source ⑥	L
	Docket Number ⑦	0 5 0 0 0 3 6 4
	Event Date ⑧	0 8 0 6 8 3
	Report Date ⑨	0 8 3 1 8 3

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

0 2 At 0810 on 8/6/83, during the performance of FNP-2-STP-213.1 (Steam Generator 2A
0 3 LT-474 Loop Calibration and Functional Test Q2C22LT0474), the instrumentation
0 4 channel associated with level transmitter LT-474 was declared inoperable due to
0 5 its trip setpoint being out of tolerance. Tech. Spec. 3.3.1, in part, requires
0 6 this channel to be operable. Tech. Spec. 3.3.1 action statement requirements were
0 7 met. Health/safety of the public was not affected.
0 8

0 9	System Code ⑪	Cause Code ⑫	Cause Subcode ⑬	Component Code ⑭	Comp. Subcode ⑮	Valve Subcode ⑯
	I A	E	G	I N S T R U	Y	Z

⑰ LER/RO Report Number	Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
	8 3	—	0 3 1	/	0 3	L	—	0

Action Taken ⑱	Future Action ⑲	Effect on Plant ⑳	Shutdown Method ㉑	Hours ㉒	Attachment Submitted ㉓	NPRD-4 Form Sub. ㉔	Prime Comp. Supplier ㉕	Component Manufacturer ㉖
E	Z	Z	Z	0 0 0 0	N	Y	N	W 1 2 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ㉗

1 0 This event was caused by setpoint drift of a comparator card. The card was
1 1 adjusted and following satisfactory performance of FNP-2-STP-213.1, the LT-474
1 2 instrumentation channel was declared operable at 0950 on 8/6/83.
1 3
1 4

1 5	Facility Status ㉘	% Power ㉙	Other Status ㉚	Method of Discovery ㉛	Discovery Description ㉜
	E	1 0 0	NA	B	Surveillance Test

1 6	Activity Released ㉝	Content of Release ㉞	Amount of Activity ㉟	Location of Release ㊱
	Z	Z	NA	NA

1 7	Personnel Exposures Number ㊲	Type ㊳	Description ㊴
	0 0 0	Z	NA

1 8	Personnel Injuries Number ㊵	Description ㊶
	0 0 0	NA

1 9	Loss of or Damage to Facility Type ㊷	Description ㊸
	Z	NA

8309090575 830831
PDR ADOCK 05000348
S PDR

2 0	Publicity Issued ㊹	Description ㊺	NRC USE ONLY
	N	N.	

NAME OF PREPARER W. G. Hairston, III PHONE: (205)899-5156