

JUL 25 1983

South Carolina Electric and Gas Company
ATTN: Mr. O. W. Dixon, Jr.
Vice President, Nuclear Operations
P. O. Box 764 (Mail Code F-04)
Columbia, SC 29218

Gentlemen:

SUBJECT: REPORT NO. 50-395/83-17

This refers to the routine safety inspection conducted by Mr. J. L. Skolds of this office on May 16 - June 10, 1983, of activities authorized by NRC Operating License No. NPF-12 for the V. C. Summer facility. Our preliminary findings were discussed with Mr. O. S. Bradham, Station Manager, at the conclusion of the inspection.

Areas examined during the inspection and our findings are discussed in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

During the inspection, it was found that certain activities under your license appear to violate NRC requirements. These items and references to pertinent requirements are listed in the Notice of Violation enclosed herewith as Appendix A. Elements to be included in your response are delineated in Appendix A.

We have examined actions you have taken with regard to previously identified enforcement matters. These are discussed in the enclosed inspection report.

The violations addressed in this report and other recent violations were the subject of an enforcement conference held in Region II on June 7, 1983. The summary of that meeting is detailed in report number 50-395/83-21. Regarding the violation where the turbine driven auxiliary feedwater pump controller was left in the slow position following a surveillance, the importance of second verification of items important to safety is reemphasized and you are requested to specifically address your corrective actions in this area in your reply.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosures will be placed in the NRC's Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1).

The responses directed by this letter and the enclosures are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

JUL 25 1983

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,

R. C. Lewis, Director
Division of Project and
Resident Programs

Enclosures:

- 1. Appendix A, Notice of Violation
- 2. Inspection Report No. 50-395/83-17

cc w/encls:

- J. B. Knotts, Jr.
- O. S. Bradham, Station Manager
- B. G. Croley, Manager, Nuclear
Engineering
- D. A. Lavigne, Director
Surveillance Systems

bcc w/encls:

- NRC Resident Inspector
- Document Management Branch
- State of South Carolina

RII
KB
for JSkolds:dr
7/7/83

RII
KB
RButcher
7/7/83

RII
FC
FCantrell
7/11/83

RII
DV
DVerrelli
7/21/83

RII
RL
RCLewis
6/22/83